

PMNorthAnna3COLPEmails Resource

From: Barry Bryant [barry.bryant@dom.com]
Sent: Tuesday, November 06, 2012 9:04 AM
To: Kallan, Paul
Cc: Patel, Chandu; Regina Borsh
Subject: RE: North Anna Section 5 3 1

Paul,

I have reviewed the changes proposed by Joel Jenkins and agree that the two STD SUPs need to be added to the North Anna S-COLA. I created a new entry in our COLA Change Request database to track the implementation of this change. The change will be incorporated in a future submission of the S-COLA. Thank you for bringing this to our attention.

Regards,

Barry

Barry C. Bryant, P.E.

Dominion Resources Services, Inc.
North Anna 3 Project
Office: 804.273.3279
Cell: 804.516.9986
barry.bryant@dom.com

From: Kallan, Paul [<mailto:Paul.Kallan@nrc.gov>]
Sent: Thursday, November 01, 2012 12:13 PM
To: Barry Bryant (Generation - 6)
Subject: FW: North Anna Section 5 3 1
Importance: High

Hi Barry,

Here are some comments on Section 5.3.1. Staff believes that the two STD SUPs need to be included in the North Anna application.

regards,

Paul

From: Jenkins, Joel
Sent: Thursday, November 01, 2012 11:06 AM
To: Kallan, Paul
Cc: Patel, Chandu; Terao, David; Ray, Neil; Downey, Steven
Subject: North Anna Section 5 3 1

Paul,

I have reviewed section 5.3.1 of the North Anna COL. North Anna COL Section 5.3.1 is identical with the Comanche Peak COL Section 5.3.1 except that the Comanche Peak COL contains the following two STD SUPs.

STD SUP 5.3(1)

Insert the following at the end of the second paragraph in DCD Subsection 5.3.1.6.1.
“Test specimens are taken from material used for the reactor vessel beltline.”

STD SUP 5.3(2)

Insert the following after the first sentence in the fifth paragraph in DCD Subsection 5.3.1.6.1.
“The capsules are sealed in an inert environment.”

For consistency with the lead COL and because of the importance of the reactor vessel surveillance program, I believe the above two STD SUPs need to be included in the North Anna COL.

Joel Jenkins
NRO/DE/CIB
301-415-2955

CONFIDENTIALITY NOTICE: This electronic message contains information which may be legally confidential and/or privileged and does not in any case represent a firm ENERGY COMMODITY bid or offer relating thereto which binds the sender without an additional express written confirmation to that effect. The information is intended solely for the individual or entity named above and access by anyone else is unauthorized. If you are not the intended recipient, any disclosure, copying, distribution, or use of the contents of this information is prohibited and may be unlawful. If you have received this electronic transmission in error, please reply immediately to the sender that you have received the message in error, and delete it. Thank you.

Hearing Identifier: NorthAnna3_Public_EX
Email Number: 1106

Mail Envelope Properties (DBFB7D590C94A84895EB135FBE06C55A06802F82)

Subject: RE: North Anna Section 5 3 1
Sent Date: 11/6/2012 9:03:38 AM
Received Date: 11/6/2012 9:03:47 AM
From: Barry Bryant

Created By: barry.bryant@dom.com

Recipients:

"Patel, Chandu" <Chandu.Patel@nrc.gov>
Tracking Status: None
"Regina Borsh" <regina.borsh@dom.com>
Tracking Status: None
"Kallan, Paul" <Paul.Kallan@nrc.gov>
Tracking Status: None

Post Office: DOM-MBX03.mbu.ad.dominionnet.com

Files	Size	Date & Time
MESSAGE	2645	11/6/2012 9:03:47 AM

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: