



**Entergy Operations, Inc.**  
17265 River Road  
Killona, LA 70057-3093  
Tel 504-739-6660  
Fax 504-739-6678  
djacob2@entergy.com

**Donna Jacobs**  
Vice President - Operations  
Waterford 3

10 CFR 50.54(f)

W3F1-2012-0100

November 26, 2012

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
11555 Rockville Pike  
Rockville, MD 20852

**SUBJECT:** Seismic Walkdown Report - Entergy's Response to NRC Request for Information Pursuant to 10 CFR 50.54(f) Regarding the Seismic Aspects of Recommendation 2.3 of the Near-Term Task Force Review of Insights from the Fukushima Dai-Ichi Accident  
Waterford Steam Electric Station, Unit 3 (Waterford 3)  
Docket No. 50-382  
License No. NPF-38

**REFERENCES:** 1. NRC Letter, *Request for Information Pursuant to Title 10 of the Code of Federal Regulations 50.54(f) Regarding Recommendations 2.1, 2.3, and 9.3 of the Near-Term Task Force Review of Insights from the Fukushima Dai-Ichi Accident*, dated March 12, 2012. (ADAMS Accession No. ML12053A340)  
2. *Entergy's 120-Day Response to NRC Request for Information (RFI) Pursuant to 10 CFR 50.54(f) Regarding the Seismic Aspects of Recommendation 2.3 of the Near-Term Task Force Review of Insights from the Fukushima Dai-Ichi Accident (Waterford 3)*, dated July 9, 2012. (ADAMS Accession No. ML12192A208)

Dear Sir or Madam:

On March 12, 2012, the NRC issued Reference 1 to all power reactor licensees. Enclosure 3 of Reference 1 contains specific requested actions, requested information, and required responses associated with Recommendation 2.3 for seismic walkdowns. Entergy Operations, Inc. (Entergy) confirmed in Reference 2 that it would use the seismic walkdown procedure (EPRI Report 1025286, *Seismic Walkdown Guidance: For Resolution of Fukushima Near-Term Task Force Recommendation 2.3: Seismic*) as endorsed by the NRC as the basis to conduct the walkdowns and develop the needed information at Waterford Steam Electric Station, Unit 3 (Waterford 3).

Pursuant to Required Response 2 of Reference 1, Enclosure 3, Entergy is providing the Seismic Walkdown Report for Waterford 3 in the enclosure. All potentially adverse seismic conditions identified in the report have been evaluated in the Corrective Action Program for operability concerns and no immediate operability concerns have been identified.

This letter contains new regulatory commitments, which are identified in the attachment. Should you have any questions regarding this submittal, please contact Michael Mason, Licensing Manager (acting), at 504.739.6673.

I declare under penalty of perjury that the foregoing is true and correct. Executed on November 26, 2012.

Sincerely,

  
for  
Donna Jacobs

DJ/WH

Attachment: List of Regulatory Commitments  
Enclosure: Waterford 3 Seismic Walkdown Report

cc: w/ attachment  
w/o enclosure

Director, Office of Nuclear Reactor Regulation  
U. S. NRC  
RidsNrrMailCenter@nrc.gov

Mr. Elmo E. Collins, Jr., Regional Administrator  
U. S. NRC, Region IV  
RidsRgn4MailCenter@nrc.gov

NRC Program Manager for Waterford 3  
Kaly.Kalyanam@nrc.gov

NRC Senior Resident Inspector for Waterford 3  
Marlone.Davis@nrc.gov

**ATTACHMENT to  
W3F1-2012-0100**

**LIST OF REGULATORY COMMITMENTS**

List of Regulatory Commitments

The following table identifies those actions committed to by Entergy in this document. Any other statements in this submittal are provided for information purposes and are not considered to be regulatory commitments.

COMMITMENT	TYPE (Check One)		SCHEDULED COMPLETION DATE  (If Required)
	ONE- TIME ACTION	CONTINUING COMPLIANCE	
Entergy will perform walkdowns for equipment that could not be inspected as identified in Section 6.3 of the Seismic Walkdown Report.	✓		On a schedule specified in Section 6.3 of the Waterford 3 Seismic Walkdown Report
Entergy will submit an updated Seismic Walkdown Report.	✓		On a schedule specified in Section 6.3 of the Waterford 3 Seismic Walkdown Report