

Date: November 28, 2012

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE - PNO-I-12-008A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. Some of the information received may not yet be fully verified or evaluated by the Region Staff.

<u>Facility</u>	<u>Licensee Emergency Classification</u>
Entergy Nuclear Operations, Inc	<input checked="" type="checkbox"/> Notification of Unusual Event
James A. FitzPatrick Nuclear Power Plant	<input type="checkbox"/> Alert
Lycoming, NY	<input type="checkbox"/> Site Area Emergency
Docket: 50-333	<input type="checkbox"/> General Emergency
	<input type="checkbox"/> Not Applicable

Subject: **UPDATE:** JAMES A. FITZPATRICK NUCLEAR POWER PLANT
NOTIFICATION OF UNUSUAL EVENT DUE TO FIRE IN MAIN
TRANSFORMER

This preliminary notification supplements information in PNO-1-12-008, which documented the declaration of an Unusual Event at the Fitzpatrick plant on November 11, 2012, following a fire in the T1-A main transformer. On-site fire brigade personnel, with assistance from a local fire department, extinguished the transformer fire. Operators declared an Unusual Event (UE) at 5:45 a.m. EST and exited the UE at 8:01 a.m. the same day. The plant includes two main transformers T1-A and T1-B. These transformers are located on-site, outside and adjacent to the turbine building.

On November 12, 2012, while the FitzPatrick plant was shut down, Entergy staff began maintenance activities that included inspection of the T1-A and T1-B main transformers. Entergy's investigation determined that the problem initiated in the "B" Phase winding of the T1-A main transformer that subsequently resulted in the fire. Entergy personnel replaced the T1-A main transformer and determined the T1-B was not damaged. FitzPatrick operators re-started the plant after completing replacement and testing of the replacement T1-A main transformer, and testing of other similar transformers. The plant reached full power on November 27, 2012.

The NRC staff continues to closely follow Entergy's causal evaluations of the transformer failure and corrective actions. NRC oversight is being conducted through the NRC's baseline inspection program.

Entergy issued two news releases on November 11, 2012, related to the Unusual Event declaration, transformer fire, and termination. The information presented herein has been discussed with Entergy and is current as of November 28, 2010, at 10:00 a.m. Region I Public Affairs has responded to media inquiries.

This preliminary notification is issued for information only and no further notification by the staff is anticipated.

ADAMS Accession Number: **ML12333A307**

Contacts: Mel Gray
(610) 337-5209
mel.gray@nrc.gov

DISTRIBUTIONS:
BY E-MAIL:

OWFN

Chairman MacFarlane
Comm. Svinicki
Comm. Apostolakis
Comm. Magwood
Comm. Ostendorff
OIP
OCA
OGC
OPA
EDO
OE
NRR
SECY
IRO
ACRS
NSIR
SRO
PDR
RSLO
SECY
IRO
ACRS
NSIR
NRO
PDR
RSLO
Regional Offices

TWEN

NMSS
OIG
RES

By Fax:

INPO
NSAC
RI Resident Office
Licensee: Entergy Nuclear Operations Inc.
(FitzPatrick)

ADAMS Accession Number:

DOCUMENT NAME: G:\DRP\PNs\PNO-I-12-008A - UPDATE FITZ NOUE FOR FIRE IN MAIN TRANSFORMER.docx

ADAMS ACCESSION NUMBER: **ML12333A307**

<input type="checkbox"/> SUNSI Review		<input checked="" type="checkbox"/> Non-Sensitive <input type="checkbox"/> Sensitive		<input checked="" type="checkbox"/> Publicly Available <input type="checkbox"/> Non-Publicly Available	
OFFICE	RI/DRP	RI/PAO	RI/SLO	RI/DRP	RI/ORA
NAME	MGray/ar for	DScrenci	DTiff	DRobert /prw for	WDean
DATE	11/28/2012	11/28/2012	11/28/2012	11/28/2012	11/28/2012

OFFICIAL RECORD COPY