



NOV 26 2012

10 CFR 50.54(f)

LR-N12-0370

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Salem Generating Station, Units 1 and 2
Renewed Facility Operating License Nos. DPR-70 and DPR-75
NRC Docket Nos. 50-272 and 50-311

Subject: Salem Generating Station Response to Recommendation 2.3: Flooding Walkdown of the Near-Term Task Force Review of Insights from the Fukushima Dai-Ichi Accident

- References:
- (1) US Nuclear Regulatory Commission (NRC) letter dated March 12, 2012, "Request for Information Pursuant to Title 10 of the Code of Federal Regulations 50.54(f) Regarding Recommendations 2.1, 2.3, and 9.3, of the Near-Term Task Force Review of Insights from the Fukushima Dai-Ichi Accident"
 - (2) PSEG Letter LR-N12-0170 dated June 7, 2012, "PSEG Nuclear LLC's Response to NRC Request for Information Pursuant to 10 CFR 50.54(f) Regarding the Flooding Aspects of Recommendations 2.1 and 2.3 of the Near-Term Task Force Review of Insights from the Fukushima Dai-ichi Accident"
 - (3) NEI 12-07 Revision 0-A dated May 2012, "Guidelines for Performing Verification Walkdowns of Plant Flood Protection Features"

On March 12, 2012, the Nuclear Regulatory Commission (NRC) issued a request for information (Reference 1) to PSEG Nuclear LLC (PSEG). Reference 1 includes a request for PSEG to perform flooding walkdowns using NRC-endorsed walkdown methodology. By letter dated June 7, 2012 (Reference 2) PSEG confirmed that it would use the NRC-endorsed flooding walkdown guidance in NEI 12-07, "Guidelines for Performing Verification Walkdowns of Plant Flood Protection Features" (Reference 3).

ADD 1
NRR


Enclosure 1 provides the requested flooding walkdown report for the Salem Generating Station, Units 1 and 2.

There are no regulatory commitments contained in this transmittal. If you have any questions or require additional information, please do not hesitate to contact Mrs. Emily Bauer at 856-339-1023.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on 11/26/2012
(Date)

Sincerely,



Carl J. Fricker
Site Vice President
Salem Generating Station

Enclosure (1)

cc: Mr. E. Leeds, Director of Office of Nuclear Reactor Regulation
Mr. W. Dean, Administrator, Region I, NRC
Mr. J. Hughey, Project Manager, NRC
NRC Senior Resident Inspector, Salem
Mr. P. Mulligan, Manager IV, NJBNE
Salem Commitment Tracking Coordinator
PSEG Commitment Coordinator – Corporate



PSEG

NUCLEAR LLC

Salem Generating Station Units 1 & 2

SGS Flood Walkdown Report

10 CFR 50.54(f) Section 2.3 (Flood) Response