

In the Matter of: Entergy Nuclear Operations, Inc.
(Indian Point Nuclear Generating Units 2 and 3)

ASLBP #: 07-858-03-LR-BD01
Docket #: 05000247 | 05000286
Exhibit #: NYS000187-00-BD01
Admitted: 10/15/2012
Rejected:
Other:

Identified: 10/15/2012
Withdrawn:
Stricken:



October 16, 2007

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-III-08-011

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region III staff on this date.

Facility

Quad Cities
Exelon Nuclear Generation Company
Warrenville, Illinois
Docket: 50-254; 50-265
License: DPR-30

Licensee Emergency Classification

Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: TRITIUM LEAKAGE

DESCRIPTION:

On October 12, 2007, Exelon's Quad Cities Station informed the resident inspectors and the NRC's Region III Office in Lisle, Ill. that elevated levels of tritium (the radioactive isotope of hydrogen) had been found in newly installed onsite ground water monitoring wells. The tritium levels measured up to 800,000 picocuries per liter. No other radionuclides had been identified.

The utility has sampled other onsite ground water wells located closer to the plant property lines and identified no detectable migration of tritium offsite. Based on current information, the effects of the leakage are localized to the immediate area within the licensee's protected area and do not represent a health and safety hazard to the public.

The additional wells were recently installed to investigate fluctuations in tritium measurements in the existing wells that were installed in 2006 as part of Exelon's fleet-wide tritium investigation. Each of these wells was installed by the licensee for monitoring purposes and is not used for drinking water.

The utility is investigating the source of the tritium leak. Underground piping from the condensate water storage tank is being examined as a possible source.

The utility has notified state, local, and federal officials and has issued a press release to local media.

The NRC Region III Office is monitoring the utility's activities and plans to perform independent measurements to verify the utility's sampling results.

The State of Illinois, as well as appropriate local and federal officials, has been informed.

This information is current as of 9:45 a.m. on Tuesday, October 16, 2007.

CONTACT:

Steven Orth
(630)829-9827