

In the Matter of: Entergy Nuclear Operations, Inc.
(Indian Point Nuclear Generating Units 2 and 3)

ASLBP #: 07-858-03-LR-BD01
Docket #: 05000247 | 05000286
Exhibit #: RIV00053F-00-BD01
Admitted: 10/15/2012
Rejected:
Other:
Identified: 10/15/2012
Withdrawn:
Stricken:

RIV00053F

Submitted: December 27, 2011



COMBUSTION ENGINEERING, INC.
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A142
SHEET 34 OF 79
DATE 4-22-03 BY SMURRELL
CHECK DATE 4-27-03 BY HELFER

CHARGE NO. _____

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS

5- DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTION:

1. REDUNDANT FORCES:

THE ABOVE MATRIX WITH THE GIVEN LOADING VECTORS FOR PRESSURE AND THE TRANSIEN CONDITIONS FOR BOTH RANGE OF STRESS AND PEAK STRESS GIVE THE FOLLOWING VALUES FOR THE REDUNDANT FORCES.
— FOR RANGE OF STRESS —

TRANSIENT	H ₁ KIP/IN	M ₁ IN-KIP/IN	H ₂ KIP/IN	M ₂ IN-KIP/IN	H ₃ KIP/IN	M ₃ IN-KIP/IN	H ₄ KIP/IN	M ₄ IN-KIP/IN	
PRESSURE ONLY	-1.4800P	-4.0236P	-1.4597P	-9.5635P	0.9909P	51.5276P	-29.8560P	-110.4336P	
U = Vertical	400 Hz	5.4218	-1.9297	2.8411	9.2769	1.6582	53.9849	-5.6804	13.1555
	425	5.7652	-1.8840	2.9779	9.9809	1.5267	53.8035	-5.7380	10.7364
	435	5.9028	-1.8072	3.0245	10.267	1.5114	53.9330	-5.7330	10.7487
	447	6.0690	-1.8299	3.0865	10.6073	1.3483	53.2669	-5.8186	7.0057
	500	6.2067	-0.3096	2.7739	11.9022	0.3808	32.3227	-3.3944	1.4660
Stress	6.2340	0.9222	2.3724	12.6809	-0.6379	5.6658	-0.1588	-0.2734	
U = Vertical	400 Hz	0.8400	2.7851	-0.4398	3.4015	-2.2358	-47.0802	5.3413	-13.1506
	425	0.4919	2.7183	-0.5732	2.6625	-2.0994	-46.7069	5.3900	-10.7289
	435	0.3387	2.6950	-0.6270	2.3680	-2.0822	-46.7841	5.3859	-10.7136
	447	0.1653	2.6543	-0.6907	2.0043	-1.9219	-46.5901	5.4718	-7.1183
	500	0.0249	1.1797	-0.3880	0.7599	-0.9844	-25.7664	3.1338	-1.6585
Stress	6.2340	0.9222	2.3724	12.6809	-0.6379	5.6658	-0.1588	-0.2734	
U = f	400 Hz	6.3407	0.9380	2.4131	12.8981	-0.6488	5.7628	-0.1616	-0.2781
	425	6.3435	0.9384	2.4141	12.9037	-0.6491	5.7653	-0.1616	-0.2782
	435	6.3366	0.9374	2.4115	12.8998	-0.6484	5.7591	-0.1614	-0.2779
U = 0	0	0	0	0	0	0	0	0	
U = 30 Hz	400 Hz	4.1645	-2.0371	2.2937	6.7150	0.9230	45.0705	-2.6381	10.5043
	55	4.2388	0.6271	1.6131	0.6224	-0.4337	3.8525	-0.1080	-0.1559
	CO 300 Hz	0.7437	2.5950	-0.5902	2.1894	-1.2013	-38.8840	2.5159	-7.1246
U = m	6.3407	0.9380	2.4131	12.8981	-0.6488	5.7628	-0.1616	-0.2781	
U = n	6.2340	0.9222	2.3724	12.6809	-0.6379	5.6658	-0.1588	-0.2734	

COMBUSTION ENGINEERING, INC.
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A 143
 SHEET 25 OF 69
 DATE 4-22-68 BY COOPER
 CHECK DATE 1-21-68 BY HEINER

CHARGE NO. _____
 DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SURVEYS

5. DETAILED ANALYSIS:

- 1. PRESSURE AND THERMAL INTERACTION:
- 4. REDUNDANT FORCES:

- FOR PEAK STRESS -

TRANSIENT	H ₁ KIP/IN	M ₁ IN-KIP/IN	H ₂ KIP/IN	M ₂ IN-KIP/IN	H ₃ KIP/IN	M ₃ IN-KIP/IN	H ₄ KIP/IN	M ₄ IN-KIP/IN	
a - Helium	4.00 HRS	5.4314	-3.3474	2.8545	7.4518	1.1275	-244.7520	-6.9856	-313.7740
	4.25	5.7743	-3.2997	2.9846	8.1440	1.0213	-246.2679	-6.9801	-318.2831
	4.35	5.9120	-3.2858	3.0372	8.4150	1.0037	-247.5879	-6.9811	-319.8527
	4.47	6.2782	-3.2595	3.0993	9.7540	0.8381	-249.7035	-7.0727	-325.1178
	5.00	6.2115	-0.2463	2.7805	11.5336	0.1159	-140.7465	-4.0447	-177.8202
STEADY STATE	6.2340	0.9222	2.3724	12.6809	-0.6379	5.6658	-0.1588	-0.2734	
b - Carbon Dioxide	4.00 HRS	0.9308	4.1929	-0.4532	5.2765	-1.7052	251.6967	6.6465	313.7789
	4.25	0.4774	4.1241	-0.5859	4.4994	-1.5941	253.3645	6.6322	318.2906
	4.35	0.3225	4.1157	-0.6397	4.2136	-1.5744	254.7368	6.6241	319.8880
	4.47	0.1561	4.0938	-0.7035	3.9577	-1.4117	256.8794	6.7259	325.0652
	5.00	0.0201	1.1673	-0.3946	1.1085	-0.7195	147.3529	3.7840	177.6277
c	6.2340	0.9222	2.3724	12.6809	-0.6379	5.6658	-0.1588	-0.2734	
d → f	6.3407	0.9380	2.4131	12.6981	-0.6488	5.7628	-0.1616	-0.2781	
g	6.3455	0.9394	2.4141	12.9037	-0.6491	5.7653	-0.1616	-0.2782	
h	6.3366	0.9374	2.4115	12.9898	-0.6484	5.7591	-0.1614	-0.2779	
i	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
j	N.D.								
	3.0 HRS	0.1757	-3.4566	2.3064	4.9617	0.4129	-257.8999	-5.8922	-321.6773
	SS.	4.2393	0.6271	1.6131	8.6224	-0.4337	3.9525	-0.1080	-0.1859
3.0 HRS	0.2344	4.0746	-0.6030	4.0428	-0.6911	264.0863	3.7700	325.0589	
k → m	6.3407	0.9380	2.4131	12.8981	-0.6488	5.7628	-0.1616	-0.2781	
n	6.2340	0.9222	2.3724	12.6809	-0.6379	5.6658	-0.1588	-0.2734	

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P

A144

SHEET 30

OF 69

CHARGE NO. _____

DATE 4-22-68

BY SKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION

CHECK DATE 4-22-68

BY SKRELL

DE INLET NOZZLE - VESSEL SUPPORTS

DETAILED ANALYSIS:

STRESSES:

COMBINED STRESSES - UNCONCENTRATED:

FOR THIS SECTION OF THE ANALYSIS, STRESSES WILL BE CALCULATED AT THE TEN LOCATIONS AS SHOWN ON SHEET 17.


LOCATION 1 & 2:

PRESSURE STRESS:

$$\sigma_x = \pm \frac{6M_x R_1}{L^2 R_1} + \frac{D^2 P}{2R_1 t} = \pm 0.9670 M_1 + 2.5200 P$$

$$\sigma_\theta = \pm \frac{\sqrt{6} M_x R_1}{L^2 R_1} + \frac{E W_1}{R_1} + \frac{D P}{t} = \pm 0.2901 M_1 + 0.06667 E W_1 + 5.5000 P$$

$$\sigma_r = -P$$



$$I = \frac{\pi}{4} (r_o^4 - r_i^4) = 26691 \text{ in}^4$$

$$A = \pi (r_o^2 - r_i^2) = 235.6 \text{ in}^2$$

THERMAL STRESS:

$$\sigma_x = \pm \frac{6M_x R_1}{L^2 R_1} = \pm 0.9670 M_1$$

$$\sigma_\theta = \pm \frac{\sqrt{6} M_x R_1}{L^2 R_1} + \frac{E W_1}{R_1} = \pm 0.2901 M_1 + 0.06667 E W_1$$

THERMAL INDUCED PIPE REACTIONS:

	LOCATION - 1	LOCATION - 2
$\sigma_x = -\frac{F_x}{A} \pm \frac{M_x}{I}$	$-0.00424 F_x + 0.00052 M_x$ POINT A $-0.00424 F_x - 0.00052 M_x$ B $-0.00424 F_x + 0.00052 M_x$ C $-0.00424 F_x - 0.00052 M_x$ D	$-0.00424 F_x + 0.00061 M_x$ POINT A $-0.00424 F_x - 0.00061 M_x$ B $-0.00424 F_x + 0.00061 M_x$ C $-0.00424 F_x - 0.00061 M_x$ D
$T_{10} = \frac{E R}{I D} \pm \frac{M_x}{I}$	$0.00845 F_x + 0.00026 M_x$ POINT A $0.00845 F_x - 0.00026 M_x$ B $0.00845 F_x + 0.00026 M_x$ C $0.00845 F_x - 0.00026 M_x$ D	$0.00845 F_x + 0.00031 M_x$ POINT A $0.00845 F_x - 0.00031 M_x$ B $0.00845 F_x + 0.00031 M_x$ C $0.00845 F_x - 0.00031 M_x$ D

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A145SHEET 27 OF 69DATE 4-22-68 BY LOCKECHECK DATE 4-22-68 BY AGUIER

CHARGE NO. _____

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS5. DETAILED ANALYSIS:C - STRESSES:1. COMBINED STRESSES - UNCONCENTRATED:SEISMIC PIPE REACTIONS:

THE FORMULAS FOR CALCULATING THE STRESSES DUE TO THE SEISMIC PIPE REACTIONS ARE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS.

NOTE:


THERE WILL BE NO STRESS PRODUCED AT LOCATIONS 1-6 DUE TO THE STATIC LOADING THROUGH SUPPORTS, EARTHQUAKE LOADING THROUGH SUPPORTS, OR DUE TO THERMAL EXPANSION OR CONTRACTION.

LOCATION 3 & 4:PRESSURE STRESS:

$$\sigma_x = \pm \frac{6M_1}{t_1^2} + \frac{b^2 P}{2R_1 t_1} = \pm 1.1532 M_1 + 2.7428 P$$

$$\sigma_\theta = \pm \frac{\sqrt{6} M_1}{t_1} + \frac{E W_1}{R_2} + \frac{bP}{t_1} = \pm 0.3460 M_1 + 0.0662 E W_1 + 6.0251 P$$

$$\sigma_r = -P$$



$$I = \frac{\pi}{4} (r_o^4 - r_i^4) = 24961 \text{ in}^4$$

$$A = \pi (r_o^2 - r_i^2) = 216.6 \text{ in}^2$$

THERMAL STRESS

$$\sigma_x = \pm \frac{6M_1}{t_1^2} = \pm 1.1532 M_1$$

$$\sigma_\theta = \pm \frac{\sqrt{6} M_1}{t_1} + \frac{E W_1}{R_2} = \pm 0.3460 M_1 + 0.0662 E W_1$$

COMBUSTION ENGINEERING, INC.
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A146
SHEET 39 OF 69
DATE 4-22-68 BY LOCKRILL
CHECK DATE 4-22-69 BY HEUER

CHARGE NO. _____

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS

5- DETAILED ANALYSIS:

2- STRESSES:

1- COMBINED STRESSES - UNCONCENTRATED:

THERMAL INDUCED PIPE REACTIONS:

	LOCATION - 3	LOCATION - 4
$\sigma_x = \frac{E}{L} \Delta L = \frac{M_x}{I}$	POINT A = $-0.00462 F_x + 0.00056 M_x$	POINT A = $-0.00462 F_x + 0.00065 M_x$
	B = $-0.00462 F_x - 0.00056 M_x$	B = $-0.00462 F_x - 0.00065 M_x$
	C = $-0.00462 F_x + 0.00056 M_x$	C = $-0.00462 F_x + 0.00065 M_x$
	D = $-0.00462 F_x - 0.00056 M_x$	D = $-0.00462 F_x - 0.00065 M_x$
$\tau_{xy} = \frac{FQ}{Ib} + \frac{Mx}{2I}$	POINT A = $0.00926 F_x + 0.00028 M_x$	POINT A = $0.00926 F_x + 0.00033 M_x$
	B = $0.00926 F_x - 0.00028 M_x$	B = $0.00926 F_x - 0.00033 M_x$
	C = $0.00926 F_x + 0.00028 M_x$	C = $0.00926 F_x + 0.00033 M_x$
	D = $0.00926 F_x - 0.00028 M_x$	D = $0.00926 F_x - 0.00033 M_x$

SEISMIC PIPE REACTIONS:

THE FORMULAS FOR CALCULATING THE STRESSES ARE THE SAME AS FOR THE THERMAL INDUCED PIPE REACTIONS.


LOCATION 5-6:

PRESSURE STRESS:

$$\sigma_x = \pm \frac{6M_x}{t_{in}^2} + \frac{bP}{2R_o t_{in}} = \pm 1.0637 M_x + 26342P$$

$$\sigma_{\theta} = \pm \frac{3M_x}{t_{in}^2} + \frac{EM_{\theta}}{R_o} + \frac{bP}{t_{in}} = \pm 0.3191 M_x + 0.0662 E M_{\theta} + 57975P$$

$\sigma_r = -P$



$$I = \frac{\pi}{4} (r_o^4 - r_i^4) = 26158 \text{ in}^4$$

$$A = \pi (r_o^2 - r_i^2) = 286.2 \text{ in}^2$$

THERMAL STRESS:

$$\sigma_x = \pm \frac{6M_x}{t_{in}^2} = \pm 1.0637 M_x$$

$$\sigma_{\theta} = \pm \frac{3M_x}{t_{in}^2} + \frac{EM_{\theta}}{R_o} = \pm 0.3191 M_x + 0.0662 E M_{\theta}$$

COMBUSTION ENGINEERING, INC.
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A147
SHEET 39 OF 49
DATE 4-22-69 BY COCKRELL
CHECK DATE 4-11-69 BY HENDER

CHARGE NO. _____

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUMMITS

5. DETAILED ANALYSIS:

C. STRESSES:

1. COMBINED STRESSES - UNCOMPENSATED:

THERMAL INDUCED PIPE REACTIONS:

SINCE THE PIPE REACTIONS ARE APPLIED AT THE SMALL END OF THE NOZZLE, THE PIPE REACTIONS MUST BE RESOLVED TO THE CROSS SECTION OF INTEREST. THIS IS DONE AS FOLLOWS.

$$\begin{aligned} \bar{F}_x &= F_x = 14.8 & \bar{M}_x &= M_x & & = -3783 \\ \bar{F}_y &= F_y = -92 & \bar{M}_y &= M_y + 2.923 F_x & & = 4579.4 \\ \bar{F}_z &= F_z = 27.5 & \bar{M}_z &= M_z - 2.923 F_y & & = 7710.0 \end{aligned}$$

LOCATION - 5		LOCATION - 6	
$\sigma_x = -\frac{E_x}{A} \pm \frac{M_x}{I}$	$= -0.00442 \bar{F}_x + 0.00053 \bar{M}_z$	POINT A	$= -0.00442 \bar{F}_x + 0.00062 \bar{M}_z$ POINT A
	$= -0.00442 \bar{F}_y - 0.00053 \bar{M}_z$	B	$= -0.00442 \bar{F}_y - 0.00062 \bar{M}_z$ B
	$= -0.00442 \bar{F}_x + 0.00053 \bar{M}_y$	C	$= -0.00442 \bar{F}_x + 0.00062 \bar{M}_y$ C
	$= -0.00442 \bar{F}_y - 0.00053 \bar{M}_y$	D	$= -0.00442 \bar{F}_y - 0.00062 \bar{M}_y$ D
$T_{10} = \frac{E_y}{I_b} \pm \frac{M_y}{I}$	$= 0.00891 \bar{F}_z + 0.00026 \bar{M}_x$	POINT A	$= 0.00891 \bar{F}_z + 0.00031 \bar{M}_x$ POINT A
	$= 0.00891 \bar{F}_z - 0.00026 \bar{M}_x$	B	$= 0.00891 \bar{F}_z - 0.00031 \bar{M}_x$ B
$b = 2t_{2A}$	$= 0.00891 \bar{F}_y + 0.00026 \bar{M}_z$	C	$= 0.00891 \bar{F}_y + 0.00031 \bar{M}_z$ C
	$= 0.00891 \bar{F}_y - 0.00026 \bar{M}_z$	D	$= 0.00891 \bar{F}_y - 0.00031 \bar{M}_z$ D

SEISMIC PIPE REACTIONS:

THE FORMULAS FOR CALCULATING THE STRESSES DUE TO THE SEISMIC PIPE REACTIONS ARE THE SAME AS FOR THE THERMAL INDUCED PIPE REACTIONS.

COMBUSTION ENGINEERING, INC.
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A 148

SHEET 40 OF 69

CHARGE NO. _____

DATE 4-22-69 BY Coccrall

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
DE INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-69 BY Heiker

5. DETAILED ANALYSIS:

C. STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

LOCATION 7 & B:

PRESSURE STRESS:

$$\sigma_r = \frac{6M_s R_o}{t_{in}^2 R_{in}} + \frac{b^2 P}{2t_{in}^2 R_{in}} = \pm 0.0574 M_s + 0.6197 P$$

$$\sigma_\theta = \pm \frac{\sqrt{6} M_s R_o}{t_{in} R_{in}} + \frac{E \alpha \Delta T}{R_{in}} + \frac{b P}{R_{in}} = \pm 0.0172 M_s + 0.0456 E \alpha \Delta T + 1.6349 P$$

$$\sigma_z = -P$$

THERMAL STRESS:

$$\tau_{rz} = \pm \frac{6 M_s R_o}{t_{in} R_{in}} = \pm 0.0574 M_s$$


$$\tau_{\theta z} = \pm \frac{\sqrt{6} M_s E \alpha}{t_{in} R_{in}} + \frac{E \alpha \Delta T}{R_{in}} = \pm 0.0172 M_s + 0.0456 E \alpha \Delta T$$

THERMAL INDUCED PIPE REACTIONS:

SINCE THE PIPE REACTIONS ARE APPLIED AT THE SMALL END OF THE NOZZLE, THE PIPE REACTIONS MUST BE RESOLVED TO THE CROSS SECTION OF INTEREST. THIS IS DONE AS FOLLOWS.

$$\begin{aligned} \bar{F}_1 = F_1 &= 14.8 & \bar{M}_1 = M_1 &= -3783 \\ \bar{F}_2 = F_2 &= -92 & \bar{M}_2 = M_2 + 30.313 F_2 &= 5332.6 \\ \bar{F}_3 = F_3 &= 27.5 & \bar{M}_3 = M_3 - 30.313 F_3 &= 10229.8 \end{aligned}$$

LOCATION - 7		LOCATION - B	
$\sigma_x = \frac{\bar{F}_1}{A} \pm \frac{\bar{M}_2}{Z}$	$-0.00071 \bar{F}_1 + 0.00005 \bar{M}_2$	POINT A	$-0.00071 \bar{F}_1 + 0.00005 \bar{M}_2$ POINT A
	$-0.00071 \bar{F}_1 - 0.00005 \bar{M}_2$	B	$-0.00071 \bar{F}_1 - 0.00005 \bar{M}_2$ B
	$-0.00071 \bar{F}_1 + 0.00005 \bar{M}_2$	C	$-0.00071 \bar{F}_1 + 0.00005 \bar{M}_2$ C
	$-0.00071 \bar{F}_1 - 0.00005 \bar{M}_2$	D	$-0.00071 \bar{F}_1 - 0.00005 \bar{M}_2$ D



$$I = \frac{\pi}{4} (r_o^4 - r_i^4) = 35424016$$

$$A = \pi (r_o^2 - r_i^2) = 140016$$

COMBUSTION ENGINEERING, INC.
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A 149
SHEET 41 OF 69
DATE 4-22-69 BY COLEMAN
CHECK DATE 4-22-69 BY HENKER

CHARGE NO. _____
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

e. STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

	LOCATION - 7		LOCATION - 8	
$T_{10} = \frac{F_2}{I_b} \pm \frac{M_2}{Z_L}$	$= 0.00138 \bar{F}_2 + 0.000024 \bar{M}_2$	POINT A	$= 0.00138 \bar{F}_2 + 0.000039 \bar{M}_2$	POINT A
	$= 0.00138 \bar{F}_2 - 0.000024 \bar{M}_2$	B	$= 0.00138 \bar{F}_2 - 0.000039 \bar{M}_2$	B
$b' = 2t_{in}$	$= 0.00138 \bar{F}_y + 0.000024 \bar{M}_x$	C	$= 0.00138 \bar{F}_y + 0.000039 \bar{M}_x$	C
	$= 0.00138 \bar{F}_y - 0.000024 \bar{M}_x$	D	$= 0.00138 \bar{F}_y - 0.000039 \bar{M}_x$	D

SEISMIC PIPE REACTIONS:

IN SETTING UP EQUATIONS TO ACCOUNT FOR THE SEISMIC PIPE REACTIONS, THE FORCES EXERTED ON THE NOZZLE WHICH ARE APPLIED THROUGH THE SUPPORT PAD MUST BE RESOLVED TO THE CROSS SECTION OF INTEREST. THESE FORCES ARE LABELED H AND V AS SHOWN ON SHEET 9. THE VALUES FOR THE DESIGN EARTHQUAKE AND THE NO LOSS OF FUNCTION CONDITION WHICH WILL BE CONSIDERED ARE PRESENTED IN THE TABLE ON SHEET 9. THE EQUATIONS FOR STRESS WILL BE THE SAME FOR THE SEISMIC CONDITIONS AS FOR THE THERMAL INDUCED PIPE REACTIONS EXCEPT THE VALUES FOR \bar{F}_x , \bar{F}_y , \bar{F}_z , \bar{M}_x , \bar{M}_y , AND \bar{M}_z WILL BE AS FOLLOWS.

$$\begin{aligned} \bar{F}_x &= F_x = -57.9 & \bar{M}_x &= M_x - 27H = -1492.7 \\ \bar{F}_y &= F_y + V = -340.2 & \bar{M}_y &= M_y + 30.313 F_z + 13.0 H = 23715.1 \\ \bar{F}_z &= F_z + H = 699.4 & \bar{M}_z &= M_z - 30.313 F_y - 13.0 V = 15492.6 \end{aligned}$$

STATIC LOADING THROUGH SUPPORTS:

THE EQUATIONS FOR STRESS ARE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS WITH THE FOLLOWING VALUES FOR \bar{F}_y & \bar{M}_z .

$$\begin{aligned} \bar{F}_y &= V = 561.1 \text{ SEE SHEET 1A FOR VALUES OF V WITH OR WITHOUT} \\ \bar{M}_z &= -13.0V = -729.3 \text{ THE DYNAMIC LOAD OF TRIPPED CONTROL RODS.} \end{aligned}$$

COMBUSTION ENGINEERING, INC.
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A 150
SHEET 42 OF 69
DATE 4-22-68 BY COCKRELL
CHECK DATE 8-22-69 BY HOLLER

CHARGE NO. _____

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS

5- DETAILED ANALYSIS:

E- STRESSES:

1- COMBINED STRESSES - UNCONCENTRATED:

EARTHQUAKE LOADING - THREE SUPPORTS:

THE EQUATIONS FOR STRESS DUE TO THE EARTHQUAKE LOADING THROUGH THE SUPPORTS WILL BE THE SAME AS FOR THE THERMAL INCURRED PIPE REACTIONS WITH THE FOLLOWING VALUES FOR \bar{F}_y , \bar{F}_z , \bar{M}_x , \bar{M}_y , AND \bar{M}_z

$$\begin{aligned} \bar{F}_y &= V = -126.4 & \bar{M}_x &= -27H = -9090.9 \\ \bar{F}_z &= H = 336.7 & \bar{M}_y &= 13H = 4377.1 \\ & & \bar{M}_z &= -13V = 1643.2 \end{aligned}$$

THERMAL EXPANSION AND CONTRACTION:

THE EQUATIONS FOR STRESS DUE TO EXPANSION AND CONTRACTION ARE AS FOLLOWS WITH THE VALUES FOR \bar{F}_x AND \bar{M}_z EQUAL TO.

$$\left. \begin{aligned} \bar{F}_x &= F = 162.3 \\ \bar{M}_z &= 2BF = 4714 \end{aligned} \right\} \text{SEE SHEET 10 FOR VALUES OF } F.$$

	LOCATION - 7		LOCATION - 8	
$\sigma_x = \frac{\bar{F}_x}{A} \pm \frac{\bar{M}_z}{I}$	$= -0.00071 \bar{F}_x + 0.00005 \bar{M}_z$	POINT A	$= -0.00071 \bar{F}_x + 0.00005 \bar{M}_z$	POINT A
	$= -0.00071 \bar{F}_x - 0.00005 \bar{M}_z$	B	$= -0.00071 \bar{F}_x - 0.00005 \bar{M}_z$	B
	$= -0.00071 \bar{F}_x$	C	$= -0.00071 \bar{F}_x$	C
	$= -0.00071 \bar{F}_x$	D	$= -0.00071 \bar{F}_x$	D

	LOCATION - 7	LOCATION - 8	
σ_z	$= 0.00069 F$	$= 0.00153 F$	POINT A
	$= -0.00211 F$	$= -0.00295 F$	B
	$= -0.00071 F$	$= -0.00071 F$	C
	$= -0.00071 F$	$= -0.00071 F$	D

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. _____

NUMBER 5-211-P

| AISI

SHEET 43 OF 69DATE 4-27-68 BY COOPERDESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTSCHECK DATE 4-22-68 BY HEIDER5- DETAILED ANALYSIS:9. STRESSES:1- COMPOUND STRESSES - UNCONCENTRATED:LOCATION 9&10:PRESSURE STRESS:


NOTE HERE THAT IT WILL BE NECESSARY TO CALCULATE STRESS IN BOTH THE LONGITUDINAL AND CIRCUMFERENTIAL DIRECTIONS FOR PRESSURE

POINTS A & B (LONGITUDINAL PLANE):

$$\sigma_x = \pm \frac{6M_x}{t_s^2} - \frac{H_x}{t_s} + \frac{V_x \sin \theta}{t_s} = \pm 0.05192 M_x - 0.09302 H_x + 0.0882 P$$

$$\sigma_\theta = \pm \frac{26M_x}{t_s} + \frac{EW_x}{R_s \sin \theta} + \frac{D_s P}{t_s} = \pm 0.01558 M_x + 0.0462 EW_x + 7.9477 P$$

$$\sigma_r = -P$$

POINTS C & D (CIRCUMFERENTIAL PLANE):

$$\sigma_x = \pm \frac{26M_x}{t_s} + \frac{EW_x}{R_s \sin \theta} + \frac{D_s P}{2R_s t_s} = \pm 0.01558 M_x + 0.0462 EW_x + 3.7297 P$$

$$\sigma_\theta = \pm \frac{6M_x}{t_s^2} - \frac{H_x}{t_s} + \frac{V_x \sin \theta}{t_s} = \pm 0.05192 M_x - 0.0918 H_x + 0.0882 P$$

$$\sigma_r = -P$$

THERMAL STRESS:POINTS A & B (LONGITUDINAL PLANE):

$$\sigma_x = \pm \frac{6M_x}{t_s^2} - \frac{H_x}{t_s} = \pm 0.05192 M_x - 0.0930 H_x$$

$$\sigma_\theta = \pm \frac{26M_x}{t_s} + \frac{EW_x}{R_s \sin \theta} = \pm 0.01558 M_x + 0.0462 EW_x$$

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. 6866

NUMBER 5-211-P | A152

SHEET 44 OF 69

DATE 4-22-68 BY SMITH

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORT

CHECK DATE 4-22-68 BY HEUSER

5. DETAILED ANALYSIS:

5.1. STRESSES:

5.1.1. COMBINED STRESSES - UNCONCENTRATED:

POINTS C & D (CIRCUMFERENTIAL PLANE):

$$\sigma_x = \pm \frac{\sqrt{6}M_x}{t_s} + \frac{EM_x}{K_{G.S.N.P.}} = \pm 0.2155B M_x + 0.0462 EM_x$$

$$\sigma_\theta = \pm \frac{6M_x}{t_s} - \frac{4M_x}{t_s} = \pm 0.05192 M_x - 0.09181 M_x$$

THERMAL INDUCED PIPE REACTIONS:

THE STRESSES IN THE VESSEL WALL DUE TO THE THERMALLY INDUCED PIPE REACTIONS WILL BE CALCULATED BY THE METHOD OUTLINED IN REF 14 FOR A CYLINDRICAL ATTACHMENT TO A CYLINDRICAL SHELL. SINCE THE PIPE REACTIONS ARE APPLIED AT THE SMALL END OF THE NOZZLE, THEY MUST BE RESOLVED TO THE MID-RADIUS OF THE VESSEL WALL. THIS IS DONE BY THE FOLLOWING RELATIONSHIP OF FORCES.

$$F_x = F_1 = 14.8$$


$$F_y = F_1 = -92$$

$$F_z = F_2 = 27.5$$

$$\bar{M}_x = M_x = -5783$$

$$\bar{M}_y = M_y + 35.635 F_z = 5490.4$$

$$\bar{M}_z = M_z - 35.635 F_y = 10724.3$$



WITH THE GEOMETRIC PARAMETERS OF $\gamma = \frac{R_m}{T} = 8.5$ AND $\beta = 0.875 \frac{t}{R_m} = 0.260$ AND THE CURVES IN REF. 14 WE GET THE FOLLOWING EXPRESSIONS FOR STRESS.

COMBUSTION ENGINEERING, INC.
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

DESCRIPTION STRUCTURE AND FRAME EVALUATION OF JET NOZZLE - VESSEL SUPPORT
 CHANGE NO. _____

NUMBER 5-211-P | A153
 SHEET 45 OF 109
 DATE 4-22-68 BY W. Carroll
 CHECK DATE 4-22-68 BY W. Carroll

3-DETAILED ANALYSIS:
 STRESSER:

IN-PLANE STRESSES - UNIFORM STRESS:

$$\sigma_x = \left(\frac{M_x}{F_x/R_{m,B}}\right) \frac{F_x}{R_{m,T}} \pm \left(\frac{M_x}{F_x}\right) \frac{6E_x}{T^2} \pm \left(\frac{M_y}{M_y/R_{m,B}}\right) \frac{M_y}{R_{m,B}T} \pm \left(\frac{M_x}{M_y/R_{m,B}}\right) \frac{6M_y}{R_{m,B}T^2} \pm \left(\frac{M_x}{M_x/R_{m,B}}\right) \frac{M_x}{R_{m,B}T} \pm \left(\frac{M_x}{M_x/R_{m,B}}\right) \frac{6M_x}{R_{m,B}T^2}$$

$$= -11.43 \frac{F_x}{978.58} \pm (0.972) \frac{6E_x}{115.56} \pm (0.50) \frac{M_x}{2316.2} \pm (0.055) \frac{6M_y}{2735.2} \pm (0.29) \frac{M_x}{2316.2} \pm (0.057) \frac{6M_x}{2735.2}$$

LOCATION - 9	LOCATION - 10
-0.00143 F _x + 0.00374 F _y + 0.000012 M _x - 0.00015 M _y POINT A	-0.00143 F _x - 0.00374 F _y - 0.000012 M _x + 0.00015 M _y POINT A
-0.00143 F _x + 0.00374 F _y - 0.000012 M _x + 0.00015 M _y B	-0.00143 F _x - 0.00374 F _y - 0.000012 M _x - 0.00015 M _y B
-0.00143 F _x + 0.00374 F _y + 0.000022 M _y - 0.00012 M _x C	-0.00143 F _x - 0.00374 F _y + 0.000022 M _y + 0.00012 M _x C
-0.00143 F _x + 0.00374 F _y - 0.000022 M _y + 0.00012 M _x D	-0.00143 F _x - 0.00374 F _y - 0.000022 M _y - 0.00012 M _x D

$$\sigma_y = \left(\frac{M_y}{F_y/R_{m,B}}\right) \frac{F_y}{R_{m,T}} \pm \left(\frac{M_y}{F_y}\right) \frac{6E_y}{T^2} \pm \left(\frac{M_x}{M_x/R_{m,B}}\right) \frac{M_x}{R_{m,B}T} \pm \left(\frac{M_y}{M_x/R_{m,B}}\right) \frac{6M_x}{R_{m,B}T^2} \pm \left(\frac{M_y}{M_y/R_{m,B}}\right) \frac{M_y}{R_{m,B}T} \pm \left(\frac{M_y}{M_y/R_{m,B}}\right) \frac{6M_y}{R_{m,B}T^2}$$

$$= -1.25 \frac{F_y}{978.58} \pm (0.094) \frac{6E_y}{115.56} \pm (0.27) \frac{M_x}{2316.2} \pm (0.097) \frac{6M_x}{2735.2} \pm (1.00) \frac{M_y}{2316.2} \pm (0.092) \frac{6M_y}{2735.2}$$

LOCATION - 9	LOCATION - 10
-0.00128 F _x + 0.00489 F _y + 0.000043 M _x - 0.000092 M _y POINT A	-0.00128 F _x - 0.00489 F _y + 0.000043 M _x + 0.000092 M _y POINT A
-0.00128 F _x + 0.00489 F _y - 0.000043 M _x + 0.000092 M _y B	-0.00128 F _x - 0.00489 F _y - 0.000043 M _x - 0.000092 M _y B
-0.00128 F _x + 0.00489 F _y + 0.000012 M _y - 0.00021 M _x C	-0.00128 F _x - 0.00489 F _y + 0.000012 M _y + 0.00021 M _x C
-0.00128 F _x + 0.00489 F _y - 0.000012 M _y + 0.00021 M _x D	-0.00128 F _x - 0.00489 F _y - 0.000012 M _y - 0.00021 M _x D

$$T_z \pm \frac{F_z}{T_{c,T}} \pm \frac{F_x}{T_{c,T}} + \frac{M_x}{2716.2} =$$

0.00110 F _z + 0.00002 M _x	POINT A
-0.00110 F _z + 0.00002 M _x	B
0.00110 F _z + 0.00002 M _x	C
-0.00110 F _z + 0.00002 M _x	D

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. _____

NUMBER 5-211-P

A 154

SHEET 46 OF 69

DATE 4-22-69 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORT

CHECK DATE 4-22-69 BY HENNER

5. DETAILED ANALYSIS:1. STRESSES:1.1. COMBINED STRESSES - UNMOMENTATED:SEISMIC PIPE REACTIONS

THE EQUATIONS FOR STRESS FOR THE SEISMIC PIPE REACTIONS WILL BE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS. THE VALUES FOR \bar{F}_x , \bar{F}_y , \bar{F}_z , \bar{M}_x , \bar{M}_y , AND \bar{M}_z WILL BE AS FOLLOWS. SEE SHEET 13 FOR VALUES OF H AND V.

$$\begin{aligned} \bar{F}_x &= F_x = -57.9 & \bar{M}_x &= M_x - 27H = -14927.5 \\ \bar{F}_y &= F_y + V = -340.2 & \bar{M}_y &= M_y + 35.688F_z + 18.375H = 27205.6 \\ \bar{F}_z &= F_z + H = 649.4 & \bar{M}_z &= M_z - 35.688F_y - 18.375V = 17321.1 \end{aligned}$$

STATIC LOADING THROUGH SUPPORTS:

THE EQUATIONS FOR STRESS ARE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS WITH THE FOLLOWING VALUES FOR \bar{F}_y AND \bar{M}_z

$$\begin{aligned} \bar{F}_y &= V = 561.1 & \text{SEE SHEET 14 FOR VALUES OF V WITH OR} \\ \bar{M}_z &= -18.375V & \text{WITHOUT THE DYNAMIC LOAD OF TRIPPED CONTROL RODS.} \\ &= -10310.2 \end{aligned}$$

EARTHQUAKE LOADING THROUGH SUPPORTS:

THE EQUATIONS FOR STRESS ARE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS WITH THE FOLLOWING VALUES FOR \bar{F}_y , \bar{F}_z , \bar{M}_x , \bar{M}_y , AND \bar{M}_z .

$$\begin{aligned} \bar{F}_y &= V = -126.4 & \bar{M}_x &= -27H = -9090.9 \\ \bar{F}_z &= H = 336.7 & \bar{M}_y &= 18.375H = 6186.9 \\ & & \bar{M}_z &= -18.375V = 2322.6 \end{aligned}$$

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A155

SHEET 41 OF 69

DATE 4-22-69 BY COOPER

CHECK DATE 4-27-69 BY HEWLE

CHARGE NO. _____

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS

5- DETAILED ANALYSIS:

6- STRESSES:

7- COMBINED STRESSES - UNCONCENTRATED:

THERMAL EXPANSION AND CONTRACTION:

THE EQUATIONS FOR STRESS ARE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS WITH THE FOLLOWING VALUES FOR \bar{F}_x & \bar{M}_x

$\bar{F}_x = F = \pm 164.3 \text{ KIPS}$

$\bar{M}_x = 2RF = \pm 4712.4 \text{ IN-KIPS}$

CONSIDER CRITERION 5.4.1:

THE CROSS SECTION OF INTEREST IS THE SECTION SHOWN IN SHEET 40 FOR LOCATIONS 7 & 8. SINCE THERE IS BENDING IN TWO DIRECTIONS, THE FOLLOWING RELATIONSHIPS WILL BE USED TO DETERMINE THE MAXIMUM EFFECT OF BENDING BY THE THERMAL AND DESIGN SEISMIC PIPE LOADS, $K1F1H$, ETC.

$$\sigma_x = -\frac{\bar{F}_x}{A} \pm \frac{C}{I} \sqrt{\bar{M}_y^2 + \bar{M}_z^2} = -0.00071 \bar{F}_x \pm 0.00005 \sqrt{\bar{M}_y^2 + \bar{M}_z^2} \text{ INSIDE}$$

$$= -0.00071 \bar{F}_x \pm 0.00008 \sqrt{\bar{M}_y^2 + \bar{M}_z^2} \text{ OUTSIDE}$$

$$T_{12} = \frac{D}{IC} [\bar{F}_y \sin \theta + \bar{F}_z \cos \theta] + \frac{\bar{M}_{12}}{2I} = 0.00139 [\bar{F}_y \sin \theta + \bar{F}_z \cos \theta] \pm 0.000024 \bar{M}_{12} \text{ INSIDE}$$

$$= 0.00139 [\bar{F}_y \sin \theta + \bar{F}_z \cos \theta] \pm 0.000039 \bar{M}_{12} \text{ OUTSIDE}$$

$$\theta = \tan^{-1} \frac{\bar{M}_y}{\bar{M}_z}$$

LOCATION	PRESSURE STRESS			DUE TO FIT LOADS, UNIFORM		PRINCIPAL STRESS			STRESS INTENSITY		
	σ_v	σ_h	σ_r	σ_1	T_{12}	σ_1	σ_2	σ_3	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
7	1.55	4.09	-2.5	1.99	0.17	4.14	3.49	-2.5	0.65	6.64	5.99
	↓	↓	-2.5	-2.17	1.50	4.53	-1.06	-2.5	5.59	7.03	1.44
8	↓	↓	0	3.24	-0.21	4.85	4.03	0	0.82	4.85	4.03
	↓	↓	0	-3.42	1.90	4.64	-2.42	0	7.06	4.64	-2.42

$$SI_{max} = \sigma_1 - \sigma_2 = 7.06 \text{ KSI} < S_m = 26.7 \text{ KSI} \quad \text{LOCATION 8}$$

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A156

SHEET 48 OF 69

CHARGE NO. _____

DATE 4-22-69 BY COOPER

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION CHECK DATE 4-22-09 BY HEIKER

DE INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

e. STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

CONSIDER CRITERION 5.6.2:

CUT	BODY	I.P. 2Rt	O.P. t	EW R	σ_x	σ_θ	σ_r	STRESS INTENSITY		
								$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
1	1	6.30	13.75	3.16	6.30	16.91	-1.25	-10.61	7.55	18.16
1	2	6.46	15.07	1.90	6.86	16.97		-10.11	8.11	18.22
2	2	6.59	14.97	-3.59	6.59	10.88		-4.29	7.84	12.13
4	4	1.55	4.09	17.79	1.55	21.88		-20.33	7.80	23.13
4	5 LONG AXIS	7.16	19.97	11.15	7.16	31.02		-23.86	8.41	32.27
4	5 CIRC AXIS	9.32	7.07	11.15	20.47	7.07		13.40	21.72	8.32

$SI_{MAX} = \sigma_\theta - \sigma_r = \underline{32.27 \text{ KSI}} < 1.5 S_m = 40 \text{ KSI}$ CUT 4 BODY 5
LONGITUDINAL AXIS
SEE SHEET
POINTS 9 & 10

CONSIDER CRITERION 5.6.3:

LOCATION	PERCENT STRESS			STRESS DUE TO PIPE WELDS, NOZZLES, ETC			PRINCIPAL STRESSES			STRESS INTENSITY		
	σ_x	σ_θ	σ_r	σ_1	σ_2	T_{max}	σ_1	σ_2	σ_3	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
9A	7.16	31.02	-2.5	4.53	1.30	1.20	32.34	11.67	-2.5	20.67	34.84	14.17
B	7.16	31.02		4.01	2.11	1.56	33.24	11.06		22.18	35.74	8.56
C	20.47	7.07		3.85	7.42	1.61	24.58	14.22		10.36	27.08	16.72
D	20.47	7.07		4.29	8.64	-1.25	24.79	15.55		9.24	27.29	18.05
10A	7.16	31.02	0	3.36	2.57	1.20	33.60	10.91	0	23.09	33.60	10.51
B	7.16	31.02		6.73	6.24	1.56	37.37	13.79		23.53	37.37	13.79
C	20.47	7.07		6.62	9.93	1.61	27.12	16.97		10.15	27.12	16.97
D	20.47	7.07		5.86	8.74	-1.25	26.48	15.66		10.82	26.48	15.66

$SI_{MAX} = \sigma_1 - \sigma_2 = \underline{37.4 \text{ KSI}} < 1.5 S_m = 40 \text{ KSI}$ LOCATION 10B

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A157

SHEET 49 OF 69

CHARGE NO. _____

DATE 4-22-68 BY COCKRILL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HENKER

5- DETAILED ANALYSIS:

C. STRESSES:

1- COMBINED STRESSES - UNCONCENTRATED:

CONSIDER CRITERION S.E.A.:

SAFE END

$$\sigma_1 = \frac{F_1}{A} \pm \frac{C}{I} \sqrt{M_1^2 + M_2^2} = -0.00424 F_1 \pm 0.00092 \sqrt{M_1^2 + M_2^2} \quad \text{POINT 1}$$

$$= -0.00424 F_1 \pm 0.00061 \sqrt{M_1^2 + M_2^2} \quad \text{POINT 2}$$

$$T_{10} = \frac{Q}{Ib} [F_1 \sin \theta + F_2 \cos \theta] \pm \frac{M_{10}}{2I} = 0.00945 [F_1 \sin \theta + F_2 \cos \theta] \pm 0.00026 M_{10} \quad \text{POINT 1}$$

$$= 0.00945 [F_1 \sin \theta + F_2 \cos \theta] \pm 0.00031 M_{10} \quad \text{POINT 2}$$

$$e = \frac{e_x}{M_1} + \frac{e_y}{M_2}$$

LOCATION	PRESSURE STRESS			STRESS DUE TO SHOCK LOADS		PRINCIPAL STRESS			STRESS INTENSITY		
	σ_1	σ_2	σ_3	σ_4	T_{10}	σ_1	σ_2	σ_3	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
1	6.30	16.91	-2.5	8.74	1.39	17.50	14.25	-2.5	3.25	20.00	16.75
			-2.5	-8.24	0.87	16.95	-1.98	-2.5	18.93	19.45	0.52
2			0	10.21	1.43	19.16	16.28	0	2.88	19.16	16.28
			0	-9.71	0.83	16.94	-3.44	0	20.38	16.94	-3.44

$S_{I_{max}} = \sigma_1, \sigma_2 = 20.38 \text{ KSI} < 1.5 S_m = 25.05 \text{ KSI} \quad \text{LOCATION - 2}$

SMALL END OF NOZZLE

$$\sigma_0 = \frac{F_1}{A} \pm \frac{C}{I} \sqrt{M_1^2 + M_2^2} = -0.00462 F_1 \pm 0.00056 \sqrt{M_1^2 + M_2^2} \quad \text{POINT 3}$$

$$= -0.00462 F_1 \pm 0.00065 \sqrt{M_1^2 + M_2^2} \quad \text{POINT 4}$$

$$T_{10} = \frac{Q}{Ib} [F_1 \sin \theta + F_2 \cos \theta] \pm \frac{M_{10}}{2I} = 0.00926 [F_1 \sin \theta + F_2 \cos \theta] \pm 0.00024 M_{10} \quad \text{POINT 3}$$

$$= [F_1 \sin \theta + F_2 \cos \theta] \pm 0.00033 M_{10} \quad \text{POINT 4}$$

$$e = \frac{e_x}{M_1} + \frac{e_y}{M_2}$$

LOCATION	PRESSURE STRESS			STRESS DUE TO SHOCK LOADS		PRINCIPAL STRESS			STRESS INTENSITY		
	σ_1	σ_2	σ_3	σ_4	T_{10}	σ_1	σ_2	σ_3	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
3	6.96	16.97	-2.5	9.41	1.51	18.17	15.07	-2.5	3.10	20.67	17.57
			-2.5	-8.87	0.97	17.02	-2.06	-2.5	19.08	19.52	0.44
4			0	10.88	1.56	18.96	15.75	0	3.21	19.96	15.75
			0	-10.34	0.92	17.01	-3.52	0	20.53	17.01	-3.52

$S_{I_{max}} = \sigma_1 - \sigma_3 = 20.67 \text{ KSI} < 1.5 S_m = 40.05 \text{ KSI} \quad \text{LOCATION 3}$

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. _____

NUMBER 5-211-P | A157

SHEET 49 OF 69

DATE 4-22-69 BY LOCKRILL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-69 BY HEWLER

5- DETAILED ANALYSIS:

a. STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

CONSIDER CRITERION S.E.E.:

SAFE END

$$\sigma_r = -\frac{E_r}{11} \pm \frac{C}{2} \sqrt{\bar{M}_1^2 + \bar{M}_2^2} = -0.00434 \bar{F}_y \pm 0.00052 \sqrt{\bar{M}_1^2 + \bar{M}_2^2} \quad \text{POINT 1}$$

$$= -0.00424 \bar{F}_y \pm 0.00061 \sqrt{\bar{M}_1^2 + \bar{M}_2^2} \quad \text{POINT 2}$$

$$T_{10} = \frac{Q}{16} [\bar{F}_y \sin \theta + \bar{F}_z \cos \theta] \pm \frac{M_{10} C}{2I} = 0.00545 [\bar{F}_y \sin \theta + \bar{F}_z \cos \theta] \pm 0.00026 \bar{M}_x \quad \text{POINT 1}$$

$$= 0.00545 [\bar{F}_y \sin \theta + \bar{F}_z \cos \theta] \pm 0.00031 \bar{M}_x \quad \text{POINT 2}$$

LOCATION	PRESSURE STRESS			STRESS DUE TO SPRING LOADS			PRINCIPAL STRESS			STRESS INTENSITY		
	σ_1	σ_2	σ_3	σ_1	T_{10}	σ_2	σ_3	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$		
1	6.30	16.91	-2.5	8.74	1.39	17.50	14.25	-2.5	3.25	20.00	16.75	
			-2.5	-8.24	0.87	16.95	-1.98	-2.5	18.93	19.45	0.52	
2			0	10.21	1.43	19.16	16.28	0	2.88	19.16	16.28	
			0	-9.71	0.83	16.94	-3.44	0	20.38	16.94	-3.44	

$S.I._{max} = \sigma_1 - \sigma_3 = 20.38 \text{ KSI} < 1.5 S_m = 25.05 \text{ KSI} \quad \text{LOCATION - 2}$

SMALL END OF NOZZLE

$$\sigma_r = -\frac{E_r}{11} \pm \frac{C}{2} \sqrt{\bar{M}_1^2 + \bar{M}_2^2} = -0.00462 \bar{F}_y \pm 0.00056 \sqrt{\bar{M}_1^2 + \bar{M}_2^2} \quad \text{POINT 3}$$

$$= -0.00462 \bar{F}_y \pm 0.00065 \sqrt{\bar{M}_1^2 + \bar{M}_2^2} \quad \text{POINT 4}$$

$$T_{10} = \frac{Q}{16} [\bar{F}_y \sin \theta + \bar{F}_z \cos \theta] \pm \frac{M_{10} C}{2I} = 0.00926 [\bar{F}_y \sin \theta + \bar{F}_z \cos \theta] \pm 0.00029 \bar{M}_x \quad \text{POINT 3}$$

$$= [\bar{F}_y \sin \theta + \bar{F}_z \cos \theta] \pm 0.00033 \bar{M}_x \quad \text{POINT 4}$$

LOCATION	PRESSURE STRESS			STRESS DUE TO SPRING LOADS			PRINCIPAL STRESS			STRESS INTENSITY		
	σ_1	σ_2	σ_3	σ_1	T_{10}	σ_2	σ_3	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$		
3	6.96	16.97	-2.5	9.41	1.51	18.17	15.07	-2.5	3.10	20.67	17.57	
			-2.5	-8.81	0.97	17.02	-2.06	-2.5	19.09	19.52	0.44	
4			0	10.88	1.56	18.96	15.75	0	3.21	18.96	15.75	
			0	-10.54	0.92	17.01	-3.52	0	20.53	17.01	-3.52	

$S.I._{max} = \sigma_1 - \sigma_3 = 20.67 \text{ KSI} < 1.5 S_m = 40.05 \text{ KSI} \quad \text{LOCATION 3}$

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A158SHEET 50 OF 69DATE 4-22-65 BY COCKERELLCHARGE NO. _____
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTCHECK DATE 4-22-64 BY HENNER5. DETAILED ANALYSIS:5.1 STRESSES:5.1.1 COMBINED STRESSES - UNCONCENTRATED:CONSIDER CRITERION 5.1.5.1:

NOTE HERE THAT THE RANGE OF STRESS INTENSITY WAS CALCULATED AT THE TEN LOCATIONS AS SHOWN ON SHEET 11 FOR THE FOUR ORIENTATIONS A, B, C AND D. THE FOLLOWING TABLE GIVES THE RANGE OF STRESS INTENSITY FOR EACH LOCATION AND ORIENTATION. STRESSES AND STRESS INTENSITIES PRODUCING THESE RANGE OF STRESS INTENSITIES WILL NOT BE PRESENTED FOR ALL LOCATIONS AND ORIENTATIONS. ONLY STRESSES AND STRESS INTENSITIES AT THE LOCATION AND ORIENTATION WHICH PRODUCED THE HIGHEST RANGE OF STRESS WILL BE PRESENTED. THIS WAS LOCATION-10B.

LOCATION AND ORIENTATION	S.I. RANGE
1A	24.31
B	26.83
C	27.26
D	28.17
2A	33.31
B	33.46
C	33.44
D	33.27
3A	31.14
B	39.14
C	34.36
D	39.82
4A	37.69
B	35.45
C	36.78
D	35.55

LOCATION AND ORIENTATION	S.I. RANGE
5A	28.12
B	25.30
C	26.89
D	26.43
6A	36.70
B	37.07
C	36.70
D	36.70
7A	19.29
B	18.28
C	18.44
D	18.44
8A	33.28
B	33.28
C	33.33
D	33.33

LOCATION AND ORIENTATION	S.I. RANGE
9A	41.44
B	43.28
C	29.32
D	29.32
10A	42.75
B	45.54
C	32.20
D	31.05

COMBUSTION ENGINEERING, INC.
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A159
SHEET 51 OF 59
DATE 4-22-65 BY COYKELL
CHECK DATE 4-22-69 BY HEILKER

CHARGE NO. _____
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VISCOUS SUPPORTS

3. DETAILED ANALYSIS:

e. STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

LOCATION 10B

TOLERANT	PRESSURE STRESS		THERMAL STRESS		INTERNAL FORCE FROM REACTION STRESS		SEISMIC AIR BUSTON STRESS		STATIC WEIGHT STRESS				
	σ _t	σ _c	σ _t	σ _c	σ _t	σ _c	σ _t	σ _c	σ _t	σ _c			
424	10.16	16.70	-0.15	-1.09	-1.62	-1.39	-0.09	-2.50	-1.98	-1.01	1.67	1.39	0
425	17.87	29.35	-0.02	-1.11	-1.73	-1.46	-0.10						
425	19.54	30.46	-0.02	-1.11	-1.77	-1.50	-0.10						
429	19.35	31.78	0.17	-1.13	-1.81	-1.54	-0.11						
500	19.35	31.78	0.24	-0.66	-1.81	-1.54	-0.11						
400	10.16	16.70	-0.15	-1.09	-1.62	-1.38	-0.09	2.50	1.98	1.01			
425	17.87	29.35	-0.02	-1.11	-1.73	-1.46	-0.10						
435	18.54	30.48	-0.02	-1.11	-1.77	-1.50	-0.10						
447	19.35	31.78	0.17	-1.13	-1.81	-1.54	-0.11						
500	19.35	31.78	0.24	-0.66	-1.81	-1.54	-0.11						
SHRIV-SMTC			0.03	0.03	-1.81	-1.54	-0.11	-2.50	-1.98	-1.01			
			0.03	0.03	-1.81	-1.54	-0.11	2.50	1.98	1.01			
			0.03	0.03	-1.81	-1.54	-0.11	0	0	0			
400MB	2.71	4.45	0.19	1.03	-0.19	-0.16	-0.01	-2.50	-1.98	-1.01			
425			0.06	1.04	-0.09	-0.08	-0.01						
425			0.06	1.04	-0.05	-0.04	0						
447			-0.14	1.06	0	0	0						
500			-0.21	0.61	0	0	0						
400			0.19	1.03	-0.19	-0.16	-0.01						
425			0.06	1.04	-0.09	-0.08	-0.01	2.50	1.98	1.01			
435			0.06	1.04	-0.09	-0.08	-0.01						
447			-0.14	1.06	0	0	0						
500			-0.21	0.61	0	0	0						

COMBUSTION ENGINEERING, INC.
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A161
SHEET 53 OF 69

CHARGE NO. _____

DATE 4-22-69 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS.

CHECK DATE 4-22-69 BY HEILKER

5. DETAILED ANALYSIS:

E. STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

TOLERANT	CARRIER LOADS FROM SUPPORT STRESS CONCENTRATION			STRESSING BY GEOMETRIC STRESS CONCENTRATION			TOTAL STRESS			PRINCIPAL STRESS			STRESS INTENSITY		
	σ _x	σ _y	τ _{xy}	σ _x	σ _y	τ _{xy}	σ ₁	σ ₂	τ ₁₂	σ ₁	σ ₂	τ ₁₂	σ ₁₋₀₃	σ ₂₋₀₃	σ ₃₋₀₃
4.00 ME	-0.39	-0.31	-0.55	-1.67	-1.67	0	5.53	11.65	0	-1.66	12.07	5.11	6.96	12.07	5.11
4.25							13.27	24.21		-1.67	24.46	13.02	11.44	24.46	13.02
4.25							13.90	25.29		-1.67	25.52	13.66	11.86	25.52	13.66
4.47							14.96	26.54		-1.67	26.79	14.42	12.16	26.79	14.42
5.00							14.92	27.21		-1.67	27.24	14.69	12.54	27.24	14.69
4.00	0.39	0.31	0.55				11.29	16.24		1.47	16.64	10.99	5.75	16.64	10.99
4.25							19.09	28.90		1.46	29.01	18.81	10.20	29.01	18.81
4.25							19.67	29.99		1.46	30.10	19.47	10.63	30.10	19.47
4.47							20.62	31.13		1.46	31.33	20.42	10.91	31.33	20.42
5.00							20.69	31.60		1.46	31.79	20.49	11.30	31.79	20.49
5.00	-0.39	-0.31	-0.55	0	0	0	16.35	29.31		-1.67	29.52	16.14	13.39	29.52	16.14
5.00	0.39	0.31	0.55				22.11	33.90		1.46	34.29	21.93	12.14	34.29	21.93
5.00	0	0	0				19.23	31.61		-2.11	31.61	19.23	12.39	31.61	19.23
5.00	-0.38	-0.31	-0.55	1.67	1.67	0	3.14	6.09		-1.58	6.77	2.45	4.32	6.77	2.45
4.25							3.11	6.18		-1.57	6.84	2.45	4.40	6.84	2.45
4.25							3.15	6.22		-1.57	6.97	2.49	4.59	6.97	2.49
4.47							3.00	6.29		-1.57	6.90	2.37	4.53	6.90	2.37
5.00							2.93	5.93		-1.57	6.51	2.25	4.26	6.51	2.25
4.00	0.39	0.31	0.55				9.39	12.67		1.55	11.58	7.99	3.53	11.58	7.99
4.25							9.97	10.77		1.56	11.65	7.99	2.00	11.65	7.99
4.25							9.91	10.81		1.56	11.68	8.03	3.06	11.68	8.03
4.47							9.76	10.97		1.57	11.70	7.93	3.77	11.70	7.93
5.00							9.69	10.42		1.57	11.34	7.77	3.57	11.34	7.77

Location I.D.B.

2 - HEATKO

6. COOLDOWN

COMBUSTION ENGINEERING, INC.
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A162
SHEET 54 OF 69

RECEPTION: Structures and Fatigue Evaluation
CHECK DATE 4-22-69 BY H. K. K. K.

5. Detailed Analysis:
a. Stresses:
1. Combined Stresses - Unstressed

LOCATION 10B

TRANSIENT	FATIGUE CRACK PROPAGATION STRESS			EXPOSURE AND CONCENTRATION STRESS			TOTAL STRESS				POSSIBLE STRESS			STRESS INTENSITY		
	σ_f	σ_b	σ_{T0}	σ_f	σ_b	σ_{T0}	σ_f	σ_b	σ_{T0}	σ_f	σ_b	σ_3	$\sigma_f-\sigma_b$	$\sigma_b-\sigma_3$	$\sigma_f-\sigma_3$	
c 20 min	0	0	0	0	0	0	19.23	31.61	0	-0.11	31.61	19.23	0	12.37	31.61	19.23
d 20 min							19.23	31.61			31.61	19.23		12.37	31.61	19.23
e 100 SEC							15.29	30.05			30.05	12.29		11.77	30.05	12.29
	725 SEC						19.45	31.96			31.96	19.45		12.51	31.96	19.45
f 40 SEC							19.64	32.59			32.60	19.83		12.76	32.60	19.83
	100 SEC						19.32	31.75			31.75	19.32		12.43	31.75	19.32
	260 SEC						19.29	30.05			30.05	19.29		11.77	30.05	19.29
g 2 min							20.27	33.30			33.30	20.26		13.04	33.30	20.26
	3.2 min						20.09	33.02			33.02	20.09		12.93	33.02	20.09
	10 min						18.37	30.19			30.19	18.37		11.82	30.19	18.37
h 10 SEC							18.98	31.18			31.18	18.97		12.21	31.18	18.97
	65 SEC						16.31	26.80			26.80	16.31		10.50	26.80	16.31
i 320 min							28.54	45.54		0	45.54	28.54		16.99	45.54	28.54
j 3.0 HRS							10.90	17.51		-0.08	17.51	10.90		6.61	17.51	10.90
	5.5 C.D.						21.97	35.65		-0.08	35.65	21.96		13.68	35.65	21.96
	3.0 HRS						4.51	6.33		0	6.33	4.51		1.81	6.33	4.51
k ~							20.09	33.02		-0.11	33.02	20.09		12.93	33.02	20.09
	~						18.37	30.19			30.19	18.37		11.82	30.19	18.37
l 12 SEC							19.23	31.61			31.61	19.23		12.37	31.61	19.23
m 10 SEC							23.62	39.81			39.81	23.62		15.19	39.81	23.62
	28 SEC						19.12	29.77			29.77	18.11		11.66	29.77	18.11
	160 SEC						12.27	20.16			20.16	12.27		7.90	20.16	12.27
n 33 SEC							2.46	4.06			4.07	2.46		1.61	4.07	2.46
	54 SEC						5.90	9.71			9.71	5.90		3.81	9.71	5.90

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. _____

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS

NUMBER 5-211-P | A163

SHEET 55 OF 69

DATE 4-22-69 BY CEMPRELL

CHECK DATE 4-22-69 BY HELMER

3. DETAILED ANALYSIS:

C. STRESSES:

1. COMBINED STRESSES - UNCOMPENSATED:

CONSIDER STRESSES DURING NO LOSS OF FUNCTION SEISMIC LOADING:

IN THIS SECTION THE ALLOWABLE STRESSES LISTED ON SHEET 7 FOR CRITERIA 5.6.1, 5.6.3, AND 5.6.4 WILL BE INCREASED BY A FACTOR OF 1.2; SEE REF. 20.

CONSIDER CRITERION 5.6.1:

LOCATION	PRESSURE STRESS			STRESS DUE TO EXTERNAL LOADS			PRINCIPAL STRESS			STRESS INTENSITY		
	σ_x	σ_y	σ_z	σ_x	σ_y	T_{xy}	σ_1	σ_2	σ_3	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
7	1.55	4.09	-2.5	3.08	-0.36		4.81	3.91	-2.5	0.90	7.31	6.41
			-2.5	-3.22	1.78		4.60	-2.18	-2.5	6.78	7.10	0.32
8			0	4.97	-0.99		6.87	3.34	0	3.15	6.87	3.34
			0	-5.11	2.41		4.79	-4.26	0	9.05	4.79	-4.26

$S_{I, MAX} = \sigma_1 - \sigma_3 = \underline{9.05 \text{ KSI}} < 1.2 S_m = 32.04 \text{ KSI}$ LOCATION 8

CONSIDER CRITERION 5.6.3:

LOCATION	PRESSURE STRESS			STRESSES DUE TO EXTERNAL LOADS			PRINCIPAL STRESS			STRESS INTENSITY		
	σ_x	σ_y	σ_z	σ_x	σ_y	T_{xy}	σ_1	σ_2	σ_3	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
9A	7.16	31.02	-2.5	5.24	1.63	1.02	32.67	12.26	-2.5	20.41	35.17	14.76
B	7.16	31.02		5.49	2.70	2.66	34.06	12.32		21.74	36.56	14.82
C	20.47	7.07		5.70	11.48	2.32	26.82	17.90		8.92	29.32	20.40
D	20.47	7.07		7.04	13.84	-0.52	27.53	20.87		6.66	30.05	23.37
10A	7.16	31.02	0	5.06	4.27	0.98	35.34	12.18	0	23.16	35.34	12.18
B	7.16	31.02		7.52	6.98	2.61	38.29	14.39		23.90	38.29	14.39
C	20.47	7.07		8.49	13.56	2.31	29.56	20.04		9.52	29.56	20.04
D	20.47	7.07		9.56	14.51	-0.51	30.06	21.56		8.50	30.06	21.56

$S_{I, MAX} = \sigma_1 - \sigma_3 = \underline{38.3 \text{ KSI}} < 1.2(1.5 S_m) = 48.1 \text{ KSI}$ LOCATION 10B

COMBUSTION ENGINEERING, INC.
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A164
SHEET 56 OF 69
DATE 4-22-69 BY COOPER
CHECK DATE 4-22-69 BY HEILKE

CHARGE NO. _____

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUMMARY

S- DETAILED ANALYSIS:

1- STRESSES

1- COMBINED STRESSES - UNCONCENTRATED:

CONSIDER CRITERION 5.6.4:

SAFE END

LOCATION	PRESSURE STRESS			STRESS DUE TO SEISMIC LOADS			PRINCIPAL STRESSES			STRESS INTENSITY		
	σ_1	σ_2	σ_3	σ_4	T_{SD}	σ_1	σ_2	σ_3	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$	
1	6.30	16.91	-2.5	13.71	2.46	21.37	18.55	-2.5	5.92	23.97	18.05	
			-2.5	-13.01	1.00	16.95	-6.75	-2.5	23.70	19.45	-4.25	
2			0	16.02	2.60	23.37	15.96	0	7.50	23.37	15.96	
			0	-15.32	0.86	16.94	-9.05	0	25.99	16.94	-9.05	

$S.I_{max} = \sigma_1 - \sigma_2 = 25.99 \text{ KSI} < 1.2(1.55m) = 30.06 \text{ KSI}$ LOCATION 2

SMALL END OF NOZZLE

LOCATION	PRESSURE STRESS			STRESS DUE TO SEISMIC LOADS			PRINCIPAL STRESS			STRESS INTENSITY		
	σ_1	σ_2	σ_3	σ_4	T_{SD}	σ_1	σ_2	σ_3	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$	
3	6.96	16.97	-2.5	14.76	2.67	22.04	15.75	-2.5	7.09	25.34	18.25	
			-2.5	-14.00	1.11	17.02	-7.19	-2.5	24.21	19.52	-4.69	
4			0	17.07	2.81	24.92	15.98	0	9.94	24.92	15.98	
			0	-16.31	0.97	17.01	-9.49	0	26.50	17.01	-9.49	

$S.I_{max} = \sigma_1 - \sigma_2 = 25.07 \text{ KSI} < 1.2(1.55m) = 48.06 \text{ KSI}$ LOCATION 3

Submitted: December 27, 2011

COMBUSTION ENGINEERING, INC.
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A 165
SHEET 57 OF 69
DATE 4-22-69 BY COOPER
CHECK DATE 4-22-69 BY HENKER
REVISED 4-19-69 BY COOPER

CHARGE NO. _____

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORT

5. DETAILED ANALYSIS:e. STRESSES:1. COMBINED STRESSES - UNCONCENTRATED:CONSIDER THE COMBINED FORCES ON THE PAD:

THE MAXIMUM AND MINIMUM VERTICAL FORCE ON THE INLET NOZZLE PADS WAS FOUND TO BE,

$$\begin{aligned} \bar{V}_{MAX} &= 1204.3 \text{ KIPS} \\ \bar{V}_{MIN} &= 9.7 \text{ KIPS} \end{aligned} \left. \begin{array}{l} \text{NOTE HERE THAT THESE FORCES WERE DETERMINED} \\ \text{USING THE DESIGN SEISMIC PIPE LOADS, THERMAL} \\ \text{INDUCED PIPE LOADS AND THE SEISMIC SHOCK FACTORS} \\ \text{GIVEN IN REF 20} \end{array} \right\}$$

NOTE THAT SINCE THE MINIMUM VALUE OF \bar{V} IS POSITIVE, THE VESSEL WILL NOT LIFT OFF THE SUPPORT STRUCTURE UNDER THE DESIGN CONDITIONS.

THE MAXIMUM HORIZONTAL FORCE ON THE INLET NOZZLE PADS WAS FOUND TO BE,

$$\bar{F}_{MAX} = 1026.5 \text{ KIPS} \quad \text{SEE NOTE ABOVE FOR } \bar{V}_{MAX} \text{ \& } \bar{V}_{MIN}$$

THE ABOVE MAXIMUM FORCES PRODUCE BEARING STRESSES IN THE PAD EQUATION,

$$\left. \begin{aligned} \sigma_{BEAR} &= \frac{\bar{V}_{MAX}}{A} = \frac{1204.3}{21.5} = 55 \text{ KSI} \\ \sigma_{BEAR} &= \frac{\bar{F}_{MAX}}{A} = \frac{1026.5}{234.10} = 4.11 \text{ KSI} \end{aligned} \right\} < S_y = 44.5 \text{ KSI @ 400}^\circ\text{F}$$

NOTE THAT THE BEARING STRESS ON THE BOTTOM OF THE PAD IS 50 KSI WHEN CONSIDERING DEAD WEIGHT AND THERMAL PIPE REACTIONS ONLY. THIS COMPARES WITH A DESIRED BEARING STRESS OF 50 KSI. THIS STRESS BELONGS 4.0 KSI WHEN CONSIDERING THREE SUPPORT ONLY.

COMBUSTION ENGINEERING, INC.
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A166
SHEET 58 OF 69
DATE 4-22-69 BY COOPER
CHECK DATE 4-22-69 BY HEILER

CHARGE NO. _____

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS


5. DETAILED ANALYSIS:

1. STRESSES:

2. PEAK STRESSES:

THE FOLLOWING VALUES OF STRESS CONCENTRATION FACTORS WILL BE USED TO CALCULATE PEAK STRESSES AT LOCATIONS 6, 9 AND 10. THE STRESS CONCENTRATION FACTORS AT ALL OTHER LOCATIONS WILL BE ONE; HENCE, THE EXPRESSIONS FOR PEAK STRESS WILL BE THE SAME AS THOSE GIVEN ON SHEETS 36-47 WITH THE FOLLOWING EXCEPTIONS (1) THE TERM $\frac{E\alpha}{(1-\nu)}(T_1 - T_2)$ IS ADDED TO REFLECT THE STRESS DUE TO THE RADIAL GRADIENT (2) THE $\frac{6M}{L^2}$ AND $\frac{7.6M}{L^2}$ TERMS FOR STRESSES DUE TO THERMAL EFFECTS WILL INCLUDE THE THERMAL MOMENT DUE TO THE RADIAL GRADIENT, AND (3) FOR LOCATION 10, THE PRESSURE STRESS WILL BE CALCULATED USING THE STRESS INDICES GIVEN IN 1-612 OF SECTION III.

LOCATION 6:



$D = 26.062$ $h = 10.75$ $\beta = 55^\circ$ $\frac{D}{h} = 5.713$
 $d = 4.562$ $R = 3.219$ $\frac{R}{d} = 3.644$ $\frac{h}{R} = 3.34$


FROM EQUATIONS 6.20 AND 6.24 OF REF. 11:

$K_{T0} = 1.42$
 $K_{R0} = 1.22$

FROM EQUATION 6.22 OF REF. 11:

$K_T = 1.27$
 $K_B = 1.14$

LOCATION 9 & 10



$t = 12.636$ $r = 5.375$
 $D = 21.372$ $\frac{r}{D} = 0.509$

FOR $\frac{r}{D} = 0.503$

$K_T = 1.80$
 $K_B = 1.50$ } FROM FIG. A.7-1 REF. 3

COMBUSTION ENGINEERING, INC.
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A167
 SHEET 59 OF 69
 DATE 4-22-52 BY SMITH
 CHECK DATE 4-22-52 BY HELVOR

CHARGE NO. _____
 DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

1. STRESSES:

2. PEAK STRESS:

THE FOLLOWING EXPRESSIONS FOR STRESS WILL BE USED TO CALCULATE PEAK STRESS AT LOCATIONS 6, 8 AND 10.

LOCATION 6:

PRESSURE STRESS:

$$\sigma_x = - \frac{6 M_2}{L^2} K_3 + \frac{b P}{R_2 E A} K_T = -1.2126 M_2 + 3.3454 P$$

$$\sigma_y = - \frac{\nu 6 M_2}{L^2} K_3 + \frac{E \nu W}{R_2} + \frac{b P}{L A} = -0.3639 M_2 + 0.0662 E W_2 + 5.7495 P$$

$\sigma_z = 0$

THERMAL STRESS:

$$\sigma_x = - \frac{6(A_1 - M_2)}{L^2} K_3 + \frac{E \alpha}{(1-\nu)} (T_m - T) K_T = -1.2126 M_2 + 1.9143 E \alpha_i (T_m - T)$$

$$\sigma_y = - \frac{\nu(A_1 - M_2)}{L^2} K_3 + \frac{E \nu \alpha}{R_2} + \frac{E \alpha}{(1-\nu)} (T_m - T) = -0.3639(M_2 + M_{2T}) + 0.0662 E W_2 + 1.4286 E \alpha_i (T_m - T)$$

THERMAL INLET PIPE REACTIONS:

$$\begin{aligned} F_x = \frac{E}{A} K_1 + \frac{M_2}{I} K_2 &= -0.00561 F_x + 0.00071 M_2 & \text{POINT A} \\ &= -0.00561 F_x - 0.00071 M_2 & \text{B} \\ &= -0.00561 F_x + 0.00071 M_y & \text{C} \\ &= -0.00561 F_x - 0.00071 M_y & \text{D} \end{aligned}$$

$$\begin{aligned} T_m = \frac{E \alpha}{L^2} K_3 + \frac{M_2}{I} K_4 &= 0.01004 F_x + 0.00035 M_x & \text{POINT A} \\ &= 0.01004 F_x - 0.00035 M_y & \text{B} \\ &= 0.01004 F_x + 0.00035 M_x & \text{C} \\ &= 0.01004 F_x - 0.00035 M_y & \text{D} \end{aligned}$$

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. _____

NUMBER 5-211-P

A168

SHEET 60 OF 69DATE 4-22-68 BY LOCKBELLCHECK DATE 4-22-69 BY WILSONDESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTDETAILED ANALYSIS:STRESSES:2.1 PEAK STRESSES:SEISMIC PIPE REACTIONS:

THE FORMULAS FOR CALCULATING THE STRESSES DUE TO THE SEISMIC PIPE REACTIONS ARE THE SAME AS FOR THE THERMAL INDUCED PIPE REACTIONS.

LOCATION 8:PRESSURE STRESS

$$\sigma_x = -\frac{6M_x R_i}{L_{30}^2} K_B + \frac{6P}{2R_{30} K_7} K_7 = -0.0861 M_x + 1.1155 P$$

$$\sigma_y = -\frac{\sqrt{6} M_y R_i}{L_{30}^2} K_B + \frac{E R_i}{R_{30}} + \frac{6P}{L_{30}} = -0.0258 M_y + 0.0456 E W_{30} + 1.6399 P$$

$$\sigma_z = 0$$

THERMAL STRESS

$$\sigma_x = -\frac{6(M_x + M_T)}{L_{30}^2} R_i K_B + \frac{E R_i}{(1-\nu)} (T_m - T) K_7 = -0.0861 (M_x + M_T) + 2.5719 E \Delta T$$

$$\sigma_y = -\frac{\sqrt{6} (M_y + M_T)}{L_{30}^2} R_i K_B + \frac{E R_i}{R_{30}} + \frac{E R_i}{(1-\nu)} (T_m - T) = -0.0258 (M_y + M_T) + 0.0456 E W_{30} + 1.4296 E \Delta T$$

THERMAL INDUCED PIPE REACTIONS:

$$\begin{aligned} \sigma_x &= -\frac{E R_i}{L_{30}^2} K_B + \frac{M_x}{I} K_B = -0.00128 \bar{F}_x + 0.00012 \bar{M}_x \\ &= -0.00128 \bar{F}_x - 0.00012 \bar{M}_x \\ \sigma_y &= -0.00128 \bar{F}_y + 0.00012 \bar{M}_y \\ &= -0.00128 \bar{F}_y - 0.00012 \bar{M}_y \end{aligned}$$

$$\begin{aligned} T_{30} \frac{E R_i}{L_{30}^2} K_B &= 0.00207 \bar{F}_x + 0.000057 \bar{M}_x \\ &= 0.00207 \bar{F}_y - 0.000057 \bar{M}_y \\ &= 0.00207 \bar{F}_y + 0.000057 \bar{M}_y \\ &= 0.00207 \bar{F}_y - 0.000057 \bar{M}_x \end{aligned}$$

COMBUSTION ENGINEERING, INC.
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A169
SHEET 61 OF 69
DATE 4-22-63 BY COOPER
CHECK DATE 1.12.63 BY HONKER

CHARGE NO. _____
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

e. STRESSES:

2. PEAK STRESSES:

THE EQUATIONS FOR STRESS DUE TO SEISMIC PIPE REACTIONS, STATIC LOADING THROUGH SUPPORTS, EARTHQUAKE LOADING THROUGH SUPPORTS, AND THERMAL EXPANSION & CONTRACTION ARE THE SAME AS FOR THE THERMAL INDUCED PIPE REACTIONS. THE VALUES OF $F_x, F_y, F_z, \bar{M}_x, \bar{M}_y,$ AND \bar{M}_z ARE THE SAME AS THOSE LISTED ON SHEETS 40 - 42.

LOCATION 10:

PRESSURE STRESS:

POINTS A & B LONGITUDINAL PLANE	POINTS C & D CIRCUMFERENTIAL PLANE
$\sigma_x = i_c \left(\frac{bD}{t} + \frac{P}{S} \right) = 5.4477P$	$= 17.7402P$
$\sigma_\theta = i_c \left(\frac{bD}{t} + \frac{P}{2} \right) = 10.1373P$	$= 21.9641P$
$\sigma_r = 0$	

THERMAL STRESS:

POINTS A & B (LONGITUDINAL PLANE):

$$\sigma_x = -\frac{6}{c^3} (M_x + M_{3T}) K_B - \frac{H_x}{c_s} K_T + \frac{E \alpha_i}{(1-\nu)} (T_m - T) K_T = \frac{-0.0779(M_x + M_{3T}) - 0.1674 H_x}{+ 2.5714 E \alpha_i (T_m - T)}$$

$$\sigma_\theta = -\frac{3b}{c^3} (M_x + M_{3T}) K_B + \frac{E \alpha_i}{R_s S W D} + \frac{E \alpha_i}{(1-\nu)} (T_m - T) = \frac{-0.0234(M_x + M_{3T}) + 0.0462 E \alpha_i}{+ 1.4206 (T_m - T)}$$

POINTS C & D (CIRCUMFERENTIAL PLANE):

$$\sigma_x = -\frac{3b}{c^3} (M_x + M_{3T}) K_B + \frac{E \alpha_i}{R_s S W D} + \frac{E \alpha_i}{(1-\nu)} (T_m - T) = \frac{-0.0234(M_x + M_{3T}) + 0.0462 E \alpha_i}{+ 1.4206 (T_m - T)}$$

$$\sigma_\theta = -\frac{6}{c^3} (M_x + M_{3T}) K_B - \frac{H_x}{c_s} K_T + \frac{E \alpha_i}{(1-\nu)} (T_m - T) K_T = \frac{-0.0779(M_x + M_{3T}) - 0.1674 H_x}{+ 2.5714 E \alpha_i (T_m - T)}$$

COMBUSTION ENGINEERING, INC.
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A170
SHEET 62 OF 69
DATE 4-22-69 BY LOCKRELL
CHECK DATE 4-22-69 BY HEILKER

CHARGE NO. _____
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

- 1. STRESSES:
- 2. PEAK STRESSES:

THERMAL INDUCED PIPE REACTIONS:

$$\sigma_{1T} = - \left(\frac{N_1}{E_1 R_0} \right) \frac{E_1}{R_0} K_T + \left(\frac{M_1}{F_1} \right) \frac{E_1}{R_0} K_T + \left(\frac{N_2}{E_1 R_0^2 \beta} \right) \frac{E_1}{R_0^2 \beta} K_T + \left(\frac{M_2}{E_1 R_0 \beta} \right) \frac{6E_1}{R_0 \beta} K_0$$

- = - 0.0027 \bar{F}_1 + 0.0025 \bar{M}_2 POINT A
- = - 0.01427 \bar{F}_1 - 0.0025 \bar{M}_2 B
- = - 0.01427 \bar{F}_1 + 0.0022 \bar{M}_4 C
- = - 0.01427 \bar{F}_1 - 0.0022 \bar{M}_4 D

$$\sigma_{2T} = - \left(\frac{N_2}{E_1 R_0} \right) \frac{E_1}{R_0} K_T + \left(\frac{M_2}{F_1} \right) \frac{6E_1}{R_0} K_0 + \left(\frac{N_3}{E_1 R_0^2 \beta} \right) \frac{E_1}{R_0^2 \beta} K_T + \left(\frac{M_3}{E_1 R_0 \beta} \right) \frac{6E_1}{R_0 \beta} K_0$$

- = - 0.00962 \bar{F}_1 + 0.0022 \bar{M}_2 POINT A
- = - 0.00962 \bar{F}_1 - 0.0022 \bar{M}_2 B
- = - 0.00962 \bar{F}_1 + 0.0034 \bar{M}_4 C
- = - 0.00962 \bar{F}_1 - 0.0034 \bar{M}_4 D

$$T_{1T} = \pm \frac{E_1}{210T} K_0 + \frac{E_1}{210T} K_0 = 0.00165 \bar{F}_2 + 0.00003 \bar{M}_4 \text{ POINT A}$$

$$= - 0.00165 \bar{F}_2 + 0.00003 \bar{M}_4 \text{ B}$$

$$= 0.00165 \bar{F}_4 + 0.00003 \bar{M}_4 \text{ C}$$

$$= - 0.00165 \bar{F}_4 + 0.00003 \bar{M}_4 \text{ D}$$

THE EQUATIONS FOR STRESS DUE TO SEISMIC PIPE REACTIONS, STATIC LOADING THROUGH SUPPORTS, EARTHQUAKE LOADING THROUGH SUPPORTS, AND THERMAL EXPANSION AND CONTRACTION ARE THE SAME AS FOR THE THERMAL INDUCED PIPE REACTIONS. THE VALUES OF \bar{F}_1 , \bar{F}_4 , \bar{F}_2 , \bar{M}_2 , \bar{M}_4 , AND \bar{M}_3 ARE THE SAME AS THOSE GIVEN ON SHEETS 44 THRU 47.

COMBUSTION ENGINEERING, INC.
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | 471
 SHEET 63 OF 69
 DATE 4-22-69 BY CHURCHILL
 CHECK DATE 4-27-69 BY HELMER

CHARGE NO. _____
 DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

a. STRESSES:

1. PEAK STRESSES

THE FOLLOWING VALUES OF ($T_{MEAN} - T_{SURFACE}$) FOR THE INSIDE AND OUTSIDE SURFACES ARE TO BE USED TO CALCULATE PEAK STRESSES FOR THE FATIGUE EVALUATION.

TRANSIENT	CUT-1 BODY-1		CUT-1 BODY-2		CUT-2 BODY-2		CUT-4 BODY-4 & BODY-5		
	ΔT_{INSIDE}	$\Delta T_{SURFACE}$	ΔT_{INSIDE}	$\Delta T_{SURFACE}$	ΔT_{INSIDE}	$\Delta T_{SURFACE}$	ΔT_{INSIDE}	$\Delta T_{SURFACE}$	
Heatup	400ms	-5	3	-4	3	-6	4	-55	30
	1.25	↓	↓	↓	↓	↓	↓	↓	↓
	1.35	↓	↓	↓	↓	↓	↓	↓	↓
	1.47	↓	↓	↓	↓	↓	↓	↓	↓
	5.00	0	0	0	0	-1	1	-28	17
Cool down	400ms	8	-3	4	-3	6	-4	55	-30
	1.25	↓	↓	↓	↓	↓	↓	↓	↓
	1.35	↓	↓	↓	↓	↓	↓	↓	↓
	1.47	↓	↓	↓	↓	↓	↓	↓	↓
	5.00	0	0	0	0	1	1	28	-17

TRANSIENT	FOR ALL QUOTES	
	ΔT_{INSIDE}	$\Delta T_{SURFACE}$
STEADY STATE	0	0
c 20 MIN	-7.8	
d 20 MIN	7.8	
e 30 SEC	11.2	
	215 SEC	1.7
f 40 SEC	-9.3	
	100 SEC	-13.3
	240 SEC	-1.3
g 2 MIN	12	
	32 MIN	15
	104 MIN	0
h 10. SEC	-9.5	
	5.5 SEC	9.5
i 220 MIN	0	↓
j 3.1183	-8	3
	55	0
	2.5	8
k ~	6	0
	-6	
l 12 SEC	33.3	
m 10 SEC	-30.2	
	28 SEC	-41.2
	160 SEC	-4.8
n 53 SEC	117	
	54 SEC	197

COMBUSTION ENGINEERING, INC.
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A172

SHEET 6A OF 64

DATE 4-22-69 BY POCKRELL

CHECK DATE 4-27-69 BY HELMER

CHARGE NO. _____

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS

3. DETAILED ANALYSIS:

3.1 STRESSES

3.1.1 PEAK STRESSES

NOTE HERE THAT PEAK STRESSES WERE CALCULATED AT THE TEN LOCATIONS AS SHOWN ON SHEET 11 FOR THE FOUR ORIENTATIONS A, B, C AND D. THE FOLLOWING TABLE GIVES THE OVERALL USAGE FACTORS FOR EACH LOCATION AND EACH ORIENTATION. STRESSES AND STRESS INTENSITIES PER EACH THESE USAGE FACTORS WILL NOT BE PRESENTED FOR ALL LOCATIONS AND ORIENTATIONS. ONLY STRESSES AND STRESS INTENSITIES AT THE LOCATION AND ORIENTATION WHICH PRODUCED THE HIGHEST OVERALL USAGE FACTOR WILL BE PRESENTED. THIS WAS LOCATION 10C.

LOCATION AND ORIENTATION	Overall
1 A	0.00215
B	0.00213
C	0.00214
D	0.00214
2 A	0
B	0
C	0
D	0
3 A	0.0011
B	0.0015
C	0.0011
D	0.0013
4 A	0.0018
B	0.0013
C	0.0016
D	0.00216

LOCATION AND ORIENTATION	Overall
5 A	0.00242
B	0.00083
C	0.00049
D	0.00098
6 A	0.0048
B	0.0039
C	0.0049
D	0.0058
7 B	0.0034
B	0.0038
C	0.0037
D	0.0039
8 A	0.0040
B	0.0046
C	0.0059
D	0.0054

LOCATION AND ORIENTATION	Overall
9 A	0.019
B	0.015
C	0.0032
D	0.0030
10 A	0.0061
B	0.0024
C	0.042
D	0.037



LOCATION 10C

TOLERANT	PRESSURE STRESS			THERMAL STRESS		THERMAL LOGS/FW REACTION STRESS			SEISMIC FWD REACTION STRESS			STATIC WINDMNT STRESS		
	St	Ob	Tr	St	Ob	St	Ob	Tr	Ob	Ob	Tr	St	Ob	Tr
4.00 MP	33.39	41.34	0	7.35	15.34	0.95	1.54	-0.24	6.54	9.81	-1.01	0	0	0.93
4.25	36.26	45.64		7.44	15.69	1.01	1.64	-0.25						
4.35	39.25	47.35		7.47	15.74	1.03	1.67	-0.26						
4.47	39.92	49.42		7.51	16.10	1.06	1.72	-0.27						
5.00	39.92	49.42		4.32	9.44	1.06	1.72	-0.27						
4.00	33.39	41.34		7.35	15.34	0.95	1.54	-0.24	-6.54	-9.81	1.01			
4.25	36.26	45.64		7.44	15.69	1.01	1.64	-0.25						
4.35	39.25	47.40		7.47	15.74	1.03	1.67	-0.26						
4.47	39.92	49.42		7.51	16.10	1.06	1.72	-0.27						
5.00				4.32	9.44									
STEEL 1 - 27018				-0.03	0.05				6.54	9.81	-1.01			
				-0.03	0.05				-6.54	-9.81	1.01			
				-0.03	0.05				0	0	0			
6 - Concrete	5.59	6.92		-6.65	-13.91	0.11	0.18	-0.03	6.54	9.81	-1.01			
4.25				-6.59	-13.98	0.05	0.08	-0.01						
4.35				-6.56	-13.92	0.03	0.05	-0.01						
4.47				-6.53	-14.14	0	0	0						
5.00				-3.66	-9.11	0	0	0						
4.00				-6.65	-13.91	0.11	0.18	-0.03	-6.54	-9.81	1.01			
4.25				-6.59	-13.98	0.05	0.08	-0.01						
4.35				-6.56	-13.92	0.03	0.05	-0.01						
4.47				-6.53	-14.14	0	0	0						
5.00				-3.66	-9.11	0	0	0						

1 - DIRECTIONAL STRESS:
2 - BENT STRESS:

COMBUSTION ENGINEERING, INC.
ENGINEERING DEPARTMENT, CANTON, MASS.
CHARGE NO. _____
DESCRIPTION: Generator and Flywheel Examination
Dr. Miller Nozzle - Vapor Sensors
NUMBER: 5-211-2 SHEET: 165 OF 179
DATE: 4-22-69 BY: W. S. BELL
CHECK DATE: 4-22-69 BY: Hubert

LOCATION - IOC

TRANSIENT	ELEMENTARY LOADS TENSION STRESS			EXPANSION AND CONTRACTION STRESS		TOTAL STRESS				PRINCIPAL STRESS			STRESS INTENSITY			
	σ_x	σ_y	τ_{xy}	σ_x	σ_y	σ_1	σ_2	σ_3	τ_{12}	σ_1	σ_2	σ_3	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$	
1 - Airframe	4.00MS	1.36	2.10	-0.49	-1.39	-1.62	47.97	69.73	0	-0.90	58.77	47.94	0	22.83	28.77	27.94
	4.25						51.60	73.49		-0.82	73.52	51.57		21.95	73.52	51.57
	4.5						59.24	75.29		-0.82	75.32	53.60		22.32	75.32	53.60
	4.75						54.77	77.76		-0.83	77.79	54.74		23.05	77.79	54.74
	5.0						51.58	71.11		-0.93	71.14	51.54		19.60	71.14	51.54
	4.00	-1.36	-2.10	0.49			32.16	44.91		2.18	45.29	31.79		13.49	45.29	31.79
	4.25						35.79	49.67		2.16	50.01	35.46		14.55	50.01	35.46
	4.5						37.26	51.51		2.16	51.84	36.94		14.90	51.84	36.94
	4.75						39.96	52.94		2.15	54.24	38.66		15.59	54.24	38.66
	5.0						35.77	47.29		2.15	47.68	35.38		12.31	47.68	35.38
STEADY-STATE	1.36	2.10	-0.49	0	0	48.85	65.10		-0.93	53.15	43.30		14.34	53.15	43.30	
	-1.36	-2.10	0.49			33.05	39.28		2.15	39.45	32.38		7.57	39.45	32.38	
	0	0	0			48.95	51.19		0.66	51.23	40.91		10.32	51.23	40.91	
2 - Fuselage	4.00MS	1.36	2.10	-0.48	1.39	1.62	9.57	6.49		-0.99	6.55	8.52		-1.97	6.55	9.52
	4.25						9.57	6.32		-0.98	6.39	8.49		-2.10	6.39	9.49
	4.5						9.53	6.34		-0.97	6.42	8.50		-2.09	6.42	9.50
	4.75						9.53	6.07		-0.96	6.17	8.43		-2.32	6.17	9.43
	5.0						11.45	12.10		-0.96	11.17	12.33		-1.20	11.17	12.33
	4.00	-1.36	-2.10	0.48			-7.24	-7.33		1.97	-17.49	-7.54		-10.34	-17.49	-7.09
	4.25						-7.24	-17.50		1.99	-17.65	-7.09		-10.56	-17.65	-7.09
	4.5						-7.23	-17.48		1.99	-17.63	-7.08		-10.56	-17.63	-7.08
	4.75						-7.22	-17.75		2.00	-17.89	-7.08		-10.91	-17.89	-7.08
	5.0						-4.36	-11.72		2.00	-12.01	-4.00		-7.95	-12.01	-4.06

1 - Design Analysis
2 - Stress
3 - Peak Stresses

COMBUSTION ENGINEERING, INC.
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.
CHARGE NO. _____
DATE 4-22-64 BY HENDER
DESCRIPTION: STRUCTURE AND FATIGUE EVALUATION CHECK DATE 4-22-64 BY HENDER
OF PART ABOVE - VIBRATION STRESS

NUMBER 5-211-0
SHEET 6 OF 69
DATE 4-22-64 BY HENDER

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. _____

NUMBER 5-211-P | E176

SHEET 69 OF 69

DATE 4-22-69 BY McKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-69 BY HEILGER

5. DETAILED ANALYSIS:

C. STRESSES:

2. PEAK STRESSES:

LOCATION: 10C

TIME/LOAD	EXTREMES LOADS STRESS			TOTAL STRESS			PEAKING STRESS			STRESS INTENSITY			
	ST	OB	TOP	ST	OB	TOP	ST	OB	TOP	ST-05	OB-05	TS-05	
C 20 MIN	0	0	0	40.95	51.19	0	0.66	51.23	40.91	0	10.32	51.23	40.91
D 20 MIN				40.98	51.19			51.23	40.91		10.32	51.23	40.91
E 100 SEC				38.00	49.77			49.32	38.95		7.86	49.32	38.95
F 200 SEC				41.59	51.74			51.78	41.35		10.43	51.78	41.35
G 40 SEC				42.19	52.73			52.77	42.15		10.62	52.77	42.15
H 100 SEC				41.13	51.41			51.45	41.08		10.37	51.45	41.08
I 240 SEC				39.00	48.77			49.82	38.95		9.86	49.82	38.95
J 2 MIN				43.08	53.82			53.86	43.04		10.83	53.86	43.04
K 3.2 MIN				42.72	53.33			53.43	42.68		10.74	53.43	42.68
L 100 MIN				39.18	48.99			49.04	39.13		9.91	49.04	39.13
M 10 SEC				40.42	50.53			50.57	40.37		10.10	50.57	40.37
N 65 SEC				38.92	43.72			43.77	38.87		9.90	43.77	38.87
O 200 MIN				55.44	68.64		0.93	69.70	55.37		13.33	69.70	55.37
P 20 MIN				22.86	29.28		0.74	29.37	22.78		6.59	29.37	22.78
Q 5.5 C.O				45.04	56.09		0.74	56.14	44.99		11.15	56.14	44.99
R 30.803				5.66	6.17		0.93	6.88	4.96		1.92	6.88	4.96
S ~				42.72	53.33		0.66	53.43	42.68		10.74	53.43	42.68
T ~				39.18	48.99			49.04	39.13		9.91	49.04	39.13
U 12 SEC				40.95	51.19			51.23	40.91		10.32	51.23	40.91
V 10 SEC				50.00	62.39			62.43	49.96		12.46	62.43	49.96
W 28 SEC				38.64	48.33			49.38	38.60		9.78	49.38	38.60
X 160 SEC				26.58	33.40			33.46	26.52		6.74	33.46	26.52
Y 35 SEC				6.36	8.36			9.56	6.16		2.40	9.56	6.16
Z 50 SEC				13.45	17.14			17.26	13.34		3.92	17.26	13.34

COMBUSTION ENGINEERING, INC.
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A177

SHEET 69 OF 69

CHARGE NO. _____


DATE 4-22-69 BY CEPPRL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION
DE INLET NOZZLE - VESSEL SUMMITS

CHECK DATE 4-77-69 BY HENKOP

5. DETAILED ANALYSIS:

5. FATIGUE EVALUATION:



Stress	S _{MIN}	S _{MEAN}	S _{MAX}	Number of Cycles	N ^u	U
72.79	-17.99	47.94	47.94	200	4900	0.0409
63.70	0	34.35	34.35	5	14000	0.0004
62.43	9.56	26.94	26.94	5	34000	0.0002
62.43	33.46	14.99	14.99	75	46000	0.0002
56.14	0	29.07	29.07	5	34000	0.0002
52.56	43.77	5.05	5.05	200	∞	∞

$$U_{\text{overall}} = 0.042$$