


<b>United States Nuclear Regulatory Commission Official Hearing Exhibit</b>	
<b>In the Matter of:</b>	Entergy Nuclear Operations, Inc. (Indian Point Nuclear Generating Units 2 and 3)
	<b>ASLBP #:</b> 07-858-03-LR-BD01 <b>Docket #:</b> 05000247   05000286 <b>Exhibit #:</b> ENT000223-00-BD01 <b>Admitted:</b> 10/15/2012 <b>Rejected:</b> <b>Other:</b>
	<b>Identified:</b> 10/15/2012 <b>Withdrawn:</b> <b>Stricken:</b>

ENT000223  
Submitted: March 29, 2012



NUREG-1916, Vol. 2

# Safety Evaluation Report

## Related to the License Renewal of Shearon Harris Nuclear Power Plant, Unit 1

Docket No. 50-400

### Carolina Power & Light Company



## AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

### NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>.

Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and *Title 10, Energy*, in the Code of *Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents  
U.S. Government Printing Office  
Mail Stop SSOP  
Washington, DC 20402-0001  
Internet: [bookstore.gpo.gov](http://bookstore.gpo.gov)  
Telephone: 202-512-1800  
Fax: 202-512-2250
2. The National Technical Information Service  
Springfield, VA 22161-0002  
[www.ntis.gov](http://www.ntis.gov)  
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: U.S. Nuclear Regulatory Commission  
Office of Administration  
Mail, Distribution and Messenger Team  
Washington, DC 20555-0001

E-mail: [DISTRIBUTION@nrc.gov](mailto:DISTRIBUTION@nrc.gov)

Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

### Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library  
Two White Flint North  
11545 Rockville Pike  
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute  
11 West 42<sup>nd</sup> Street  
New York, NY 10036-8002  
[www.ansi.org](http://www.ansi.org)  
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).



NUREG-1916, Vol. 2

# **Safety Evaluation Report**

Related to the License Renewal of  
Shearon Harris Nuclear Power  
Plant, Unit 1

Docket No. 50-400

**Carolina Power & Light Company**

Manuscript Completed: August 2008  
Date Published: November 2008

Prepared by  
M. Heath

Office of Nuclear Reactor Regulation



## ABSTRACT

This safety evaluation report (SER) documents the technical review of the Shearon Harris Nuclear Power Plant (HNP), Unit 1, license renewal application (LRA) by the United States (US) Nuclear Regulatory Commission (NRC) staff (the staff). By letter dated November 14, 2006, Carolina Power & Light (CP&L) Company, doing business as Progress Energy Carolinas, Inc., submitted the LRA in accordance with Title 10, Part 54, of the *Code of Federal Regulations*, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants." CP&L requests renewal of the Unit 1 operating license (Facility Operating License Number NPF-63) for a period of 20 years beyond the current expiration at midnight October 24, 2026, for Unit 1.

HNP is located approximately 16 miles southwest of Raleigh, NC., and 15 miles northeast of Sanford, NC. The NRC issued the construction permit for Unit 1 on January 27, 1978, and operating license on January 12, 1987. Unit 1 is of a dry ambient pressurized water reactor design. Westinghouse supplied the nuclear steam supply system and Daniel International originally designed and constructed the balance of the plant with the assistance of its agent, Ebasco. The Unit 1 licensed power output is 2900 megawatt thermal with a gross electrical output of approximately 900 megawatt electric.

This SER presents the status of the staff's review of information submitted through July 21, 2008, the cutoff date for consideration in the SER. The staff identified an open item and two confirmatory items that were resolved before the staff made a final determination on the application. SER Sections 1.5 and 1.6 summarize these items and their resolution. Section 6.0 provides the staff's final conclusion on the review of the HNP LRA.



# TABLE OF CONTENTS

ABSTRACT .....	iii
TABLE OF CONTENTS .....	v
ABBREVIATIONS .....	xiv
INTRODUCTION AND GENERAL DISCUSSION .....	1-1
1.1 <u>Introduction</u> .....	1-1
1.2 <u>License Renewal Background</u> .....	1-2
1.2.1 Safety Review .....	1-3
1.2.2 Environmental Review .....	1-4
1.3 <u>Principal Review Matters</u> .....	1-5
1.4 <u>Interim Staff Guidance</u> .....	1-6
1.5 <u>Summary of Open Items</u> .....	1-7
1.6 <u>Summary of Confirmatory Items</u> .....	1-9
1.7 <u>Summary of Proposed License Conditions</u> .....	1-13
STRUCTURES AND COMPONENTS SUBJECT TO AGING MANAGEMENT REVIEW ...	2-1
2.1 <u>Scoping and Screening Methodology</u> .....	2-1
2.1.1 Introduction .....	2-1
2.1.2 Summary of Technical Information in the Application .....	2-1
2.1.3 Scoping and Screening Program Review .....	2-2
2.1.3.1 Implementation Procedures and Documentation Sources for Scoping and Screening .....	2-3
2.1.3.2 Quality Controls Applied to LRA Development .....	2-5
2.1.3.3 Training .....	2-6
2.1.3.4 <i>Conclusion of Scoping and Screening Program Review</i> ...	2-7
2.1.4 Plant Systems, Structures, and Components Scoping Methodology ..	2-7
2.1.4.1 Application of the Scoping Criteria in 10 CFR 54.4(a)(1) ...	2-8
2.1.4.2 Application of the Scoping Criteria in 10 CFR 54.4(a)(2) ..	2-10
2.1.4.3 Application of the Scoping Criteria in 10 CFR 54.4(a)(3) ..	2-17
2.1.4.4 Plant-Level Scoping of Systems and Structures .....	2-20
2.1.4.5 Conclusion for Scoping Methodology .....	2-24
2.1.5 Screening Methodology .....	2-24
2.1.5.1 General Screening Methodology .....	2-24
2.1.5.2 Mechanical Component Screening .....	2-26
2.1.5.3 Structural Component Screening .....	2-28
2.1.5.4 Electrical Component Screening .....	2-30
2.1.5.5 Conclusion for Screening Methodology .....	2-32
2.1.6 Summary of Evaluation Findings .....	2-32
2.2 <u>Plant-Level Scoping Results</u> .....	2-32
2.2.1 Introduction .....	2-32
2.2.2 Summary of Technical Information in the Application .....	2-32
2.2.3 Staff Evaluation .....	2-33
2.2.4 Conclusion .....	2-36
2.3 <u>Scoping and Screening Results - Mechanical Systems</u> .....	2-37

2.3.1	Reactor Vessel, Internals, and Reactor Coolant System. . . . .	2-41
2.3.1.1	Reactor Vessel and Internals. . . . .	2-42
2.3.1.2	Incore Instrumentation System. . . . .	2-45
2.3.1.3	Reactor Coolant System. . . . .	2-46
2.3.1.4	Reactor Coolant Pump and Motor. . . . .	2-47
2.3.1.5	Pressurizer. . . . .	2-48
2.3.1.6	Steam Generator. . . . .	2-50
2.3.2	Engineered Safety Features Systems. . . . .	2-52
2.3.2.1	Containment Spray System. . . . .	2-53
2.3.2.2	Containment Isolation System. . . . .	2-56
2.3.2.3	High-Head Safety-Injection System. . . . .	2-58
2.3.2.4	Low-Head Safety-Injection / Residual Heat Removal System. . . . .	2-60
2.3.2.5	Passive Safety-Injection System. . . . .	2-61
2.3.2.6	Control Room Area Ventilation System. . . . .	2-62
2.3.3	Auxiliary Systems. . . . .	2-64
2.3.3.1	Chemical and Volume Control System. . . . .	2-65
2.3.3.2	Boron Thermal Regeneration System. . . . .	2-66
2.3.3.3	Primary Makeup System. . . . .	2-68
2.3.3.4	Primary Sampling System. . . . .	2-69
2.3.3.5	Post-Accident Sampling System. . . . .	2-70
2.3.3.6	Circulating Water System. . . . .	2-71
2.3.3.7	Cooling Tower System. . . . .	2-73
2.3.3.8	Cooling Tower Make-Up System. . . . .	2-74
2.3.3.9	Screen Wash System. . . . .	2-75
2.3.3.10	Main Reservoir Auxiliary Equipment. . . . .	2-76
2.3.3.11	Auxiliary Reservoir Auxiliary Equipment. . . . .	2-77
2.3.3.12	Normal Service Water System. . . . .	2-78
2.3.3.13	Emergency Service Water System. . . . .	2-79
2.3.3.14	Component Cooling Water System. . . . .	2-82
2.3.3.15	Waste Processing Building Cooling Water System. . . . .	2-83
2.3.3.16	Essential Services Chilled Water System. . . . .	2-85
2.3.3.17	Nonessential Services Chilled Water System. . . . .	2-87
2.3.3.18	Emergency Screen Wash System. . . . .	2-88
2.3.3.19	Generator Gas System. . . . .	2-89
2.3.3.20	Hydrogen Seal Oil System. . . . .	2-90
2.3.3.21	Emergency Diesel Generator System. . . . .	2-91
2.3.3.22	Diesel Generator Fuel Oil Storage and Transfer System. . . . .	2-93
2.3.3.23	Diesel Generator Lubrication System. . . . .	2-95
2.3.3.24	Diesel Generator Cooling Water System. . . . .	2-96
2.3.3.25	Diesel Generator Air Starting System. . . . .	2-98
2.3.3.26	Security Power System. . . . .	2-99
2.3.3.27	Instrument Air System. . . . .	2-100
2.3.3.28	Service Air System. . . . .	2-102
2.3.3.29	Bulk Nitrogen Storage System. . . . .	2-104
2.3.3.30	Hydrogen Gas System. . . . .	2-105
2.3.3.31	Fire Protection System. . . . .	2-106
2.3.3.32	Storm Drains System. . . . .	2-128
2.3.3.33	Oily Drains System. . . . .	2-129



2.3.3.34	Radioactive Floor Drains System.....	2-130
2.3.3.35	Radioactive Equipment Drains System. ....	2-132
2.3.3.36	Secondary Waste System. ....	2-133
2.3.3.37	Laundry and Hot Shower System. ....	2-134
2.3.3.38	Upflow Filter System. ....	2-136
2.3.3.39	Potable and Sanitary Water System. ....	2-137
2.3.3.40	Demineralized Water System. ....	2-138
2.3.3.41	Filter Backwash System. ....	2-139
2.3.3.42	Radiation Monitoring System.....	2-140
2.3.3.43	Oily Waste Collection and Separation System.....	2-142
2.3.3.44	Liquid Waste Processing System. ....	2-144
2.3.3.45	Secondary Waste Treatment System. ....	2-146
2.3.3.46	Boron Recycle System. ....	2-148
2.3.3.47	Gaseous Waste Processing System. ....	2-149
2.3.3.48	Radwaste Sampling System. ....	2-151
2.3.3.49	Refueling System. ....	2-152
2.3.3.50	New Fuel Handling System. ....	2-153
2.3.3.51	Spent Fuel System. ....	2-155
2.3.3.52	Spent Fuel Pool Cooling System. ....	2-156
2.3.3.53	Spent Fuel Pool Cleanup System. ....	2-157
2.3.3.54	Spent Fuel Cask Decontamination and Spray System...	2-159
2.3.3.55	Spent Resin Storage and Transfer System.....	2-160
2.3.3.56	Containment Auxiliary Equipment. ....	2-161
2.3.3.57	Containment Liner Penetration Auxiliary Equipment. ....	2-162
2.3.3.58	Security Building HVAC System. ....	2-163
2.3.3.59	Containment Vacuum Relief System. ....	2-164
2.3.3.60	Bridge Crane Equipment. ....	2-166
2.3.3.61	Containment Pressurization System. ....	2-167
2.3.3.62	Penetration Pressurization System. ....	2-168
2.3.3.63	Containment Cooling System. ....	2-169
2.3.3.64	Airborne Radioactivity Removal System. ....	2-171
2.3.3.65	Containment Atmosphere Purge Exhaust System.....	2-172
2.3.3.66	Control Rod Drive Mechanism Ventilation System.....	2-174
2.3.3.67	Primary Shield and Reactor Supports Cooling System. ...	2-175
2.3.3.68	Fuel Cask Handling Crane System. ....	2-176
2.3.3.69	Reactor Auxiliary Building Ventilation System. ....	2-177
2.3.3.70	Emergency Service Water Intake Structure Ventilation System. ....	2-180
2.3.3.71	Turbine Building Area Ventilation System. ....	2-182
2.3.3.72	Waste Processing Building HVAC System. ....	2-184
2.3.3.73	Diesel Generator Building Ventilation System. ....	2-186
2.3.3.74	Fuel Oil Transfer Pump House Ventilation System. ....	2-187
2.3.3.75	Fuel Handling Building Auxiliary Equipment.....	2-189
2.3.3.76	Fuel Handling Building HVAC System.....	2-190
2.3.3.77	Turbine Building Health Physics Room Auxiliary Equipment.....	2-191
2.3.3.78	Polar Crane Auxiliary Equipment.....	2-192
2.3.3.79	Elevator System. ....	2-193
2.3.3.80	Technical Support Center HVAC System. ....	2-194

2.3.3.81	Mechanical Components in Electrical Systems. . . . .	2-195
2.3.3.82	Monorail Hoists Equipment. . . . .	2-196
2.3.3.83	Post-Accident Hydrogen System. . . . .	2-197
2.3.4	Steam and Power Conversion Systems. . . . .	2-198
2.3.4.1	Steam Generator Blowdown System. . . . .	2-199
2.3.4.2	Steam Generator Chemical Addition System. . . . .	2-201
2.3.4.3	Main Steam Supply System. . . . .	2-202
2.3.4.4	Steam Dump System. . . . .	2-204
2.3.4.5	Auxiliary Boiler/Steam System. . . . .	2-205
2.3.4.6	Feedwater System. . . . .	2-206
2.3.4.7	Feedwater Heater Drains & Vents System. . . . .	2-208
2.3.4.8	Auxiliary Feedwater System. . . . .	2-209
2.3.4.9	Auxiliary Steam Condensate System. . . . .	2-211
2.3.4.10	Condensate System. . . . .	2-212
2.3.4.11	Condensate Storage System. . . . .	2-213
2.3.4.12	Secondary Sampling System. . . . .	2-215
2.3.4.13	Steam Generator Wet Lay Up System. . . . .	2-216
2.3.4.14	Turbine System. . . . .	2-217
2.3.4.15	Digital-Electric Hydraulic System. . . . .	2-218
2.3.4.16	Turbine-Generator Lube Oil System. . . . .	2-219
2.4	<u>Scoping and Screening Results - Structures.</u> . . . .	2-220
2.4.1	Containment Building. . . . .	2-221
2.4.1.1	Containment Structure. . . . .	2-221
2.4.1.2	Containment Internal Structures. . . . .	2-224
2.4.1.3	Containment Building Functions. . . . .	2-225
2.4.2	Other Class I and In-Scope Structures. . . . .	2-227
2.4.2.1	Reactor Auxiliary Building. . . . .	2-228
2.4.2.2	Auxiliary Reservoir Channel. . . . .	2-231
2.4.2.3	Auxiliary Dam and Spillway. . . . .	2-232
2.4.2.4	Auxiliary Reservoir. . . . .	2-233
2.4.2.5	Auxiliary Reservoir Separating Dike. . . . .	2-234
2.4.2.6	Cooling Tower. . . . .	2-235
2.4.2.7	Cooling Tower Makeup Water Intake Channel. . . . .	2-237
2.4.2.8	Circulating Water Intake Structure. . . . .	2-238
2.4.2.9	Diesel Generator Building. . . . .	2-239
2.4.2.10	Main Dam and Spillway. . . . .	2-241
2.4.2.11	Diesel Fuel Oil Storage Tank Building. . . . .	2-242
2.4.2.12	Emergency Service Water and Cooling Tower Makeup Intake Structure. . . . .	2-244
2.4.2.13	Emergency Service Water Discharge Channel. . . . .	2-247
2.4.2.14	Emergency Service Water Discharge Structure. . . . .	2-248
2.4.2.15	Emergency Service Water Intake Channel. . . . .	2-249
2.4.2.16	Fuel Handling Building. . . . .	2-250
2.4.2.17	HVAC Equipment Room. . . . .	2-254
2.4.2.18	Outside the Power Block Structures. . . . .	2-255
2.4.2.19	Main Reservoir. . . . .	2-256
2.4.2.20	Security Building. . . . .	2-258
2.4.2.21	Emergency Service Water Screening Structure. . . . .	2-259
2.4.2.22	Normal Service Water Intake Structure. . . . .	2-261

2.4.2.23	Switchyard Relay Building.....	2-262
2.4.2.24	Transformer and Switchyard Structures.....	2-263
2.4.2.25	Turbine Building.....	2-265
2.4.2.26	Tank Area/Building.....	2-266
2.4.2.27	Waste Processing Building.....	2-268
2.4.2.28	Yard Structures.....	2-270
2.5	<u>Scoping and Screening Results - Electrical and Instrumentation and Controls (I&amp;C)</u>	
	<u>Systems.....</u>	2-272
2.5.1	Electrical and I&C Component Commodity Groups.....	2-273
2.5.1.1	Summary of Technical Information in the Application.....	2-273
2.5.1.2	Staff Evaluation.....	2-274
2.5.1.3	Conclusion.....	2-275
2.6	<u>Conclusion for Scoping and Screening.....</u>	2-275
AGING MANAGEMENT REVIEW RESULTS.....		3-1
3.0	<u>Applicant's Use of the Generic Aging Lessons Learned Report.....</u>	3-1
3.0.1	Format of the License Renewal Application.....	3-2
3.0.1.1	Overview of Table 1s.....	3-2
3.0.1.2	Overview of Table 2s.....	3-3
3.0.2	Staff's Review Process.....	3-4
3.0.2.1	Review of AMPs.....	3-5
3.0.2.2	Review of AMR Results.....	3-6
3.0.2.3	FSAR Supplement.....	3-6
3.0.2.4	Documentation and Documents Reviewed.....	3-6
3.0.3	Aging Management Programs.....	3-6
3.0.3.1	AMPs Consistent with the GALL Report.....	3-11
3.0.3.2	AMPs Consistent with the GALL Report with Exceptions or Enhancements.....	3-53
3.0.3.3	AMPs Not Consistent with or Not Addressed in the GALL Report.....	3-162
3.0.4	QA Program Attributes Integral to Aging Management Programs.....	3-167
3.0.4.1	Summary of Technical Information in the Application.....	3-168
3.0.4.2	Staff Evaluation.....	3-168
3.0.4.3	Conclusion.....	3-169
3.1	<u>Aging Management of Reactor Vessel, Reactor Vessel Internals, and Reactor Coolant System.....</u>	3-170
3.1.1	Summary of Technical Information in the Application.....	3-170
3.1.2	Staff Evaluation.....	3-170
3.1.2.1	AMR Results Consistent with the GALL Report.....	3-191
3.1.2.2	AMR Results Consistent with the GALL Report for Which Further Evaluation is Recommended.....	3-200
3.1.2.3	AMR Results Not Consistent with or Not Addressed in the GALL Report.....	3-225
3.1.3	Conclusion.....	3-238
3.2	<u>Aging Management of Engineered Safety Features System.....</u>	3-239
3.2.1	Summary of Technical Information in the Application.....	3-239
3.2.2	Staff Evaluation.....	3-239
3.2.2.1	AMR Results Consistent with the GALL Report.....	3-250
3.2.2.2	AMR Results Consistent with the GALL Report for Which Further	

	Evaluation is Recommended .....	3-252
	3.2.2.3 AMR Results Not Consistent with or Not Addressed in the GALL Report .....	3-267
	3.2.3 Conclusion .....	3-272
3.3	<u>Aging Management of Auxiliary Systems</u> .....	3-272
	3.3.1 Summary of Technical Information in the Application .....	3-274
	3.3.2 Staff Evaluation .....	3-274
	3.3.2.1 AMR Results Consistent with the GALL Report .....	3-296
	3.3.2.2 AMR Results Consistent with the GALL Report for Which Further Evaluation is Recommended .....	3-321
	3.3.2.3 AMR Results Not Consistent with or Not Addressed in the GALL Report .....	3-340
	3.3.3 Conclusion .....	3-411
3.4	<u>Aging Management of Steam and Power Conversion Systems</u> .....	3-412
	3.4.1 Summary of Technical Information in the Application .....	3-412
	3.4.2 Staff Evaluation .....	3-412
	3.4.2.1 AMR Results Consistent with the GALL Report .....	3-421
	3.4.2.2 AMR Results Consistent with the GALL Report for Which Further Evaluation is Recommended .....	3-423
	3.4.3 Conclusion .....	3-470
3.5	<u>Aging Management of Containments, Structures, and Component Supports</u> .....	3-470
	3.5.1 Summary of Technical Information in the Application .....	3-471
	3.5.2 Staff Evaluation .....	3-471
	3.5.2.1 AMR Results Consistent with the GALL Report .....	3-486
	3.5.2.2 AMR Results Consistent with the GALL Report for Which Further Evaluation is Recommended .....	3-507
	3.5.2.3 AMR Results Not Consistent with or Not Addressed in the GALL Report .....	3-530
	3.5.3 Conclusion .....	3-561
3.6	<u>Aging Management of Electrical and Instrumentation and Controls System</u> ..	3-562
	3.6.1 Summary of Technical Information in the Application .....	3-562
	3.6.2 Staff Evaluation .....	3-562
	3.6.2.1 AMR Results Consistent with the GALL Report .....	3-566
	3.6.2.2 AMR Results Consistent with the GALL Report for Which Further Evaluation is Recommended .....	3-568
	3.6.2.3 AMR Results Not Consistent with or Not Addressed in the GALL Report .....	3-575
	3.6.3 Conclusion .....	3-580
3.7	<u>Conclusion for Aging Management Review Results</u> .....	3-580
TIME-LIMITED AGING ANALYSES .....		4-1
4.1	<u>Identification of Time-Limited Aging Analyses</u> .....	4-1
	4.1.1 Summary of Technical Information in the Application .....	4-1
	4.1.2 Staff Evaluation .....	4-2
	4.1.3 Conclusion .....	4-3
4.2	<u>Reactor Vessel Neutron Embrittlement</u> .....	4-3
	4.2.1 Neutron Fluence .....	4-3
	4.2.1.1 Summary of Technical Information in the Application .....	4-3

4.2.1.2	Staff Evaluation .....	4-4
4.2.1.3	FSAR Supplement .....	4-5
4.2.1.4	Conclusion .....	4-5
4.2.2	Upper Shelf Energy Analysis .....	4-6
4.2.2.1	Summary of Technical Information in the Application .....	4-6
4.2.2.2	Staff Evaluation .....	4-6
4.2.2.3	FSAR Supplement .....	4-8
4.2.2.4	Conclusion .....	4-8
4.2.3	Pressurized Thermal Shock Analysis .....	4-8
4.2.3.1	Summary of Technical Information in the Application .....	4-8
4.2.3.2	Staff Evaluation .....	4-9
4.2.3.3	FSAR Supplement .....	4-11
4.2.3.4	Conclusion .....	4-11
4.2.4	Operating Pressure-Temperature Limits Analysis .....	4-11
4.2.4.1	Summary of Technical Information in the Application .....	4-11
4.2.4.2	Staff Evaluation .....	4-12
4.2.4.3	FSAR Supplement .....	4-14
4.2.4.4	Conclusion .....	4-14
4.2.5	Low-Temperature Overpressure Limits Analysis .....	4-14
4.2.5.1	Summary of Technical Information in the Application .....	4-14
4.2.5.2	Staff Evaluation .....	4-15
4.2.5.3	FSAR Supplement .....	4-16
4.2.5.4	Conclusion .....	4-16
4.3	<u>Metal Fatigue</u> .....	4-16
4.3.1	Explicit Fatigue Analyses (NSSS Components) .....	4-16
4.3.1.1	Reactor Vessel .....	4-17
4.3.1.2	Reactor Vessel Internals .....	4-20
4.3.1.3	Control Rod Drive Mechanism .....	4-21
4.3.1.4	Reactor Coolant Pumps .....	4-22
4.3.1.5	Steam Generators .....	4-22
4.3.1.6	Pressurizer .....	4-25
4.3.1.7	Reactor Coolant Pressure Boundary Piping (ASME Class 1) .....	4-29
4.3.2	Implicit Fatigue Analysis (ASME Class 2, Class 3, and ANSI B31.1 Piping) .....	4-32
4.3.2.1	ASME Class 2 and 3 Piping .....	4-32
4.3.2.2	ANSI B31.1 Piping .....	4-34
4.3.3	Environmentally-Assisted Fatigue Analysis .....	4-38
4.3.3.1	Summary of Technical Information in the Application .....	4-38
4.3.3.2	Staff Evaluation .....	4-39
4.3.3.3	FSAR Supplement .....	4-42
4.3.3.4	Conclusion .....	4-43
4.3.4	RCS Loop Piping Leak-Before-Break Analysis .....	4-44
4.3.4.1	Summary of Technical Information in the Application .....	4-44
4.3.4.2	Staff Evaluation .....	4-45
4.3.4.3	FSAR Supplement .....	4-45
4.3.4.4	Conclusion .....	4-45
4.3.5	<i>Cyclic Loads That Do Not Relate to RCS Transients</i> .....	4-45
4.3.5.1	Primary Sample Lines .....	4-46

4.3.5.2	Steam Generator Blowdown Lines	4-48
4.4	<u>Environmental Qualification of Electrical Equipment</u>	4-49
4.4.1	Summary of Technical Information in the Application	4-50
4.4.2	Staff Evaluation	4-50
4.4.3	FSAR Supplement	4-51
4.4.4	Conclusion	4-51
4.5	<u>Concrete Containment Tendon Prestress</u>	4-51
4.5.1	Summary of Technical Information in the Application	4-51
4.5.2	Staff Evaluation	4-51
4.5.3	FSAR Supplement	4-51
4.5.4	Conclusion	4-51
4.6	<u>Containment Liner Plate, Metal, Metal Containments, and Penetrations Fatigue Analysis</u>	4-51
4.6.1	Containment Mechanical Penetration Bellows Fatigue	4-51
4.6.1.1	Mechanical Penetration Bellows - Valve Chambers	4-51
4.6.1.2	Mechanical Penetration Bellows - Fuel Transfer Tube Bellows Expansion Joint	4-53
4.7	<u>Other Plant-Specific Time-Limited Aging Analyses</u>	4-55
4.7.1	Turbine Rotor Missile Generation Analysis	4-55
4.7.1.1	Summary of Technical Information in the Application	4-55
4.7.1.2	Staff Evaluation	4-55
4.7.1.3	FSAR Supplement	4-56
4.7.1.4	Conclusion	4-56
4.7.2	Crane Cyclic Analyses	4-57
4.7.2.1	Polar Crane	4-57
4.7.2.2	Jib Cranes	4-59
4.7.2.3	Reactor Cavity Manipulator Crane	4-61
4.7.2.4	Fuel Cask Handling Crane	4-62
4.7.2.5	Fuel Handling Bridge Crane	4-64
4.7.2.6	Fuel Handling Building Auxiliary Crane	4-65
4.7.3	Main and Auxiliary Reservoir Sedimentation Analyses	4-67
4.7.3.1	Summary of Technical Information in the Application	4-67
4.7.3.2	Staff Evaluation	4-68
4.7.3.3	FSAR Supplement	4-68
4.7.3.4	Conclusion	4-68
4.7.4	High-Energy Line Break Location Postulation Based on Fatigue Cumulative Usage Factor	4-68
4.7.4.1	Summary of Technical Information in the Application	4-68
4.7.4.2	Staff Evaluation	4-69
4.7.4.3	FSAR Supplement	4-71
4.7.4.4	Conclusion	4-72
4.8	<u>Conclusion for TLAAs</u>	4-72

REVIEW BY THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS . . . . . 5-1

CONCLUSION . . . . . 6-1

## Appendices

Appendix A: Commitments for License Renewal .....	A-1
Appendix B: Chronology .....	B-1
Appendix C: Principal Contributors .....	C-1
Appendix D: References .....	D-1

## Tables

Table 1.4-1 Current Interim Staff Guidance .....	1-7
Table 2.3.3.31-1 Component/Commodity Locations in License Renewal Application .....	2-109
Table 2.3.3.31-2 Component/Commodity Locations in License Renewal Application .....	2-116
Table 2.3.3.31-6 Component/Commodity Justification for Exclusion .....	2-124
Table 3.0.3-1 HNP Aging Management Programs .....	3-7
Table 3.0.3.1.5-1 Aging Effects and Inspection Methods Within the Scope of the One-Time Inspection Program .....	3-25
Table 3.1-1 Staff Evaluation for Reactor Vessel, Reactor Vessel Internals, and Reactor Coolant System Components in the GALL Report .....	3-171
Table 3.2-1 Staff Evaluation for Engineered Safety Features System Components in the GALL Report .....	3-240
Table 3.3-1 Staff Evaluation for Auxiliary System Components in the GALL Report .....	3-275
Table 3.4-1 Staff Evaluation for Steam and Power Conversion Systems Components in the GALL Report .....	3-413
Table 3.5-1 Staff Evaluation for Containments, Structures, and Supports Components in the GALL Report .....	3-472
Table 3.6-1 Staff Evaluation for Electrical and Instrumentation and Controls in the GALL Report .....	3-563

#### **4.2.5.3 FSAR Supplement**

The applicant provided an FSAR supplement summary description of its TLAA evaluation of low-temperature overpressure limits analysis in LRA Section A.1.2.1.4. On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address the low-temperature overpressure limits analysis is adequate.

#### **4.2.5.4 Conclusion**

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(ii), that the analyses have been projected to the end of the period of extended operation that the effects of aging on the intended function(s) will be adequately managed for the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

### **4.3 Metal Fatigue**

By letter dated August 31, 2007, the applicant revised LRA Section 4.3 to summarize several thermal and mechanical fatigue analyses of plant mechanical components presented as TLAAs addressed in the following subsections.

- 4.3.1 Explicit Fatigue Analyses (Nuclear Steam Supply System (NSSS) Components)
  - 4.3.1.1 Reactor Vessel
  - 4.3.1.2 Reactor Vessel Internals
  - 4.3.1.3 Control Rod Drive Mechanism
  - 4.3.1.4 Reactor Coolant Pumps
  - 4.3.1.5 Steam Generators
  - 4.3.1.6 Pressurizer
  - 4.3.1.7 Reactor Coolant Pressure Boundary Piping (ASME Class 1)
- 4.3.2 Implicit Fatigue Analysis (ASME Class 2, Class 3, and American National Standards Institute (ANSI) B31.1 Piping)
  - 4.3.2.1 ASME Class 2 and Class 3 Piping
  - 4.3.2.2 ANSI B31.1 Piping
- 4.3.3 Environmentally-Assisted Fatigue Analysis
- 4.3.4 RCS Loop Piping Leak-Before-Break Analysis
- 4.3.5 Cyclic Loads that Do Not Relate to RCS Transients
  - 4.3.5.1 Primary Sample Lines
  - 4.3.5.2 Steam Generator Blowdown Lines

#### **4.3.1 Explicit Fatigue Analyses (NSSS Components)**

The applicant submits the latest design fatigue analyses for each NSSS component within the reactor coolant pressure boundary (RCPB) to demonstrate that the design analyses will remain



bounding through the period of extended operation. Components within the scope of this review include nonpressure-boundary reactor internals components.

Original fatigue design calculations assumed a large number of design transients from relatively severe system dynamics over the original 40-year design life. In general, actual plant operations have resulted in only a fraction of the originally expected fatigue duty.

A review to establish the current design basis for the major NSSS components showed that the use of transients from the steam generator replacement/uprating analysis is reasonable and limiting for the primary equipment except the pressurizer surge line and portions of the pressurizer lower head analyzed separately (LRA Subsections 4.3.1.6 and 4.3.1.7); therefore, the governing transients, "NSSS Design Transients," are those from the steam generator replacement/uprating analysis. Table 4.3-2 presents 40-year design cumulative usage factor (CUF) values compiled from design documents including the recent steam generator replacement/uprating analysis.

The next evaluation factored the effects of the reactor water environment on fatigue. The evaluation of NSSS components demonstrated compliance with 10 CFR 54.21(c)(1) by a combination of methods under 10 CFR 54(c)(1)(ii) and (iii).

The following sections summarize the results for each of the major NSSS components evaluated.

#### **4.3.1.1 Reactor Vessel**

##### **4.3.1.1.1 Summary of Technical Information in the Application**

LRA Section 4.3.1.1 summarizes the reactor vessel evaluation for the period of extended operation. There are TLAAs for several reactor vessel subcomponents. The use of transients from the steam generator replacement/uprating analysis is reasonable and limiting for the primary equipment with the exceptions of the pressurizer surge line and portions of the pressurizer lower head analyzed separately. Forty-year design CUF values were also parts of the steam generator replacement/uprating analysis. The reactor vessel fatigue analysis demonstrated that, if reactor vessel components were exposed to a bounding set of postulated transient cycles, their CUF values would not exceed 1.0.

The applicant stated that for the component parts of the reactor vessel, the highest 40-year design fatigue usage value is 0.37 for the closure studs. Multiplying this fatigue usage by 1.5 to account for 60 years of operation yields a CUF of 0.56. This value does not exceed the design limit of 1.0 and is, therefore, acceptable. This 60-year fatigue usage bounds the maximum environmentally-adjusted usage factor of 0.1740 for the reactor vessel outlet nozzles in LRA Table 4.3-3; therefore, the analysis has been projected to the period of extended operation per 10 CFR 54.21(c)(1) (ii).

#### 4.3.1.1.2 Staff Evaluation

The staff reviewed LRA Section 4.3.1.1 to verify pursuant to 10 CFR 54.21(c)(1)(ii) that the analysis has been projected to the end of the period of extended operation.

The staff reviewed LRA Table 4.3-1 for an adequate list of the assumed transients.

During the audit, the staff asked the applicant to address following questions:

- (1) Describe the method for estimating the number of cycles for 60 years of operation for the transients listed in LRA Table 4.3-1 and explain why the cycles to date and the cycles projected for 60 years can be zero.
- (2) The staff reviewed FSAR Table 3.9-1 ("Summary of Limiting Reactor Coolant Design Transients") and determined that LRA transients loop out of service shutdown, loop out of service startup, and inadvertent startup of an inactive loop may not be present at HNP. Why are those transients cycles in LRA Table 4.3-1?
- (3) Does HNP address the inadvertent auxiliary spray cooling transient in FSAR Table 3.9-1?

On the first question, it was unclear why the applicant addressed the 60-year projected cycle of zero based on 18 years (cycles to date) operation. The applicant responded, "The cycle projections will be removed from the License Renewal Application. Cycle projections will not be used to justify acceptability of fatigue-related TLAA's by 10 CFR 54.21(c)(1)(i) - the analyses remain valid for the period of extended operation."

On the bases that the staff reviewed all metal fatigue TLAA's to confirm that the applicant will not use cycle projections to justify fatigue-related TLAA's under 10 CFR 54.21(c)(1)(i), that the analyses remain valid for the period of extended operation, and that the applicant's LRA Amendment 2 by letter dated, August 31, 2007 deleted cycle projections from the LRA, the staff finds this response acceptable.

On the second question, the applicant responded,

Normal Transients 13, 14, and Upset Transient 8 were included in the qualifications performed by WCAP-14778, Revision 1, "Carolina Power and Light Harris Nuclear Plant Steam Generator Replacement/Upgrading Analysis and Licensing Project NSSS Engineering Report," September 2000. As noted in the license renewal basis document, Normal Condition transients 13 and 14 (Loop Out of Service) are not applicable to the current HNP license. HNP is not currently licensed to operate with N-1 loops. The Loop Out of Service transients were included in the Westinghouse System Standard Design Criteria 1.3, Revision 2 so that the components are designed in case the plant is licensed to operate with N-1 loops. It was recommended by Westinghouse that the "Loop Out of Service" transients continue to be considered for the SGR/Upgrading Project; therefore, the transients were carried forward to the License Renewal fatigue

evaluation. This also applies to Upset Transient 8 (Inadvertent Startup of an Inactive Loop).

The staff reviewed Westinghouse Commercial Atomic Power (WCAP)-14778 to confirm consideration of those loop out of service transients in the design analysis. On the basis that consideration of additional transients in the fatigue analysis generates conservative design results, the staff finds the use of transients from the steam generator replacement/uprating analysis for reactor vessel components acceptable.

On the third question, the applicant responded;

The inadvertent auxiliary spray transient is a subcategory of the umbrella transient Inadvertent RCS Depressurization. The Inadvertent RCS Depressurization has 20 cycles with 10 of those cycles being the postulated as inadvertent auxiliary spray events. The inadvertent auxiliary spray events were not specifically listed, since the inadvertent auxiliary spray events were already included in the Inadvertent RCS Depressurization transients.

The staff reviewed the transient definition from the basis document, "Westinghouse System Standard Design Criteria 1.3," to confirm that the inadvertent auxiliary spray transient could be enveloped by the umbrella transient inadvertent RCS depressurization. On this basis, the staff finds this response acceptable.

The staff reviewed LRA Table 4.3-2 to confirm the 40-year design maximum reactor vessel CUF of 0.3744 for closure studs. The CUF value 0.562 accounts for the additional 20 years of extended operation by multiplying the 40-year design CUF of 0.3744 by 1.5. On this basis, the staff concluded that the analyses have been projected to the end of the period of extended operation per 10 CFR 54.21(c)(1) (ii).

#### 4.3.1.1.3 FSAR Supplement

The applicant provided an FSAR supplement summary description of its TLAA evaluation of the reactor vessel in LRA Section A1.2.2.1. On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address the reactor vessel is adequate.

#### 4.3.1.1.4 Conclusion

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(ii), that, for, the analyses have been projected to the end of the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

### **4.3.1.2 Reactor Vessel Internals**

#### **4.3.1.2.1 Summary of Technical Information in the Application**

LRA Section 4.3.1.2 summarizes the evaluation of reactor vessel internals for the period of extended operation. There is a TLAA for the reactor vessel internals. The NSSS design transients are those shown in the steam generator replacement/uprating analysis, in which 40-year design CUF values also were determined. The reactor vessel internals fatigue analysis demonstrated that, if exposed to a bounding set of postulated transient cycles, reactor vessel internals component CUF values would not exceed 1.0.

For the reactor vessel internals, the 40-year design fatigue usage value is 0.52 for the core internals. Multiplying this fatigue usage by 1.5 to account for 60 years of operation yields a CUF of 0.78. This value does not exceed the design limit of 1.0; therefore, the analysis has been projected to the period of extended operation per 10 CFR 54.21(c)(1) (ii).

#### **4.3.1.2.2 Staff Evaluation**

The staff reviewed the applicant's basis document WCAP-16353-P, "Harris Nuclear Plant Fatigue Evaluation for License Renewal," and confirmed the core internal CUF of 0.52 for the 40-year design life. The staff accepted the projection of the 60-year CUF of 0.78 by multiplying the 40-year CUF of 0.52 by 1.5.

On this basis, the staff concluded the analysis has been projected to the end of the period of extended operation per 10 CFR 54.21(c)(1) (ii).

#### **4.3.1.2.3 FSAR Supplement**

The applicant provided an FSAR supplement summary description of its TLAA evaluation of the reactor vessel internals in LRA Section A.1.2.2.2. On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address the reactor vessel internals is adequate.

#### **4.3.1.2.4 Conclusion**

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(ii), that, for reactor vessel internals, the analyses have been projected to the end of the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

### **4.3.1.3 Control Rod Drive Mechanism**

#### **4.3.1.3.1 Summary of Technical Information in the Application**

LRA Section 4.3.1.3 summarizes the evaluation of the control rod drive mechanism for the period of extended operation. There are TLAA's for several Control Rod Drive Mechanism (CRDM) subcomponents. The NSSS design transients are those shown in the steam generator replacement/uprating analysis, in which 40-year design CUF values also were determined. The CRDM fatigue analysis demonstrated that, if exposed to a bounding set of postulated transient cycles, CRDM component CUF values would not exceed 1.0.

For the CRDM, the highest 40-year design fatigue usage value is 0.99 for the "Lower Joint Canopy Area" (LRA Table 4.3-2). Multiplying this fatigue usage by 1.5 to account for 60 years of operation yields a CUF of 1.49. This value exceeds the design limit of 1.0 and, therefore, requires an AMP. The Reactor Coolant Pressure Boundary Fatigue Monitoring Program will keep fatigue usage within the design limit or take appropriate re-evaluation or corrective action to manage the effects of fatigue on the CRDM for the period of extended operation in accordance with 10 CFR 54.21(c)(1)(iii).

#### **4.3.1.3.2 Staff Evaluation**

The GALL Report recommends a fatigue monitoring program to manage metal fatigue according to 10 CFR 54.21(c)(1)(iii). The staff has evaluated the applicant's AMP B3.1, "Reactor Coolant Pressure Boundary Fatigue Monitoring Program," for monitoring and tracking the number of critical thermal and pressure transients for RCS components, determined that this program is acceptable to address metal fatigue of RCS components according to 10 CFR 54.21(c)(1)(iii), and documented its evaluation and acceptance in SER Section 3.0. On the basis that the applicant's action is consistent with the GALL Report recommendation, the staff finds that management of the effects of aging on intended functions will be adequate for the period of extended operation.

#### **4.3.1.3.3 FSAR Supplement**

The applicant provided an FSAR supplement summary description of its TLAA evaluation of the CRDM in LRA Section A.1.2.2.3. On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address the CRDM is adequate.

#### **4.3.1.3.4 Conclusion**

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(iii), that the effects of aging on the intended function(s) will be adequately managed for the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

#### **4.3.1.4 Reactor Coolant Pumps**

##### **4.3.1.4.1 Summary of Technical Information in the Application**

LRA Section 4.3.1.4 summarizes the evaluation of RCPs for the period of extended operation. The RCPs have been designed and analyzed to meet the ASME Code of record. The original design fatigue analysis used fatigue waiver requirements and showed the pumps as having a TLAA. The RCP fatigue analysis demonstrated that, if the RCPs were exposed to a bounding set of postulated transient cycles, the fatigue waiver would remain valid.

The current design fatigue analysis for the RCPs used the ASME Code NB-3222.4(d) waiver of fatigue requirements; therefore, determination of a 40-year or 60-year fatigue usage factor for the RCPs was unnecessary. Using the general approach described in LRA Section 4.3.1, the applicant made 60-year fatigue cycle projections for license renewal. Based on the projections, the fatigue waiver remains valid for 60 years of operation.

##### **4.3.1.4.2 Staff Evaluation**

The staff reviewed LRA Section 4.3.1.4, ASME Code Section III and NB-3222.4(d), which defines components not requiring analysis for cyclic service, and concluded that there is no significant cyclic change in temperature, pressure, or mechanical loading. The conditions addressed in NB-3222.4(d), remain valid for the period of extended operation; therefore, the fatigue waiver remains valid for the period of extended operation.

##### **4.3.1.4.3 FSAR Supplement**

The applicant provided an FSAR supplement summary description of its TLAA evaluation of the RCPs in LRA Section A.1.2.2.4. On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address the RCPs is adequate.

##### **4.3.1.4.4 Conclusion**

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(i), that, for the RCPs, the analyses remain valid for the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

#### **4.3.1.5 Steam Generators**

##### **4.3.1.5.1 Summary of Technical Information in the Application**

LRA Section 4.3.1.5 summarizes the evaluation of steam generators for the period of extended operation. There are TLAAs for several steam generator subcomponents. The use of transients

from the steam generator replacement/uprating analysis is reasonable and limiting for the primary equipment with the exceptions of the pressurizer surge line and portions of the pressurizer lower head analyzed separately; therefore, the NSSS design transients are those shown in the steam generator replacement/uprating analysis, in which 40-year design CUF values also were determined. The steam generator fatigue analysis demonstrated that, if steam generator subcomponents were exposed to a bounding set of postulated transient cycles, component CUF values would not exceed 1.0 with the exceptions of the secondary manway bolts and the 4-inch inspection port bolts addressed in more detail below.

Other than those for the secondary manway bolts and the 4-inch inspection port bolts, the highest 40-year design fatigue usage value is 0.98 for minor shell taps. Multiplying this fatigue usage by 1.5 to account for 60 years of operation yields a CUF of 1.47. This value exceeds the design limit of 1.0, and, therefore, requires an AMP.

The Reactor Coolant Pressure Boundary Fatigue Monitoring Program will keep fatigue usage within the design limit or take appropriate re-evaluation or corrective action to manage the effects of fatigue on the steam generator (other than the secondary manway bolts and the 4-inch inspection port bolts) for the period of extended operation in accordance with 10 CFR 54.21(c)(1)(iii).

The steam generator secondary manway bolts and 4-inch inspection port bolts have 40-year design fatigue usage factors over 1.0. These components were "to be replaced based on a replacement schedule;" however, the applicant reanalyzed the steam generator secondary manway cover bolts and 4-inch inspection port bolts to remove unnecessary conservatism. The update changed only the number of unit loading and unit unloading transient cycles in the previous design analysis. Each transient was to occur 2000 times over the life of the plant, a number still greater than the best estimate number in the previous design analysis. Reanalysis of the usage factor for the secondary manway bolts and the 4-inch inspection port bolts used 40-year design cycles for all transients except the unit-loading and unit-unloading transients. These transients were limited to 2,000 cycles each compared to the 18,300 cycles for normal condition transients 3 and 4. The calculated usage for the bolts based on this transient set is as follows:

- Secondary Manway Cover Bolts: Fatigue Usage = 0.83
- 4-inch inspection port bolts: Fatigue Usage = 0.81

Multiplying this fatigue usage by 1.5 to account for 60 years of operation yields:

- Secondary Manway Cover Bolts: Fatigue Usage = 1.245
- 4-inch inspection port bolts: Fatigue Usage = 1.215

These values exceed the design limit of 1.0 and, therefore, require an AMP. The Reactor Coolant Pressure Boundary Fatigue Management Program will maintain the design allowable cycles for all transients (except unit-loading and unit-unloading) and the reduced number of unit loading and unit unloading transients or take appropriate re-evaluation or corrective action to

manage the effects of fatigue on the secondary manway bolts and the 4-inch inspection port bolts for the period of extended operation in accordance with 10 CFR 54.21(c)(1)(iii).

#### 4.3.1.5.2 Staff Evaluation

The staff reviewed LRA Section 4.3.1.5 to verify, pursuant to 10 CFR 54.21(c)(1)(iii), that management of the effects of aging on intended functions will be adequate for the period of extended operation.

During audit and review, the staff confirmed that steam generator components will be managed under a cycle-based fatigue monitoring program. The staff also confirmed that analysis of the steam generator secondary manway cover bolts and 4-inch inspection port bolts fatigue evaluations was based on design transient cycles except the number of unit-loading and unit-unloading transient cycles assumed to occur 2000 times over the life of the plant; therefore, the enhanced Fatigue Management Program will track these cycles with a limit of 2000 cycles and an alarm limit of 1500 cycles. In the applicant's letter dated August 31, 2007, Commitment 32 stated that the enhanced fatigue monitoring program will address corrective actions through the Corrective Action Program for components exceeding alarm limits, including a revised fatigue analysis or repair or replacement of the component. In this letter, the applicant also set the cycle/transient alarm limit at around 75 percent of the design basis cycle/transient and provided an adequate time frame for corrective actions. On these bases, the staff concluded that the applicant's alarm limit for the cycle-based fatigue management program is adequate.

The GALL Report recommends a fatigue monitoring program to manage metal fatigue according to 10 CFR 54.21(c)(1)(iii). The staff has evaluated the applicant's AMP B3.1, "Reactor Coolant Pressure Boundary Fatigue Monitoring Program," for monitoring and tracking the number of critical thermal and pressure transients for RCS components, determined that this program is acceptable to address metal fatigue of RCS components according to 10 CFR 54.21(c)(1)(iii), and documented its evaluation and acceptance in SER Section 3.0. On the basis that the applicant's action is consistent with the GALL Report recommendation, the staff finds that management of the effects of aging on intended function will be adequate for the period of extended operation.

#### 4.3.1.5.3 FSAR Supplement

The applicant provided an FSAR supplement summary description of its TLAA evaluation of steam generators in LRA Section A.1.2.2.5. On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address steam generators is adequate.

#### 4.3.1.5.4 Conclusion

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(iii), that the effects of aging on the intended function(s) will be adequately managed for the period of extended operation. The staff also



concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

#### **4.3.1.6 Pressurizer**

##### **4.3.1.6.1 Summary of Technical Information in the Application**

LRA Section 4.3.1.6 summarizes the evaluation of the pressurizer for the period of extended operation. There are TLAAs for several pressurizer subcomponents. The use of transients from the steam generator replacement/uprating analysis is reasonable and limiting for the primary equipment with the exceptions of the pressurizer surge line and portions of the pressurizer lower head analyzed separately; therefore, the NSSS design transients are those shown in the steam generator replacement/uprating analysis, in which 40-year design CUF values also were determined.

The pressurizer fatigue analysis demonstrated that, if pressurizer subcomponents were exposed to a bounding set of postulated transient cycles, CUF values would not exceed 1.0 for all components; however, certain pressurizer lower head locations are not bounded by the original design fatigue analysis because it did not consider insurge/outsurge transients discovered subsequently.

For the pressurizer (other than the lower head and surge line nozzle), the highest 40-year design fatigue usage value is 1.00 for the "Trunnion Bolt Hole" (LRA Table 4.3-2). Multiplying this fatigue usage by 1.5 to account for 60 years of operation yields a CUF of 1.50.

The applicant used Westinghouse Owners Group (WOG) recommendations to address operational pressurizer insurge/outsurge transients by reviewing plant operating records in sufficient detail to determine pressurizer insurge/outsurge transients for past operation, updating pressurizer lower head and surge nozzle transients to reflect past and projected future operations, and evaluating the impact of the updated transients on the structural integrity of the pressurizer. The WOG also recommended operating strategies that may be useful in addressing the insurge/outsurge issue. On January 20, 1994, the applicant adopted the modified operating procedures recommended by the WOG to mitigate pressurizer insurge/outsurge transients.

The applicant used plant data from hot functional testing to January 20, 1994, to establish pre-modified operating procedure transients that represent past plant heat-up and cool-down operations and collected and processed plant data from July 19, 1999, to October 18, 2004, for post-modified operating procedures operations. The 5.26 years of data history with the pre-modified operating procedure transients was projected to predict 60-year fatigue usage based on current operating practices.

Fatigue evaluations of the pressurizer lower head and surge line nozzle used the online monitoring and Westinghouse proprietary design analysis features of the WESTEMS™ Integrated Diagnostics and Monitoring System. The fatigue evaluations follow the procedures of

ASME Code, Section III, NB-3200. Calculations of stress ranges, cycle pairing, and fatigue usage factors were by use of WESTEMS™ consistent with the ASME Code and WOG recommendations.

The fatigue evaluations at critical locations of the pressurizer lower head (including the pressurizer surge line nozzle) and of the surge line RCS hot leg nozzle were based upon pre-modified operating procedure transients with the post-modified operating procedure transients that include the effects of insurge/outsurge and surge line stratification. These transients were developed based upon plant-specific data and WOG information and guidelines. The predicted fatigue usage was determined assuming future operations following current operating procedures.

For 40 years of plant life, the pressurizer lower head has the highest fatigue usage of 0.36 at the inside surface of the lower head at the heater penetration region. Multiplying this fatigue usage by 1.5 to account for 60 years of operation yields a fatigue usage of 0.54. Evaluation of this location also accounted for the effects of reactor water environment on fatigue. The 60-year fatigue usage for this location is 1.35 as shown in LRA Table 4.3-3.

For the pressurizer, the maximum fatigue usage for 60 years of operation is 1.35. This value exceeds the design limit of 1.0 and, therefore, requires an AMP. The Reactor Coolant Pressure Boundary Fatigue Monitoring Program will maintain the design limit fatigue usage or take appropriate re-evaluation or corrective action to manage the effects of fatigue on the pressurizer for the period of extended operation in accordance with 10 CFR 54.21(c)(1)(iii).

#### 4.3.1.6.2 Staff Evaluation

During audit and review, the staff asked the applicant what components are in the stress-based fatigue monitoring portion of the HNP program. The applicant responded as follows:

The HNP Fatigue Evaluation for License Renewal (WCAP-16353-P) resulted in the following locations recommended for inclusion into the program.

- Pressurizer Lower Head
- Pressurizer Surge Line
- CVCS Piping and Heat Exchanger

Based on the Westinghouse recommendations, the HNP fatigue monitoring program will be enhanced to include the above components by monitoring fatigue usage for these locations using online fatigue monitoring software.

In this letter, the applicant also indicated its stress-based fatigue monitoring locations and stress-based alarm limit of 0.9. On the basis that the 0.9 alarm limit will provide adequate time for actions, the staff concluded that the applicant's stress-based alarm limit is adequate. For all other locations managed through a cycle-based monitoring program, the applicant also provided its alarm limit. Commitment 32 states that the enhanced program will address

corrective actions through the Corrective Action Program for components exceeding alarm limits, including a revised fatigue analysis or repair or replacement of the component.

LRA Amendment 2 states that the applicant used plant data from July 19, 1999, to October 18, 2004, to predict 60-year fatigue usage based on current operating practices. The staff does not agree with this prediction, which used 5.26 years of data to determine the next 40 years of operation transients; however, the applicant, by letter date January 17, 2008, committed to a stress-based fatigue monitoring program to manage those components. On this basis, the staff finds this LRA amendment acceptable. Therefore the applicant projections will not be used. The applicant will manage the effects of aging for the period of extended operation.

LRA Amendment 2 also states that the pressurizer lower head heater penetration region has the highest fatigue usage (0.36) for the 40 years of plant life. LRA Table 4.3-2 lists a design fatigue usage factor of 0.909 for this location. The staff asked the applicant to address the difference. This item was confirmatory item (CI) 4.3 and needed the applicant's docketed response to complete the staff's review.

In letter dated April 23, 2008, the applicant stated that HNP will update the piping design specification to reflect the current design basis operational transients used in the Time-Limited Aging Analyses for the reactor coolant pressure boundary (See Commitment No. 37). The applicant also amended LRA FSAR Supplement Section A.1.2.2.2.10 to indicate that the TLAA on metal fatigue of the charging nozzle, surge line, and pressurizer lower head and surge nozzle will be managed in accordance with the 10 CFR 54.21(c)(1)(iii). This is consistent with the applicant's TLAA on metal fatigue of the Class 1 piping components (as provided in LRA Section 4.3.5), which indicates that the Fatigue Monitoring Program will be used to manage the effects of aging for these components in accordance with the TLAA acceptance criterion requirement in 10 CFR 54.21(c)(1)(iii).

Based on this review, the staff finds that the applicant has appropriately addressed the staff's confirmatory item on the TLAA on metal fatigue of the reactor coolant pressure boundary. Confirmatory Item 4.3 is closed.

During the audit and review, the staff asked the applicant to explain the input of stresses to apply the stress transfer function of fatigue analysis software, WESTEMS™, to the stressed components or the stress intensity and asked for input and results of any benchmarking problems for pressure, temperature, or moment loadings.

The applicant's response is in pages 67 to 93 of Enclosure 3 of LRA Amendment 2 by letter dated August 31, 2007.

The staff reviewed the applicant's response explaining the method for the stress transfer function of fatigue analysis software WESTEMS. On the basis of its review, the staff confirmed that the applicant superimposed stress at the component stress level for each time step and for each applied loading type. The staff concluded that the method is in accordance with ASME Section III, Division 1, NB-3200 criteria.

The applicant also stated,

The verification of fatigue analysis software thermal and mechanical stress calculations have been performed in the programs verification and validation documentation. However, each application verification of the finite element model and of the final thermal transfer function databases should be performed in order to show applicability to the problem being modeled. To do this for mechanical loads, Westinghouse verifies the finite element model results by comparing them to the expected theoretical values. For the time varying thermal results, the applicant performs thermal stress analyses using both the finite element program and WESTEMS™.”

On the basis that verified fatigue analysis software stress results had the theoretical values and traditional finite element analysis, the staff finds the applicant's transfer function method for evaluating stress results acceptable.

The staff also reviewed the applicant's benchmark verification results plotted in Figures B-1 through B-11 and additional results of samples 1 and 2 all indicating that the stress results generated from fatigue analysis software and those generated from traditional finite element ANSYS analysis have negligible differences. On this basis, the staff concludes that stress evaluation by fatigue analysis software is acceptable.

The GALL Report recommends a fatigue monitoring program to manage metal fatigue according to 10 CFR 54.21(c)(1)(iii). The staff has evaluated the applicant's AMP B3.1, “Reactor Coolant Pressure Boundary Fatigue Monitoring Program,” for monitoring and tracking the number of critical thermal and pressure transients for RCS components, determined that this program is acceptable to address metal fatigue of RCS components according to 10 CFR 54.21(c)(1)(iii), and documented its evaluation and acceptance in SER Section 3.0. On the basis that the applicant's action is consistent with the GALL Report recommendation, the staff finds that management of the effects of aging on intended functions will be adequate for the period of extended operation.

#### 4.3.1.6.3 FSAR Supplement

The applicant provided an FSAR supplement summary description, as amended by letter dated April 23, 2208, of its TLAA evaluation of the pressurizer in LRA Section A.1.2.2.6. On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address pressurizer is adequate.

#### 4.3.1.6.4 Conclusion

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(iii), that management of the effects of aging on intended functions will be adequate for the period of extended operation. The staff also concludes that the FSAR supplement is an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

### **4.3.1.7 Reactor Coolant Pressure Boundary Piping (ASME Class 1)**

#### **4.3.1.7.1 Summary of Technical Information in the Application**

LRA Section 4.3.1.7 summarizes the evaluation of RCPB piping (ASME Class 1) for the period of extended operation. There are TLAAs for RCPB piping components. The use of transients from the steam generator replacement/uprating analysis is reasonable and limiting for the primary equipment with the exceptions of the pressurizer surge line and portions of the pressurizer lower head analyzed separately; therefore the NSSS design transients are those shown in the steam generator replacement/uprating analysis, in which 40-year design CUF values also were determined. The RCPB piping fatigue analysis demonstrated that, if the RCPB piping components were exposed to a bounding set of postulated transient cycles, their CUF values would not exceed 1.0; however, the pressurizer surge line is not bounded by the original design fatigue analysis.

In response to NRC Bulletin 88-11, "Pressurizer Surge Line Thermal Stratification," the applicant evaluated the pressurizer surge line stratification transients separately for 40 years of operation.

For component parts of the RCPB piping, the highest 40-year design fatigue usage value is 0.98 for the pressurizer spray piping (LRA Table 4.3-2) before evaluation of the effects of reactor water environments on fatigue (LRA Subsection 4.3.3). Multiplying this fatigue usage by 1.5 to account for 60 years of operation yields a CUF of 1.47.

Accounting for the effects of reactor water environments on fatigue, the highest 60-year fatigue usage is 2.120 for the pressurizer surge line as shown in LRA Table 4.3-3.

As these values exceed the design limit of 1.0, they require an AMP. The Reactor Coolant Pressure Boundary Fatigue Monitoring Program will maintain the design limit fatigue usage or take appropriate re-evaluation or corrective action to manage the effects of fatigue on the pressurizer for the period of extended operation in accordance with 10 CFR 54.21(c)(1)(iii).

#### **4.3.1.7.2 Staff Evaluation**

The staff reviewed LRA Section 4.3.1.7 and LRA Table 4.3-2, which lists design fatigue usage factors. Section 4.3.1.7 addresses the pressurizer spray piping and surge line piping fatigue management only and not other Class 1 piping fatigue management. The staff requested from the applicant clarification addressing all the Class 1 piping.

In a letter dated January 17, 2008, the applicant clarified that the basis for aging management in LRA Section 4.3.17 should have applied to the entire scope of the Class 1 piping for HNP, and should not have been limited to only pressurizer spray piping and surge line piping. In this response, the applicant amended its LRA to state that:

Therefore, the effects of fatigue on the reactor coolant pressure boundary piping will be managed for the period of extended operation in accordance with 10 CFR 54.21(c)(1)(iii).

This LRA amendment expands the scope of the applicant's metal fatigue assessment in LRA Section 4.3.1.7 to the entire Class 1 piping in the reactor coolant pressure boundary and addresses the staff's issue.

The staff noted that Footnote C of LRA Table 4.3-3 had indicated that the design basis transients for the surge line, charging nozzle, and pressurizer lower head and surge nozzle had been redefined. The staff's position is that an ASME design report should follow design specification and that if the design conditions change, an updated design specification should reflect the change(s). In a supplemental question (followup question), the staff asked the applicant to: (1) clarify what the redefined transients are that had been mentioned in Footnote C of LRA Table 4.3-3 and (2) clarify whether the piping design specification had been updated to address the redefined transients mentioned in this footnote.

The applicant responded to the staff's followup question by letter dated January 17, 2007. In this letter (Audit Question LRA 4.3.3-5 [Followup] Response in Enclosure 1), the applicant provided a summary of the transients that were redefined for the surge line, charging nozzle, and pressurizer. The applicant stated that the design specification had not been updated to reflect the redefined transients for the surge line, charging nozzle, and pressurizer lower head and surge nozzle.

The staff position is that an ASME design report should follow design specification. If design conditions change, an updated design specification should reflect the change(s). The applicant has not updated the piping design specification. The LRA does not currently include a commitment to update the design specification for the surge line, charging nozzle, and pressurizer lower head and surge nozzle based on the reanalyses that were performed by the applicant (as discussed in the followup response to Question 4.3.3-6). Thus, the issue on whether the applicant currently reflects the redefined transients in the design basis CUF calculations for the surge line, charging nozzle, and pressurizer lower head and surge nozzle remains a confirmatory item. This was CI 4.3.

In letter dated April 23, 2008, the applicant stated that HNP will update the piping design specification to reflect the current design basis operational transients used in the Time-Limited Aging Analyses for the reactor coolant pressure boundary (See Commitment No. 37). The applicant also amended LRA FSAR Supplement Section A.1.2.2.2.10 to indicate that the TLAA on metal fatigue of the charging nozzle, surge line, and pressurizer lower head and surge nozzle will be managed in accordance with the 10 CFR 54.21(c)(1)(iii). This is consistent with the applicant's TLAA on metal fatigue of the Class 1 piping components (as provided in LRA Section 4.3.5), which indicates that the Fatigue Monitoring Program will be used to manage the effects of aging for these components in accordance with the TLAA acceptance criterion requirement in 10 CFR 54.21(c)(1)(iii).

Based on this review, the staff finds that the applicant has appropriately addressed the staff's confirmatory item on the TLAA on metal fatigue of the reactor coolant pressure boundary. Confirmatory Item 4.3 is closed.

#### 4.3.1.7.3 FSAR Supplement

The applicant provided an FSAR supplement summary description of its TLAA evaluation of RCPB Piping (ASME Class 1) in LRA Section A.1.2.2.7 stating that the effects of fatigue on the pressurizer will be managed for the period of extended operation. The staff asked the applicant to clarify whether all Class 1 piping will be managed instead of the pressurizer only.

By letter dated January 17, 2008, the applicant clarified that the basis for aging management in LRA Section 4.3.1.7 should have applied to the entire scope of the Class 1 piping for HNP, and should not have been limited to only pressurizer spray piping and surge line piping. In this response, the applicant amended LRA Section A.1.2.2.7 to state that:

Therefore, the effects of fatigue on the reactor coolant pressure boundary piping will be managed for the period of extended operation.

This amendment of LRA Section A.1.2.2.7 expands the scope of the applicant's FSAR supplement on the metal fatigue assessment in LRA Section 4.3.1.7 to the entire Class 1 piping in the reactor coolant pressure boundary.

In SER Section 4.3.1.7, the staff determined that the applicant had redefined the design basis transients for the surge line, charging nozzle, and pressurizer lower head and surge nozzle but had not updated the design specification for these components to reflect the redefined transients used in the fatigue assessment for these components. The applicant, in a teleconference, agreed to add Commitment No. 37 to update, prior to the period of extended operation, the design specifications to reflect current design basis transients. This is to be formalized in a docketed correspondence. This was CI 4.3.

In letter dated April 23, 2008, the applicant stated that HNP will update the piping design specification to reflect the current design basis operational transients used in the Time-Limited Aging Analyses for the reactor coolant pressure boundary (See Commitment No. 37). The applicant also amended LRA FSAR Supplement Section A.1.2.2.2.10 to indicate that the TLAA on metal fatigue of the charging nozzle, surge line, and pressurizer lower head and surge nozzle will be managed in accordance with the 10 CFR 54.21(c)(1)(iii). This is consistent with the applicant's TLAA on metal fatigue of the Class 1 piping components (as provided in LRA Section 4.3.5), which indicates that the Fatigue Monitoring Program will be used to manage the effects of aging for these components in accordance with the TLAA acceptance criterion requirement in 10 CFR 54.21(c)(1)(iii).

Based on this review, the staff finds that the applicant has appropriately addressed the staff's confirmatory item on the TLAA on metal fatigue of the reactor coolant pressure boundary. Confirmatory Item 4.3 is closed.

On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address RCPB piping (ASME Class 1) is inadequate.

#### 4.3.1.7.4 Conclusion

On the basis of its review, as discussed above, with the resolution of the confirmatory item, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(iii), that the effects of aging on the intended function(s) will be adequately managed for the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

#### 4.3.2 Implicit Fatigue Analysis (ASME Class 2, Class 3, and ANSI B31.1 Piping)

##### 4.3.2.1 ASME Class 2 and 3 Piping

###### 4.3.2.1.1 Summary of Technical Information in the Application

LRA Section 4.3.2.1 summarizes the evaluation of ASME Classes 2 and 3 piping for the period of extended operation. Auxiliary piping designed to ASME Section III, Code Classes 2 and 3 requirements required no explicit fatigue evaluation. Instead, for such piping the code implicitly treats fatigue using a stress range reduction factor ( $f$ ), which is a function of the total number of thermal expansion stress range cycles, equal to 1.0 for up to 7,000 cycles. For greater numbers of cycles,  $f$  may be reduced further, reducing the thermal expansion range stress allowable. The applicant's fatigue evaluation for Classes 2 and 3 piping shows the original design evaluations for Classes 2 and 3 components remain valid for 60 years.

The affected Classes 2 and 3 piping are effectively extensions of the adjacent Class 1 piping; therefore, the cycle count depends closely on reactor operating cycles and can be estimated by a review of the limiting reactor coolant system design transients in FSAR Table 3.9.1-1. Of those listed normal conditions likely to produce full-range thermal cycles in a 40-year plant lifetime are the 200 heatup and cooldown cycles. The assumption that all upset conditions lead to full-range thermal cycles adds 980 cycles for a total of 1180 occurrences. The 980 cycles are equal to the summation of upset condition transients 1 through 12 plus five operating-basis earthquakes at 10 cycles each. For the 60-year period of extended operation, the number of full-range thermal cycles for these piping analyses would be increased proportionally to 1770, only a fraction of the 7000 full-range thermal cycles for a stress range reduction factor of 1.0; therefore, the analysis for Classes 2 and 3 piping has been projected to the period of extended operation per 10 CFR 54.21(c)(1) (ii).

###### 4.3.2.1.2 Staff Evaluation

During the audit and review, the staff asked the applicant why the Class 1 piping thermal transients are relevant to Classes 2 and 3 piping. LRA Amendment 2 dated August 31, 2007, states, "The CL 2 & 3 piping are the extension of Class piping and subject to same cycle counting; therefore, the cycle count depends closely on reactor operating cycles."

The staff sought supplement information on this response and, in a supplemental (followup) question, asked the applicant to clarify whether the LRA amendment in LRA Amendment 2



postulates that the Class 2 and 3 piping is subject to the same design transients as that for Class 1 piping.

In its response dated January 17, 2008, the applicant clarified that the assessment of the Class 2 and 3 piping is based on an assessment of the number of full thermal transient cycles (full temperature cycles) that the piping is projected to be subjected to. This is consistent with the staff's basis for evaluating ASME Code Class 2 and 3 piping in SRP-LR Sections 4.3.2.1.2 and 4.3.2.1.4, and is acceptable. The staff's supplemental question on the Class 2 and 3 piping is resolved.

In LRA Amendment 2 dated August 31, 2007, the applicant clarified how its projections of the full thermal transient cycles for the Class 2 and 3 piping was performed. In this response, the applicant clarified that the full thermal transient cycles for the Class 2 and 3 piping are considerably less frequent and of a smaller temperature range than those analyzed for the plant's heatups and cooldowns of the reactor coolant pressure boundary (i.e., for the Class 1 pressure boundary components) and that as a result, the applicant uses the heatups and cooldowns as a conservative basis for estimating the full thermal transients that are applicable to the Class 2 and 3 piping components. The applicant also clarified that it conservatively included all assumed upset transients for the plant in 60-year projections of the full thermal transients for the Class 2 and 3 piping components and that it applied a factor 1.5 (i.e. a factor of 60/40) to these 40-year totals, arriving at a 60-year full thermal transient projection of 1770 cycles for the Class 2 and 3 piping components. The applicant stated that, based on this projection, the number of full thermal transient cycles for the Class 2 and 3 piping over a 60-year life is still less 7000 cycles and that, based on this number, the maximum allowable stress range for the Class 2 and 3 piping would not need to be reduced and that the original design basis fatigue calculation for these components remains valid for the period of extended operation. The staff finds this to be acceptable because it is in conformance with the staff's metal fatigue criteria for evaluating these components in SRP-LR Sections 4.3.2.1.2 and 4.3.2.1.4.

On this basis, the staff finds the Class 2 and 3 piping fatigue analyses to be acceptable because: (1) the applicant has used a conservative basis for estimating the 60-year projections for full thermal transients that apply to the Class 2 and 3 piping components, (2) based on these projections, the applicant has demonstrated that design basis fatigue analysis for the Class 2 and 3 piping components will remain valid for the period of extended operation, and (3) applicant's basis for evaluating the fatigue analysis for the Class 2 and 3 is in conformance with the staff's criteria in SRP-LR Sections 4.3.2.1.2 and 4.3.2.1.4.

On the basis of this review, the staff concludes that the applicant has demonstrated that the fatigue analysis for the Class 2 and 3 piping remains valid for the period of extended operation in accordance with the criterion in 10 CFR 54.21(c)(1)(i).

In the applicant's response dated January 17, 2008, the applicant also amended LRA Section 4.3.2.1 to verify that the metal fatigue Class 2 and 3 piping was determined to be acceptable in accordance with the criterion in 10 CFR 54.21(c)(1)(i), in that the current TLAA analysis has been determined to be valid for the period of extended operation.

#### 4.3.2.1.3 FSAR Supplement

The applicant provided an FSAR supplement summary description of its TLAA evaluation of ASME Classes 2 and 3 piping in LRA Section A.1.2.2.8. By letter dated January 17, 2008, the applicant amended the LRA to indicate that the fatigue analysis for the Class 2 and 3 piping would be dispositioned and found acceptable in accordance with the criterion in 10 CFR 54.21(c)(1)(i) in that the applicant has provided a valid basis for demonstrating that the number of full thermal transient cycles for the Class 2 and 3 piping will be less than 7000 cycles over a 60-year licensed plant life. The staff also verified that the amendment of the LRA in the applicant's response dated January 17, 2008, included an amendment of FSAR supplement Section A.1.2.2.8 to reflect the change in the LRA.

In SER Section 4.3.2.1.3, the staff provided its basis for concluding that the applicant had provided an acceptable basis for accepting the TLAA on metal fatigue of the Class 2 and 3 piping in accordance with the TLAA acceptance criterion in 10 CFR 54.21(c)(1)(i). On the basis of this review, the staff concludes that FSAR supplement Section A.1.2.2.9 with respect to the applicant's TLAA on metal fatigue of the Class 2 and 3 piping, as amended in the applicant's response dated January 17, 2008, is adequate.

#### 4.3.2.1.4 Conclusion

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(i), that, for ASME Code Class 2 and 3 piping, the analyses remain valid for the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

### **4.3.2.2 ANSI B31.1 Piping**

#### 4.3.2.2.1 Summary of Technical Information in the Application

LRA Section 4.3.2.2 summarizes the evaluation of ANSI B31.1 piping for the period of extended operation. In addition to ASME Classes 2 and Class 3 piping, the scope of license renewal includes nonsafety-related piping designed to ANSI B31.1. Auxiliary piping designed to ANSI B31.1 requirements required no explicit fatigue evaluation. Instead, for ANSI B31.1 piping, the "power piping" code implicitly treats fatigue using a stress allowable reduction factor ( $f$ ), which is a function of the total number of thermal expansion stress range cycles, equal to 1.0 for up to 7,000 cycles. For greater number of cycles,  $f$  may be reduced further, reducing the thermal expansion range stress allowable.

For the main feedwater system and associated systems (e.g., condensate system) and main steam system and associated systems (e.g., steam generator system), anticipated thermal cycles correspond to heatup and cooldown cycles. For the 60-year period of extended operation, the number of full-range thermal cycles for these piping analyses would be increased proportionally to 300; therefore, main feedwater and main steam system components will not experience 7000 cycles during the period of extended operation.

The auxiliary feedwater system supplies feedwater to the secondary side of the steam generators when the normal feedwater system is not available to maintain the heat sink capabilities of the steam generator. The system is an alternative to the feedwater system during startup, hot standby, and cooldown and also functions as an engineered safeguards system. HNP relies directly on the auxiliary feedwater system to prevent core damage during plant transients caused by loss of normal feedwater flow, steam line rupture, main feedwater line rupture, loss of coolant accidents (LOCAs), loss of offsite power, or any combination of these causes by supplying feedwater to the unaffected steam generators to maintain their inherent heat sink capability. The total numbers of cycles projected for 40 years of operation are as follows: 200 heatup and cooldown cycles, 2000 cycles of feedwater cycling at hot standby, 980 cycles for all upset conditions, 240 cycles of quarterly auxiliary feedwater pump tests in accordance with ASME Code Section XI, and 40 cycles of tests per plant technical specifications for a total of 3460 cycles. For the 60-year period of extended operation, the number of full-range thermal cycles for these piping analyses would increase proportionally to 5,190; therefore, auxiliary feedwater components will not experience 7000 cycles during the period of extended operation.

The diesel generators in the emergency diesel generator system undergo monthly surveillance tests in accordance with plant technical specifications. For the 60-year period of extended operation, the number of full-range thermal cycles for these piping analyses would increase proportionally to 720; therefore, the emergency diesel generator diesel exhaust piping will experience significantly fewer than 7000 equivalent full-temperature cycles during the period of extended operation.

The diesel generator in the security power system undergoes a monthly surveillance test to satisfy fire protection program surveillance requirements. For the 60-year period of extended operation, the number of full-range thermal cycles for these piping analyses would increase proportionally to 720; therefore, the security diesel generator diesel exhaust piping will experience significantly fewer than 7000 equivalent full-temperature cycles during the period of extended operation.

The diesel-driven fire pump in the fire protection system undergoes a monthly test to satisfy fire protection program surveillance requirements. For the 60-year period of extended operation, the number of full-range thermal cycles for these piping analyses would increase proportionally to 720; therefore, the diesel-driven fire pump piping will experience significantly fewer than 7000 equivalent full-temperature cycles during the period of extended operation, and the analysis for ANSI B31.1 piping has been projected to the period of extended operation using per 10 CFR 54.21(c)(1) (ii).

#### 4.3.2.2.2 Staff Evaluation

The staff reviewed the technical information in LRA Section 4.3.2, pertaining to the non-Class 1 fatigue analysis of piping, against the criteria contained in SRP-LR Section 4.3.2.1.2 and documented the results in the Audit Report.

SRP-LR Section 4.3.2.1.2.1 states that for piping designed or analyzed to ANSI B31.1 standards, the acceptance criteria is the existing fatigue strength reduction factors remain valid because the number of cycles would not be exceeded during the period of extended operation. Although ANSI B31.1 Code does not require explicit fatigue analysis, it considers fatigue implicitly in the design calculation by applying an allowable stress range reduction factor. Fatigue also can depend on the number of design thermal expansion cycles.

The staff reviewed the applicant's basis document which provided the basis and calculations for the metal fatigue. In the basis document, the applicant discussed the operating cycles for the piping, piping components, or piping elements in B31.1 piping systems, including but not limited to those in the main steam system, main feedwater system, condensate system, auxiliary feedwater system, and steam generator system. This also includes B31.1 piping components associated with the diesel generators in the emergency diesel generator system and the security power system and associated with the diesel-driven fire pump in the fire protection system. For these B31.1 piping systems, the applicant concluded that B31.1 piping, piping components, and piping elements will experience less than 7000 full thermal transient cycles for 60-years of licensed operation and that, based on this determination, the maximum allowable stress range for these components would not need to be reduced.

By letter dated August 31, 2007), the applicant supplemented the LRA and clarified that the number of startups and shutdowns for the Class 1 piping in the reactor coolant pressure boundary (i.e., 300 cycles) could be used as a conservative basis for estimating the number of full thermal transients that are projected for the B31.1 piping, piping components, and piping elements in the main steam, main feedwater, condensate, and steam generator systems through 60-years of licensed operations.

The staff finds this to be a valid basis for projecting the number of full thermal transient cycles for these B31.1 piping, piping components, and piping elements through 60-years of licensed operations because: (1) the full temperature range for startup/shutdown cycling of the reactor coolant pressure boundary is bounding for the full temperature ranges associated with operational/isolational cycling of these B31.1 systems, and (2) over the life of the plant, the number of times the reactor coolant pressure boundary is thermally cycled during plant startup/shutdowns will exceed the number of operational/isolational cycles that occur in these B31.1 systems. Thus, the staff concludes that the applicant has provided an acceptable basis for concluding that the number of full thermal transients for the B31.1 piping in these systems will be less 7000 cycles through 60 years of licensed operations and that the metal fatigue analysis for these systems will remain valid for the period of extended operation. This is acceptable because it is in conformance with the recommendations in SRP-LR Section 4.3.2.1.2.1.

By letter dated August 31, 2007, the applicant supplemented the LRA and provided its basis for concluding that 5190 cycles represents a conservative estimate of the number of full thermal transients that are projected for the B31.1 piping, piping components, and piping elements in the auxiliary feedwater system through 60 years of licensed operations. The applicant has based its 60-year full thermal transient projection for the auxiliary feedwater system piping on the number of plant startups and shutdowns that are projected to occur through 60 years of operation, as well as on the number of upset transients, the number of feedwater cycles during

hot standby, the number of auxiliary feedwater pump tests that are required by the plant's inservice testing program (IST) program, and the number of auxiliary feedwater system functional tests that are required by technical specifications that are projected to occur through 60 years of operation.

The staff finds this to be an acceptable basis because: (1) the applicant's 60-year projection for the auxiliary system B31.1 piping is based not only the projected number of plant startups and shutdowns, but also on the number of auxiliary system actuations that are projected to occur during anticipated operational transients, required system testing, and system operation during hot standby, and (2) the applicant's projection includes a margin of 1.5 on the cycle projection to account for the period of extended operation. Thus, the staff concludes that the applicant has provided an acceptable basis for concluding that the number of full thermal transients for the B31.1 piping in the auxiliary feedwater system will be less than 7000 cycles through 60 years of licensed operations and that the metal fatigue analysis for this system will remain valid for the period of extended operation. This is acceptable because it is in conformance with the recommendations in SRP-LR Section 4.3.2.1.2.1.

The B31.1 piping associated with the emergency diesel generator system, security power system, and diesel-driven fire protection pump are not normally in service, but undergo a monthly system test in accordance plant technical specifications. The applicant estimated that the number of full thermal transients associated with these systems corresponds to the number of monthly actuations that are projected to occur in the system tests through 60 years of licensed operation (i.e., 720 full thermal cycle actuations).

The staff was of the opinion that the applicant should have included the number of time these systems were projected to actuate during system operational transients or other testing. However, the staff determined that, even if the number of plant trips represented in LRA Table 4.3-1 for upset conditions were accounted for in the projection with a safety factor of two (i.e., bringing the total to 1140), the number of full thermal transients for these systems would still be less than 7000 full thermal transient cycles. Thus, the staff concludes that the applicant has provided an acceptable basis for concluding that the metal fatigue assessment for the B31.1 piping, piping components, and piping elements associated with the emergency diesel generator system, security power system, and diesel-driven fire protection pump will remain valid for the period of extended operation. This is acceptable because it is in conformance with the recommendations in SRP-LR Section 4.3.2.1.2.1.

Based on this assessment, the staff concludes that: (1) the applicant has provided an acceptable basis to demonstrate that the number of full thermal transients for the B31.1 piping, piping components, and piping elements associated with the main steam, main feedwater, condensate, steam generator, auxiliary feedwater, emergency diesel generator, and security power systems, and with the diesel-driven fire protection pumps will be less than 7000 full thermal transient cycles through 60 years of licensed operation, and (2) this is acceptable because it is in conformance with the staff's criterion for acceptance in SRP-LR Section 4.3.2.1.2.1. On the basis of its audit and review, the staff concludes that the applicant has demonstrated that the metal fatigue analyses for these ANSI B31.1 piping systems will remain valid for the period of extended operation, as required by 10 CFR 54.21(c)(1)(i).

By letter dated January 17, 2008, the applicant amended the LRA to indicate that the fatigue analysis for the ANSI B31.1 piping would be dispositioned and found acceptable in accordance with the criterion in 10 CFR 54.21(c)(1)(i) in that the number full thermal transient cycles for the ANSI B31.1 piping are projected to be less than 7000 over a 60-year licensed plant life. The staff has verified that the applicant has used a conservative estimate of the number of full thermal transient cycles that are projected to occur in the ANSI B31.1 piping components through 60 years of licensed operations. Based on this assessment, the staff concludes that the applicant has provided an acceptable basis for accepting the TLAA on metal fatigue for the ANSI B31.1 piping in accordance with 10 CFR 54.21(c)(1)(i).

#### 4.3.2.2.3 FSAR Supplement

The applicant provided an FSAR supplement summary description of its TLAA evaluation of ANSI B31.1 piping in LRA Section A.1.2.2.9. By letter dated January 17, 2008, the applicant amended the LRA to indicate that the fatigue analysis for the ANSI B31.1 piping would be dispositioned and found acceptable in accordance with the criterion in 10 CFR 54.21(c)(1)(i) in that the applicant has provided a valid basis for demonstrating that the number of full thermal transient cycles for the ANSI B31.1 piping will be less than 7000 cycles over a 60-year licensed operating period. The staff also verified that the amendment of the LRA in the applicant's letter dated January 17, 2008, included an amendment of FSAR supplement Section A.1.2.2.9 to reflect the change that the applicant is accepting this TLAA in accordance with the TLAA acceptance criterion in 10 CFR 54.21(c)(1)(i).

In SER Section 4.3.2.2.3, the staff provided its basis for concluding that the applicant had provided an acceptable basis for accepting the TLAA on metal fatigue of the ANSI B31.1 piping in accordance with the TLAA acceptance criterion in 10 CFR 54.21(c)(1)(i). Based on this assessment, the staff concludes that the applicant has provided an acceptable basis for accepting the TLAA on metal fatigue for the ANSI B31.1 piping in accordance with 10 CFR 54.21(c)(1)(i). On the basis of this review, the staff concludes that FSAR supplement Section A.1.2.2.9 on the applicant's TLAA on metal fatigue of the ANSI B31.1 piping, as amended in the applicant's letter dated January 17, 2008, is adequate.

#### 4.3.2.2.4 Conclusion

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(i), that, for ANSI B31.1 piping, the analyses remain valid for the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

### 4.3.3 Environmentally-Assisted Fatigue Analysis

#### 4.3.3.1 Summary of Technical Information in the Application

LRA Section 4.3.3 summarizes the evaluation of environmentally-assisted fatigue analysis for the period of extended operation. Reactor water environment effects on fatigue were evaluated

for a subset of representative components selected based upon the evaluations in NUREG/CR-6260, "Application of NUREG/CR-5999 Interim Design Curves to Selected Nuclear Power Plant Components." Because the Class 1 piping was designed in the more recent history of Westinghouse plant design, locations selected corresponded to the Westinghouse newer vintage plant. Representative components evaluated are as follows:

- Reactor Vessel Shell and Lower Head
- Reactor Vessel Inlet and Outlet Nozzles
- Pressurizer Surge Line
- Charging Nozzle
- Safety Injection Nozzle
- Residual Heat Removal (RHR) System Class 1 Piping

In addition to these representative NUREG/CR-6260 locations, locations in the pressurizer lower head potentially subject to insurge/outsurge transients also were evaluated for reactor water environmental effects.

The methods for evaluating environmental effects on fatigue were based on NUREG/CR-6583, "Effects of LWR Coolant Environments on Fatigue Design Curves of Carbon and Low Alloy Steels," NUREG/CR-5704, "Effects of LWR Coolant Environments on Fatigue Design Curves of Austenitic Stainless Steels," and NUREG/CR-6717, "Environmental Effects of Fatigue Crack Initiation in Piping and Pressure Vessel Steels." The applicant used environmental fatigue life correction factors to obtain adjusted cumulative fatigue usage, which includes the effects of reactor water environments.

For the charging nozzle, additional analyses for several "partial cycle" transients accounted for transients much less severe than design so they would not be counted as full design cycles. The ANSI B31.1 Power Piping Code, 1967 Edition, Section 102.3.2, provides the following equation and methodology for the mathematical determination of the number of equivalent full temperature range changes from the number of lesser temperature range changes:

$$N = N_E + r_1^5 N_1 + r_2^5 N_2 + \dots + r_n^5 N_n$$

Where: N = the number of equivalent full temperature cycles,  
 $N_E$  = number of cycles at full temperature change for which expansion stress has been calculated,  
 $N_1, N_2 \dots N_n$  = number of cycles at lesser temperature changes,  
 $r_1, r_2 \dots r_n$  = ratio of lesser temperature cycles to the cycle for which the expansion stress has been calculated.

#### 4.3.3.2 Staff Evaluation

The staff reviewed LRA Section 4.3.3 to verify (1) pursuant to 10 CFR 54.21(c)(1)(ii) that the analyses have been projected to the end of the period of extended operation or (2) pursuant to

10 CFR 54.21(c)(1)(iii) that the effects of aging on the intended function(s) will be adequately managed for the period of extended operation.

The staff reviewed LRA Section 4.3.3 against SRP-LR Section 4.3.3.2, "Generic Safety Issue." The SRP-LR recommends that license renewal applicants address Generic Safety Issue 190. To assess the impact of the reactor coolant environment on a sample of critical components, the SRP-LR states that applicants should address the recommendations as follows:

- (1) The critical components include, as a minimum, those selected in NUREG/CR-6260.
- (2) Evaluation of the sample of critical components has applied environmental correction factors to the ASME Code fatigue analyses.
- (3) Formulas for calculating the environmental life correction factors are those in NUREG/CR-6583 for carbon and low-alloy steels and in NUREG/CR-5704 for austenitic stainless steels or approved technical equivalents.

In LRA Table 4.3-3, the applicant has evaluated the sample of critical components by applying environmental correction factors to the ASME Code fatigue analysis.

The staff confirmed that the critical components include those selected in NUREG/CR-6260 and that calculations of environmental life correction factors use NUREG/CR-6583 formulas for carbon and low-alloy steels and NUREG/CR-5704 formulas for austenitic stainless steels; therefore, the staff confirmed that the applicant has followed staff recommendations to assess the impact of the reactor coolant environment consistently with the SRP-LR.

The methodology described in ANSI B31.1 Power Piping Code, 1967 Edition, Section 102.3.2 for partial cycle counting does not apply to ASME Code Class 1 components and that ANSI B31.1 power piping thermal qualification does not consider the ranges of pressure, temperature, and moment as for Class 1 piping. The staff asked the applicant to justify use of the ANSI B31.1 code method for cycle reduction. In LRA Amendment 2, the applicant responded that an independent ASME Code Section III, Division I, Subsection NB fatigue evaluation has established a quantitative basis for application of the ANSI B31.1 cycle reduction methodology to cycle counting of HNP charging nozzle transients. The staff reviewed the result of the CUF evaluation. On the basis that the applicant's calculation results demonstrate a conservative fatigue usage factor, the staff finds this approach acceptable for this location and specific transient reduction only.

During the review of LRA Amendment 2, dated August 31, 2007, the staff noted that Column C of LRA Table 4.3-3 states that for the surge line, charging nozzle, and pressurizer lower head at heater penetration the CUF evaluation used redefined transients. The staff asked the applicant which transients had been redefined for the environmental fatigue analyses for these component locations and whether the design specification for these component locations had been updated based on the redefined transients for these components.



The applicant responded to the staff's follow-up question by letter dated January 17, 2007. In this letter (refer to the Audit Question LRA 4.3.3-5 [Followup] Response in Enclosure 1), the applicant provided a summary of the transients that were redefined for the surge line, charging nozzle, and pressurizer. In its response, the applicant also indicated that the design specification had not been updated to reflect the redefined transients for the surge line, charging nozzle, and pressurizer lower head and surge nozzle.

The staff position is that an ASME design report should follow design specification and that if design conditions change, an updated design specification should reflect the change(s). The applicant has not updated the piping design specification to reflect the redefinition of the design transients that are applicable to the surge line, the charging nozzle, and the pressurizer lower head and surge nozzle. The LRA does not currently include a commitment to update the design specification for these components based on the reanalyses that were performed by the applicant (as discussed in the followup response to Question 4.3.3-5). Thus, the issue on whether the applicant currently reflects the redefined transients in the design basis and environmental CUF calculations for the surge line, charging nozzle, and pressurizer lower head and surge nozzle was not properly addressed in the applicants response.

The applicant, in a teleconference, agreed to add Commitment No. 37 to update, prior to the period of extended operation, the design specifications to reflect current design basis transients. This is to be formalized in a docketed correspondence. This was CI 4.3.

In letter dated April 23, 2008, the applicant stated that HNP will update the piping design specification to reflect the current design basis operational transients used in the Time-Limited Aging Analyses for the reactor coolant pressure boundary (See Commitment No. 37). The applicant also amended LRA FSAR Supplement Section A.1.2.2.2.10 to indicate that the TLAA on metal fatigue of the charging nozzle, surge line, and pressurizer lower head and surge nozzle will be managed in accordance with the 10 CFR 54.21(c)(1)(iii). This is consistent with the applicant's TLAA on metal fatigue of the Class 1 piping components (as provided in LRA Section 4.3.5), which indicates that the Fatigue Monitoring Program will be used to manage the effects of aging for these components in accordance with the TLAA acceptance criterion requirement in 10 CFR 54.21(c)(1)(iii).

Based on this review, the staff finds that the applicant has appropriately addressed the staff's confirmatory item on the TLAA on metal fatigue of the reactor coolant pressure boundary. Confirmatory Item 4.3 is closed.

The staff reviewed LRA Table 4.3-3 to confirm that the applicant has evaluated bottom head junction, reactor vessel nozzles, and RHR piping CUFs by multiplying environmental correction factors by design fatigue usage factors and further multiplying by 1.5 to account for 60 years. Based on this review, the staff concluded that reactor vessel lower head and nozzles fatigue TLAA's have been projected through the period of extended operation in accordance with 10 CFR 54.21(C)(1)(ii). The other four components, surge line, charging nozzle and pressurizer lower head at heater penetration, will be within the scope of the applicant's Reactor Coolant Pressure Boundary Fatigue Monitoring Program to manage environmentally-assisted metal fatigue of the surge line, charging nozzle, safety-injection nozzle, and pressurizer lower head and surge nozzle in accordance with 10 CFR 54.21(c)(1)(iii). LRA Amendment 2, as provided in

the applicant's letter dated August 31, 2007, does not indicate the method for management of the fatigue effects. The applicant, in a teleconference, agreed to provide the method of management for these components.

By letter dated January 17, 2008, the applicant clarified that the TLAA on environmentally-assisted metal fatigue of the surge line, charging line, safety injection nozzle, and pressurizer lower head in accordance with the TLAA acceptance criterion in 10 CFR 54.21(c)(1)(iii) and that the Reactor Coolant Pressure Boundary Fatigue Monitoring Program is credited to manage environmentally-assisted metal fatigue in these components for the period of extended operation.

The GALL Report recommends a fatigue monitoring program to manage metal fatigue in accordance with 10 CFR 54.21(c)(1)(iii). The staff has evaluated the applicant's AMP B3.1, "Reactor Coolant Pressure Boundary Fatigue Monitoring Program," for monitoring and tracking the number of critical thermal and pressure transients (cycle-based monitoring) for RCS components and for evaluating stress-based fatigue, determined that this program is acceptable to address metal fatigue of RCS components according to 10 CFR 54.21(c)(1)(iii), and documented its evaluation and acceptance in SER Section 3.0. On the basis that the applicant's action is consistent with the GALL Report recommendation, the staff finds that management of the effects of aging on intended functions will be adequate for the period of extended operation.

#### **4.3.3.3 FSAR Supplement**

The applicant provided an FSAR supplement summary description of its TLAA evaluation of environmentally-assisted fatigue analysis in LRA Section A.1.2.2.10. The staff has determined that the current version of FSAR supplement Section A.1.2.2.10 indicates that the TLAA on environmentally-assisted metal fatigue of reactor coolant pressure boundary components was found acceptable for the period of extended operation. However, the staff has verified that the applicant has credited its Reactor Coolant Pressure Boundary Fatigue Monitoring Program to manage environmentally-assisted metal fatigue in the HNP surge line, charging nozzle, and pressurizer lower head and surge nozzle in accordance with 10 CFR 54.21(c)(1)(iii). Thus, FSAR Supplement Section A.1.1.38 and Commitment No. 32 are also applicable to the evaluation of this TLAA and the summary description in FSAR Supplement Section A.1.2.2.10 does not reflect this information.

The staff has verified that the applicant's Reactor Coolant Pressure Boundary Fatigue Monitoring Program, as enhanced in Commitment No. 32 is an AMP that is consistent with the staff's recommended program element criteria in GALL AMP X.M1, "Metal Fatigue of the Reactor Coolant Pressure Boundary." The staff has verified that the applicant included this acceptance criterion in FSAR Supplement Section A.1.1.38 and has included its commitment to manage the effects of aging in the surge line, charging nozzle, and pressurizer lower head and surge nozzle within the scope of Commitment No. 32, as provided in the applicant's letter dated January 17, 2008:

Based on this assessment, the staff concludes that the summary description in FSAR Supplement Section A.1.1.38 and the applicant's enhancement of the Reactor Coolant

Pressure Boundary Fatigue Monitoring Program, as given in LRA Commitment No. 32, tie in appropriately to the applicant's basis for accepting the TLAA on environmentally-assisted metal fatigue of the surge line, charging nozzle, and pressurizer lower head and surge nozzle. This is an acceptable basis for accepting the TLAA on environmentally-assisted metal fatigue, as assessed relative to the surge line, charging nozzle, and pressurizer lower head and surge nozzle, because it is in compliance with the staff acceptance basis in 10 CFR 54.21(c)(1)(iii). The staff's evaluation of the Reactor Coolant Pressure Boundary Fatigue Monitoring Program is given in SER Section 3.0.3.2.26.

In CI 4.3, the staff requested additional information to ensure that the applicant would provide a design specification for the surge line, the charging nozzle, and the pressurizer lower head and surge nozzle that was based on the redefined transients for these components, as discussed in the applicant's follow-up response to Audit Question 4.3.3-5, dated January 17, 2008. The CI included a request to update FSAR supplement Section A.1.2.2.10 to reflect that the applicant is crediting its Reactor Coolant Pressure Boundary Fatigue Monitoring Program to manage environmentally-assisted metal fatigue in the HNP surge line, charging nozzle, and pressurizer lower head and surge nozzle in accordance with 10 CFR 54.21(c)(1)(iii). The staff's resolution of CI 4.3 on the acceptability of FSAR supplement Section A.1.2.2.10 was pending formalized docketed correspondence.

In letter dated April 23, 2008, the applicant stated that HNP will update the piping design specification to reflect the current design basis operational transients used in the Time-Limited Aging Analyses for the reactor coolant pressure boundary (See Commitment No. 37). The applicant also amended LRA FSAR Supplement Section A.1.2.2.2.10 to indicate that the TLAA on metal fatigue of the charging nozzle, surge line, and pressurizer lower head and surge nozzle will be managed in accordance with the 10 CFR 54.21(c)(1)(iii). This is consistent with the applicant's TLAA on metal fatigue of the Class 1 piping components (as provided in LRA Section 4.3.5), which indicates that the Fatigue Monitoring Program will be used to manage the effects of aging for these components in accordance with the TLAA acceptance criterion requirement in 10 CFR 54.21(c)(1)(iii).

Based on this review, the staff finds that the applicant has appropriately addressed the staff's confirmatory item on the TLAA on metal fatigue of the reactor coolant pressure boundary. Confirmatory Item 4.3 is closed.

On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address environmentally-assisted fatigue analysis is adequate.

#### **4.3.3.4 Conclusion**

On the basis of its review, the staff concludes that, pursuant to 10 CFR 54.21(c)(1)(ii), the applicant has demonstrated that the analyses have been projected to the end of the period of extended operation and, that pursuant to 10 CFR 54.21(c)(1)(iii), with resolution of CI 4.3, the applicant has demonstrated that the effects of aging on the intended function(s) will be adequately managed for the period of extended operation. The staff also concludes that with

resolution of CI 4.3, the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

#### **4.3.4 RCS Loop Piping Leak-Before-Break Analysis**

##### **4.3.4.1 Summary of Technical Information in the Application**

LRA Section 4.3.4 summarizes the evaluation of the RCS loop piping leak-before-break analysis for the period of extended operation. In accordance with the CLB, a leak-before-break (LBB) analysis showed that any potential leak that develops in the RCS loop piping can be detected by plant leak monitoring systems before a postulated crack causing the leak would grow to unstable proportions during the 40-year plant life. LBB evaluations postulate a surface flaw at a limiting stress location and demonstrate that a through-wall crack will not be the result of exposure to a lifetime of design transients. A separate evaluation assumes a through-wall crack of sufficient size for the resultant leakage to be detected easily by the existing leakage monitoring system and then demonstrates that, even under maximum faulted loads, the crack is much smaller (with margin) than a critical flaw size that could grow to pipe failure. The aging effects to be addressed during the period of extended operation include thermal aging of the primary loop piping components and fatigue crack growth.

WCAP-14549-P, Addendum 1, "Technical Justification for Eliminating Large Primary Loop Pipe Rupture as the Structural Design Basis for the Harris Nuclear Plant for the License Renewal Program," is a new LBB calculation applicable to large-bore RCS piping and components with allowances for reduction of fracture toughness of cast austenitic stainless steel due to thermal embrittlement during a 60-year operating period, concluded that:

- Stress corrosion cracking is precluded by use of fracture-resistant materials in the piping system and controls on reactor coolant chemistry, temperature, pressure, and flow during normal operation. An Electric Power Research Institute material reliability program is underway to address the Alloy 82/182 primary water stress corrosion cracking issue for the industry due to the V. C. Summer cracking incident; however, per calculations for Alloy 82/182 locations this material is not bounding.
- Water hammer should not occur in the RCS piping because of system design, testing, and operational considerations.
- The effects of low- and high-cycle fatigue on primary piping integrity are negligible. The fatigue crack growth evaluated is insignificant.
- There is a margin of 10 between the leak rate of small stable leakage flaws and the capability (1 gpm) of the RCS pressure boundary leakage detection System.
- There is a margin of two or more between the small stable leakage flaw sizes and the larger critical stable flaws.

The new analysis meets LBB requirements required by 10 CFR Part 50, Appendix A, General Design Criterion 4 and uses the recommendations and criteria from the NRC Standard Review Plan for LBB evaluations; therefore, the RCS primary loop piping LBB analysis has been projected to the end of the period of extended operation. When the EPRI Materials Reliability Program methodology described in MRP-140, "Materials Reliability Program:

Leak-Before-Break Evaluation for PWR Alloy 82/182 Welds," is reviewed and approved by the staff, the applicant will review its plant-specific calculation for consistency with the approved approach.

#### **4.3.4.2 Staff Evaluation**

The staff reviewed LRA Section 4.3.4, to verify pursuant to 10 CFR 54.21(c)(1)(ii), that the analyses have been projected to the end of the period of extended operation.

The staff reviewed the final licensing basis LBB document, WCAP-14549-P, Addendum 1, "Technical Justification for Eliminating Large Primary Loop Pipe Rupture as the Structural Design Basis for the Harris Nuclear Plant for the License Renewal Program," and confirmed the use of saturated material fracture toughness in the LBB analysis. The staff also confirmed the fatigue crack growth evaluation for 60 years that no through-wall crack will occur. No flaw growth evaluation due to primary water stress corrosion cracking was considered but the applicant monitors for such cracking and will address the issue under current licensing requirements. In LRA Amendment 2, Commitment 35 states that when the EPRI Materials Reliability Program methodology described in MRP-140, "Material Reliability Program: Leak-Before-Break Evaluation for PWR Alloy 82/182 Welds," is reviewed and approved by the staff, the applicant will review its plant-specific calculation for consistency with the approved approach. On this basis, the staff finds the applicant's analysis acceptable.

#### **4.3.4.3 FSAR Supplement**

The applicant provided an FSAR supplement summary description of its TLAA evaluation of RCS loop piping in LRA Section A.1.2.2.11. On the basis of its review of the FSAR supplement and Commitment 35, the staff concludes that the summary description of the applicant's actions to address RCS loop piping is adequate.

#### **4.3.4.4 Conclusion**

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(ii), that, for the RCS loop piping LBB analysis, the analyses have been projected to the end of the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

#### **4.3.5 Cyclic Loads That Do Not Relate to RCS Transients**

This section addresses components listed with thermal fatigue TLAA's where the number of thermal cycles may not correspond to Class 1 component transient cycles. These components were designed originally in accordance with ASME Section III, Class 2 or Class 3 or the ANSI B31.1 Power Piping Code, which requires instead of explicit CUF values, implicit fatigue analyses using stress range reduction factors. These design codes account for cyclic loading by reducing the allowable stress for the component if the number of anticipated cycles exceeds certain limits. It requires the designer to determine the overall number of anticipated thermal

cycles for the component and apply stress range reduction factors if this number exceeds 7,000. This implicit fatigue analysis method effectively reduces the allowable stress for the component to keep the applied loads below the endurance limit for the material.

The basic strategy in the following subsections considers the number of transient cycles postulated for 40 years and for license renewal determines whether the number of cycles for 60 years would require a reduction in stress beyond that applied during the original design process. These determinations can be made by a comparison of the design cycles projected for 60 years against the 7,000-cycle criterion for a stress range reduction factor. If the total number of cycles projected for 60 years does not exceed 7,000, then the original design considerations remain valid.

#### **4.3.5.1 Primary Sample Lines**

##### **4.3.5.1.1 Summary of Technical Information in the Application**

LRA Section 4.3.5.1 summarizes the evaluation of primary sample lines for the period of extended operation. System equipment in the scope of this TLAA are system piping and valves (a) parts of the RCPB and (b) normally or automatically isolated from the RCPB. Part (a) is the portions of piping upstream of the piping anchor for the outboard isolation valves for penetrations M-78A, B, and C. These portions are essentially the safety-related system piping component and a small portion of the nonsafety-related tubing up to the first anchor. Part (b) is the portion of piping downstream from the anchor on the nonsafety-related tubing is not relevant to the applicant for safety determinations. There are three sample line penetrations involved: RCS hot legs (M-78A), pressurizer liquid space (M-78B), and pressurizer steam space (M-78C). The following analyses determined the number of cycles to which the equipment would be subject and compared it to the implicit fatigue analysis acceptance criterion of 7,000 cycles. The applied cycles are determined on the manner of equipment use.

Penetration M-78A - RCS hot legs: The piping downstream of M-78A has three parallel branch lines that supply the post-accident sample panel in the post-accident sampling system, the primary sample panel in the reactor coolant sample system, and the gross failed fuel detector in the gross failed fuel detection system. The gross failed fuel detector operates continuously during reactor startup, operation, and shutdown and the base load follows the reactor thermal cycles; however, as a result of this configuration, the safety-related portion of the reactor coolant sample lines may experience additional thermal cycles whenever flow through the detector is interrupted.

This experience would occur when the containment isolation valves are closed, when flow is swapped between RCS Hot Leg 2 and Hot Leg 3, or when flow to the letdown line, volume control tank, and boron thermal regeneration system is isolated. The cyclic operation of the primary sample panel has no effect on the thermal cycles experienced by the flow through Penetration M-78A due to the continuous flow through the gross failed fuel detector. Interruption of flow through the detector from downstream equipment would require isolation of the letdown line, volume control tank, and boron thermal regeneration system. This latter possibility happening is very rare and a negligible contributor to the consideration of the number of cycles.

Based on this consideration, the total number of cycles experienced by the RCS hot leg sample lines can be estimated by adding to the number of RCS thermal cycles the number of times the hot leg is swapped and the number of cycles caused by Penetration M-78A isolations of sufficient duration to permit cool-down of the sample lines. This evaluation conservatively considers a penetration isolation lasting more than 10 minutes while the RCS hot leg temperature exceeds 500°F one thermal cycle.

Currently RCS flow is swapped between Hot Legs 2 and 3 on an approximate monthly schedule. Even though this swap results in six cycles on each supply from the hot legs, this evaluation conservatively considers twelve cycles each year and simplifies the evaluation. Over 60 years of operation with shutdowns ignored the result is 720 cycles. Rounding up this number to 1,000 cycles accounts for uncertainty in early plant operating practice.

The estimated number of cycles due to reactor shutdowns and the number of Penetration M-78A isolations that would result in a thermal cycle were based on plant data over a period of approximately 6.75 years when there were 9 cycles due to reactor shutdowns and 30 thermal cycles due to penetration isolation valve closure. A ratio of 60 to 6.75 years yields 8.88 rounded up to 9 multiplied by 9 shutdown cycles and 30 penetration isolation cycles yields the following 60-year projections:

- 81 reactor thermal cycles
- 270 thermal cycles due to penetration isolations

Therefore, the total number of hot leg thermal cycles for penetration M-78A is 1,351 cycles, fewer than the requisite 7,000 cycles. As the total number of thermal cycles for the sample lines is fewer than 7,000 cycles, no reanalysis of the piping design calculations is necessary; therefore, an evaluation as required by 10 CFR 54.21(c)(1) successfully demonstrated under 10 CFR 54.21(c)(1) (i) that the reactor coolant sample line design analyses of record remain valid for the period of extended operation (60 years).

#### 4.3.5.1.2 Staff Evaluation

The staff reviewed LRA Section 4.3.5.1 to verify pursuant to 10 CFR 54.21(c)(1)(i), that the analyses remain valid for the period of extended operation.

The staff confirmed design of these primary sample lines in accordance with ASME Code Classes 2 and 3. On the basis that the total number of thermal cycles for these lines is less than 7000 for 60 years, the staff concluded that the primary sample lines analyses remain valid for the period of extended operation in accordance with 10 CFR 54.21(c)(1)(i).

#### 4.3.5.1.3 FSAR Supplement

The applicant provided an FSAR supplement summary description of its TLAA evaluation of primary sample lines in LRA Section A.1.2.2.12. On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address primary sample lines is adequate.

#### 4.3.5.1.4 Conclusion

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(i), that, for the primary sample lines fatigue analysis, the analyses remain valid for the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

#### 4.3.5.2 Steam Generator Blowdown Lines

##### 4.3.5.2.1 Summary of Technical Information in the Application

LRA Section 4.3.5.2 summarizes the evaluation of steam generator blowdown lines for the period of extended operation. The steam generator blowdown lines included in this TLAA are listed in FSAR Table 3.2.1-1 as the system portion designed to ASME Section III, Class 2 and ANSI B31.1 codes. This FSAR table lists these components as (a) "the system piping and valves from the steam generator to and including outboard containment isolation valves," (b) "from containment isolation valves to RAB Wall," and (c) "Other." Components in the turbine building also may be designed to ANSI B31.1 as noted in the "Other" listing, but these have no bearing on equipment within the scope of license renewal.

Blowdown flow normally is maintained during operation to maintain steam generator water chemistry. A thermal cycle in the blowdown lines may result whenever blowdown flow to the flash tank is interrupted. There are many potential reasons for interruption of blowdown flow during periods of operation. For example, blowdown flow would be interrupted by an auxiliary feedwater pump actuation signal, a safety injection signal, high-condenser hotwell level signal, steam generator flash tank hi-hi level, containment isolation, or other testing purposes. These interruptions could result in thermal cycles in addition to reactor heat-up and cool-down cycles.

The method of estimating the number of cycles is to review data over a recent time period and count the number of cycles in which blowdown flow was interrupted. This number of cycles multiplied by a ratio based on years estimates the total number of cycles expected over 60 years of operation. The potential to undercount comes from the assumption that the number of cycles counted for the period reviewed represents past and future operations. Additionally, no partial cool-down cycles are counted. To offset the potential undercount, a conservative count extrapolates the total number of cycles to 60 years.

The conservative method counts one cycle when blowdown flow is interrupted for more than 30 minutes. For the purposes of thermal fatigue, a complete thermal cycle is defined as a heat-up from ambient to operating temperature followed by a cool-down to ambient temperature. The thermal cycle counting is conservative because it includes interruptions of blowdown flow in which a significant decrease in temperature is not expected based on the operating practice for re-establishing blowdown flow following a blowdown isolation valve closure. This operating practice states that if the isolation valves are closed for more than 30 minutes the downstream piping must be warmed up before the isolation valves are opened; therefore, an isolation valve closed for less than 30 minutes does not constitute a significant cool-down period.



The number of cycles due to reactor shutdowns is included in the blowdown cycles counted. Based on plant data over a period of approximately 5.5 years, the estimated number blowdown flow interruptions that would result in thermal cycles is 37 cycles. Application of a ratio for 60 and 100 years yields 404 and 673 cycles, respectively. As the total number of thermal cycles for the steam generator blowdown lines is fewer than 7,000 cycles, no reanalysis of the piping design calculations is necessary; therefore, an evaluation as required by 10 CFR 54.21(c)(1) successfully demonstrated under 10 CFR 54.21(c)(1) (i) that the steam generator blowdown line design analyses of record remain valid for the period of extended operation (60 years).

#### 4.3.5.2.2 Staff Evaluation

The staff reviewed LRA Section 4.3.5.2 to verify pursuant to 10 CFR 54.21(c)(1)(i), that the analyses remain valid for the period of extended operation.

The staff confirmed design of the steam generator blowdown lines in accordance with ASME Code Class 2 and ANSI B31.1. On the basis that the total number of thermal cycles for these lines is less than 7000 for 60 years, the staff concluded that the steam generator blowdown lines analyses remain valid for the period of extended operation in accordance with 10 CFR 54.21(c)(1)(i).

#### 4.3.5.2.3 FSAR Supplement

The applicant provided an FSAR supplement summary description of its TLAA evaluation of steam generator blowdown lines in LRA Section A.1.2.2.13. On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address steam generator blowdown lines is adequate.

#### 4.3.5.2.4 Conclusion

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(i), that, for steam generator blowdown lines, the analyses remain valid for the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

### **4.4 Environmental Qualification of Electrical Equipment**

The 10 CFR 50.49 EQ program is a TLAA for purposes of license renewal. The TLAA of the environmental qualification (EQ) electrical components includes all long-lived, passive, and active electrical and instrumentation and control components that are important to safety and located in a harsh environment. The harsh environments of the plant are those areas subject to environmental effects by LOCAs or high-energy line breaks. EQ equipment comprises safety-related and Q-list equipment, nonsafety-related equipment the failure of which could prevent satisfactory accomplishment of any safety-related function, and necessary post-accident monitoring equipment.

As required by 10 CFR 54.21(c)(1), the applicant must provide a list of EQ TLAAAs in the LRA. The applicant shall demonstrate that for each type of EQ equipment, one of the following is true: (1) the analyses remain valid for the period of extended operation, (2) the analyses have been projected to the end of the period of extended operation, or (3) the effects of aging on the intended function(s) will be adequately managed for the period of extended operation.

#### **4.4.1 Summary of Technical Information in the Application**

LRA Section 4.4 summarizes the evaluation of EQ of electrical equipment for the period of extended operation. Thermal, radiation, and cyclical aging analyses of plant electrical and instrumentation and control components required to meet 10 CFR 50.49 qualification are TLAAAs.

The NRC has established nuclear station EQ requirements in 10 CFR Part 50, Appendix A, General Design Criterion 4 and in 10 CFR 50.49, which specifically requires establishment of an EQ program to demonstrate that electrical components in harsh plant environments (plant areas that could be subject to environmental effects of LOCAs, high-energy line breaks, or post-LOCA radiation) are qualified to perform safety functions in such environments despite the effects of inservice aging. Section 50.49 requires EQ to address the effects of significant aging mechanisms.

#### **4.4.2 Staff Evaluation**

The staff reviewed LRA Section 4.4, to verify pursuant to 10 CFR 54.21(c)(1)(iii), that the effects of aging on the intended function(s) will be adequately managed for the period of extended operation.

The staff reviewed the program basis calculation for adequate information for 10 CFR 54.21(c)(1). For the electrical equipment shown in LRA Table 4.1-1, the applicant demonstrated per 10 CFR 54.21(c)(1)(iii) that the aging effects of EQ equipment will be adequately managed during the period of extended operation. The staff reviewed the Environmental Qualification (EQ) Program for whether it maintain electrical and instrumentation and control component performance of intended functions consistent with the CLB for the period of extended operation. The staff's evaluation of the qualification of these components focused on how the Environmental Qualification (EQ) Program manages the aging effects for 10 CFR 50.49 requirements.

The staff's audit of the information in LRA Section B3.2 and the program bases documents is documented in SER Section 3.0.3.1.13. On the basis of its audit, the staff finds that the Environmental Qualification (EQ) Program, for which the applicant claimed consistency with GALL AMP X.E1, "Environment Qualification of Electrical Components," is consistent with the GALL Report; therefore, the staff finds the program capable of programmatically managing the qualified life of components within the scope of license renewal. The continued implementation of the Environmental Qualification (EQ) Program reasonably assures management of the aging effects for continued performance by components within the scope of the program of intended functions for the period of extended operation.

#### **4.4.3 FSAR Supplement**

The applicant provided an FSAR supplement summary description of its TLAA evaluation of EQ of electrical equipment in LRA Section A.1.2.3. On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address EQ of electrical equipment is adequate.

#### **4.4.4 Conclusion**

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(iii), that, for EQ of electrical equipment, the effects of aging on the intended function(s) will be adequately managed for the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

### **4.5 Concrete Containment Tendon Prestress**

#### **4.5.1 Summary of Technical Information in the Application**

LRA Section 4.5 summarizes the evaluation of concrete containment tendon prestress for the period of extended operation. NUREG-1800 assigns TLAA Section 4.5 to the issue of Concrete Containment Tendon Prestress. The Unit 1 containment structures have no prestressed tendons; therefore, this section is not applicable.

#### **4.5.2 Staff Evaluation**

The containment has no prestressed tendons; therefore, the staff finds this TLAA not required.

#### **4.5.3 FSAR Supplement**

The staff concludes that no FSAR supplement is required because the containment building has no pre-stressed tendons.

#### **4.5.4 Conclusion**

On the basis of its review, as discussed above, the staff concludes this TLAA is not required.

### **4.6 Containment Liner Plate, Metal, Metal Containments, and Penetrations Fatigue Analysis**

#### **4.6.1 Containment Mechanical Penetration Bellows Fatigue**

##### ***4.6.1.1 Mechanical Penetration Bellows - Valve Chambers***

#### 4.6.1.1.1 Summary of Technical Information in the Application

LRA Section 4.6.1.1 summarizes the evaluation of mechanical penetration bellows - valve chambers for the period of extended operation. The four mechanical penetration bellows addressed by this section are the containment spray and safety injection system recirculation valve chamber bellows (two each) for containment penetrations M-47 through M-50. These penetrations are illustrated in FSAR Table 6.2.4-1. Each line has motor-operated gate valves enclosed in valve chambers leak-tight at containment design pressure. Each line from the containment sump to the valve is enclosed in a separate concentric guard pipe also leak-tight. A seal keeps both the chamber and the guard pipe from connecting directly to the containment sump or to the containment atmosphere.

Per plant specifications, the valve chamber bellows expansion joint design is in accordance with ASME Section III, Paragraph NC-3649.1 so no single corrugation is permitted to deflect more than its maximum allowable amount. Each bellows is designed to withstand over a lifetime of 40 years a total of 7,000 expansion and compression cycles due to maximum normal operating conditions and 10 cycles of movement due to safe shutdown earthquake conditions.

This TLAA addresses the requirement that the 40-year lifetime may be extended to 60 years without exceeding the design criterion of 7,000 expansion and compression cycles. The 10 cycles of movement due to safe shutdown earthquake conditions are still available because no earthquake of such magnitude has been experienced.

Operating cycles of expansion and compression due to maximum normal operating conditions are calculated conservatively by addition of RCS (Class 1) design cycles corresponding to containment heat-up and cool-down to the number of times the containment is pressurized during Type A integrated leak rate testing plus the number of Type B local leak rate tests.

The expansion bellows is the barrier between the valve chamber and the reactor auxiliary building. The containment isolation valves for these chambers isolate the containment sumps from the containment spray and RHR systems and therefore normally experience no fluid flow. RHR operation during RCS cool-down would have a negligible impact on the bellows due to the piping configuration but is included because RHR operation typically corresponds to RCS (Class 1) cycles.

The number of reactor thermal cycles projected over 60 years is 81. Containment integrated leak rate testing is infrequent (*i.e.*, every 10 years). A conservative assumption of integrated leak rate testing every 5 rather than 10 years yields 12 cycles. In the Type B local leak rate test program the maximum test interval for this equipment is 24 months. A conservative assumption is a minimum of yearly with an additional 60 cycles and a total number of 153 cycles anticipated for 60 years.

The total number of thermal cycles for the containment spray and safety injection system recirculation valve chamber bellows is fewer than 7,000 so no reanalysis of the design calculations is necessary. An evaluation as required by 10 CFR 54.21(c)(1) successfully demonstrated under 10 CFR 54.21(c)(1)(i) that the containment spray and safety injection

system recirculation valve chamber bellows design analyses of record remain valid for the period of extended operation.

#### 4.6.1.1.2 Staff Evaluation

The staff reviewed LRA Section 4.6.1.1 to verify pursuant to 10 CFR 54.21(c)(1)(i), that the analyses remain valid for the period of extended operation.

The staff confirmed design of the bellows in accordance with ASME Class 2 to withstand 7000 cycles of thermal expansion and compression and 10 cycles of safe shutdown earthquake movement. The staff reviewed the applicant's conservative estimation of the thermal cycle for the bellows. On the basis that the total number of thermal cycles for these bellows is less than 7000 for 60 years with 10 cycles of safe shutdown earthquake movement still available, the staff concluded that the bellows design analyses remain valid for the period of extended operation in accordance with 10 CFR 54.21(c)(1)(i).

#### 4.6.1.1.3 FSAR Supplement

The applicant provided an FSAR supplement summary description of its TLAA evaluation of mechanical penetration bellows - valve chambers in LRA Section A.1.2.4.1. On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address mechanical penetration bellows - valve chambers is adequate.

#### 4.6.1.1.4 Conclusion

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(i), that, for mechanical penetration bellows - valve chambers the analyses remain valid for the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

### **4.6.1.2 Mechanical Penetration Bellows - Fuel Transfer Tube Bellows Expansion Joint**

#### 4.6.1.2.1 Summary of Technical Information in the Application

LRA Section 4.6.1.2 summarizes the evaluation of mechanical penetration bellows - fuel transfer tube bellows expansion joint for the period of extended operation. The fuel transfer tube is essentially a tubular passageway connecting the transfer canal in the containment building with that in the spent fuel pit building. Per plant specifications, the fuel transfer tube bellows-expansion-joint design is in accordance with ASME Section III, Paragraph NC-3649.1, with no single corrugation permitted to deflect more than its maximum allowable amount. Each bellows is designed to withstand a total of 7,000 cycles of expansion and compression over a lifetime of 40 years of maximum normal operating conditions and 10 cycles of movement due to safe shutdown earthquake conditions.

This TLAA addresses the requirement that the 40-year lifetime extend to 60 years without exceeding the design criterion of 7,000 cycles of expansion and compression. The 10 cycles of movement due to safe shutdown earthquake are still available as no earthquake of such magnitude has been experienced.

The expansion cycles would occur when the tube is flooded between the transfer canal in the containment building and the fuel handling building. This operation typically occurs twice every refueling outage; therefore, the maximum number of operating cycles projected over a 60-year period is 80 cycles.

The total number of thermal cycles for the fuel transfer tube bellows expansion joint is fewer than 7,000 so no reanalysis of the design calculations is necessary. An evaluation as required by 10 CFR 54.21(c)(1) successfully demonstrated that the fuel transfer tube bellows expansion joint design analyses of record remain valid for the period of extended operation (60 years).

#### 4.6.1.2.2 Staff Evaluation

The staff reviewed LRA Section 4.6.1.2 to verify pursuant to 10 CFR 54.21(c)(1)(i), that the analyses remain valid for the period of extended operation.

The staff confirmed design of the bellows in accordance with ASME Class 2 to withstand 7000 cycles of thermal expansion and compression and 10 cycles of safe shutdown earthquake movement. The staff reviewed the applicant's conservative estimation of the thermal cycle for the bellows. On the basis that the total number of thermal cycles for these bellows is less than 7000 for 60 with 10 cycles of safe shutdown earthquake movement still available, the staff concluded that the bellows design analyses remain valid for the period of extended operation in accordance with 10 CFR 54.21(c)(1)(i).

#### 4.6.1.2.3 FSAR Supplement

The applicant provided an FSAR supplement summary description of its TLAA evaluation of mechanical penetration bellows - fuel transfer tube bellows expansion joint in LRA Section A.1.2.4.2. On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address mechanical penetration bellows - fuel transfer tube bellows expansion joint is adequate.

#### 4.6.1.2.4 Conclusion

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(i), that, for mechanical penetration bellows - fuel transfer tube bellows expansion joint, the analyses remain valid for the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

## **4.7 Other Plant-Specific Time-Limited Aging Analyses**

### **4.7.1 Turbine Rotor Missile Generation Analysis**

#### ***4.7.1.1 Summary of Technical Information in the Application***

LRA Section 4.7.1 summarizes the evaluation of turbine rotor missile generation analysis for the period of extended operation.

According to 10 CFR Part 50, Appendix A, General Design Criterion 4, nuclear power plant safety-related structures, systems, and components must be protected appropriately against dynamic effects, including those of missiles. Failures of large steam turbines of the main turbine generator could eject large high-energy missiles that can damage plant structures, systems, and components. The overall safety objective is to protect safety-related structures, systems, and components adequately from potential turbine missiles.

RG 1.115 describes methods acceptable to the staff for protecting safety-related structures, systems, and components against low-trajectory missiles from turbine failure by appropriate orientation and placement of the turbine generator set. The applicant complies with RG 1.115, Revision 1 with the exception of Position C.2.

FSAR Section 3.5.1.3.2, "Probability of Turbine Missile Generation," describes a Westinghouse study based upon mechanics to obtain a rough estimate of turbine-generator reliability based on expected operating conditions. The study determined the number of cycles required to cause a crack (flaw) to grow larger and calculated as 140,000 the number of cold start-up cycles (worst-case stress environment) required for the undetectable flaw of maximum size to grow to 1/3 of the critical crack size. A estimated reasonable upper limit for the number of this type of stress cycle is five per year or 200 per 40 years plant life; thus, the maximum undetectable crack poses no threat to the integrity of a turbine-generator with the designed mechanical properties.

The original analysis estimated five cycles per year for 40 years of plant operation. For the period of extended operation, the estimate of 5 cycles per year yields 300 cycles for 60 years of plant life, well below the 140,000 cycles required by the maximum size undetectable flaw to grow to 1/3 of the critical crack size; therefore, this analysis projects to the end of the period of extended operation.

#### ***4.7.1.2 Staff Evaluation***

The staff reviewed LRA Section 4.7.1, to verify pursuant to 10 CFR 54.21(c)(1)(ii), that the analyses have been projected to the end of the period of extended operation.

The staff reviewed FSAR Section 3.5.1.3.2. and the applicant's analyses in LRA Section 4.7.1 to confirm that the number of projected cycles of 300 is well below the 140,000 required by the maximum undetectable flaw to grow to 1/3 of the critical crack size. On this basis, the staff

concluded that this analysis remains valid for period of extended operation in accordance with 10 CFR 54.21(c)(1)(i).

The applicant stated that the fracture mechanics crack growth analysis of the number of turbine start-up cycles that could result in critical flaw size is projected to the end of the period of extended operation. The staff noted that the fracture mechanics analysis remains valid but did not project to critical flaw size; therefore, the method should be that of 10 CFR 54(c)(1)(i) instead of (ii).

By letter dated January 17, 2008. In its response, the applicant agreed that the basis for accepting the TLAA on the turbine rotor missile generation analysis should have been dispositioned in accordance with the staff's acceptance criterion in 10 CFR 54.21(c)(1)(i), in that the existing analysis has been demonstrated to be valid for the period of extended operation. The applicant stated that an amendment of LRA Section 4.7.1 would be made to reflect this. The staff verified that the applicant included the appropriate amendment of LRA Section 4.7.1 in Enclosure 2 of the letter dated January 17, 2008. Thus, dispositioning this TLAA in accordance with the criterion in 10 CFR 54.21(c)(1)(i) and appropriately reflecting this in an amendment of LRA Section 4.7.1 is resolved.

#### **4.7.1.3 FSAR Supplement**

The applicant provided an FSAR supplement summary description of its TLAA evaluation of turbine rotor missile generation analysis in LRA Section A.1.2.5. On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address turbine rotor missile generation analysis is adequate.

By letter dated January 17, 2008, the applicant agreed that the basis for accepting the TLAA on the turbine rotor missile generation analysis should have been dispositioned in accordance with the staff's acceptance criterion in 10 CFR 54.21(c)(1)(i), in that the existing analysis has been demonstrated to be valid for the period of extended operation. The applicant stated that an amendment of FSAR supplement Section A.1.2.5 would be made to reflect this. The staff verified that the applicant included the appropriate amendment to FSAR supplement Section A.1.2.5 in Enclosure 2 of the letter dated January 17, 2008. Thus, dispositioning this TLAA in accordance with the criterion in 10 CFR 54.21(c)(1)(i) and appropriately reflecting this in an amendment of FSAR supplement Section A.1.2.5 is resolved.

On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the TLAA on the turbine rotor missile generation analysis, as given in LRA Section A.1.2.5 and amended in the applicant's letter dated January 17, 2008, is adequate.

#### **4.7.1.4 Conclusion**

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(i), that, for turbine rotor missile generation analysis, the analyses remain valid to the end of the period of extended operation. The staff



also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

#### **4.7.2 Crane Cyclic Analyses**

The applicant indicated load cycle limits for cranes as potential TLAA's. The following cranes within the scope of license renewal have TLAA's, which require evaluation for 60 years.

- Polar Crane
- Jib Cranes
- Reactor Cavity Manipulator Crane
- Fuel Cask Handling Crane
- Fuel Handling Bridge Crane
- Fuel Handling Building Auxiliary Crane

The method of review for the crane cyclic load limit TLAA involves:

- review of the existing 40-year design basis to determine the number of load cycles in the design of each of the cranes within the scope of license renewal
- development of 60-year load cycle projections for each of the cranes within the scope of license renewal compared to the number of design cycles for 40 years

##### **4.7.2.1 Polar Crane**

###### **4.7.2.1.1 Summary of Technical Information in the Application**

LRA Section 4.7.2.1 summarizes the polar crane evaluation for the period of extended operation. The overhead crane in the containment (250-ton / 50-ton) for reactor servicing operations is of the polar configuration and seated on a girder bracketed off the containment wall.

The polar crane purchasing specification required conformance to Crane Manufacturers Association of America (CMAA) Specification 70, 1971 edition, for electric overhead traveling cranes. The purchasing specification did not state a service classification but the crane meets the Service Class A requirement. The crane, therefore, was designed for 20,000 to 100,000 maximum-rated load cycles for a 40-year life.

The number of maximum rated load cycles for the 250-ton (main hook) originally projected for 40 years was 2,720. The number of maximum rated cycles for a 60-year life based on 40 refueling outages is 4,020, fewer than the 20,000 to 100,000 permissible cycles and, therefore, acceptable.

The number of maximum rated load cycles for the 50-ton (auxiliary hook) originally projected for 40 years was 1,080. The number of maximum rated cycles for a 60-year life based on 40 refueling outages is 1,600, fewer than the 20,000 to 100,000 permissible cycles and, therefore, acceptable.

The polar crane main hook and auxiliary hook ultimately share the same structure and therefore their cycles should be combined as follows:  $4020 + 1,600 = 5,620$  cycles, fewer than the 20,000 to 100,000 permissible cycle range and, therefore, acceptable.

Therefore, the Polar Crane fatigue analysis has been projected successfully for 60 years of plant operation.

#### 4.7.2.1.2 Staff Evaluation

The staff reviewed LRA Section 4.7.2.1, to verify pursuant to 10 CFR 54.21(c)(1)(ii), that the analyses have been projected to the end of the period of extended operation.

The staff reviewed the applicant's estimate of the number of the maximum rated load cycles for the 60 years operation compared to the number of permissible design cycles. On the basis that the 60-year number of operation cycles, 5620, is much less than the permissible number, 20,000 to 100,000, the staff concluded that this analysis remains valid for period of extended operation in accordance with 10 CFR 54.21(c)(1)(i).

The staff noted that the design analysis remains valid but does not project the analysis result to 60 years; therefore, the method should be that of 10 CFR 54(c)(1)(i) instead of (ii).

By letter dated January 17, 2008, the applicant agreed that the basis for accepting the TLAA on the polar crane should have been dispositioned in accordance with the staff's acceptance criterion in 10 CFR 54.21(c)(1)(i), in that the existing analysis has been demonstrated to be valid for the period of extended operation. The applicant stated that an amendment of LRA Section 4.7.2.1 would be made to reflect this. The staff verified that the applicant included the appropriate amendment of LRA Section 4.7.2.1 in Enclosure 2 of the letter dated January 17, 2008. Thus, dispositioning this TLAA in accordance with the criterion in 10 CFR 54.21(c)(1)(i) and appropriately reflecting this in an amendment of LRA Section 4.7.2.1 is resolved.

#### 4.7.2.1.3 FSAR Supplement

The applicant provided an FSAR supplement summary description of its TLAA evaluation of the polar crane in LRA Section A.1.2.6.1. On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address the polar crane is adequate.

By letter dated January 17, 2008 the applicant agreed that the basis for accepting the TLAA on the polar crane should have been dispositioned in accordance with the staff's acceptance criterion in 10 CFR 54.21(c)(1)(i), in that the existing analysis has been demonstrated to be

valid for the period of extended operation. The applicant stated that an amendment of FSAR supplement Section A.1.2.6.1 would be made to reflect this. The staff verified that the applicant included the appropriate amendment of FSAR supplement Section A.1.2.6.1 in Enclosure 2 of the letter dated January 17, 2008. Thus, the reflected item in the amendment of FSAR supplement Section A.1.2.6.1 is resolved.

On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the TLAA on the polar crane, as given in LRA Section A.1.2.6.1 and amended in the applicant's letter of January 17, 2008, is adequate.

#### 4.7.2.1.4 Conclusion

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(i), that, for the polar crane, the analyses remain valid to the end of the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

#### 4.7.2.2 Jib Cranes

##### 4.7.2.2.1 Summary of Technical Information in the Application

LRA Section 4.7.2.2 summarizes the evaluation of jib cranes for the period of extended operation. The two containment jib cranes (5-ton) support low-load capacity refueling and maintenance and have the flexibility to be mounted on any of six base plates to relieve and increase availability for the ever-critical path polar crane.

The jib crane purchasing specification required conformance to CMAA Specification 74 for under-running single-girder electric overhead traveling cranes, Service Class A1 (standby). The crane, therefore, was designed for 20,000 to 100,000 maximum rated load cycles for a 40-year life.

The number of maximum rated load cycles originally projected for 40 years was 12,690. The number of maximum rated load cycles for a 60-year life based on 40 refueling outages is 18,800, fewer than the 20,000 to 100,000 permissible cycles and, therefore, acceptable.

Therefore, the jib crane fatigue analysis has been projected successfully for 60 years of plant operation.

##### 4.7.2.2.2 Staff Evaluation

The staff reviewed LRA Section 4.7.2.2, to verify pursuant to 10 CFR 54.21(c)(1)(ii), that the analyses have been projected to the end of the period of extended operation. The staff reviewed the applicant's estimate of the number of maximum-rated load cycles for the 60 years of operation compared to the number of permissible design cycles. On the basis that the

60-year number of operation cycles, 18,800, is less than the permissible number, 20,000 to 100,000, the staff concluded that this analysis remains valid for period of extended operation in accordance with 10 CFR 54.21(c)(1)(i).

The staff noted that the design analysis remains valid but does not project the analysis result to 60 years; therefore, the method should be that of 10 CFR 54.21(c)(1)(i) instead of (ii).

By letter dated January 17, 2008, the applicant agreed that the basis for accepting the TLAA on the jib cranes should have been dispositioned in accordance with the staff's acceptance criterion in 10 CFR 54.21(c)(1)(i), in that the existing analysis has been demonstrated to be valid for the period of extended operation. The applicant stated that an amendment of LRA Section 4.7.2.2 would be made to reflect this. The staff verified that the applicant included an appropriate amendment of LRA Section 4.7.2.2 in Enclosure 2 of the letter dated January 17, 2008. Thus, the TLAA is in accordance with 10 CFR 54.21(c)(1)(i) and appropriately reflecting this in an amendment of LRA Section 4.7.2.2 is resolved.

#### 4.7.2.2.3 FSAR Supplement

The applicant provided an FSAR supplement summary description of its TLAA evaluation of jib cranes in LRA Section A.1.2.6.2. On the basis of its review of the FSAR supplement, the staff did not initially agree with the fatigue analysis projected. The staff concludes that the summary description of the applicant's actions to address jib cranes is not adequate.

By letter dated January 17, 2008 the applicant agreed that the basis for accepting the TLAA on the jib cranes should have been dispositioned in accordance with the staff's acceptance criterion in 10 CFR 54.21(c)(1)(i), in that the existing analysis has been demonstrated to be valid for the period of extended operation. The applicant stated that an amendment of FSAR supplement Section A.1.2.6.2 was made to reflect this. The staff verified that the applicant included the applicable amendment of FSAR supplement Section A.1.2.6.2 in Enclosure 2 of the letter dated January 17, 2008. Thus, the applicant appropriately reflected this in an amendment of FSAR supplement Section A.1.2.6.2.

On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the TLAA on the jib cranes, as given in LRA Section A.1.2.6.2 and amended in the applicant's letter dated January 17, 2008, is adequate.

#### 4.7.2.2.4 Conclusion

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(i), that, for jib cranes, the analyses remain valid to the end of the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

### **4.7.2.3 Reactor Cavity Manipulator Crane**

#### **4.7.2.3.1 Summary of Technical Information in the Application**

LRA Section 4.7.2.3 summarizes the evaluation of the reactor cavity manipulator crane for the period of extended operation. The rectilinear bridge and trolley crane with a vertical mast extending down into the refueling water flexibly grips, removes, and replaces fuel assemblies to support refueling operations. Only the passive bridge structure manufactured from carbon steel is within the scope of license renewal.

The reactor cavity manipulator crane purchasing specification required the maximum design stress for the crane structure to be 1/5 of ultimate tensile strength. The low maximum design stress for the crane structure indicates stress marginally below the fatigue limit for the carbon steel material, which is estimated to be acceptable for  $10^7$  cycles; therefore, the estimated number of lifts for 40 years is  $10^7$  cycles.

The number of load cycles originally projected for 40 years was 11,390. The number of maximum rated load cycles for a 60-year life based on 40 refueling outages is 16,824, fewer than the  $10^7$  permissible cycles and, therefore, acceptable.

Therefore, the reactor cavity manipulator crane fatigue analysis has been projected successfully for 60 years of plant operation.

#### **4.7.2.3.2 Staff Evaluation**

The staff reviewed LRA Section 4.7.2.3, to verify pursuant to 10 CFR 54.21(c)(1)(ii), that the analyses have been projected to the end of the period of extended operation.

The staff reviewed the applicant's estimate of the number of the maximum-rated load cycles for 60 years of operation compared to the permissible number of design cycles. On the basis that the 60-year number of operation cycles, 16,824, is much less than the permissible number,  $10^7$ , the staff concluded that this analysis remains valid for period of extended operation in accordance with 10 CFR 54.21(c)(1)(i).

The staff noted that design analysis remains valid but does not project the analysis result to 60 years; therefore, the method should be that of 10 CFR 54(c)(1)(i) instead of (ii).

By letter dated January 17, 2008, the applicant agreed that the basis for accepting the TLAA on the reactor cavity manipulator crane should have been dispositioned in accordance with the staff's acceptance criterion in 10 CFR 54.21(c)(1)(i), in that the existing analysis has been demonstrated to be valid for the period of extended operation. The applicant stated that an amendment of LRA Section 4.7.2.3 would be made to reflect this. The staff verified that the applicant included the appropriate amendment of LRA Section 4.7.2.3 in Enclosure 2 of the letter dated January 17, 2008.

#### 4.7.2.3.3 FSAR Supplement

The applicant provided an FSAR supplement summary description of its TLAA evaluation of reactor cavity manipulator crane in LRA Section A.1.2.6.3. On the basis of its review of the FSAR supplement, the staff does not agree with the fatigue analysis projected. The applicant agreed that the basis for accepting the TLAA on the reactor cavity manipulator crane should have been dispositioned in accordance with the staff's acceptance criterion in 10 CFR 54.21(c)(1)(i), in that the existing analysis has been demonstrated to be valid for the period of extended operation. The applicant stated that an amendment of FSAR supplement Section A.1.2.6.3 would be made to reflect this. The staff verified that the applicant included the applicable amendment of FSAR supplement Section A.1.2.6.3 in Enclosure 2 of the letter dated January 17, 2008. Thus, the applicant appropriately reflected this in an LRA amendment of FSAR supplement Section A.1.2.6.3.

On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the TLAA on the reactor cavity manipulator crane, as given in LRA Section A.1.2.6.3 and amended in the applicant's letter dated January 17, 2008, is adequate.

#### 4.7.2.3.4 Conclusion

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(i), that, for the reactor cavity manipulator crane, the analyses remain valid to the end of the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

### **4.7.2.4 Fuel Cask Handling Crane**

#### 4.7.2.4.1 Summary of Technical Information in the Application

LRA Section 4.7.2.4 summarizes the evaluation of the fuel cask handling crane for the period of extended operation. The fuel cask handling crane (150-ton) transfers the spent fuel cask between the railroad car and the spent fuel cask loading pool. The fuel cask handling crane and the fuel handling auxiliary crane share the same rails supported from the fuel handling building in the overhead.

The fuel cask handling crane purchasing specification required conformance to CMAA Specification 70 for electric overhead traveling cranes. The purchasing specification did not state a service classification but the crane meets the Service Class A requirement and, therefore, was designed for 20,000 to 100,000 maximum-rated load cycles for a 40-year life.

The number of load cycles originally projected for 40 years was 7,350. The number of load cycles based on 40 refueling outages for a 60-year life is 8,750, fewer than the 20,000 to 100,000 permissible cycles and, therefore, acceptable.

Therefore, the fuel cask handling crane fatigue analysis has been projected successfully for 60 years of plant operation.

#### 4.7.2.4.2 Staff Evaluation

The staff reviewed LRA Section 4.7.2.4, to verify pursuant to 10 CFR 54.21(c)(1)(ii), that the analyses have been projected to the end of the period of extended operation.

The staff reviewed the applicant's estimate of the number of maximum-rated load cycles for 60 years of operation compared to the permissible number of design cycles. On the basis that the 60-year number of operation cycles, 8,750, is much less than the permissible number, 20,000 to 100,000, the staff concluded that this analysis remains valid for period of extended operation in accordance with 10 CFR 54.21(c)(1)(i).

The staff noted that the design analysis remains valid but does not project the analysis result to 60 years; therefore, the method should be that of 10 CFR 54(c)(1)(i) instead of (ii).

By letter dated January 17, 2008, the applicant agreed that the basis for accepting the TLAA on the fuel cask handling crane should have been dispositioned in accordance with the staff's acceptance criterion in 10 CFR 54.21(c)(1)(i), in that the existing analysis has been demonstrated to be valid for the period of extended operation. The applicant stated that an amendment of LRA Section 4.7.2.4 would be made to reflect this. The staff verified that the applicant included appropriate amendment of LRA Section 4.7.2.4 in Enclosure 2 of the letter dated January 17, 2008. The applicant appropriately reflected this in an amendment of LRA Section 4.7.2.4.

#### 4.7.2.4.3 FSAR Supplement

The applicant provided an FSAR supplement summary description of its TLAA evaluation of the fuel cask handling crane in LRA Section A.1.2.6.6. On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the applicant's actions to address the fuel cask handling crane is adequate.

By letter dated January 17, 2008, the applicant agreed that the basis for accepting the TLAA on the fuel cask handling crane should have been dispositioned in accordance with the staff's acceptance criterion in 10 CFR 54.21(c)(1)(i), in that the existing analysis has been demonstrated to be valid for the period of extended operation. The applicant stated that an amendment of FSAR supplement Section A.1.2.6.4 would be made to reflect this. The staff verified that the applicant included the appropriate amendment of FSAR supplement Section A.1.2.6.4 in Enclosure 2 of the letter dated January 17, 2008. The applicant appropriately reflected this in an LRA amendment of FSAR supplement Section A.1.2.6.4.

On the basis of its review of the FSAR supplement, the staff concludes that the summary description of the TLAA on the fuel cask handling crane, as given in LRA Section A.1.2.6.4 and amended in the applicant's letter of January 17, 2008, is adequate.

#### 4.7.2.4.4 Conclusion

On the basis of its review, as discussed above, the staff concludes that the applicant has demonstrated, pursuant to 10 CFR 54.21(c)(1)(i), that, for the fuel cask handling crane, the analyses remain valid to the end of the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate summary description of the TLAA evaluation, as required by 10 CFR 54.21(d).

#### 4.7.2.5 Fuel Handling Bridge Crane

##### 4.7.2.5.1 Summary of Technical Information in the Application

LRA Section 4.7.2.5 summarizes the evaluation of the fuel handling bridge crane for the period of extended operation. The fuel handling bridge crane (1.25-ton) is a wheel-mounted walkway spanning the width of the fuel handling building. The crane carries an electric monorail hoist on an overhead structure.

The fuel handling bridge crane purchasing specification required the maximum design stress for all load-bearing parts, design load plus structural weight, to be 1/5 of the ultimate strength of the material. Westinghouse specified neither a permissible number of cycles for the lifetime of the crane nor a service class. Material of construction for this crane conforms to American Society for Testing and Materials Specification A-36. The low maximum design stress for the carbon steel crane structure above the refueling water elevation indicates the stress is marginally below the fatigue limit for the carbon steel material, which, therefore, is acceptable for an estimated  $10^7$  cycles; therefore, the estimated acceptable number of maximum-rated load cycles for 40 or 60 years was  $10^7$  cycles.

The number of load cycles originally projected for 40 years was 18,602 based on crane usage for the original fuel load, fuel movements during 27 refueling outages, usage for fuel and fuel insert shuffles, and movement of spent fuel from other applicant facilities. The number of load cycles projected for 60 years is 27,558, assuming 40 refueling outages and projected crane use for fuel handling activities, fewer than the  $10^7$  permissible cycles and, therefore, acceptable.

Therefore, the fuel handling bridge crane fatigue analysis has been projected successfully for 60 years of plant operation.

##### 4.7.2.5.2 Staff Evaluation

The staff reviewed LRA Section 4.7.2.5, to verify pursuant to 10 CFR 54.21(c)(1)(ii), that the analyses have been projected to the end of the period of extended operation.

The staff reviewed the applicant's estimate of the number of the maximum-rated load cycles for 60 years of operation compared to the permissible number of design cycles. On the basis that the 60-year number of operation cycles, 27,558, is much less than the permissible number,  $10^7$ , the staff concluded that this analysis remains valid for period of extended operation in accordance with 10 CFR 54.21(c)(1)(i).