

United States Nuclear Regulatory Commission Official Hearing Exhibit

In the Matter of: Entergy Nuclear Operations, Inc.
(Indian Point Nuclear Generating Units 2 and 3)

	ASLBP #: 07-858-03-LR-BD01	Identified: 10/15/2012
	Docket #: 05000247 05000286	Withdrawn:
	Exhibit #: ENT000324-00-BD01	Stricken:
	Admitted: 10/15/2012	
	Rejected:	
	Other:	

ENT000324
Submitted: March 29, 2012

From: Mayer, Donald M
Sent: Wednesday, November 5, 2008 4:10 PM
To: 'jrw1@nrc.gov'
Subject: Indian Point 1

John-

I am happy to report that we have completed the draining and de-sludging of the Unit 1 fuel pools. The fuel has been safely removed from the west pool (as of 9/19/08), the fuel pools are drained (as of 10/15/08) and de-sludge operations are completed (10/31/08). As an added measure for long-term SAFSTOR maintenance the most contaminated (west pool) has had a fixative (coating) applied to minimize the potential for future airborne contamination (this was completed today). This ends an important project for IPEC which has terminated the leakage from the Unit 1 spent fuel pools thus stopping the introduction of radiological contaminants to the underlying groundwater from this source. The contamination of ground water as a result of an actively leaking pool complex at Unit 1 has been terminated.

Not insignificantly this was completed with no personnel safety or radiological issues and for dose which was ALARA and below our goal.

Don

Don Mayer
Director, Unit 1
Entergy Nuclear
Indian Point Energy Center
(w) 914 827-7716
(c) 914 582-6901