

ENT000429
 Submitted: March 30, 2012

Work Order Task Details

TN	SN	Status	Pri	Ins	Rsc	Description
01	16	FINISHED	4G	+	+	EC-25391: PERFORM GPR SURVEY AT IP2 A.B.F.P. BLDG
02	16	FINISHED	4G	+	+	EC-25391: INSTALL EC-25391, CORE BORE IN AFB FOR IP2 CST PIPING CATHOD
03	16	FINISHED	4G	+	+	EC-25391: NON-INTRUSIVE ELECT. INSTALLATION(CST CATHOD PROT)
04	16	FINISHED	4G	+	+	EC-25391: CADWELD ON IP2 CST PIPING FOR CATHODIC PROT.
05	16	FINISHED	4G	+	+	EC-25391: SCAFFOLD UP IN A.B.F.P. BLDG FOR CATHODIC PROT.
06	16	FINISHED	4G	+	+	EC-25391: IP2 CST PIPING - TEST PAINT FOR LEAD
07	16	FINISHED	4G	+	+	EC-25391: MATERIAL ONLY
08	16	FINISHED	4G	+	+	EC-25391: TRENCHING AND BACKFILL FOR ANODES
09	16	WORKING	4G	+	+	EC-25391: SCAFFOLD DOWN
10	16	FINISHED	4G	+	+	EC-25391: PRIME / PAINT IP2 CST PIPING AFTER CADWELD
11	16	FINISHED	4G	+	+	EC-25391: SECURITY SUPPORT FOR AFB BLDG CATHODIC PROTECTION
12	16	WORKING	4G	+	+	EC-25391: POST MOD TESTING FOR CST PIPING CATHODIC PROT.

SCREEN SHOT OF WORK ORDERS ASSOCIATED WITH THE INSTALLATION OF MODIFICATION TO ADD CATHODIC PROTECTION TO PROTECT INDIAN POINT 2 BURIED CST LINES TO THE AUX FEED WATER BLDG/PUMPS
 REF: EC 25391 Sheet 1 of 2

TIMM100 - WORK TASK OUTLINE - Windows Internet Explorer

https://passport.entropy.com/fa_prod/common/JF?Frame.jsp?clientTimeZoneOffset=240

Time Zone: Central Standard Time

Home | Alerts | New Session | Log Out | Help

EXECUTE OPTIONS CURRENCY CERTIFY

SHORTCUTS

NAVIGATOR TIMM100 - WORK TASK OUTLINE

OK APPLY CANCEL REFRESH SEARCH EXECUTE

Select to step thru task planning. Execute to create new task.

W/O: 00278282 W/O Type: MID Status: ACTIVE Date: 02/08/2012

Title: EC-25391: IP2 CST PIPING CATHODIC PROTECTION SYSTEM Ref Id: Outage: Capital: Reimbursable: Orig W/O: IAS Project: Model W/O Rev:

Facility: IPC Work Status: OPEN

Priority: 4G Dspln: MNTS

W/O Due: Work Group: W/O Planner: WEARM91

PM Early Date: PCTR: MODS

PM Late: Model W/O

In Srvce: Model W/O

Execute

N/R + Address - Property - Attributes + Completion + Estimate + Schedule + Act. Trk -

Work Order Task Details

TN	SN	Status	Pri	Pro	Ins	Rsc	Description
14	16	FINISHED	4G	+	+	+	(EC-25391: ANODE CONFIGURATION CHANGE PER ECN-32520
15	16	FINISHED	4G	+	+	+	(EC-25391: PERFORM UT INSPECTION OF CST LINES BEFORE CADWELD
16	16	FINISHED	4G	+	+	+	(EC-25391/ECN-33659: RECONFIGURE POWER FEED
17	17	FINISHED	4G	+	+	+	(EC-25391: ADD ADDITIONAL CONDUIT SUPPORT

Done

Local intranet

100%

2:15 AM Wednesday

Start Links Drafts

3 Microsoft... 3 Microsoft... 3 Microsoft... 4 Sybase... 2 Interne... R:\Bob Lee\... H:\My Docu... C:\Docume... 3 Adobe... CATHODIC... Document1...

SCREEN SHOT OF WORK ORDERS ASSOCIATED WITH THE INSTALLATION OF MODIFICATION TO ADD CATHODIC PROTECTION TO PROTECT INDIAN POINT 2 BURIED CST LINES TO THE AUX FEED WATER BLDG/PUMPS

REF: EC 25391 Sheet 2 of 2

TIMM1100 - WORK TASK OUTLINE - Windows Internet Explorer

https://passport.entropy.com/fa_prod/common/IFAFrame.jsp?clientTimeZoneOffset=-240

Time Zone: Central Standard Time

Home | Alerts | New Session | Log Out | Help

EXECUTE | OPTIONS | CURRENCY | SHORTCUTS | CERTIFY

Navigator: TIMM1100 - WORK TASK OUTLINE

OK | APPLY | CANCEL | REFRESH | SEARCH | EXECUTE | ESTIMATE | SCHEDULE | ACT. TRK

Select to step thru task planning. Execute to create new task.

W/O: 00286296 | W/O Type: MD | Status: ACTIVE | Date: 02/21/2012

Title: EC-27604: IP3 CST PIPING CATHODIC PROTECTION SYSTEM

Facility: IPC | Work Status: OPEN

Priority: 4G | Dspln: MNITS

W/O Due: 12/03/2011 | W/O Planner: WBARW91

PM Early Date: | PCTR: MODS

In Srvc: | Model W/O Rev: | Reimbursable: | IAS Project: | Model W/O Rev:

Execute

Address | Property | Attributes | Completion | Estimate | Schedule | Act. Trk

Work Order Task Details

TN	SN	Status	Pri	Pro	Ins	Rsc	Description
01	01	FINISHED	4G	+	+	+	EC-27604: PERFORM GPR SURVEY
02	02	FINISHED	4G	+	+	+	EC-27604: IP3 CST CATHODIC PROT EXCAVATION - OUTSIDE
03	03	FINISHED	4G	+	+	+	EC-27604: COREBORE AFWP BLDG FLOOR
04	04	FINISHED	4G	+	+	+	EC-27604: NON-INTRUSIVE ELECT. INSTALLATION(CST CATHOD PROT)
05	05	FINISHED	4G	+	+	+	EC-27604: MATERIAL ONLY FOR IP3 CST PIPING
06	06	FINISHED	4G	+	+	+	EC-27604: ERECT SCAFFOLD U3 AFW BUILDING GROUND FLOOR
07	07	FINISHED	4G	+	+	+	EC-27604: TEST PAINT FOR LEAD
08	08	PLAN	4G	+	+	+	EC-27604: REMOVE SCAFFOLD
09	09	FINISHED	4G	+	+	+	EC-27604: CADWELDS FOR IP3 CST PIPING
10	10	FINISHED	4G	+	+	+	EC-27604: PRIME AND PAINT IP3 CST PIPING CADWELDS
11	11	PLAN	4G	+	+	+	EC-27604: SECURITY SUPPORT U3 AFWPUMP BLDG CATHODIC PROTECT
12	12	WORKING	4G	+	+	+	EC-27604: POST MOD TESTING FOR CST PIPING CATHODIC PROT.

Done

Start | Links | Drafts

3 Microsoft... | 3 Microsoft... | 3 Microsoft... | 4 Sybase... | 2 Interne... | R:\Bob Lee... | H:\My Docu... | C:\Docume... | 3 Adobe... | CATHODIC... | Document1...

Local intranet | 100% | 2:21 AM | Wednesday

SCREEN SHOT OF WORK ORDERS ASSOCIATED WITH THE INSTALLATION OF MODIFICATION TO ADD CATHODIC PROTECTION TO PROTECT INDIAN POINT 3 BURIED CST LINES TO THE AUX FEED WATER BLDG/PUMPS

REF: EC 27604 Sheet 1 of 2

TIMM1100 - WORK TASK OUTLINE - Windows Internet Explorer

https://passport.entropy.com/fa_prod/common/JFiframe.jsp?clientTimeZoneOffset=240

Time Zone: Central Standard Time

Home | Alerts | New Session | Log Out | Help

EXECUTE OPTIONS CURRENCY SHORTCUTS CERTIFY

NAVIGATOR TIMM1100 - WRK TASK OUTLINE

OK APPLY CANCEL REFRESH SEARCH EXECUTE

Select to step thru task planning. Execute to create new task.

SCOPE CHANGE IN PROGRESS

W/O: 00286296

Title: EC-27604: IP3 CST PIPING CATHODIC PROTECTION SYSTEM

Facility: IPC

Priority: 4G

W/O Due: 12/03/2011

PM Early Date:

PM Late:

In Srvce:

W/O Type: MID

Work Status: OPEN

Dspln: MNTS

Work Group: WEARM91

W/O Planner: MODS

PCTR:

Model W/O:

Status: ACTIVE

Ref Id:

Outage:

Capital:

Reimbursable:

Orig W/O:

IAS Project:

Model W/O Rev:

Execute

Address - Property - Attributes - Completion - Estimate - Schedule - Act. Trk

Work Order Task Details

TN	SN	Status	Pri	Pro	Ins	Rsc	Description
14	14	PLAN	4G	+	-	+	(EC-27604: ASPHALT WHERE REMOVED FOR EXCAVATION
15	15	CANCELED	4G	+	+	+	(EC-27604: TERMINATE POWER CABLE FOR CST CATHODIC PROT SYS
16	16	FINISHED	4G	+	+	+	(EC-27604: PERFORM UT INSPECTION OF CST LINES BEFORE CADWELD
17	17	FINISHED	4G	+	+	+	(EC-27604/ECN-33661: TERMINATE POWER FEED
18	18	FINISHED	4G	+	+	+	(EC-27604/ECN-33661: RECONFIGURE FOR NEW POWER FEED
19	19	FINISHED	4G	+	+	+	(EC-27604/ECN-34834: RECONFIGURE SUPPORT PER ECN

Local intranet

100% 2:23 AM Wednesday

Links Drafts

3 Microsoft... 3 Microsoft... 3 Microsoft... 4 Sybase... 2 Interne... R:\Bob Lee... H:\My Docu... C:\Docume... 3 Adobe... CATHODIC... Document1...

SCREEN SHOT OF WORK ORDERS ASSOCIATED WITH THE INSTALLATION OF MODIFICATION TO ADD CATHODIC PROTECTION TO PROTECT INDIAN POINT 3 BURIED CST LINES TO THE AUX FEED WATER BLDG/PUMPS

REF: EC 27604 Sheet 2 of 2