

**FINAL**

**Southern Nuclear  
E. I. Hatch Nuclear Plant**

**Operations Training  
JPM**

**ADMIN 1 – SRO ONLY**

| <b>TITLE</b>                      |                     |             |
|-----------------------------------|---------------------|-------------|
| <b>VERIFY FUEL MOVEMENT SHEET</b> |                     |             |
| <b>AUTHOR</b>                     | <b>MEDIA NUMBER</b> | <b>TIME</b> |
| Anthony Ball                      | 2012-301 ADMIN-1    | 30 Minutes  |
| <b>RECOMMENDED BY</b>             | <b>APPROVED BY</b>  | <b>DATE</b> |
| N/R                               | C. M. EDMUND        | 06/07/2012  |



|   |             |
|---|-------------|
| <b>SOUTHERN NUCLEAR OPERATING COMPANY</b><br><b>PLANT E. I. HATCH</b> | Page 1 of 1 |
| <b>FORM TITLE: TRAINING MATERIAL REVISION SHEET</b>                   |             |

|   |  |             |
|---|--|-------------|
| <b>SOUTHERN NUCLEAR OPERATING COMPANY</b><br><b>PLANT E. I. HATCH</b> |  | Page 1 of 1 |
| <b>FORM TITLE: TRAINING MATERIAL REVISION SHEET</b>                   |  |             |

|   |             |
|---|-------------|
| <b>SOUTHERN NUCLEAR OPERATING COMPANY</b><br><b>PLANT E. I. HATCH</b> | Page 1 of 1 |
| <b>FORM TITLE: TRAINING MATERIAL REVISION SHEET</b>                   |             |

---

Program/Course Code: **OPERATIONS TRAINING** Media Number: **2012-301 ADMIN-1**

---

Program/Course Code: **OPERATIONS TRAINING** Media Number: **2012-301 ADMIN-1**

[illegible]

UNIT 1 (X) UNIT 2 (X)

**TASK TITLE:** VERIFY FUEL MOVEMENT SHEET**JPM NUMBER:** 2012-301 ADMIN-1**TASK STANDARD:** The task will be complete when the operator has identified all in-core placement errors of all components listed on Page 1 of the attached Fuel Movement Sheet.**TASK NUMBER:** 045.033**OBJECTIVE NUMBER:** 045.033.O**PLANT HATCH JTA IMPORTANCE RATING:****RO** Not Available**SRO** Not Available**K/A CATALOG NUMBER:** G2.1.35**K/A CATALOG JTA IMPORTANCE RATING:****RO** 2.2**SRO** 3.9**OPERATOR APPLICABILITY:** Senior Reactor Operator

|                            |  |
|----------------------------|--|
| <b>GENERAL REFERENCES:</b> | <b>Refuel Floor</b>  |
|                            | 34FH-OPS-001-0 (current version)<br>42FH-ERP-014-0 (current version)                         |
| <b>REQUIRED MATERIALS:</b> | <b>Refuel Floor</b>  |
|                            | Fuel Movement Sheets<br>34FH-OPS-001-0 (current version)<br>42FH-ERP-014-0 (current version) |

**APPROXIMATE COMPLETION TIME:** 30 Minutes**SIMULATOR SETUP:** N/A

# **EVALUATOR COPY**

## **UNIT 2**

### **READ TO THE OPERATOR**

#### **INITIAL CONDITIONS:**

1. Unit 2 is in a refueling outage.
2. You are the oncoming Refuel Floor SRO.
3. The off-going Refuel Floor SRO asks you to verify Page 1 of the attached Fuel Movement Sheet.
4. The fuel movement sheet, Core Map and pictures of the core cells are available.

#### **INITIATING CUES:**

Verify the in-core placement of all components listed on Page 1 of the attached Fuel Movement Sheet.

| STEP # | PERFORMANCE STEP | STANDARD | SAT/UNSAT (COMMENTS) |
|--------|------------------|----------|----------------------|
|--------|------------------|----------|----------------------|

For **INITIAL** Operator Programs:

**For OJT/OJE**; ALL PROCEDURE STEPS must be completed for Satisfactory Performance.

**For License Examinations**; ALL CRITICAL STEPS must be completed for Satisfactory Performance.

|             | IF  | THEN   |
|-------------|---|--|
| <b>PASS</b> | <input type="checkbox"/> Human performance tools, safety, PPE met (1), <b>AND</b><br><input type="checkbox"/> For initial trg <b>all</b> steps completed correctly OR<br><input type="checkbox"/> For continuing trg, <b>critical</b> steps (if used) completed correctly | <input type="checkbox"/> Mark the JPM as a <b>PASS</b> |
| <b>FAIL</b> | <input type="checkbox"/> Above standards not met  | <input type="checkbox"/> Mark the JPM as a <b>FAIL</b> |

(1) The standard for human performance tools, safety, PPE, and other pertinent expectations is considered met provided any deviations are minor and have little or no actual or potential consequence. Errors may be self-corrected provided the action would not have resulted in significant actual or potential consequences. Reference: NMP-TR-111, "On-The-Job Training and Task Performance Evaluation".

**START TIME:** \_\_\_\_\_

PROMPT: Hand the operator the fuel movement sheet, Core Map and pictures of the core cells.

PROMPT: **IF** the operator has problems reading the bundle serial numbers, **THEN** provide the serial numbers to the operator.

PROMPT: **IF** the operator asks about Spent Fuel Pool verification, **THEN** tell the operator he is only responsible for in-core verifications.

|    |                                 |  |  |
|----|---------------------------------|--|--|
| 1. | Obtains the correct procedures. | Obtains and reviews 42FH-ERP-014-0, "Fuel Movement" and 34FH-OPS-001-0, "Fuel Movement Operation." |  |
|----|---------------------------------|--|--|

(\*\* Indicates critical step)

| STEP # | PERFORMANCE STEP                                   | STANDARD   | SAT/UNSAT (COMMENTS) |
|--------|--|--|----------------------|
| 2.     | Verify correct loading of Control Cell 38-37.      | Operator determines Control Cell 38-37 bundles are the correct bundles and in the correct orientation:   |                      |
|        |  | • JLV675   |                      |
|        |  | • JLV682   |                      |
|        |  | • JLK804   |                      |
|        |  | • JLK817   |                      |
| **3.   | Determine INCORRECT loading of Control Cell 14-37. | Operator determines Control Cell 14-37 bundles are the correct bundles but in the INCORRECT orientation: |                      |
|        |  | • JLV678   |                      |
|        |  | • JLV670   |                      |

**NOTE:** Bundles JLV678 and JLV670 are 180° out.

|      |  |  |  |
|------|--|--|--|
| 4.   | Verify correct loading of Control Cell 14-37.      | Operator determines Control Cell 14-37 bundles are the correct bundles and in the correct orientation: |  |
|      |  | • JLK805   |  |
|      |  | • JLK812   |  |
| **5. | Determine INCORRECT loading of Control Cell 38-17. | Operator determines Control Cell 38-17 bundle is the INCORRECT bundle but in the correct orientation:  |  |
|      |  | • JLV668   |  |

**NOTE:** Wrong bundle loaded. The correct bundle is JLV698

(\*\* Indicates critical step)

| STEP # | PERFORMANCE STEP                                   | STANDARD   | SAT/UNSAT (COMMENTS) |
|--------|--|--|----------------------|
| 6.     | Verify correct loading of Control Cell 38-17.      | Operator determines Control Cell 14-37 bundles are the correct bundles and in the correct orientation: |                      |
|        |  | • JLV674   |                      |
|        |  | • JLK807   |                      |
|        |  | • JLK820   |                      |
| **7.   | Determine INCORRECT loading of Control Cell 14-17. | Operator determines Control Cell 14-17 Double Blade Guide is in the INCORRECT orientation.             |                      |

END  
TIME: \_\_\_\_\_

**NOTE:** The terminating cue shall be given to the Operator when:

- After JPM step #7 is complete.
- With no reasonable progress, the Operator exceeds double the allotted time.
- Operator states the task is complete.

**TERMINATING CUE:** We will stop here.

**EVALUATOR – PICK UP** the Initiating Cue sheet.

(\*\* Indicates critical step)

## **UNIT 2**

### **READ TO THE OPERATOR**

#### **INITIAL CONDITIONS:**

1. Unit 2 is in a refueling outage.
2. You are the oncoming Refuel Floor SRO.
3. The off-going Refuel Floor SRO asks you to verify Page 1 of the attached Fuel Movement Sheet.
4. The fuel movement sheet, Core Map and pictures of the core cells are available.

#### **INITIATING CUES:**

Verify the in-core placement of all components listed on Page 1 of the attached Fuel Movement Sheet.



SNC PLANT E. I. HATCH

Pg 46 of 59

DOCUMENT TITLE:

DOCUMENT NUMBER:

Version No:

FUEL MOVEMENT OPERATION

34FH-OPS-001-0

24.0

ATTACHMENT 7

TITLE: UNIT 2 CORE MAP

Att. Pg.


1 of 1

NORTH  
←

## HATCH UNIT 2

**Northeast  
Quadrant**

**Southeast  
Quadrant**



**Northwest  
Quadrant**

□ — IRM


○ — SRM

CENTER IS AT (24,29)

**Southwest  
Quadrant**

EAST

N  
O  
R  
T  
H




S  
O  
U  
T  
H

WEST

CONTROL CELL 38-37

EAST




N  
O  
R  
T  
H

S  
O  
U  
T  
H

WEST

CONTROL CELL 14-37

EAST



S  
O  
U  
T  
H


WEST

CONTROL CELL 38-17

EAST

SOUTH

NORTH



WEST

CONTROL CELL 14-17

FORM TITLE:  
FUEL MOVEMENT SHEETSTYPE OF FUEL MOVEMENT:  
(check the type of fuel sheets)Core Off-Load: \_\_\_\_\_  
Core Reload: X  
Shuffle: \_\_\_\_\_  
General Moves: \_\_\_\_\_  
Special Activity: \_\_\_\_\_Partial Offload: \_\_\_\_\_  
Upfront Shuffle: \_\_\_\_\_  
Backend Shuffle: \_\_\_\_\_  
Other (Specify): \_\_\_\_\_Brief description of moves: Control Cells 38-37, 14-37 and 38-37 to be loaded with fuel and blade guides removed. Control Cell 14-17 to have blade guide installed for insertion of control rod.

Verify the following for all core reload move sheets:

The first 4 steps in the movement sequence will place bundles around the SRM which will first be in the fueled region.

|     |   |      |
|-----|---|------|
| N/A | / | Date |
| N/A | / | Date |

Verify the following for all core shuffle move sheets:

At least 2 irradiated fuel assemblies will remain around each SRM unless approved by the Reactor Engineering Supervisor or designated alternate.

|                       |   |                 |      |
|-----------------------|---|-----------------|------|
| <u>Samuel Johnson</u> | / | <u>06/18/12</u> | Date |
| <u>* Michael Best</u> | / | <u>06/18/12</u> | Date |

|                 |                                |                   |      |
|-----------------|--------------------------------|-------------------|------|
| Prepared by:    | <u>Ben Williams</u>            | <u>1 06/18/12</u> | Date |
|                 | Reactor Engineering            |                   | Date |
| Verified by:    | <u>Mike Watson</u>             | <u>1 06/18/12</u> | Date |
|                 | Reactor Engineering            |                   | Date |
| * Verified by:  | <u>Kenneth Fairson</u>         | <u>1 06/18/12</u> | Date |
|                 | Reactor Engineering            |                   | Date |
| ** Approved by: | <u>William Jefferson</u>       | <u>1 06/18/12</u> | Date |
|                 | Reactor Engineering Supervisor |                   | Date |

\* Additional verification IF required by the Reactor Engineering Supervisor for certain evolutions or marked N/A, initialed and dated by the RE Supervisor.

\*\* The "Approved" space on the actual sheets is to be signed by the Reactor Engineering Supervisor or designated alternate.

|  |                          |                   |      |
|--|--------------------------|-------------------|------|
| Spent Fuel Pool Inventory Database Updated By: | <u>Kenneth Fairson</u>   | <u>1 06/18/12</u> | Date |
| Verified By:                                   | <u>William Jefferson</u> | <u>1 06/18/12</u> | Date |

|                                       |   |   |                                      |                 |
|---------------------------------------|---|---|--------------------------------------|-----------------|
| SOUTHERN NUCLEAR<br>PLANT E. I. HATCH | Unit <u>2</u>   |   | Page 1 of 1                          |                 |
| FORM TITLE:<br>FUEL MOVEMENT SHEETS   | <input checked="" type="checkbox"/> Performs these<br>moves in sequence | <input type="checkbox"/> These may be<br>performed non-sequentially | Approved<br><i>William Jefferson</i> | Date<br>6/18/12 |

| Step<br># | Move From:    |      |     |      |               | Comments: | Move To:      |      |     |      | Double Verif. |          |
|-----------|---------------|------|-----|------|---------------|-----------|---------------|------|-----|------|---------------|----------|
|           | Location      | Init | OR  | Init | Serial Number |           | Location      | Init | OR  | Init | Init          | Date     |
| 1         | 23K11         | JH   | SW  | JH   | JLV675        |           | 37-36         | JH   | SE  | JH   | AC            | 06/18/12 |
| 2         | 23K10         | JH   | SW  | JH   | JLV682        |           | 39-38         | JH   | NW  | JH   | AC            | 06/18/12 |
| 3         | 37-38 / 39-36 | JH   | N/A | JH   | DBL B/G       |           | 17F11 / 17G10 | JH   | N/A | JH   | AC            | 06/18/12 |
| 4         | 23H12         | JH   | SW  | JH   | JLK804        |           | 37-38         | JH   | SW  | JH   | AC            | 06/18/12 |
| 5         | 23H11         | JH   | SW  | JH   | JLK817        |           | 39-36         | JH   | NE  | JH   | AC            | 06/18/12 |
| 6         | 23H10         | JH   | SW  | JH   | JLV678        |           | 13-36         | JH   | SE  | JH   | AC            | 06/18/12 |
| 7         | 23H09         | JH   | SW  | JH   | JLV670        |           | 15-38         | JH   | NW  | JH   | AC            | 06/18/12 |
| 8         | 13-38 / 15-36 | JH   | N/A | JH   | DBL B/G       |           | 17F10 / 17G09 | JH   | N/A | JH   | AC            | 06/18/12 |
| 9         | 23K09         | JH   | SW  | JH   | JLK805        |           | 13-38         | JH   | SW  | JH   | AC            | 06/18/12 |
| 10        | 23K08         | JH   | SW  | JH   | JLK812        |           | 15-36         | JH   | NE  | JH   | AC            | 06/18/12 |
| 11        | 23G11         | JH   | SW  | JH   | JLV698        |           | 37-16         | JH   | SE  | JH   | AC            | 06/18/12 |
| 12        | 23G10         | JH   | SW  | JH   | JLV674        |           | 39-18         | JH   | NW  | JH   | AC            | 06/18/12 |
| 13        | 37-18 / 39-16 | JH   | N/A | JH   | DBL B/G       |           | 17F09 / 17G08 | JH   | N/A | JH   | AC            | 06/18/12 |
| 14        | 23F10         | JH   | SW  | JH   | JLK807        |           | 37-18         | JH   | SW  | JH   | AC            | 06/18/12 |
| 15        | 23F09         | JH   | SW  | JH   | JLK820        |           | 39-16         | JH   | NE  | JH   | AC            | 06/18/12 |
| 16        | 17J13 / 17J12 | JH   | N/A | JH   | DBL B/G       |           | 13-18 / 15-16 | JH   | N/A | JH   | AC            | 06/18/12 |

| Print | Init | Date |
|-------|------|------|
|-------|------|------|



**FINAL**

**Southern Nuclear  
E. I. Hatch Nuclear Plant**

**Operations Training  
JPM**

**ADMIN 2 - ALL**

| TITLE  |                  |              |
|--|------------------|--------------|
| CORRECT RWL INDICATORS FOR HIGH DRYWELL TEMPERATURES |                  |              |
| AUTHOR   | MEDIA NUMBER     | TIME         |
| ANTHONY BALL   | 2012-301 ADMIN-2 | 11.0 Minutes |
| RECOMMENDED BY                                       | APPROVED BY      | DATE         |
| N/R  | C. M. EDMUND     | 06/07/2012   |



|   |             |
|---|-------------|
| <b>SOUTHERN NUCLEAR OPERATING COMPANY</b>           |             |
| <b>PLANT E. I. HATCH</b>                            | Page 1 of 1 |
| <b>FORM TITLE: TRAINING MATERIAL REVISION SHEET</b> |             |

|   |             |
|---|-------------|
| <b>SOUTHERN NUCLEAR OPERATING COMPANY</b>           |             |
| <b>PLANT E. I. HATCH</b>                            | Page 1 of 1 |
| <b>FORM TITLE: TRAINING MATERIAL REVISION SHEET</b> |             |

|   |             |
|---|-------------|
| <b>SOUTHERN NUCLEAR OPERATING COMPANY</b>           |             |
| <b>PLANT E. I. HATCH</b>                            | Page 1 of 1 |
| <b>FORM TITLE: TRAINING MATERIAL REVISION SHEET</b> |             |

---

Program/Course Code: **OPERATIONS TRAINING**      Media Number: **2012-301 ADMIN-2**

[illegible]

UNIT 1 (X) UNIT 2 (X)

**TASK TITLE:** CORRECT RWL INDICATORS FOR HIGH DRYWELL TEMPERATURES

**JPM NUMBER:** 2012-301 ADMIN-2

**TASK STANDARD:** The task shall be completed when the operator has determined the corrected RWL for the specified instrumentation per 34AB-B21-002.

**TASK NUMBER:** 201.099

**OBJECTIVE NUMBER:** 201.099.B

**PLANT HATCH JTA IMPORTANCE RATING:**

RO 4.57

SRO 3.83

STA 4.00

**K/A CATALOG NUMBER:** G2.1.35

**K/A CATALOG JTA IMPORTANCE RATING:**

RO 3.90

SRO 4.20

**OPERATOR APPLICABILITY:** Nuclear Plant Operator (NPO)  
Shift Technical Advisor (STA)

| GENERAL REFERENCES: | Unit 1                              | Unit 2                              |
|---------------------|-------------------------------------|-------------------------------------|
|                     | 34AB-B21-002-1<br>(current version) | 34AB-B21-002-2<br>(current version) |

| REQUIRED MATERIALS: | Unit 1                              | Unit 2                              |
|---------------------|-------------------------------------|-------------------------------------|
|                     | 34AB-B21-002-1<br>(current version) | 34AB-B21-002-2<br>(current version) |

**APPROXIMATE COMPLETION TIME:** 11.0 Minutes

**SIMULATOR SETUP:** N/A

# **EVALUATOR COPY**

## **UNIT 1**

### **READ TO THE OPERATOR**

#### **INITIAL CONDITIONS:**

1. The Reactor has scrammed and the board operator has reported the following **UNCOMPENSATED** Reactor Water Levels:

1B21-R604A and 1B21-R623A (Wide Range) is -132 inches.

1B21-R604B and 1B21-R623B (Wide Range) is -134 inches.

1B21-R623A (Fuel Zone) is -170 inches

2. NO erratic behavior for the specified instruments has been observed.

#### **INITIATING CUES:**

Determine which of these RWL indications are valid

and

report the corrected RWL for EACH valid RWL instrument.

| STEP # | PERFORMANCE STEP | STANDARD | SAT/UNSAT (COMMENTS) |
|--------|------------------|----------|----------------------|
|--------|------------------|----------|----------------------|

For **INITIAL** Operator Programs:

**For OJT/OJE**; ALL PROCEDURE STEPS must be completed for Satisfactory Performance.

**For License Examinations**; ALL CRITICAL STEPS must be completed for Satisfactory Performance.

|             | IF  | THEN   |
|-------------|---|--|
| <b>PASS</b> | <input type="checkbox"/> Human performance tools, safety, PPE met (1), <b>AND</b><br><input type="checkbox"/> For initial trg <b>all</b> steps completed correctly OR<br><input type="checkbox"/> For continuing trg, <b>critical</b> steps (if used) completed correctly | <input type="checkbox"/> Mark the JPM as a <b>PASS</b> |
| <b>FAIL</b> | <input type="checkbox"/> Above standards not met  | <input type="checkbox"/> Mark the JPM as a <b>FAIL</b> |

(1) The standard for human performance tools, safety, PPE, and other pertinent expectations is considered met provided any deviations are minor and have little or no actual or potential consequence. Errors may be self-corrected provided the action would not have resulted in significant actual or potential consequences. Reference: NMP-TR-111, "On-The-Job Training and Task Performance Evaluation".

**START TIME:** \_\_\_\_\_

|    |   |  |  |
|----|---|--|--|
| 1. | Operator identifies the procedure needed to perform the task. | Operator has identified the correct procedure as 34AB-B21-002-1. |  |
|----|---|--|--|

**NOTE:** If the operator (STA) indicates that SPDS would be checked, give the operator Supplement 1.

**PROMPT:** IF the operator addresses Drywell temperature indications, **INDICATE** for the operator that temperature is greater than 150°F (Use Supplement 1 if SPDS is addressed).

|    |   |  |  |
|----|---|--|--|
| 2. | Determine if RWL corrections are required.                        | Using SPDS (or Drywell temp indications) the operator <b>DETERMINES:</b><br><br>Drywell temperature is greater than 150°F.<br><br>RWL corrections <b>ARE</b> required. |  |
| 3. | Review Caution 1 and Caution 2 on Attachment 1 of 34AB-B21-002-1. | The operator has <b>REVIEWED</b> Caution 1 and Caution 2 on Attachment 1 of 34AB-B21-002-1.  |  |

(\*\* Indicates critical step)

| STEP # | PERFORMANCE STEP   | STANDARD  | SAT/UNSAT (COMMENTS) |
|--------|--|---|----------------------|
| 4.     | Confirm there is no indication of erratic instrument behavior. | <p>The operator has VERIFIED, by observation or by addressing the panel operator, that the following RWL instruments show NO erratic instrument behavior:</p> <p>1B21-R604A</p> <p>1B21-R604B</p> <p>1B21-R623A (Wide Range)</p> <p>1B21-R623B (Wide Range)</p> <p>1B21-R623A (Fuel Zone)</p> |                      |

PROMPT: **WHEN** the operator indicates use of the Diagnostic screen of SPDS, **GIVE** the operator Supplement 2.

|    |  |   |  |
|----|--|---|--|
| 5. | Determine highest temperature for RTD Group 1 and 2 (Maximum Run Temperature). | <p>At SPDS panel, the operator has DETERMINED the following Maximum Run Temperatures:</p> <p>RTD Group 1 - 260°F</p> <p>RTD Group 2 - 257°F</p> |  |
|----|--|---|--|

PROMPT: **IF** the operator addresses temperature indications on Panels P654 and P657; indications can be **SIMULATED** using the values from Supplement 2.

|      |  |  |  |
|------|--|--|--|
| **6. | Determine if the RWL instrument may be used by comparing the Minimum Indicated Level for the associated Maximum Run Temperature. | <p>The operator has DETERMINED the following RWL instruments are <b>VALID</b>:</p> <p>1B21-R623A (Fuel Zone)</p>   |  |
| 7.   | Determine if the RWL instrument may be used by comparing the Minimum Indicated Level for the associated Maximum Run Temperature. | <p>The operator has DETERMINED the following RWL instruments are <b>INVALID</b>:</p> <p>1B21-R604A</p> <p>1B21-R604B</p> <p>1B21-R623A (Wide Range)</p> <p>1B21-R623B (Wide Range)</p> |  |

(\*\* Indicates critical step)

| STEP<br>#   | PERFORMANCE STEP                                  | STANDARD  | SAT/UNSAT<br>(COMMENTS) |
|-------------|---|---|-------------------------|
| <b>**8.</b> | Determine corrected Fuel Zone Level (1B21-R623A). | Using Attachment 3 of 34AB-B21-002-1, the operator has DETERMINED <b>Corrected Level</b> for 1B21-R623A (fuel zone) is -137 inches (accept $\pm 1$ inch). |                         |

END  
TIME: \_\_\_\_\_

**NOTE:** The terminating cue shall be given to the Operator when:

- After JPM step #8 is complete.
- With no reasonable progress, the Operator exceeds double the allotted time.
- Operator states the task is complete.

**TERMINATING CUE:** We will stop here.

**EVALUATOR – PICK UP** the Initiating Cue sheet.

(\*\* Indicates critical step)

## UNIT 1

### READ TO THE OPERATOR

#### INITIAL CONDITIONS:

1. The Reactor has scrammed and the board operator has reported the following **UNCOMPENSATED** Reactor Water Levels:

1B21-R604A and 1B21-R623A (Wide Range) is -132 inches.

1B21-R604B and 1B21-R623B (Wide Range) is -134 inches.

1B21-R623A (Fuel Zone) is -170 inches

2. NO erratic behavior for the specified instruments has been observed.

#### INITIATING CUES:




Determine which of these RWL indications are valid

and

report the corrected RWL for EACH valid RWL instrument.



MODE: RUN



VENT  
HNP 1   $\mu\text{Ci/cc}$   
HNP 2   $\mu\text{Ci/cc}$   
STACK   $\mu\text{Ci/cc}$

ISOLATION  
PRIMARY

1 ALL  
2 ALL  
3  
4  
5 ALL

|     |   |    |    |
|-----|---|----|----|
| 1   | 3 | 2A | 2B |
| 4   | 5 | 2C | 2D |
|     |   | 2E |    |
|     |   |    |    |
| SEC |   |    |    |


SECONDARY

HNP 1   
HNP 2

SUPPLEMENT 1

# DRYWELL TEMPERATURE DIAGNOSTIC

VOLUMETRIC  
AVG. TEMP **220** DEG. F



SUPPLEMENT 2

**FINAL**

**Southern Nuclear  
E. I. Hatch Nuclear Plant**

**Operations Training  
JPM**

**ADMIN 3 - RO ONLY**

| <b>TITLE</b>  |                     |             |
|---|---------------------|-------------|
| <b>Determine if plant conditions allow a "Quick Restart" of a Recirculation Pump.</b> |                     |             |
| <b>AUTHOR</b>   | <b>MEDIA NUMBER</b> | <b>TIME</b> |
| Anthony Ball  | 2012-301 ADMIN-3    | 15 Minutes  |
| <b>RECOMMENDED BY</b>   | <b>APPROVED BY</b>  | <b>DATE</b> |
| NR  | C. M. EDMUND        | 06/07/2012  |



**FORM TITLE: TRAINING MATERIAL REVISION SHEET**

Page 1 of 1

---

Program/Course Code: **OPERATIONS TRAINING** Media Number: **2012-301 ADMIN-3**

[illegible]

UNIT 1 (X) UNIT 2 ( )

**TASK TITLE:** Determine if plant conditions allow a "Quick Restart" of a Recirculation Pump.

**JPM NUMBER:** 2012-301 ADMIN-3

**TASK STANDARD:** The task shall be complete when it has been determined that the requirements of 34SO-B31-001-1, "Reactor Recirculation System" have been met to start a Reactor Recirculation pump.

**TASK NUMBER:** 004.002

**OBJECTIVE NUMBER:** 004.002.A

**K/A CATALOG NUMBER:** Generic 2.1.20/Generic 2.1.32

**K/A CATALOG JTA IMPORTANCE RATING:**

**RO** 4.3/3.4

**SRO** 4.2/3.8

**OPERATOR APPLICABILITY:** Nuclear Plant Operator (NPO)/Senior Reactor Operator (SRO)

|                            |                                  |
|----------------------------|----------------------------------|
| <b>GENERAL REFERENCES:</b> | <b>Unit 1</b>                    |
|                            | 34SO-B31-001-1 (Current Version) |
| <b>REQUIRED MATERIALS:</b> | <b>Unit 1</b>                    |
|                            | 34SO-B31-001-1 (Current Version) |

**APPROXIMATE COMPLETION TIME:** 15 Minutes

**SIMULATOR SETUP:** N/A, Used for NRC Admin JPM (classroom setting)

## **EVALUATOR COPY**

### **UNIT 1**

#### **READ TO THE OPERATOR**

##### **INITIAL CONDITIONS:**

1. 10 minutes ago, the Unit 1 reactor scrammed from 100% power.
2. Both Reactor Recirculation pumps tripped during the scram transient.
3. Reactor water level went as low as -10 inches and has been restored to +37 inches using Reactor Feedwater Pumps.
4. HPCI and RCIC were not required during the transient and have remained in standby.
5. RWCU is in service.
6. The Shift Supervisor has given direction to perform a Quick Restart of the "1B" Reactor Recirculation pump to prevent thermal stratification.
7. An operator has entered 34SO-B31-001-1, "Reactor Recirculation System" and completed steps 7.1.4.2.1 through 7.1.4.2.5 ("Recirc Pump B Quick Re-start").
8. Data collection began 4 minutes ago and the operator has completed gathering plant data for use with step 7.1.4.2.6 of 34SO-B31-001-1.

##### **INITIATING CUES:**

Determine if plant conditions meet the procedural requirements for "Quick" starting the "1B" Reactor Recirculation pump per step 7.1.4.2.6 of 34SO-B31-001-1, "Reactor Recirculation System".

| STEP<br># | PERFORMANCE STEP | STANDARD | SAT/UNSAT<br>(COMMENTS) |
|-----------|------------------|----------|-------------------------|
|-----------|------------------|----------|-------------------------|

For **INITIAL** Operator Programs:

**For OJT/OJE**; ALL PROCEDURE STEPS must be completed for Satisfactory Performance.

**For License Examinations**; ALL CRITICAL STEPS must be completed for Satisfactory Performance.

|             | IF  | THEN   |
|-------------|---|--|
| <b>PASS</b> | <input type="checkbox"/> Human performance tools, safety, PPE met (1), <b>AND</b><br><input type="checkbox"/> For initial trg <b>all</b> steps completed correctly OR<br><input type="checkbox"/> For continuing trg, <b>critical</b> steps (if used) completed correctly | <input type="checkbox"/> Mark the JPM as a <b>PASS</b> |
| <b>FAIL</b> | <input type="checkbox"/> Above standards not met  | <input type="checkbox"/> Mark the JPM as a <b>FAIL</b> |

(1) The standard for human performance tools, safety, PPE, and other pertinent expectations is considered met provided any deviations are minor and have little or no actual or potential consequence. Errors may be self-corrected provided the action would not have resulted in significant actual or potential consequences. Reference: NMP-TR-111, "On-The-Job Training and Task Performance Evaluation".

**START  
TIME:** \_\_\_\_\_

**NOTE: 34SO-B31-001-1, Attachment 6** serves as an answer key for this JPM. It is NOT to be provided to the student.

**NOTE:** At this time, provide the operator with **Attachment 1** (Plant Data page) and a copy of 34SO-B31-001-1.

**PROMPT:** **IF** addressed by the operator, **INFORM** the operator that the ASD is NOT in local control.

|             |  |   |  |
|-------------|--|---|--|
| 1.          | Operator refers to step 7.1.4.2.6 and is directed to Attachment 6 of 34SO-B31-001-1. | Step 7.1.4.2.6  |  |
| 2.          | Operator selects "B" Recirc Pump.  | Places a check mark next to "B" Recirc. Att. 6 Step 1.0 |  |
| 3.          | The operator enters the current time.  | Records current time. Att. 6 Step 2.0                   |  |
| <b>**4.</b> | The operator determines RPV saturation temperature.                                  | Tsat = 521° F (±2° F)<br>Att. 6 Step 2.0 (A)            |  |

(\*\* Indicates critical step)

| STEP # | PERFORMANCE STEP | STANDARD | SAT/UNSAT (COMMENTS) |
|--------|------------------|----------|----------------------|
|--------|------------------|----------|----------------------|

**NOTE:** Data is NOT required to be filled in for the "1A" Recirc Pump in the following step.

|             |  |  |  |
|-------------|--|--|--|
| 5.          | The Operator enters suction temperature for Recirculation Pumps.                               | Recirc "1A": 470° F<br>Recirc "1B": 475° F<br>(Att. 6 Step 2.0 (A) & (B))  |  |
| 6.          | The operator enters the bottom head temperature.   | Bottom head temperature: 365° F<br>(Att. 6 Step 2.0 (D))   |  |
| 7.          | The operator calculates the $\Delta t$ between the "1B" loop and the RPV.                      | $\Delta t = (521^\circ \text{ F} - 475^\circ \text{ F}) = 46^\circ \text{ F}$<br>( $\pm 2^\circ \text{ F}$ ) (Att. 6 Step 1.2.1) |  |
| <b>**8.</b> | The operator determines the $\Delta t$ between the "1B" loop and the RPV <b>IS</b> acceptable. | $\Delta t$ of 46° F ( $\pm 2^\circ \text{ F}$ ) is < 50° F<br>(Att. 6 Step 3.1)  |  |

**NOTE:** The student should NOT use step 4.2 to perform the following confirmation of plant conditions due to the NOTE that precedes step 4.0 (RWCU is in service). If the operator does refer to step 4.2, the check will NOT be acceptable due to Feedwater temperature < 300° F.

|              |  |   |  |
|--------------|--|---|--|
| <b>**9.</b>  | The operator calculates the $\Delta t$ between bottom head and steam dome.                           | $\Delta t = (521^\circ \text{ F} - 379^\circ \text{ F}) = 142^\circ \text{ F}$<br>( $\pm 2^\circ \text{ F}$ ) (Att. 6 Step 4.1) |  |
| <b>**10.</b> | The operator determines that the $\Delta t$ between bottom head and steam dome <b>IS</b> acceptable. | $\Delta t$ of 142° F ( $\pm 2^\circ \text{ F}$ ) is < 145° F<br>(Att. 6 Step 4.1)   |  |
| 11.          | The operator reports to the Shift Supervisor.  | Plant conditions <b>ARE</b> acceptable for starting the "1B" Reactor Recirculation pump.  |  |

**NOTE:** Step 4.2 is **NOT** required to be performed (it is an alternate method). If the student chooses to perform step 4.2, the conditions will **NOT** allow the start of the Recirc Pump (FW temp < 300 F). The following information is expected to be determined by the student (see **Attachment** for details):

- (a) is met (>40% of rated flow prior to the RPT).
- (b) is met (HPCI and RCIC have not injected since the RPT)
- (c) is NOT met (FW temp is not >300 F since the RPT) is met (<30 minutes since trip) and start time (calculated time to start is required to be 30 minutes from the RPT time)

(\*\* Indicates critical step)



| STEP<br># | PERFORMANCE STEP | STANDARD | SAT/UNSAT<br>(COMMENTS) |
|-----------|------------------|----------|-------------------------|
|-----------|------------------|----------|-------------------------|

PROMPT: IF addressed by the operator, as the STA, **INFORM** the operator that power/flow map conditions are acceptable for starting the Recirc Pump.

PROMPT: IF addressed by the operator, as the Shift Supervisor, **INFORM** the operator that another operator will verify his calculations.

END  
TIME: \_\_\_\_\_

**NOTE:** The terminating cue shall be given to the operator when:

- After JPM step #11 is complete.
- With no reasonable progress, the operator exceeds double the allotted time.
- Operator states the task is complete.

**TERMINATING CUE:** We will stop here.

**EVALUATOR – PICK UP** the Initiating Cue sheet.

(\*\* Indicates critical step)

## CONTINUOUS

**EVALUATOR USE ONLY**  
**(KEY)**  
**DO NOT** give to candidate

- Pre-startup checks for (✓): \_\_\_\_\_ "A" recirc  
 \_\_\_\_\_ ✓ "B" recirc

- |     | Parameter                 | Location  | Value               |     |
|-----|---------------------------|---|---------------------|-----|
| (A) | RPV Saturation Temp.      | SPDS MISC RPV Heatup/<br>Cooldown <u>OR</u> Steam Tables                            | <b>521°F (±2°F)</b> | (A) |
| (B) | “A” Recirc Suction Temp   | 1B31-R650 <u>OR</u> Equivalent,<br>average of process computer<br>points B034, B035 | <b>470°F</b>        | (B) |
| (C) | “B” Recirc Suction Temp   | 1B31-R650 <u>OR</u> Equivalent,<br>average of process computer<br>points B036, B037 | <b>475°F</b>        | (C) |
| (D) | *Vessel Bottom Head Drain | *1B21-R606 Pt 3 <u>OR</u><br>1G31-N601 Pt 5   | <b>*379°F</b>       | (D) |

## Critical

- 3.1 IF both recirc loops are idle;  
**Loop "A"**  $\Delta T = |(A) - (B)| = \underline{\hspace{2cm}}$  (acceptable  $\leq 50^\circ\text{F}$ ) NA  
OR  
**Loop "B"**  $\Delta T = |(A) - (C)| = \underline{46^\circ\text{F} (\pm 2^\circ\text{F})}$  (acceptable  $\leq 50^\circ\text{F}$ ) **INITIALS**

..... OR .....

- MACD 0000 Vol. 5

|   |                                    |                           |
|---|------------------------------------|---------------------------|
| SNC PLANT E. I. HATCH                                       |                                    | Pg 184 of 208             |
| DOCUMENT TITLE:<br>REACTOR RECIRCULATION SYSTEM             | DOCUMENT NUMBER:<br>34SO-B31-001-1 | VERSION No:<br>41.1       |
| ATTACHMENT 6<br>LE: RECIRC PUMP QUICK RE-START LIMIT CHECKS |                                    | Attachment Page<br>4 of 4 |

**NOTE:**

IF a direct indication is NOT available for Vessel Bottom Head Drain temp (D),  
THEN within 30 minutes of an RPT, the bottom head to coolant  $\Delta T$  ( $\leq 145^{\circ}\text{F}$ ) may be  
confirmed per the alternate method in step 4.2.

**Critical**

- 4.0 **Confirm** the  $\Delta T$  between the bottom head coolant temperature AND  
the reactor pressure vessel (RPV) coolant temperature is  $\leq 145^{\circ}\text{F}$   
by performing step 4.1 OR 4.2 below:

4.1  $\Delta T = |(A) - (D)| = \underline{142^{\circ}\text{F} (\pm 2^{\circ}\text{F})}$  (acceptable  $\leq 145^{\circ}\text{F}$ )

INITIALS

..... OR .....

- 4.2 Per Tech Spec BASES B.3.4.9,  
**confirm** ALL of the following:

- (a) One OR more loop drive flows were  $> 40\%$  (18,000 gpm) of rated flow  
prior to the RPT, AND
- (b) HPCI and RCIC Systems have NOT injected since the RPT, AND
- (c) Feedwater temperature has remained  $> 300^{\circ}\text{F}$  since the RPT, AND
- (d) Time between the RPT AND restart is  $< 30$  minutes.

NA TRUE

NA TRUE

NOT CORRECT

**These are calculated by the student, based on JPM start time. The time will vary.**

Record Recirc RPT trip time: \_\_\_\_\_ (T1)

Recirc start is required prior to:

(T1) + 30 minutes = \_\_\_\_\_

**EVALUATOR USE ONLY  
(KEY)  
DO NOT give to candidate**

INITIALS

**Critical**

- 5.0 IF only ONE Recirc pump is idle,  
THEN **confirm** the operating pump loop flow is  $< 22,500$  gpm.

NA

**Critical**

- 6.0 **Confirm** the:

- (1) Power/flow condition is acceptable for restart per the STA/Rx Engineering.  
OR

INITIALS

- (2) IF the OPRM System is inoperable,  
the reactor is 10% below the 61% Load Line of Attachment 1, OPRM System INOP Power  
vs. Flow map in 34AB-C51-001-1,  
in order to avoid inadvertent entry into the RPI.

INITIALS

|  |                                    |                           |
|--|------------------------------------|---------------------------|
| SNC PLANT E. I. HATCH  |                                    | Pg 185 of 208             |
| DOCUMENT TITLE:<br>REACTOR RECIRCULATION SYSTEM                    | DOCUMENT NUMBER:<br>34SO-B31-001-1 | VERSION No:<br>41.1       |
| ATTACHMENT <u>6</u><br>LE: RECIRC PUMP QUICK RE-START LIMIT CHECKS |                                    | Attachment Page<br>4 of 4 |

7.0 **Independently verify** the data recorded above is ACCEPTABLE  
prior to proceeding with the recirc pump start.

(VERIFIED) INITIALS

**Critical**

8.0 **Confirm** the steps 1.0 thru 7.0 above,  
was performed within the last 15 minutes.

INITIALS

9.0 **Record** Recirc pump start time: \_\_\_\_\_

INITIALS

**EVALUATOR USE ONLY**  
**(KEY)**  
**DO NOT** give to candidate

## **UNIT 1**

### **READ TO THE OPERATOR**

#### **INITIAL CONDITIONS:**

1. 10 minutes ago, the Unit 1 reactor scrammed from 100% power.
2. Both Reactor Recirculation pumps tripped during the scram transient.
3. Reactor water level went as low as -10 inches and has been restored to +37 inches using Reactor Feedwater Pumps.
4. HPCI and RCIC were not required during the transient and have remained in standby.
5. RWCU is in service.
6. The Shift Supervisor has given direction to perform a Quick Restart of the "1B" Reactor Recirculation pump to prevent thermal stratification.
7. An operator has entered 34SO-B31-001-1, "Reactor Recirculation System" and completed steps 7.1.4.2.1 through 7.1.4.2.5 ("Recirc Pump B Quick Re-start").
8. Data collection began 4 minutes ago and the operator has completed gathering plant data for use with step 7.1.4.2.6 of 34SO-B31-001-1.

#### **INITIATING CUES:**

Determine if plant conditions meet the procedural requirements for starting the "1B" Reactor Recirculation pump per step 7.1.4.2.6 of 34SO-B31-001-1, "Reactor Recirculation System".

**PROVIDE TO APPLICANT**

**Plant Data**

- **Reactor pressure:** 805 psig
- **“A” Recirc Suction Temp (1B31-R650):** 470° F
- **“B” Recirc Suction Temp (1B31-R650):** 475° F
- **Vessel Bottom Head Drain (1B21-R606 Pt 3):** 379° F
- **Reactor Feedwater temperature:** 295° F

**FINAL**

**Southern Nuclear  
E. I. Hatch Nuclear Plant**

**Operations Training  
JPM**

**ADMIN 4 – ALL**

| TITLE  |                  |            |
|--|------------------|------------|
| REVIEW OF HPCI PUMP OPERABILITY SURVEILLANCE |                  |            |
| AUTHOR                                       | MEDIA NUMBER     | TIME       |
| Anthony Ball                                 | 2012-301 ADMIN-4 | 15 Minutes |
| RECOMMENDED BY                               | APPROVED BY      | DATE       |
| N/A  | C. M. EDMUND     | 06/07/2012 |



**SOUTHERN NUCLEAR OPERATING COMPANY  
PLANT E. I. HATCH**

Page 1 of 1

**FORM TITLE: TRAINING MATERIAL REVISION SHEET**

**Program/Course Code: OPERATIONS TRAINING**

Media Number: 2012-301 ADMIN-4

[illegible]



UNIT 1 ( )    UNIT 2 (X)

**TASK TITLE:**    **REVIEW OF HPCI PUMP OPERABILITY  
SURVEILLANCE****JPM NUMBER:**    2012-301 ADMIN-4**TASK STANDARD:**    The task shall be complete when the operator reviews the completed surveillance procedure, 34SV-E41-002-2, makes any required calculations and determines HPCI surveillance is unsat, one PSW valve is sat and the other is inoperable.**TASK NUMBER:**    300.011**OBJECTIVE NUMBER:**    300.011.O**K/A CATALOG NUMBER:**    Generic 2.2.12**K/A CATALOG JTA IMPORTANCE RATING:****RO**    3.7**SRO**    4.1**OPERATOR APPLICABILITY:**    Nuclear Plant Operator (NPO) / Senior Reactor Operator (SRO)

|                            |                                  |
|----------------------------|----------------------------------|
| <b>GENERAL REFERENCES:</b> | <b>Unit 2</b>                    |
|                            | 34SV-E41-002-2 (current version) |

|                            |   |
|----------------------------|---|
| <b>REQUIRED MATERIALS:</b> | <b>Unit 2</b>                                   |
|                            | Completed surveillance package: 34SV-E41-002-2. |

**APPROXIMATE COMPLETION TIME:**    15 Minutes**SIMULATOR SETUP:**    N/A

# **EVALUATOR COPY**

## **UNIT 2**

### **READ TO THE OPERATOR**

#### **INITIAL CONDITIONS:**

1. Unit 2 is at 100% power.
2. A Normal HPCI Pump Quarterly Inservice Test (IST) Data Test has just been completed for the HPCI pump IAW 34SV-E41-002-2, "HPCI Pump Operability".
3. Unit 2 reactor pressure is 1043 psig.

#### **INITIATING CUES:**

Review Attachment 1 of 34SV-E41-002-2, "HPCI Pump Operability".

Complete any calculations required by the surveillance data sheets.

Using Attachment 1 of 34SV-E41-002-2 data COMPLETE Section 7.8 TEST RESULTS, step 7.8.1 through step 7.8.6.

| STEP # | PERFORMANCE STEP | STANDARD | SAT/UNSAT (COMMENTS) |
|--------|------------------|----------|----------------------|
|--------|------------------|----------|----------------------|

For **INITIAL** Operator Programs:

**For OJT/OJE**; ALL PROCEDURE STEPS must be completed for Satisfactory Performance.

**For License Examinations**; ALL CRITICAL STEPS must be completed for Satisfactory Performance.

|             | IF  | THEN   |
|-------------|---|--|
| <b>PASS</b> | <input type="checkbox"/> Human performance tools, safety, PPE met (1), <b>AND</b><br><input type="checkbox"/> For initial trg <b>all</b> steps completed correctly OR<br><input type="checkbox"/> For continuing trg, <b>critical</b> steps (if used) completed correctly | <input type="checkbox"/> Mark the JPM as a <b>PASS</b> |
| <b>FAIL</b> | <input type="checkbox"/> Above standards not met  | <input type="checkbox"/> Mark the JPM as a <b>FAIL</b> |

(1) The standard for human performance tools, safety, PPE, and other pertinent expectations is considered met provided any deviations are minor and have little or no actual or potential consequence. Errors may be self-corrected provided the action would not have resulted in significant actual or potential consequences. Reference: NMP-TR-111, "On-The-Job Training and Task Performance Evaluation".

**START  
TIME:** \_\_\_\_\_

PROMPT: **AT** this time, **GIVE** the applicant a complete copy of 34SV-E41-002-2, HPCI Pump Operability.

PROMPT: **AT** this time, **GIVE** the applicant **Attachment 2 of this JPM** (Data has been filled in for this JPM).

PROMPT: **IF** the applicant addresses the IST Book, **INFORM** the applicant that a supervisor has verified the reference data.

**NOTE:** JPM Steps 1 - 8 can be performed in any order.

|           |   |   |  |
|-----------|---|---|--|
| <b>1.</b> | The applicant evaluates parameters on Attachment 1 and finds Turbine Speed $N_r$ is acceptable. | On Attach. 1 of 34SV-E41-002-2, the applicant <b>EVALUATES</b> Turbine Speed $N_r$ data is <b>SATISFACTORY. 3900 rpm</b> (Acceptable Range: 3861 (0.99) to 3939 (1.01) rpm) |  |
|-----------|---|---|--|

(\*\* Indicates critical step)

| STEP # | PERFORMANCE STEP  | STANDARD  | SAT/UNSAT (COMMENTS) |
|--------|---|---|----------------------|
| 2.     | The applicant evaluates parameters on Attachment 1 and finds Inlet Pressure (Stopped) ( $P_i$ ) is acceptable.  | On Attach. 1 of 34SV-E41-002-2, the applicant EVALUATES Inlet Pressure (Stopped) ( $P_i$ ) data is <b>SATISFACTORY. 34 psig</b><br>Acceptable Range: >7 psig.               |                      |
| 3.     | The applicant evaluates parameters on Attachment 1 and finds Inlet Pressure (Running) ( $P_i$ ) is acceptable.  | On Attach. 1 of 34SV-E41-002-2, the applicant EVALUATES Inlet Pressure (Running) ( $P_i$ ) data is <b>SATISFACTORY. 31 psig</b><br>Acceptable Range: >7 psig.               |                      |
| 4.     | The applicant evaluates parameters on Attachment 1 and finds Outlet Pressure (Running) $P_o$ is NOT acceptable. | At step 7.8.2.1.1 of 34SV-E41-002-2, the applicant EVALUATES Outlet Pressure data <b>IS NOT SATISFACTORY.</b> 1072 psig is NOT in the Acceptable Range of $\geq 1135$ psig. |                      |

**NOTE:** At this time, the applicant may elect to inform the Shift Supervisor that Outlet Pressure (Running)  $P_o$  is NOT acceptable and HPCI has failed the surveillance. This action **IS** acceptable.

It **IS** also acceptable for the applicant to complete the review before bringing this to the supervisor's attention.

**PROMPT:** IF the applicant addresses the out of spec. item(s), **DIRECT** the applicant to finish the data package review.

(\*\* Indicates critical step)

| STEP # | PERFORMANCE STEP   | STANDARD   | SAT/UNSAT (COMMENTS) |
|--------|--|--|----------------------|
| 5.     | The applicant calculates and then evaluates on Attachment 1 and finds Differential Pressure (2) dPr is NOT acceptable. | On Attach. 1 of 34SV-E41-002-2, the applicant CALCULATES AND EVALUATES Differential Pressure (2) dPr data <b>IS NOT SATISFACTORY. 0.88 dPr is NOT in the Acceptable Range of 0.90 to 1.10 dPr.</b> |                      |

**NOTE:** Ratio Differential Pressure (2) dPr is equal to the Test Value dPr divided by the Reference Value dPr.  $1041/1183 = 0.88$ .

At this time, the applicant may elect to inform the Shift Supervisor that Differential Pressure (2) dPr is NOT acceptable and HPCI must be declared inoperable. This action **IS** acceptable.

It **IS** also acceptable for the applicant to complete the review before bringing this to the supervisor's attention.

**PROMPT:** IF the applicant addresses the out of spec. item(s), **DIRECT** the applicant to finish the data package review.

|    |  |  |  |
|----|--|--|--|
| 6. | The applicant evaluates parameters on Attachment 1 and finds Flowrate (4) (Q <sub>r</sub> ) is acceptable. | On Attach. 1 of 34SV-E41-002-2, the applicant EVALUATES Flowrate (4) (Q <sub>r</sub> ) data ( <b>4250 gpm</b> ) is SATISFACTORY. Acceptable value is 4250 gpm. |  |
|----|--|--|--|

(\*\* Indicates critical step)

| STEP # | PERFORMANCE STEP   | STANDARD   | SAT/UNSAT (COMMENTS) |
|--------|--|--|----------------------|
| 7.     | The applicant evaluates the stroke time data for the cooling water valve 2P41-F035A. | On Attach. 1 of 34SV-E41-002-2, the applicant evaluates the stroke time data for 2P41-F035A and determines that the valve data is <b>SATISFACTORY</b> .<br><b>4.4 seconds is within</b> the Calculated Allowable Time range of 1.5 to 4.5 seconds. |                      |
| 8.     | The applicant evaluates the stroke time data for the cooling water valve 2P41-F035B. | On Attach. 1 of 34SV-E41-002-2, the applicant evaluates the stroke time data for 2P41-F035B and determines that the valve data is <b>NOT SATISFACTORY</b> .<br>5.2 seconds has exceeded the <b>MAXIMUM</b> Time Limit of 5.0 seconds.              |                      |

**NOTE:** At this time, the applicant may elect to inform the Shift Supervisor that 2P41-F035B has exceeded the **MAXIMUM** Time Limit of 5.0 seconds and failed the surveillance. This action **IS** acceptable.

It **IS** also acceptable for the applicant to complete the review before bringing this to the supervisor's attention.

**PROMPT:** **WHEN** the applicant addresses the Out of Spec readings, **INFORM** the applicant to finish the data package review.

|     |   |  |  |
|-----|---|--|--|
| 9.  | The applicant performs step 7.8.1<br>Reason for test:   | The applicant places a check mark for "Norm. Surv." per the initial conditions.  |  |
| 10. | The applicant performs step 7.8.2.1.1<br>HPCI pump delivers at least 4250 gpm at a pump discharge pressure of greater than OR equal to 1135 psig with reactor pressure of > 920 psig AND < 1058 psig. | The applicant has determined HPCI pump Outlet Pressure (Running) $P_o < 1135$ psig has failed to meet the acceptance criteria of step 7.8.2.1.1. |  |

(\*\* Indicates critical step)

| STEP # | PERFORMANCE STEP   | STANDARD   | SAT/UNSAT (COMMENTS) |
|--------|--|--|----------------------|
| 11.    | The applicant performs step 7.8.2.1.2 HPCI pump discharge lines up stream of valves 2E41-F006 AND F011 are filled. | The applicant has verified that HPCI pump discharge lines up stream of valves 2E41-F006 AND F011 are filled. |                      |

PROMPT: **WHEN** the applicant addresses the HPCI pump discharge lines upstream of valves 2E41-F006 AND F011 are filled, **INFORM** the applicant that HPCI pump discharge lines up stream of valves 2E41-F006 AND F011 are filled.

|     |   |  |  |
|-----|---|--|--|
| 12. | The applicant performs step 7.8.2.1.3 2T41-B005A AND 2T41-B005B, HPCI Pump Rm Cooling Fans, auto start, WHEN HPCI is started. | The applicant has verified that 2T41-B005A AND 2T41-B005B, HPCI Pump Rm Cooling Fans, auto start, WHEN HPCI started. |  |
|-----|---|--|--|

PROMPT: **WHEN** the applicant addresses the 2T41-B005A AND 2T41-B005B, HPCI Pump Rm Cooling Fans, **INFORM** the applicant that 2T41-B005A AND 2T41-B005B, HPCI Pump Rm Cooling Fans, auto started.

|     |  |  |  |
|-----|--|--|--|
| 13. | The applicant performs step 7.8.2.1.4 2P41-F035A AND 2P41-F035B, HPCI Pump Rm Cooler Valves, OPEN, WHEN cooler is running. | The applicant has verified that 2P41-F035A AND 2P41-F035B, HPCI Pump Rm Cooler Valves, OPEN, WHEN cooler is running. |  |
|-----|--|--|--|

PROMPT: **WHEN** the applicant addresses the 2P41-F035A AND 2P41-F035B, HPCI Pump Rm Cooler Valves, open when HPCI is running, **INFORM** the applicant that 2P41-F035A AND 2P41-F035B, HPCI Pump Rm Cooler Valves, auto opened.

|     |   |   |  |
|-----|---|---|--|
| 14. | The applicant performs step 7.8.2.1.5 Oil level AND pressure is observed. | The applicant has verified that Oil level AND pressure is observed. |  |
|-----|---|---|--|

PROMPT: **WHEN** the applicant addresses the Oil level AND pressure is observed, **INFORM** the applicant that Oil level AND pressures were observed.

(\*\* Indicates critical step)

| STEP # | PERFORMANCE STEP   | STANDARD   | SAT/UNSAT (COMMENTS) |
|--------|--|--|----------------------|
| 15.    | The applicant evaluates step 7.8.2.2.1 HPCI pump Outlet Pressure (Running) $P_o$ data. | The applicant has determined that HPCI pump Outlet Pressure (Running) $P_o$ has <b>FAILED</b> to meet the acceptance criteria of step 7.8.2.2.1. |                      |

**NOTE:** At this time, the applicant may elect to inform the Shift Supervisor that Outlet Pressure (Running)  $P_o$  is NOT acceptable and HPCI has failed the surveillance. This action **IS** acceptable.

It **IS** also acceptable for the applicant to complete the review before bringing this to the supervisor's attention.

|     |  |   |  |
|-----|--|---|--|
| 16. | The applicant evaluates step 7.8.2.2.1 HPCI pump dPr data. | The applicant has determined that Differential Pressure $dP_r$ has <b>FAILED</b> to meet the acceptance criteria of step 7.8.2.2.1. |  |
|-----|--|---|--|

**NOTE:** At this time, the applicant may elect to inform the Shift Supervisor that Differential Pressure (2) dPr is NOT acceptable. This action **IS** acceptable.

It **IS** also acceptable for the applicant to complete the review before bringing this to the supervisor's attention.

|     |  |  |  |
|-----|--|--|--|
| 17. | The applicant evaluates step 7.8.2.2.1 Flowrate (4) ( $Q_r$ ) data.                        | The applicant has determined that Flowrate ( $Q_r$ ) data meets the acceptance criteria of step 7.8.2.2.1. |  |
| 18. | The applicant performs step 7.8.2.2.2 HPCI Pump Rm Cooler valve operability was performed. | The applicant has verified that HPCI Pump Rm Cooler valve operability was performed.                       |  |

**PROMPT:** **WHEN** the applicant addresses HPCI Pump Rm Cooler valve operability, **INFORM** the applicant that HPCI Pump Rm Cooler valve operability was performed.

(\*\* Indicates critical step)



| STEP # | PERFORMANCE STEP  | STANDARD   | SAT/UNSAT (COMMENTS) |
|--------|---|--|----------------------|
| 19.    | The applicant evaluates step 7.8.3 if Response Time Test was performed. | The applicant evaluates if Response Time Test was performed. |                      |

PROMPT: **WHEN** the applicant addresses Response Time Test, **INFORM** the applicant that Response Time Test was NOT performed.

|     |   |   |  |
|-----|---|---|--|
| 20. | The applicant performs step 7.8.4.1 for 2P41-F035A, The stroke times for each valve are less than the <b>MAXIMUM TIME LIMIT</b> . | The applicant compares the stroke time and has determined that HPCI 2P41-F035A stroke time <b>IS</b> less than the <b>MAXIMUM TIME LIMIT</b> .    |  |
| 21. | The applicant performs step 7.8.4.1 for 2P41-F035B, The stroke times for each valve are less than the <b>MAXIMUM TIME LIMIT</b> . | The applicant compares the stroke time and has determined that HPCI 2P41-F035B has <b>FAILED</b> to meet the acceptance criteria of step 7.8.4.1. |  |

**NOTE:** At this time, the applicant may elect to inform the Shift Supervisor that 2P41-F035B has exceeded the **MAXIMUM** Time Limit of 5.0 seconds and failed the surveillance. This action **IS** acceptable.

It **IS** also acceptable for the applicant to complete the review before bringing this to the supervisor's attention.

|     |   |   |  |
|-----|---|---|--|
| 22. | The applicant performs step 7.8.4.2 for 2P41-F035A, The stroke times for each valve are <b>WITHIN</b> the <b>CALCULATED ALLOWABLE</b> time range on Attachment 1. | The applicant compares the stroke time and has determined that HPCI 2P41-F035A stroke time <b>IS</b> within the <b>CALCULATED ALLOWABLE</b> time range on Attachment 1.     |  |
| 23. | The applicant performs step 7.8.4.2 for 2P41-F035B, The stroke times for each valve are <b>WITHIN</b> the <b>CALCULATED ALLOWABLE</b> time range on Attachment 1. | The applicant compares the stroke time and has determined that HPCI 2P41-F035B stroke time <b>IS NOT</b> within the <b>CALCULATED ALLOWABLE</b> time range on Attachment 1. |  |

(\*\* Indicates critical step)

| STEP # | PERFORMANCE STEP | STANDARD | SAT/UNSAT (COMMENTS) |
|--------|------------------|----------|----------------------|
|--------|------------------|----------|----------------------|

**NOTE:** At this time, the applicant may elect to inform the Shift Supervisor that 2P41-F035B has exceeded the CALCULATED ALLOWABLE time range. This action **IS** acceptable.

It **IS** also acceptable for the applicant to complete the review before bringing this to the supervisor's attention.

|            |  |  |  |
|------------|--|--|--|
| <b>24.</b> | The applicant performs step 7.8.4.3 Valve stem travel > 80% open based on local stem mounted position indicator. | The applicant has verified that Valve stem travel was > 80% open based on local stem mounted position indicator. |  |
|------------|--|--|--|

**PROMPT:** **WHEN** the applicant addresses valve stem travel > 80% open based on local stem mounted position indicator, **INFORM** the applicant that valve stem travel **WAS** > 80% open based on local stem mounted position indicator.

|              |  |  |  |
|--------------|--|--|--|
| <b>**25.</b> | The applicant performs step 7.8.5 Test Result. | The applicant completes step 7.8.5 and marks the step <b>UNSAT</b> . |  |
|--------------|--|--|--|

**NOTE:** JPM Steps 26 - 28 can be performed in any order.

|              |   |   |  |
|--------------|---|---|--|
| <b>**26.</b> | The applicant performs step 7.8.6 for HPCI pump Outlet Pressure (Running) $P_o$ < 1135 psig has failed to meet the acceptance criteria of step 7.8.2.1.1. | The applicant lists in step 7.8.6 that HPCI pump Outlet Pressure (Running) $P_o$ has <b>FAILED</b> to meet the acceptance criteria of step 7.8.2.1.1 & 7.8.2.2.1 (< 1135 psig). |  |
|--------------|---|---|--|

|              |   |   |  |
|--------------|---|---|--|
| <b>**27.</b> | The applicant performs step 7.8.6 HPCI Differential Pressure $dP_r$ . | The applicant also lists in step 7.8.6 that HPCI Differential Pressure $dP_r$ has <b>FAILED</b> to meet the acceptance criteria of step 7.8.2.2.1 ( $dP_r$ < 0.90). |  |
|--------------|---|---|--|

(\*\* Indicates critical step)

| STEP<br>#    | PERFORMANCE STEP                                       | STANDARD   | SAT/UNSAT<br>(COMMENTS) |
|--------------|--|--|-------------------------|
| <b>**28.</b> | The applicant performs step 7.8.6 for HPCI 2P41-F035B. | The applicant also lists in step 7.8.6 that HPCI 2P41-F035B has <b>FAILED</b> to meet the acceptance criteria of step 7.8.4.1 (Exceeded Maximum Time Limit). |                         |

**NOTE:** If the applicant addresses writing a Condition Report (CR) based on this surveillance, inform the applicant that another operator will write the CR.

**END  
TIME:** \_\_\_\_\_

**NOTE:** The terminating cue shall be given to the Applicant when:

- After JPM step #28 is complete.
- With no reasonable progress, the Applicant exceeds double the allotted time.
- Applicant states the task is complete.

**TERMINATING CUE:** We will stop here.

**EVALUATOR – PICK UP** the Initiating Cue sheet.

(\*\* Indicates critical step)

**ATTACHMENT 1**  
**\*\* KEY \*\***  
**DO NOT give this to applicant**

|  |                                    |                           |
|--|------------------------------------|---------------------------|
| SNC PLANT E. I. HATCH  |                                    | Pg 43 of 67               |
| DOCUMENT TITLE:<br>HPCI PUMP OPERABILITY   | DOCUMENT NUMBER:<br>34SV-E41-002-2 | Version No:<br>31.0       |
| ATTACHMENT <u>1</u><br>TITLE: HPCI PUMP QUARTERLY IST DATA AND ACCEPTANCE CRITERIA |                                    | Attachment Page<br>1 of 2 |

Reference Data Changes:

Is reference data being changed? ( ) Yes (✓) No

IF YES, list justification for so doing: \_\_\_\_\_

**(2E41-C001)**

| PARAMETER                            | INSTRU MPL NO. | REFERENCE VALUE | DATE REF VALUE TAKEN | TEST VALUE  | ACCEPT. RANGE    | ALERT RANGE | REQ'D ACTION RANGE (1)       | RATIO (3)   |
|--------------------------------------|----------------|-----------------|----------------------|-------------|------------------|-------------|------------------------------|-------------|
| Turbine Speed ( $N_r$ )              | 2E41-R610      | <u>3900</u>     | <u>01/18/2010</u>    | <u>3900</u> | 0.99 to 1.01 RPM | N/A         | N/A                          | N/A         |
| Inlet Pressure (Stopped) ( $P_i$ )   | 2E41-R606      | <u>34</u>       | <u>01/18/2010</u>    | <u>34</u>   | $\geq 7$ PSIG    | N/A         | $< 7$ PSIG                   | N/A         |
| Inlet Pressure (Running) ( $P_i$ )   | 2E41-R606      | <u>32</u>       | <u>01/18/2010</u>    | <u>31</u>   | $\geq 7$ PSIG    | N/A         | $< 7$ PSIG                   | N/A         |
| Outlet Pressure (Running) ( $P_o$ )  | 2E41-R601      | <u>1215</u>     | <u>01/18/2010</u>    | <u>1072</u> | N/A              | N/A         | N/A                          | N/A         |
| Differential Pressure (2) ( $DP_r$ ) | N/A            | <u>1183</u>     | <u>01/18/2010</u>    | <u>1041</u> | 0.90 to 1.10 dPr | N/A         | $< 0.90$ dPr or $> 1.10$ dPr | <u>0.88</u> |
| Flowrate (4) ( $Q_r$ )               | 2E41-R612      | <u>4250</u>     | N/A                  | <u>4250</u> | N/A              | N/A         | N/A                          | 1.0         |

- (1) Pump declared inoperable according to 31GO-INS-001-0.
- (2) Differential pressure must be calculated as:  $dP = \text{Outlet Pressure (pump running)} - \text{Inlet Pressure (Pump running)}$
- (3) Ratio = Test Value divided by Reference Value
- (4) Test value must equal reference value. Ratio for flowrate must equal 1.0.

**ATTACHMENT 1**  
**\*\* KEY \*\***  
**DO NOT** give this to applicant

|   |  |                                    |                     |
|---|--|------------------------------------|---------------------|
| SNC PLANT E. I. HATCH                                       |  | Pg 44 of 67                        |                     |
| DOCUMENT TITLE:<br>HPCI PUMP OPERABILITY                    |  | DOCUMENT NUMBER:<br>34SV-E41-002-2 | Version No:<br>31.0 |
| ATTACHMENT <u>1</u>   |  |                                    | Attachment Page     |
| TITLE: HPCI PUMP QUARTERLY IST DATA AND ACCEPTANCE CRITERIA |  |                                    | 2 of 2              |

**NOTE:** WHEN calculating OR recording valve stroke times, round off to the nearest tenth second.

| COLUMN 1<br>MPL (TYPE) | COLUMN 2<br>REFERENCE<br>TIME<br>(SEC) |       | COLUMN 3 CALCULATED<br>ALLOWABLE TIME<br>(SEC) |     |                    |     | COLUMN 4<br>OPERATING<br>TIME<br>(SEC) |       | COLUMN 5<br>MAXIMUM TIME<br>LIMIT<br>(SEC) |       | TIMED<br>BY:<br>INIT |
|------------------------|--|-------|--|-----|--------------------|-----|--|-------|--|-------|----------------------|
|                        | OPEN                                   | CLOSE | OPEN<br>MIN / MAX                              |     | CLOSE<br>MIN / MAX |     | OPEN                                   | CLOSE | OPEN                                       | CLOSE |                      |
| 2P41-F035A<br>AOV      | 3.0                                    | N/A   | 1.5  | 4.5 | N/A                | N/A | 4.4                                    | N/A   | ≤ 5  | N/A   | SMH                  |
| 2P41-F035B<br>AOV      | 2.5                                    | N/A   | 1.3  | 3.8 | N/A                | N/A | 5.2                                    | N/A   | ≤ 5  | N/A   | SMH                  |

IF operating time is less than 1 second, **record** 1 second as operating time.

VERIFY STROKE  
TIMES ACCEPTABLE: \_\_\_\_\_ DATE: \_\_\_\_\_

**ATTACHMENT 1**  
**\*\* KEY \*\***  
**DO NOT give this to applicant**

|  |                                    |                     |
|--|------------------------------------|---------------------|
| SOUTHERN NUCLEAR<br>PLANT E. I. HATCH    |                                    | PAGE<br>40 OF 67    |
| DOCUMENT TITLE:<br>HPCI PUMP OPERABILITY | DOCUMENT NUMBER:<br>34SV-E41-002-2 | VERSION NO:<br>31.0 |

**7.8 TEST RESULTS**

7.8.1 Reason for test: ( ✓ ) Norm. Surv. ( ) WO # \_\_\_\_\_  
( ) Other \_\_\_\_\_

7.8.2 Acceptance Criteria:

7.8.2.1 IF any test was performed:

7.8.2.1.1 HPCI pump delivers at least 4250 gpm at a pump discharge pressure of greater than OR equal to 1135 psig with reactor pressure of  $\geq 920$  psig AND  $\leq 1058$  psig.

7.8.2.1.2 HPCI pump discharge lines up stream of valves 2E41-F006 AND F011 are filled.

7.8.2.1.3 2T41-B005A AND 2T41-B005B, HPCI Pump Rm Cooling Fans, auto start, WHEN HPCI is started.

7.8.2.1.4 2P41-F035A AND 2P41-F035B, HPCI Pump Rm Cooler Valves, OPEN, WHEN cooler is running.

7.8.2.1.5 Oil level AND pressure is observed.

7.8.2.2 IF (IST) was performed:

7.8.2.2.1 HPCI pump data matches the reference data WITHIN the limits stated on appropriate Attachment 1, 7, OR 8.

7.8.2.2.2 HPCI Pump Rm Cooler valve operability was performed.

7.8.3 IF Response Time Test was performed:

7.8.3.1 HPCI reaches rated flow AND pressure in  $\leq 70$  seconds.

7.8.4 IF HPCI Room Cooler Valve Operability was performed:

7.8.4.1 The stroke times for each valve are less than the MAXIMUM TIME LIMIT.

7.8.4.2 The stroke times for each valve are WITHIN the CALCULATED ALLOWABLE time range on Attachment 1 or Attachment 7.

7.8.4.3 Valve stem travel  $> 80\%$  open based on local stem mounted position indicator.

**ATTACHMENT 1**  
**\*\* KEY \*\***  
**DO NOT give this to applicant**

SOUTHERN NUCLEAR  
PLANT E. I. HATCH

PAGE  
41 OF 67

DOCUMENT TITLE:  
HPCI PUMP OPERABILITY

DOCUMENT NUMBER:  
34SV-E41-002-2

VERSION NO:  
31.0

7.8.5 Test Result:

( ) Satisfactory

( ✓ ) Unsatisfactory

7.8.6 Unsatisfactory Conditions: (1)HPCI pump Outlet Pressure (Running) Po has FAILED to  
meet the acceptance criteria of step 7.8.2.1.1 & 7.8.2.2.1 (<1135 psig)

(2)HPCI Differential Pressure dPr has FAILED to meet the acceptance criteria of step  
7.8.2.2.1 (dPr < 0.90).

(3)HPCI 2P41-F035B has FAILED to meet the acceptance criteria of step 7.8.4.1  
(Exceeded Maximum Time Limit).

7.8.7 Comments/Corrective Actions:

7.8.8 Test completed and/or verified by:

\_\_\_\_\_  
Print Name

\_\_\_\_\_  
Initial

\_\_\_\_\_  
Date

\_\_\_\_\_  
Print Name

\_\_\_\_\_  
Initial

\_\_\_\_\_  
Date

\_\_\_\_\_  
Print Name

\_\_\_\_\_  
Initial

\_\_\_\_\_  
Date

\_\_\_\_\_  
Print Name

\_\_\_\_\_  
Initial

\_\_\_\_\_  
Date

# **ATTACHMENT 2 PROVIDE TO APPLICANT**

SNC PLANT E. I. HATCH

Pg 43 of 67

DOCUMENT TITLE:  
HPCI PUMP OPERABILITY

DOCUMENT NUMBER:  
34SV-E41-002-2

Version No:  
31.0

ATTACHMENT 1

TITLE: HPCI PUMP QUARTERLY IST DATA AND ACCEPTANCE CRITERIA

Attachment Page  
1 of 2

Reference Data Changes:

Is reference data being changed? ( ) Yes (✓) No

IF YES, list justification for so doing: \_\_\_\_\_

**(2E41-C001)**

| PARAMETER                            | INSTRU MPL NO. | REFERENCE VALUE | DATE REF VALUE TAKEN | TEST VALUE  | ACCEPT. RANGE    | ALERT RANGE | REQ'D ACTION RANGE (1)       | RATIO (3) |
|--------------------------------------|----------------|-----------------|----------------------|-------------|------------------|-------------|------------------------------|-----------|
| Turbine Speed ( $N_r$ )              | 2E41-R610      | <u>3900</u>     | <u>01/18/2010</u>    | <u>3900</u> | 0.99 to 1.01 RPM | N/A         | N/A                          | N/A       |
| Inlet Pressure (Stopped) ( $P_i$ )   | 2E41-R606      | <u>34</u>       | <u>01/18/2010</u>    | <u>34</u>   | $\geq 7$ PSIG    | N/A         | $< 7$ PSIG                   | N/A       |
| Inlet Pressure (Running) ( $P_i$ )   | 2E41-R606      | <u>32</u>       | <u>01/18/2010</u>    | <u>31</u>   | $\geq 7$ PSIG    | N/A         | $< 7$ PSIG                   | N/A       |
| Outlet Pressure (Running) ( $P_o$ )  | 2E41-R601      | <u>1215</u>     | <u>01/18/2010</u>    | <u>1072</u> | N/A              | N/A         | N/A                          | N/A       |
| Differential Pressure (2) ( $DP_r$ ) | N/A            | <u>1183</u>     | <u>01/18/2010</u>    | <u>1041</u> | 0.90 to 1.10 dPr | N/A         | $< 0.90$ dPr or $> 1.10$ dPr | _____     |
| Flowrate (4) ( $Q_r$ )               | 2E41-R612      | <u>4250</u>     | N/A                  | <u>4250</u> | N/A              | N/A         | N/A                          | 1.0       |

- Pump declared inoperable according to 31GO-INS-001-0.
- Differential pressure must be calculated as:  $dP = \text{Outlet Pressure (pump running)} - \text{Inlet Pressure (Pump running)}$
- Ratio = Test Value divided by Reference Value
- Test value must equal reference value. Ratio for flowrate must equal 1.0.



**ATTACHMENT 2  
PROVIDE TO APPLICANT**

SNC PLANT E. I. HATCH

Pg 44 of 67

DOCUMENT TITLE:  
HPCI PUMP OPERABILITY

DOCUMENT NUMBER:  
34SV-E41-002-2

Version No:  
31.0

ATTACHMENT 1

TITLE: HPCI PUMP QUARTERLY IST DATA AND ACCEPTANCE CRITERIA

Attachment Page  
2 of 2

**NOTE:**

WHEN calculating OR recording valve stroke times, round off to the nearest tenth second.

| COLUMN 1<br>MPL (TYPE) | COLUMN 2<br>REFERENCE<br>TIME<br>(SEC) |       | COLUMN 3 CALCULATED<br>ALLOWABLE TIME<br>(SEC) |     |                    |     | COLUMN 4<br>OPERATING<br>TIME<br>(SEC) |       | COLUMN 5<br>MAXIMUM TIME<br>LIMIT<br>(SEC) |       | TIMED<br>BY:<br>INIT |
|------------------------|--|-------|--|-----|--------------------|-----|--|-------|--|-------|----------------------|
|                        | OPEN                                   | CLOSE | OPEN<br>MIN / MAX                              |     | CLOSE<br>MIN / MAX |     | OPEN                                   | CLOSE | OPEN                                       | CLOSE |                      |
| 2P41-F035A<br>AOV      | 3.0                                    | N/A   | 1.5  | 4.5 | N/A                | N/A | 4.4                                    | N/A   | ≤ 5  | N/A   | <b>SMH</b>           |
| 2P41-F035B<br>AOV      | 2.5                                    | N/A   | 1.3  | 3.8 | N/A                | N/A | 5.2                                    | N/A   | ≤ 5  | N/A   | <b>SMH</b>           |

IF operating time is less than 1 second, **record** 1 second as operating time.

VERIFY STROKE  
TIMES ACCEPTABLE:

DATE: \_\_\_\_\_

## **UNIT 2**

### **READ TO THE OPERATOR**

#### **INITIAL CONDITIONS:**

1. Unit 2 is at 100% power.
2. A Normal HPCI Pump Quarterly Inservice Test (IST) Data Test has just been completed for the HPCI pump IAW 34SV-E41-002-2, "HPCI Pump Operability".
3. Unit 2 reactor pressure is 1043 psig.

#### **INITIATING CUES:**

Review Attachment 1 of 34SV-E41-002-2, "HPCI Pump Operability".

Complete any calculations required by the surveillance data sheets.

Using Attachment 1 of 34SV-E41-002-2 data COMPLETE Section 7.8 TEST RESULTS, step 7.8.1 through step 7.8.6.

**FINAL**

**Southern Nuclear  
E. I. Hatch Nuclear Plant**

**Operations Training  
JPM**

**Admin 5- ALL**

| TITLE   |                  |            |
|---|------------------|------------|
| RADIATION EXPOSURE CALCULATION AND REQUIRED AUTHORIZATION |                  |            |
| AUTHOR  | MEDIA NUMBER     | TIME       |
| Anthony Ball  | 2012-301 ADMIN-5 | 15 Minutes |
| RECOMMENDED BY  | APPROVED BY      | DATE       |
| N/A   | C. M. EDMUND     | 06/07/2012 |



|   |             |
|---|-------------|
| <b>SOUTHERN NUCLEAR OPERATING COMPANY</b>           |             |
| <b>PLANT E. I. HATCH</b>                            | Page 1 of 1 |
| <b>FORM TITLE: TRAINING MATERIAL REVISION SHEET</b> |             |

|   |             |
|---|-------------|
| <b>SOUTHERN NUCLEAR OPERATING COMPANY</b>           |             |
| <b>PLANT E. I. HATCH</b>                            | Page 1 of 1 |
| <b>FORM TITLE: TRAINING MATERIAL REVISION SHEET</b> |             |

|   |             |
|---|-------------|
| <b>SOUTHERN NUCLEAR OPERATING COMPANY</b>           |             |
| <b>PLANT E. I. HATCH</b>                            | Page 1 of 1 |
| <b>FORM TITLE: TRAINING MATERIAL REVISION SHEET</b> |             |

---

Program/Course Code: **OPERATIONS TRAINING** Media Number: **2012-301 ADMIN-5**

---

Program/Course Code: **OPERATIONS TRAINING** Media Number: **2012-301 ADMIN-5**

[illegible]

UNIT 1 ( ) UNIT 2 (X)

**TASK TITLE:** Radiation Exposure Calculation and Required Authorization.

**JPM NUMBER:** 2012-301 ADMIN-5

**TASK STANDARD:** The task shall be complete when it has been determined the job cannot be performed without exceeding annual administrative radiation exposure limits, and determining the level of approval to exceed the annual administrative radiation exposure limit.

**TASK NUMBER:** N/A

**OBJECTIVE NUMBER:** LT-30008.01

**K/A CATALOG NUMBER:** Generic 2.3.4

**K/A CATALOG JTA IMPORTANCE RATING:**

**RO** 3.2

**SRO** 3.7

**OPERATOR APPLICABILITY:** Nuclear Plant Operator (NPO) / Senior Reactor Operator (SRO)

|                            |                                  |
|----------------------------|----------------------------------|
| <b>GENERAL REFERENCES:</b> | <b>Unit 2</b>                    |
|                            | 60AC-HPX-001-0 (current version) |

|                            |                                  |
|----------------------------|----------------------------------|
| <b>REQUIRED MATERIALS:</b> | <b>Unit 2</b>                    |
|                            | 60AC-HPX-001-0 (current version) |

**APPROXIMATE COMPLETION TIME:** 15 Minutes

**SIMULATOR SETUP:** N/A

## EVALUATOR COPY

### UNIT 2

#### READ TO THE OPERATOR

#### INITIAL CONDITIONS:

1. You are a radiation worker at Hatch and have been assigned to perform a job in the Unit 2 Clean Up Phase Separator (CUPS) room.
2. Gamma radiation is the only type of radiation of concern for this particular job (no airborne, Beta or Alpha).
3. Your job inside the CUPS room, will take 1 hour.
4. Your total exposure (TEDE) for the year so far has been confirmed to be 1400 mrem.
5. One of the radiation fields you will work in for 20 minutes is 4500 mrem/hour (Gamma radiation).
6. The other radiation field that you will work in for 40 minutes is 1200 mrem/hour (Gamma radiation).
7. The dose in the travel path to the CUPS room is 1800 mrem/hr.
8. Travel time through the 1800 mrem/hr field to the CUPS area is 6 minutes EACH WAY.

#### INITIATING CUES:

Calculate the Total exposure you will receive for the job.

Determine if any Administrative Radiation Exposure Limits will be exceeded.

Considering your current exposure (**1400 mrem**) and that which will be received from this job, determine the HIGHEST AUTHORIZATION who must authorize the exposure, if anyone, IAW 60AC-HPX-001-0.

| STEP<br># | PERFORMANCE STEP | STANDARD | SAT/UNSAT<br>(COMMENTS) |
|-----------|------------------|----------|-------------------------|
|-----------|------------------|----------|-------------------------|

For **INITIAL** Operator Programs:

**For OJT/OJE**; ALL PROCEDURE STEPS must be completed for Satisfactory Performance.

**For License Examinations**; ALL CRITICAL STEPS must be completed for Satisfactory Performance.

|             | IF  | THEN   |
|-------------|---|--|
| <b>PASS</b> | <input type="checkbox"/> Human performance tools, safety, PPE met (1), <b>AND</b><br><input type="checkbox"/> For initial trg <b>all</b> steps completed correctly OR<br><input type="checkbox"/> For continuing trg, <b>critical</b> steps (if used) completed correctly | <input type="checkbox"/> Mark the JPM as a <b>PASS</b> |
| <b>FAIL</b> | <input type="checkbox"/> Above standards not met  | <input type="checkbox"/> Mark the JPM as a <b>FAIL</b> |

(1) The standard for human performance tools, safety, PPE, and other pertinent expectations is considered met provided any deviations are minor and have little or no actual or potential consequence. Errors may be self-corrected provided the action would not have resulted in significant actual or potential consequences. Reference: NMP-TR-111, "On-The-Job Training and Task Performance Evaluation".

**START  
TIME:** \_\_\_\_\_

**NOTE:** If the applicant addresses 8.1.2.1 which states: Prior to an individual's first work assignment in which the individual is likely to receive in excess of 2% of the limits in 8.1.1, the individual **MUST** submit a signed statement indicating the amount of occupational radiation exposure received during the current calendar year from sources of radiation possessed by other licensees. **INFORM** the applicant that this form has been signed.

|             |   |  |  |
|-------------|---|--|--|
| <b>**1.</b> | The applicant calculates exposure in the 4,500 mrem/hour field. | $\frac{(4,500 \text{ mrem/hr}) \times 20 \text{ min}}{60 \text{ min}}$ <p style="text-align: center;"><b>1500 mrem</b><br/>(± 1% to accomodate rounding)</p> |  |
|-------------|---|--|--|

|             |  |  |  |
|-------------|--|--|--|
| <b>**2.</b> | The applicant calculates exposure in the 1200 mrem/hour field. | $\frac{(1200 \text{ mrem/hr}) \times 40 \text{ min}}{60 \text{ min}}$ <p style="text-align: center;"><b>800 mrem</b><br/>(± 1% to accomodate rounding)</p> |  |
|-------------|--|--|--|

| STEP # | PERFORMANCE STEP   | STANDARD   | SAT/UNSAT (COMMENTS) |
|--------|--|--|----------------------|
| **3.   | The applicant calculates the dose received from travel time. | $\frac{(1800 \text{ mrem/hr})}{60 \text{ min}} \times 6 \text{ min} \times 2 \text{ trips}$ $= 360 \text{ mrem}$ |                      |
| **4.   | The applicant calculates total exposure for the job:         | $1500 (\pm 1\%)$ $800 (\pm 1\%)$ $\underline{360}$ $2660 \text{ mrem Total } (\pm 1\%)$                          |                      |

**NOTE:** 2660 mrem ( $\pm 1\%$ ) is the Total Exposure for the job.

|      |  |  |  |
|------|--|--|--|
| **5. | The applicant calculates their total exposure performing the job:  | $1400$ $1500 (\pm 1\%)$ $800 (\pm 1\%)$ $\underline{360}$ $4060 \text{ mrem Total } (\pm 1\%)$ |  |
| **6. | The applicant determines that the Hatch Annual Administrative Radiation Exposure limit will be exceeded while performing the work. | The Hatch Administrative limits are 2,000 and 4000 mrem/year. (60AC-HPX-001-0 step 8.2.1)      |  |

**NOTE:** The applicant may address being on the Margin List when within 400 mrem of the administrative exposure limit. It is NOT necessary for the applicant to discuss the requirements of the margin list for this JPM.

**PROMPT:** IF the applicant addresses the margin list, **STATE** that the Health Physics department is taking appropriate actions for Margin List requirements based on expected exposures for this job.



| STEP<br># | PERFORMANCE STEP  | STANDARD   | SAT/UNSAT<br>(COMMENTS) |
|-----------|---|--|-------------------------|
| **7.      | The applicant determines the authorization requirements to exceed the Annual Administrative limits. | With available exposure confirmed, the HIGHEST authorization must be written approval from the Plant Manager. (Step 8.2.2) |                         |

END  
TIME: \_\_\_\_\_

**NOTE:** The terminating cue shall be given to the Operator when:

- After JPM step #7 is complete.
- With no reasonable progress, the Operator exceeds double the allotted time.
- Operator states the task is complete.

**TERMINATING CUE:** We will stop here.

**EVALUATOR – PICK UP** the Initiating Cue sheet.

## UNIT 2

### READ TO THE APPLICANT

#### INITIAL CONDITIONS:

1. You are a radiation worker at Hatch and have been assigned to perform a job in the Unit 2 Clean Up Phase Separator (CUPS) room.
2. Gamma radiation is the only type of radiation of concern for this particular job (no airborne, beta or alpha).
3. Your job inside the CUPS room, will take 1 hour.
4. Your total exposure (TEDE) for the year so far has been confirmed to be 1400 mrem.
5. One of the radiation fields you will work in for 20 minutes is 4500 mrem/hour (gamma radiation).
6. The other radiation field that you will work in for 40 minutes is 1200 mrem/hour (gamma radiation).
7. The dose in the travel path to the CUPS room is 1800 mrem/hr.
8. Travel time through the 1800 mrem/hr field to the CUPS area is 6 minutes EACH WAY.

#### INITIATING CUES:

Calculate the total exposure you will receive for the job.

Determine if any administrative radiation exposure limits will be exceeded.

Considering your current exposure (**1400 mrem**) and that which will be received from this job, determine the HIGHEST AUTHORIZATION who must authorize the exposure, if anyone, IAW 60AC-HPX-001-0.

**FINAL**

**Southern Nuclear  
E. I. Hatch Nuclear Plant**

**Operations Training  
JPM**

**Admin 6- SRO ONLY**

|   |                     |                      |
|---|---------------------|----------------------|
| <b>TITLE</b>  |                     |                      |
| <b>EMERGENCY CLASSIFICATION AND NOTIFICATION (NEW EALS)</b> |                     |                      |
| <b>AUTHOR</b>   | <b>MEDIA NUMBER</b> | <b>TIME CRITICAL</b> |
| Anthony Ball  | 2012-301 ADMIN-6    | 15.0/15.0 Minutes    |
| <b>RECOMMENDED BY</b>                                       | <b>APPROVED BY</b>  | <b>DATE</b>          |
| N/R   | C. M. EDMUND        | 06/07/2012           |



**SOUTHERN NUCLEAR OPERATING COMPANY  
PLANT E. I. HATCH**

Page 1 of 1

**FORM TITLE: TRAINING MATERIAL REVISION SHEET**

Program/Course Code: **OPERATIONS TRAINING**

Media Number: 2012-301 ADMIN-6

[illegible]

UNIT 1 (X) UNIT 2 (X)

**TASK TITLE:** Emergency Classification and Notification (NEW EALS)**JPM NUMBER:** 2012-301 ADMIN-6**TASK STANDARD:** The task shall be completed when the event has been classified per NMP-EP-110, the EN form NMP-EP-111 Figure 1 has been completed, and offsite notifications have been directed.**TASK NUMBER:** 200.052**OBJECTIVE NUMBER:** 200.052.A**PLANT HATCH JTA IMPORTANCE RATING:****RO** 4.67**SRO** 4.04**K/A CATALOG NUMBER:** Generic 2.4.41**K/A CATALOG JTA IMPORTANCE RATING:****RO** 2.9**SRO** 4.6**OPERATOR APPLICABILITY:** Senior Reactor Operator (SRO)

|                            |                                       |
|----------------------------|---------------------------------------|
| <b>GENERAL REFERENCES:</b> | <b>Unit 1 &amp; 2</b>                 |
|                            | NMP-EP-110 (current version)          |
|                            | NMP-EP-111 (current version)          |
| <b>REQUIRED MATERIALS:</b> | <b>Unit 1 &amp; 2</b>                 |
|                            | NMP-EP-110 (current version)          |
|                            | NMP-EP-111 FIGURE 1 (current version) |

**APPROXIMATE COMPLETION TIME:** 15.0/15.0 Minutes**SIMULATOR SETUP:** N/A

# **EVALUATOR COPY**

## **UNIT 1 & 2**

### **READ TO THE OPERATOR**

#### **INITIAL CONDITIONS:**

1. **Unit 2** is in a LOSP due to a failure of the 2D and 2C SUTs.
2. The Reactor scrammed and All rods fully inserted on the scram signal.
3. For the last 15 minutes, Only Emergency Diesel 2A has been running and is supplying power to 2E 4160 VAC bus.
4. Emergency Diesel Generators 1B and 2C start attempts have not been successful.
5. All other Unit 2 parameters are normal.
6. The following Unit 1 conditions exists:  
100% power  
All parameters normal

#### **INITIATING CUES:**

**Determine** the emergency classification that should be declared.

**Complete** the EN form NMP-EP-111 Figure 1 for offsite notifications.

**Direct** the operator to make the proper offsite notifications.

**Current time is:** \_\_\_\_\_

**THIS IS TIME CRITICAL.**

| STEP # | PERFORMANCE STEP | STANDARD | SAT/UNSAT (COMMENTS) |
|--------|------------------|----------|----------------------|
|--------|------------------|----------|----------------------|

For **INITIAL** Operator Programs:

**For OJT/OJE**; ALL PROCEDURE STEPS must be completed for Satisfactory Performance.

**For License Examinations**; ALL CRITICAL STEPS must be completed for Satisfactory Performance.

|             | IF  | THEN   |
|-------------|---|--|
| <b>PASS</b> | <input type="checkbox"/> Human performance tools, safety, PPE met (1), <b>AND</b><br><input type="checkbox"/> For initial trg <b>all</b> steps completed correctly OR<br><input type="checkbox"/> For continuing trg, <b>critical</b> steps (if used) completed correctly | <input type="checkbox"/> Mark the JPM as a <b>PASS</b> |
| <b>FAIL</b> | <input type="checkbox"/> Above standards not met  | <input type="checkbox"/> Mark the JPM as a <b>FAIL</b> |

(1) The standard for human performance tools, safety, PPE, and other pertinent expectations is considered met provided any deviations are minor and have little or no actual or potential consequence. Errors may be self-corrected provided the action would not have resulted in significant actual or potential consequences. Reference: NMP-TR-111, "On-The-Job Training and Task Performance Evaluation".

**NOTE:** For the completion of this JPM, there is **TWO SEPARATE CLOCKS**.

The **CLASSIFICATION** must be made within 15 minutes of the initial prompt.

When the classification is made, a second clock starts. The EN form and direction to make the **NOTIFICATIONS MUST BE COMPLETED WITH 15 MINUTES** of that clock start.

**1<sup>st</sup> START TIME:** \_\_\_\_\_

|             |   |   |  |
|-------------|---|---|--|
| <b>1.</b>   | Operator identifies the procedure needed to perform the task. | Operator has identified the correct procedure as NMP-EP-110.            |  |
| <b>**2.</b> | Operator classified event per NMP-EP-110.                     | Operator has <b>CLASSIFIED</b> the event as an <b>ALERT EMERGENCY</b> . |  |

**NOTE:** The expected classification is an **ALERT** based on IC# SA5, Single power source to the ESF busses and an additional failure will result in a station blackout. If follow-up questioning reveals that a classification was declared and based on another IC #, the classification should be evaluated for validity.

**1<sup>st</sup> END TIME:** \_\_\_\_\_

(\*\* Indicates critical step)

| STEP<br># | PERFORMANCE STEP | STANDARD | SAT/UNSAT<br>(COMMENTS) |
|-----------|------------------|----------|-------------------------|
|-----------|------------------|----------|-------------------------|

**NOTE:** The classification **IS MADE** when the operator **STATES OR WRITES** the classification. This starts the second clock.

**PROMPT:** **WHEN** the operator enquires about Meteorological conditions, **GIVE** the operator the MIDAS Information Sheet.

**2<sup>nd</sup> START  
TIME:** \_\_\_\_\_

|             |   |  |  |
|-------------|---|--|--|
| <b>**3.</b> | Operator properly completes the EN form per NMP-EP-111. | Operator has properly <b>COMPLETED</b> NMP-EP-111 FIGURE 1, "Southern Nuclear Emergency Notification form. |  |
|-------------|---|--|--|

**NOTE:** To successfully complete the EN form, **ALL STEPS HIGHLIGHTED IN YELLOW** must be properly completed.

To be properly completed, the EN form must have all the required steps completed with correct information. **APPLICABLE HIGHLIGHTED** steps must contain sufficient information to describe the event.

|             |   |  |  |
|-------------|---|--|--|
| <b>**4.</b> | Operator directs an operator to make the EN notifications | Operator has <b>DIRECTED</b> the Nuclear Plant Operator to make the required EN notifications. |  |
|-------------|---|--|--|

**2<sup>nd</sup> END  
TIME:** \_\_\_\_\_

**NOTE:** The terminating cue shall be given to the Operator when:

- After JPM step #4 is complete.
- With no reasonable progress, the Operator exceeds double the allotted time.
- Operator states the task is complete.

**TERMINATING CUE:** We will stop here.

**EVALUATOR – PICK UP** the Initiating Cue sheet.

(\*\* Indicates critical step)



# ATTACHMENT 1 \*\* KEY \*\* DO NOT GIVE TO APPLICANT

## Southern Nuclear Operating Company



### Emergency Implementing Procedure

### Emergency Notifications

NMP-EP-111  
Version 7.1  
Page 35 of 47

Figure 1 – Emergency Notification Form (page 1 of 2)

1. ☒ DRILL ☐ ACTUAL EVENT MESSAGE # \_\_\_\_\_  
2. ☒ INITIAL ☐ FOLLOW-UP NOTIFICATION: TIME \_\_\_\_\_ DATE \_\_\_\_/\_\_\_\_/\_\_\_\_ AUTHENTICATION # \_\_\_\_\_  
3. SITE: Plant Hatch Confirmation Phone # \_\_\_\_\_

4. EMERGENCY CLASSIFICATION: ☐ UNUSUAL EVENT ☒ ALERT ☐ SITE AREA EMERGENCY ☐ GENERAL EMERGENCY  
BASED ON EAL# SA5 EAL DESCRIPTION: Single power source to the Emergency busses and an additional failure will result in a station blackout. (OR similar words describing SA5)

5. PROTECTIVE ACTION RECOMMENDATIONS: ☒ NONE  
☐ EVACUATE \_\_\_\_\_  
☐ SHELTER \_\_\_\_\_  
☐ Advise Remainder of EPZ to Monitor Local Radio/TV Stations/Tone Alert Radios for Additional Information and Consider the use of KI (potassium iodide) in accordance with State plans and policy.  
☐ OTHER \_\_\_\_\_

6. EMERGENCY RELEASE: ☒ None ☐ Is Occurring ☐ Has Occurred

7. RELEASE SIGNIFICANCE: ☒ Not applicable ☐ Within normal operating limits ☐ Above normal operating limits ☐ Under evaluation

8. EVENT PROGNOSIS: ☐ Improving ☒ Stable ☐ Degrading

9. METEOROLOGICAL DATA: Wind Direction from 130 degrees\* Wind Speed 5.0 mph\*  
(\*May not be available for Initial Notifications)\* Precipitation 0.00\* Stability Class\* ☐ A ☐ B ☐ C ☒ D ☐ E ☐ F ☐ G

☒ DECLARATION ☐ TERMINATION Time Within 15 Minutes of "Current Time" Date Today's Date

11. AFFECTED UNIT(S): ☐ 1 ☒ 2 ☒ All

12. UNIT STATUS: (Unaffected Unit(s) Status Not Required for Initial Notifications) ☐ U1 100 % Power Shutdown at Time \_\_\_\_\_ Date \_\_\_\_/\_\_\_\_/\_\_\_\_  
☒ U2 0 % Power Shutdown at Time 15 Minutes before "Current Time" Date Today's Date

13. REMARKS: May or may NOT write "NONE" or may give comments, either is acceptable.  
\*\* Step 11 is NOT critical if Unit 2 is identified in step 13. "Remarks" or another place on this form.

## FOLLOW-UP INFORMATION (Lines 14 through 16 Not Required for Initial Notifications)

EMERGENCY RELEASE DATA NOT REQUIRED IF LINE 6 A IS SELECTED.

14. RELEASE CHARACTERIZATION: TYPE: ☐ Elevated ☐ Mixed ☐ Ground UNITS: ☐ Ci ☐ Ci/sec ☐  $\mu$ Ci/sec  
MAGNITUDE: Noble Gases: \_\_\_\_\_ Iodines: \_\_\_\_\_ Particulates: \_\_\_\_\_ Other: \_\_\_\_\_  
FORM: ☐ Airborne Start Time \_\_\_\_\_ Date \_\_\_\_/\_\_\_\_/\_\_\_\_ Stop Time \_\_\_\_\_ Date \_\_\_\_/\_\_\_\_/\_\_\_\_  
☒ Liquid Start Time \_\_\_\_\_ Date \_\_\_\_/\_\_\_\_/\_\_\_\_ Stop Time \_\_\_\_\_ Date \_\_\_\_/\_\_\_\_/\_\_\_\_

15. PROJECTION PARAMETERS: Projection period: \_\_\_\_\_ Hours Estimated Release Duration \_\_\_\_\_ Hours  
Projection performed: Time \_\_\_\_\_ Date \_\_\_\_/\_\_\_\_/\_\_\_\_ Accident Type: \_\_\_\_\_

16. PROJECTED DOSE: DISTANCE TEDE (mrem) Adult Thyroid CDE (mrem)  
Site boundary \_\_\_\_\_  
2 Miles \_\_\_\_\_  
5 Miles \_\_\_\_\_  
10 Miles \_\_\_\_\_

17. APPROVED BY: \_\_\_\_\_ Applicants' Signature Title Emergency Director (ED) Time Within 15 Minutes Of Declaration Time Date Today's Date

NOTIFIED BY: \_\_\_\_\_

RECEIVED BY: \_\_\_\_\_ Time \_\_\_\_\_ Date \_\_\_\_/\_\_\_\_/\_\_\_\_  
(To be completed by receiving organization)

# MIDAS INFORMATION

## METEOROLOGICAL

10M WIND SPD  
1Y33-R601  
5.0

100M WIND SPD  
1Y33-R603  
5.0

10M WIND DIR  
1Y33-R601  
130

100M WIND DIR  
1Y33-R603  
130

AMBIENT TEMP  
(F) 10M  
54

DELTA T  
60-10  
-1.6

DELTA T  
100-10  
-2.9

RAINFALL  
15 MIN. AVG  
.000

## RADIOLOGICAL

### MAIN STACK

NORMAL RANGE KAMAN  
1D11-K600A 1D11-R631  
2.00E 01

1D11-K600B  
2.00E 01

STABILITY CLASS  
D

### U1 RX. BLDG. VENT

NORMAL RANGE KAMAN  
1D11-K619A 1D11-R631  
5.04E 01

1D11-K619B

### U2 RX. BLDG. VENT

NORMAL RANGE KAMAN  
2D11-K636A 2D11-R631  
4.00E 01

2D11-K636B  
4.00E 01

## **UNIT 1 & 2**

### **READ TO THE OPERATOR**

#### **INITIAL CONDITIONS:**

1. **Unit 2** is in a LOSP due to a failure of the 2D and 2C SUTs.
2. The Reactor scrammed and All rods fully inserted on the scram signal.
3. For the last 15 minutes, Only Emergency Diesel 2A has been running and is supplying power to 2E 4160 VAC bus.
4. Emergency Diesel Generators 1B and 2C start attempts have not been successful.
5. All other Unit 2 parameters are normal.
6. The following Unit 1 conditions exists:  
100% power  
All parameters normal

#### **INITIATING CUES:**

**Determine** the emergency classification that should be declared.

**Complete** the EN form NMP-EP-111 Figure 1 for offsite notifications.

**Direct** the operator to make the proper offsite notifications.

**Current time is:** \_\_\_\_\_

**THIS IS TIME CRITICAL.**