



NUREG-0800

U.S. NUCLEAR REGULATORY COMMISSION

STANDARD REVIEW PLAN

3.7.1 SEISMIC DESIGN PARAMETERS

REVIEW RESPONSIBILITIES

Primary - Organization responsible seismic and structural analysis reviews

Secondary - None

I. AREAS OF REVIEW

The specific areas of review are as follows:

1. Design Ground Motion. For the seismic design of nuclear power plants, it is customary to specify the design earthquake ground motion that is exerted on the plant structures or on the soil-structure interacting systems. The design earthquake ground motion, also known as the seismic input motion or control motion, is based on the seismicity and geologic conditions at the site and expressed in such a manner that it can be applied to the dynamic analysis of structures, systems, and components (SSCs). Two levels of

Draft Revision 4 - December 2012

USNRC STANDARD REVIEW PLAN

This Standard Review Plan (SRP), NUREG-0800, has been prepared to establish criteria that the U.S. Nuclear Regulatory Commission (NRC) staff responsible for the review of applications to construct and operate nuclear power plants intends to use in evaluating whether an applicant/licensee meets the NRC regulations. The SRP is not a substitute for the NRC regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide an acceptable method of complying with the NRC regulations.

The SRP sections are numbered in accordance with corresponding sections in Regulatory Guide (RG) 1.70, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)." Not all sections of RG 1.70 have a corresponding review plan section. The SRP sections applicable to a combined license application for a new light-water reactor (LWR) are based on RG 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)."

These documents are made available to the public as part of the NRC policy to inform the nuclear industry and the general public of regulatory procedures and policies. Individual sections of NUREG-0800 will be revised periodically, as appropriate, to accommodate comments and to reflect new information and experience. Comments may be submitted electronically by email to NRR_SRP@nrc.gov

Requests for single copies of SRP sections (which may be reproduced) should be made to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Reproduction and Distribution Services Section, or by fax to (301) 415-2289; or by email to DISTRIBUTION@nrc.gov. Electronic copies of this section are available through the NRC public Web site at <http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr0800/>, or in the NRC Agencywide Documents Access and Management System (ADAMS), at <http://www.nrc.gov/reading-rm/adams.html>, under Accession # ML.12352A305.

design earthquake ground motions are considered: 1) operating basis earthquake (OBE) and 2) safe shutdown earthquake (SSE). The ground motion response spectra (GMRS) in the free-field for use in developing the OBE and SSE design ground motion are needed for the design of nuclear power plant SSCs. The three spatial components of the design ground motions (two horizontal and one vertical) are reviewed. The design ground motion for the OBE and SSE should be consistent with the description of the free-field ground motion at the site provided in Standard Review Plan (SRP) Section 2.5.2, which includes the variation in and distribution of ground motion in the free field, sources and directions of motion, propagation and transmission of seismic waves, and other site response characteristics. The seismic free-field ground motions can be developed based on Regulatory Guides (RGs) 1.60 or 1.208, and they are reviewed under SRP Section 2.5.2. These RGs provide procedures that are acceptable to the staff for defining the GMRS in the free-field for use in developing the OBE and SSE design ground motion needed for the design of nuclear power plant SSCs. The GMRS are site-specific ground spectra determined on the ground surface or as free-field outcrop motions on the uppermost in-situ competent material. The site-specific GMRS at the foundation level in the free-field is referred to as the foundation input response spectra (FIRS). Both the GMRS and the FIRS are defined as free-field outcrop spectra (not including any soil layers above that elevation). Further information on the development of the GMRS and FIRS is described in ISG-01 and ISG-17. The GMRS satisfy the requirements of Title 10 of the *Code of Federal Regulations* (10 CFR) 100.23 with respect to the development of the SSE.

- The site-specific GMRS, reviewed under SRP Section 2.5.2, are determined in the free-field on the ground surface. For sites with soil layers near the surface that will be completely excavated to expose competent material, the GMRS are specified on an outcrop or a hypothetical outcrop that will exist after excavation. Motions at this hypothetical outcrop should be developed as a free surface motion, not as an in-column motion. Competent material is defined as in-situ material having a minimum shear wave velocity of 1,000 feet/second (fps). If non-competent material is present, any excavation and/or backfilling should not alter the development or location of the GMRS. However, the soft soil or backfill material needs to be considered in the soil-structure-interaction (SSI) or other analyses.
- In addition, 10 CFR Part 50, Appendix S is applicable to applications for a design certification (DC) or combined license (COL) pursuant to 10 CFR Part 52 or a construction permit (CP) or operating license (OL) pursuant to 10 CFR Part 50 submitted on or after January 10, 1997. Applications subject to this appendix must:
 - Demonstrate that the SSE ground motion in the horizontal direction in the free-field at the foundation level of the structures must be an appropriate response spectrum with a peak ground acceleration of at least 0.1g.
 - Design SSCs to the OBE and SSE loadings. However, if the OBE is set at one-third or less of the SSE, an explicit analysis or design is not required. If the OBE is set at a

value greater than one-third of the SSE, an analysis and design must be performed for the OBE to demonstrate that the applicable stress, strain, and deformation limits of the SSCs are satisfied. The magnitude of the OBE in the application is reviewed to determine whether a seismic analysis is required for this earthquake level. Throughout this SRP section, whenever the OBE is discussed, it is understood that it may not apply to the particular licensing application being reviewed depending on the magnitude of the OBE as defined above.

- A. Design Response Spectra. Design response spectra are used in the design of seismic Category I SSCs, and they are generally specified at the top of the ground surface in the free-field or at the top of the first layer of competent material as outcrop motion if soil layers near the surface will be completely excavated to the competent material. The proposed design response spectra for the OBE and SSE are reviewed against the free-field site-specific GMRS that are reviewed and accepted under SRP Section 2.5.2. The design response spectra, in general, are relatively smooth plots not exhibiting random peaks and valleys. The use of smooth spectra is preferred in the design and is needed for generic site seismic hazard evaluation, as in the design of a standard plant. The use of unsmoothed design response spectra to develop the input ground motion (design time history) will be reviewed on a case-by-case basis.

A review is also made of the approach used to demonstrate that the horizontal component of the SSE ground motion in the free-field at the foundation level of seismic Category I structures is an appropriate response spectrum with a peak ground acceleration of at least 0.1 g, as required by Appendix S to 10 CFR Part 50.

- B. Design Time Histories. Acceleration time histories for computing the response of seismic Category I SSCs are reviewed. The extent to which these time histories are compatible with the design response spectra are reviewed.

When an appropriate recorded or specified time history is not available as input ground motion for seismic system analysis, the three spatial components of artificial time histories may be generated from the design response spectra for the purpose of carrying out a time history analysis of the SSCs. In demonstrating the statistical independence of the three components of ground motion, the correlation coefficients between the time histories are reviewed. The response spectra obtained from such artificial time histories of ground motion should generally envelop the design response spectra for all damping values to be used. The procedures used to generate response spectra from the artificial time histories and the comparisons of these response spectra with the design response spectra are reviewed.

In addition to the comparison of the response spectra derived from the ground motion time histories with the design response spectra, the frequency intervals at which the spectral values are calculated are also reviewed.

When time history analyses are performed, either of the following options

may be considered. In either case, the time histories may be real or artificial.

Option 1: Single Set of Time Histories. The justification for the use of the single set of time histories is reviewed. The approach used to demonstrate that the response spectra generated from the time histories envelop the design response spectra are reviewed. Depending on the approach used, the application of the requirements to match a target power spectral density (PSD) function compatible with the design response spectra may also need to be reviewed.

Option 2: Multiple Sets of Time Histories. In lieu of the use of a single time history, multiple artificial or real ground motion time histories may be used for the seismic analyses and design of the SSCs. The parameters describing the time histories and the number of time histories are reviewed. The approach used to demonstrate the adequacy of the set of multiple time histories, in terms of the enveloping requirements and having sufficient power over the frequency range of interest, is reviewed.

In some instances, a nonlinear analysis of the SSCs may be appropriate (e.g., the evaluation of existing structures). Multiple time history analyses incorporating real earthquake time histories are appropriate when such analyses are proposed. The adequacy of time histories used for the nonlinear analyses is reviewed.

2. Percentage of Critical Damping Values. The percentage of critical damping values used for the seismic analysis of Category I SSCs is reviewed for both the OBE and the SSE. Critical damping is the amount of damping that would completely eliminate free vibration and is an important measure of the damping capacity of a structure.

Vibrating SSCs have energy losses that depend on numerous factors, such as material characteristics, stress levels, and geometric configuration. This dissipation of energy, or damping effect, occurs because a part of the excitation input is transformed into heat, sound waves, and other energy forms. The response of a system to dynamic loads is a function of the amount and type of damping existing in the system. Knowledge of appropriate values to represent this characteristic is essential for obtaining realistic results in any dynamic analysis.

In practical seismic analysis, which usually employs linear methods of analysis, damping is also used to account for many nonlinear effects such as changes in boundary conditions, joint slippage, concrete cracking, gaps, and other effects that tend to alter response amplitude. In real structures, it is often impossible to separate "true" material damping from system damping, which is the measure of the energy dissipation, from the nonlinear effects. Overall structural damping used in design is normally determined by observing experimentally the total response of the structure.

Damping values assigned to members of seismic Category I SSCs, including material damping and system damping, are reviewed. When applicable, the basis for any damping values that differ from those given in RG 1.61 is reviewed.

3. Supporting Media for Seismic Category I Structures. The description of the supporting

media for each seismic Category I structure is reviewed, including foundation embedment depth, depth of soil over bedrock, soil layering characteristics, highest groundwater elevation, dimensions of the structural foundation, total structural height, topographical conditions of the sites, and soil properties to permit evaluation of the applicability of finite-element or lumped-spring approaches for soil-structure interaction analysis.

4. Review Considerations for DC and COL Applications. For a DC application, the postulated seismic design response spectra are reviewed. The input or control location for the postulated seismic design response spectra is also reviewed. The postulated seismic design response spectra will become the certified seismic design response spectra (CSDRS) when the design receives approval by the Commission under 10 CFR Part 52. For a COL application referencing a certified design, the demonstration that the CSDRS envelops the site-specific GMRS is reviewed.
5. Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC). For DC and COL reviews, the staff reviews the applicant's proposed ITAAC associated with the SSCs (if any are identified related to this SRP section) in accordance with SRP Section 14.3, "Inspections, Tests, Analyses, and Acceptance Criteria." The staff recognizes that the review of ITAAC cannot be completed until after the rest of this portion of the application has been reviewed against acceptance criteria contained in this SRP section. Furthermore, the staff reviews the ITAAC to ensure that all SSCs in this area of review are identified and addressed as appropriate in accordance with SRP Section 14.3.
6. COL Action Items and Certification Requirements and Restrictions. For a DC application, the review will also address COL action items and requirements and restrictions (e.g., interface requirements and site parameters).

For a COL application referencing a DC or early site permit (ESP), a COL applicant must address COL action items (referred to as COL license information in certain DCs) included in the referenced DC or ESP. Additionally, a COL applicant must address requirements and restrictions (e.g., interface requirements, site parameters, and permit conditions) included in the referenced DC or ESP.

COL action items related to seismic design parameters include soil layering assumptions used in the certified design, range of soil parameters, and shear wave velocity values.

Review Interfaces

Other SRP sections interface with this section as follows:

1. Review of geological and seismological information to establish the free-field ground motion is performed under SRP Sections 2.5.1 through 2.5.3.
2. The geotechnical parameters and methods employed in the analysis of free field soil media and the soil properties are reviewed under SRP Section 2.5.4.

3. The seismic system analysis which utilizes the design earthquake ground motion developed in this SRP section are reviewed under SRP Section 3.7.2.
4. The seismic subsystem analysis for some components (e.g., buried piping, tunnels, and atmospheric tanks), which utilize the design earthquake ground motion developed in this SRP section, are reviewed under SRP Section 3.7.3.
5. For DC applications and COL applications referencing a DC rule or DC application, review of the site parameters in the Design Control Document (DCD) Tier 1 and Chapter 2 of the DCD Tier 2¹ submitted by the applicant is performed under SRP Section 2.0, "Site Characteristics/Site Parameters."

The specific acceptance criteria and review procedures are contained in the referenced SRP sections.

The results of the reviews for the OBE and the SSE site-specific free-field ground motion, soil properties, etc., are used as an integral part of the seismic analysis review of Category I SSCs.

II. ACCEPTANCE CRITERIA

Requirements

Acceptance criteria are based on meeting the relevant requirements of the following Commission regulations:

1. 10 CFR Part 50, Appendix A, General Design Criterion (GDC) 2 - The design basis shall reflect appropriate consideration of the most severe earthquakes that have been historically reported for the site and surrounding area with sufficient margin for the limited accuracy, quantity, and period of time in which historical data have been accumulated.
2. 10 CFR Part 50, Appendix S is applicable to applications for a design certification or combined license to 10 CFR Part 52 or a construction permit or operating license pursuant to 10 CFR Part 50 on or after January 10, 1997. Appendix B requires that for SSE ground motions, SSCs will remain functional and within applicable stress, strain, and deformation limits. The required safety functions of SSCs must be assured during and after the vibratory ground motion through design, testing, or qualification methods. The evaluation must take into account soil-structure interaction effects and the expected duration of the vibratory motion. If the OBE is set at one-third or less of the SSE, an explicit analysis or design is not required. If the OBE is set at a value greater than one-third of the SSE, an analysis and design must be performed to demonstrate that the applicable stress, strain, and deformation limits are satisfied. Appendix S also requires that the horizontal component of the SSE ground motion in the free-field at the foundation level of the structures must be an appropriate response spectrum with a peak ground acceleration of at least 0.1g.

¹Additional supporting information of prior DC rules may be found in DCD Tier 2 Section 14.3.

3. 10 CFR 52.47(a)(1) requires a DC applicant provide site parameters postulated for the design.
4. 10 CFR 52.47(b)(1), which requires that a DC application contain the proposed ITAAC that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a plant that incorporates the DC is built and will operate in accordance with the design certification, the provisions of the Atomic Energy Act (AEA), and the U.S. Nuclear Regulatory Commission (NRC) regulations.
5. 10 CFR 52.79(b) for a COL referencing an ESP as it relates to information sufficient to demonstrate that the design of the facility falls within the site characteristics and design parameters specified in the ESP.
6. 10 CFR 52.79(d)(1) for a combined license referencing a DC as it relates to information sufficient to demonstrate that the characteristics of the site fall within the site parameters specified in the DC.
7. 10 CFR 52.80(a), which requires that a COL application contain the proposed inspections, tests, and analyses, including those applicable to emergency planning, that the licensee shall perform, and the acceptance criteria that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, the facility has been constructed and will operate in conformity with the combined license, the provisions of the AEA, and the NRC regulations.

SRP Acceptance Criteria

Specific SRP acceptance criteria acceptable to meet the relevant requirements of the NRC regulations identified above are as follows for the review described in this SRP section. The SRP is not a substitute for the NRC regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide acceptable methods of compliance with the NRC regulations.

1. Design Ground Motion

- A. Design Response Spectra. The site-specific GMRS reviewed under SRP Section 2.5.2 are determined in the free-field on the ground surface. For sites with soil layers near the surface that will be completely excavated to expose competent material, the GMRS is specified on an outcrop or a hypothetical outcrop that will exist after excavation. Motions at this hypothetical outcrop should be developed as a free surface motion, not as an in-column motion. Although the definition of competent material is not mandated by regulation, a number of reactor designs have specified a shear wave velocity of 1000 fps as the definition of competent material, which is considered acceptable. If non-

competent material is present, any excavation and/or backfilling should not alter the development or location of the site-specific GMRS. However, the soft soil or backfill material needs to be considered in the SSI or other analyses. Additional guidance on the development of the GMRS on the ground surface or as free-field outcrop motions and the GMRS at the foundation level in the free-field, referred to as the foundation input response spectra (FIRS), is provided in ISG-01 and ISG-17.

According to Appendix S to 10 CFR Part 50, the minimum peak ground acceleration (PGA) for the horizontal component of the SSE at the foundation level in the free-field should be 0.1g or higher. The response spectrum associated with this minimum PGA should be a smooth broad-band response spectrum (e.g., RG 1.60, or other appropriate shaped spectra if justified) and is defined as an outcrop response spectrum at the free-field foundation level. This response spectrum anchored at 0.1g will be referred in this SRP section as the minimum required response spectrum.

- i. Non-standard Plant Design. For a non-standard plant design (e.g., COL application referencing only an ESP, or a COL application not referencing a CD and ESP), the design response spectra is developed from the site-specific GMRS or from a broad band shaped spectra similar to RG 1.60 which also envelops the site-specific GMRS. Foundation level response spectra consistent with the design response spectra are determined for each seismic Category I structure. These foundation level spectra are compared to the minimum required spectrum to ensure they meet the 0.1g pga requirement in accordance with Appendix S to 10 CFR Part 50. If the foundation level spectra do not bound the minimum required response spectrum, then the design response spectra can be adjusted/modified in order to bound the minimum required spectrum. If the design response spectra are not modified, then the use of the two separate sets of spectra in the analysis and design of SSCs need to be reviewed for adequacy.
- ii. Certified Standard Plant Design (CD). For a DC application, the postulated seismic design response spectra need to bound the minimum required response spectrum anchored at 0.1g (as specified in Appendix S to 10 CFR Part 50). These design response spectra are referred to as the CSDRS when the design is certified by the Commission under 10 CFR Part 52.

For a certified standard plant design (e.g., COL application that references a CD or a COL application that references a CD and ESP), a similar approach described above (under subsection II.1.a.i) is used to ensure that the CSDRS envelop the minimum required response spectrum. Foundation level response spectra consistent with the CSDRS are determined for each seismic Category I structure. These foundation level spectra are compared to the minimum required spectrum to ensure they meet the 0.1g pga requirement in accordance with Appendix S to

10 CFR Part 50. If the foundation level spectra do not bound the minimum required spectrum, then the CSDRS can be adjusted/modified in order to bound the minimum required spectrum. If the CSDRS are not modified, then the use of the two separate sets of spectra in the analysis and design of SSCs need to be reviewed for adequacy.

For evaluation of soil liquefaction and soil/rock stability of slopes that may affect plant safety, the use of the site-specific GMRS rather than the CSDRS is reviewed on a case-by-case basis in accordance with SRP Section 2.5.4.

The free-field design response spectra (also referred to as the CSDRS for a CD) are usually developed for the 5-percent damping value. In the seismic analysis and design, the applicant needs to define the free-field design response spectra corresponding to all damping values to be used. For the case of RG 1.60 response spectra, Tables 1 and 2 of RG 1.60 provide amplification factors at four frequencies for calculating response spectra corresponding to different damping values. For the case of the free-field design response spectra that are different from RG 1.60 response spectra, Appendix C to this SRP section provides procedures to calculate response spectra for different damping values other than 5 percent.

To be acceptable, the seismic design response spectra should be specified for three mutually orthogonal directions - two horizontal and one vertical. Current practice is to assume that the design response spectra (including maximum ground accelerations) in the two horizontal directions are the same.

- B. Design Time Histories. The SSE and OBE design ground motion time histories can be either real time histories or artificial time histories. To be acceptable, the design ground motion time histories should consist of three mutually orthogonal directions - two horizontal and one vertical. For both horizontal and vertical input motions, either a single time history or multiple time histories can be used. When time histories are used, each of the three ground motion time histories must be shown to be statistically independent from the others. Each pair of time histories are considered to be statistically independent if the absolute value of their correlation coefficient does not exceed 0.16. Simply shifting the starting time of a given time history cannot be used to establish a different time history. When the seed time histories are selected from real earthquake records, the response spectra corresponding to the seed record should be similar in shape to the target spectra across the frequency range of interest to the analysis (e.g., Houston, et al., 2010) and phasing characteristics of the real earthquake records should be preserved. If the target spectra include multiple characteristic events, a single recorded earthquake time history may not be able to capture the response characteristics of the target spectra. To this end, the use of multiple time histories may be appropriate in which individual time histories are developed from real earthquake records fairly representing the characteristic events embodied in the target spectra. Alternatively, an artificial time history may be developed using random generation routines or through the use of multiple time

history techniques. If a random time history generator technique is used to develop the seed time histories, then acceptability of the seed will be reviewed on a case-by-case basis.

For linear structural analyses, the total duration of the artificial ground motion time histories should be long enough such that adequate representation of the Fourier components at low frequency is included in the time history. The corresponding stationary phase strong-motion duration should be consistent with the longest duration of strong motion from the earthquakes defined in SRP Section 2.5.2 at low and high frequency and as presented in NUREG/CR-6728. The strong motion duration is defined as the time required for the Arias Intensity to rise from 5 percent to 75 percent. The uniformity of the growth of this Arias Intensity should be reviewed. The minimum acceptable strong motion duration should be six seconds. In addition to the duration, the ratios V/A and AD/V^2 (A , V , D are peak ground acceleration, ground velocity, and ground displacement, respectively) should be consistent with characteristic values for the magnitude and distance of the appropriate controlling events defining the uniform hazard response spectra. These parameters should be consistent with the values determined for the low and high frequency events described in Appendix D of RG 1.208.

For nonlinear structural analysis problems, multiple sets of ground motion time histories should be used to represent the design ground motion. Each set of ground motion time histories shall be selected from real recorded ground motions appropriate for the characteristic low and high frequency events. The amplitude of these ground motions may be scaled but the phasing of Fourier components must be maintained. The adequacy of this set of ground motions, including-duration estimates, is reviewed on a case-by-case basis.

Option 1: Single Set of Time Histories. To be considered acceptable, the response spectra generated from the artificial time history to be used as input ground motion in the free-field should satisfy the enveloping requirements for either Approach 1 or Approach 2 below:

- i. Approach 1. For Approach 1, the spectrum from the artificial ground motion time history must envelop the free-field design response spectra for all damping values used in the seismic response analysis. When spectral values (e.g., spectral accelerations) are calculated from the artificial time history, the frequency intervals at which spectral values are determined are to be sufficiently small. Table 3.7.1-1 (below) provides an acceptable set of frequencies at which the response spectra may be calculated.

Table 3.7.1-1
Suggested Frequency Intervals for Calculation
of Response Spectra

Frequency Range (hertz)	Increment (hertz)
0.2 - 3.0	0.10
3.0 - 3.6	0.15
3.6 - 5.0	0.20
5.0 - 8.0	0.25
8.0 - 15.0	0.50
15.0 - 18.0	1.0
18.0 - 22.0	2.0
22.0 - highest frequency of interest	3.0

Each calculated spectrum of the artificial time history is considered to envelop the design response spectrum when no more than five points fall below, and no more than 10 percent below, the design response spectrum.

Studies indicate that numerically generated artificial ground acceleration histories produce PSD functions having a quite different appearance from one individual function to another, even when all these time histories are generated so as to closely envelop the same design response spectra. For example, the use of the available techniques of generating acceleration time histories that satisfy enveloping RG 1.60 spectra usually results in PSD functions that fluctuate significantly and randomly as a function of frequency. It is also recognized that the more closely one tries to envelop the specified design response spectra, the more significantly and randomly do the spectral density functions tend to fluctuate and these fluctuations may lead to unconservative results for the response of SSCs. Therefore, when a single artificial ground motion time history is used in the design of seismic Category I SSCs, it must satisfy requirements for both enveloping design response spectra as well as adequately matching a target PSD function compatible with the design response spectra. Therefore, in addition to the response spectra enveloping requirement, the use of a single time history should also be justified by demonstrating sufficient energy at the frequencies of interest through the generation of PSD function, which envelops the target PSD function throughout the frequency range of significance.

When RG 1.60 response spectra are used as design response spectra, the requirements for a compatible target PSD are contained in Appendix A to this SRP section. Target PSD functions other than those given in Appendix A can be

used if justified. For design response spectra other than RG 1.60 response spectra, a compatible target PSD should be generated. For generation of target PSD in such cases, the guidelines and procedures provided in Appendix B to this SRP section can be used. Procedures used to generate the target PSD will be reviewed on a case-by-case basis. The PSD requirements are included as secondary and minimum requirements to prevent potential deficiency of power over the frequency range of interest. It should be noted that the ground motion is still primarily defined by the design response spectrum. The use of PSD criteria alone can yield time histories that may not envelop the design response spectrum.

- ii. Approach 2. For Approach 2, the artificial ground motion time histories that are generated to match or envelop the design response spectra shall comply with Steps (a) through (d) below. The general objective is to generate a modified recorded or artificial accelerogram which achieves approximately mean based fit to the target response spectrum; that is, the average ratio of the spectral acceleration calculated from the accelerogram to the target, where the ratio is calculated frequency by frequency, is only slightly greater than “1.” The aim is to achieve an accelerogram that does not have significant gaps in the Fourier amplitude spectrum, but which is not biased high with respect to the target.
 - (a) The time history shall have a sufficiently small time increment and sufficiently long duration. Records shall have a Nyquist frequency of at least 50 Hz, (e.g., a time increment of at most 0.010 seconds) and a total duration of at least 20 seconds. If frequencies higher than 50 Hz are of interest, the time increment of the record must be suitably reduced to provide a Nyquist frequency ($N_f = 1/(2\Delta t)$, where Δt = time increment) above the maximum frequency of interest. The total duration of the record can be increased by zero packing to satisfy these frequency criteria.
 - (b) Spectral acceleration at 5 percent damping shall be computed at a minimum of 100 points per frequency decade, uniformly spaced over the log frequency scale from 0.1 Hz to 50 Hz or the Nyquist frequency. The comparison of the response spectrum obtained from the artificial ground motion time history with the target response spectrum shall be made at each frequency computed in the frequency range of interest.
 - (c) The computed 5 percent damped response spectrum of the accelerogram shall not fall more than 10 percent below the target response spectrum at any one frequency. To prevent response spectra in large frequency windows from falling below the target response spectrum, the response spectra within a frequency window of no larger than ± 10 percent centered on the frequency shall be allowed to fall below the target response spectrum. This

corresponds to response spectra at no more than 9 adjacent frequency points defined in (b) above from falling below the target response spectrum.

- (d) The computed 5 percent damped response spectrum of the artificial ground motion time history shall not exceed the target response spectrum at any frequency by more than 30 percent (a factor of 1.3) in the frequency range of interest. In addition, the power spectrum density of the accelerogram needs to be computed and shown to not have significant gaps in energy at any frequency over this frequency range.

If the artificial ground motion time history, defined in Approach 2-above, is intended to be compatible to a site-specific GMRS, it shall have characteristics consistent with characteristic values for the magnitude and distance of the appropriate controlling events defined for the corresponding uniform hazard response spectrum (UHRS).

Option 2: Multiple Sets of Time Histories. As discussed in Section I.1.B and Section II.1.B of this SRP section, the use of multiple real or artificial time histories for analyses and design of SSCs is acceptable. For linear structural analyses, a minimum of four times histories should be used. For nonlinear structural analyses, the number of time histories must be greater than four and the technical basis for the appropriate number of time histories are reviewed on a case-by-case basis. This review also includes the adequacy of the characteristics of the multiple time histories.

The response spectra calculated for each individual time history need not envelop the design response spectra. However, the multiple time histories are acceptable if the average calculated response spectra generated from these time histories envelop the design response spectra. An acceptable method to demonstrate the adequacy of a set of multiple time histories, in terms of enveloping requirements and having sufficient power over the frequency range of interest, is to follow the procedures described for Approach 2 presented in subsection II.1.B.ii of this SRP. When implementing Approach 2, the criteria in paragraphs (a) and (b) of this approach need to be satisfied for each of the time histories. The criteria in paragraphs (c) and (d) of this approach can be satisfied by utilizing the results for the average of the suite of multiple time histories.

When calculating the response of structures (e.g., accelerations, member forces, and displacements) from linear analyses, the average value of the responses from the multiple time histories may be used. When calculating the response of structures from nonlinear analyses (e.g., seismic evaluation of as-built structures), the average value of the responses from the multiple time histories may be used if at least seven nonlinear time history analyses are performed. Otherwise, the maximum value (i.e., envelope) of the individual responses from the multiple time histories should be used.

In addition, if the extent of the nonlinear response is found to be significant or if the nonlinear response due to one or several time histories is found to be substantially different from the other results, then additional time histories should be considered. If there is a particular ground motion or time history analysis that dominates the response values, it should not be replaced with another motion or analysis to reduce the responses. Also, if a ratcheting effect is noted (e.g., increasing deformation with subsequent cycling of earthquake motion), then the system characteristics should be reviewed to ensure that they have been conservatively considered or the design should be revised to eliminate this behavior.

2. Percentage of Critical Damping Values. The specific percentage of critical damping values used in the analyses of Category I SSCs is considered to be acceptable if they are in accordance with RG 1.61. Damping values different from those listed in RG 1.61 (e.g., higher damping values) may be used in a dynamic seismic analysis if test data are provided to support them. These damping values will be reviewed and accepted by the staff on a case-by-case basis.

In addition, a demonstration of the correlation between stress levels and damping values will be required and reviewed for compliance with the applicable regulatory position in RG 1.61. If other methods for correlation of damping values with stress level are used, they will need to be reviewed and accepted on a case-by-case basis.

The material soil damping for foundation soils must be based upon validated values or other pertinent laboratory data, considering variation in soil properties and strains within the soil, and must include an evaluation of dissipation from pore pressure effects as well as material damping for saturated site conditions. The maximum soil damping value acceptable to the staff is 15 percent.

3. Supporting Media for Seismic Category I Structures. To be acceptable, the description of supporting media for each Category I structure must include foundation embedment depth, depth of soil over bedrock, soil layering characteristics, design groundwater elevation, dimensions of the structural foundation, total structural height, and soil properties such as shear wave velocity, shear modulus, Poisson's ratios, and density as a function of depth. If the minimum shear wave velocity of the supporting foundation material is less than 1,000 fps, additional studies need to be performed which consider the average shear wave velocity, and its degree of variability addressing potential impact on soil-structure interaction, potential settlements and design of foundation elements.
4. Review Considerations for DC and COL Applications
 - A. COL Application Referencing an ESP and DC

In addition to the criteria presented below, Figures 1 and 2 in Appendix D provide additional guidance in understanding the Part 52 process.

- i. Site-specific GMRS are reviewed separately under SRP 2.5.2 for adequacy. For COL application referencing an ESP and DC, the GMRS

are included in the ESP.

- ii. Confirm that the criterion for the minimum required response spectrum (in accordance with subsection II.1.A.ii) has been satisfied.
- iii. Confirm that COL action items contained in the DC have been met. This includes seismic design parameters such as soil layering assumptions used in the certified design, range of soil parameters, shear wave velocity values, and minimum soil bearing capacity. Technical justification for all deviations from the range of values used in the standard plant design must be provided for review.
- iv. Confirm that the ESP conditions have been met or review the COL applicant's approach to address any deviations.
- v. When the site-specific GMRS and the CSDRS, are calculated at the same elevation, confirm that the CSDRS envelop the GMRS. For this case the standard design is acceptable for that site, assuming no other issue is identified during the review process. If the CSDRS do not envelop the site-specific GMRS then proceed to step vii.
- vi. When the site-specific GMRS and the CSDRS are determined at different elevations, calculate the site-specific GMRS transferred to the base elevations of each seismic Category I foundation. These site-specific GMRS at the foundation levels are referred to as FIRS and are derived as free-field outcrop spectra; that is, only the effects of materials that are below the base elevation of the seismic Category I structure are included in the site response analysis. For each seismic Category I structure foundation, if the CSDRS-consistent spectra at the foundation level envelop the site-specific FIRS at the foundation level, the standard design is acceptable for that site, assuming no other issue is identified during the review process. If not, then proceed to step vii.
- vii. Perform an SSI analysis using the site-specific FIRS and an advanced seismic analytical technique (e.g., method that considers the effects of incoherent ground motion). When such analytical methods are utilized, the detailed technical justification shall be reviewed on a case-by-case basis. Further discussion on consideration of the effects of incoherent ground motion is provided in subsection II.4.C (under the heading Input Ground Motion, Specific Guidelines for SSI Analysis) in SRP Section 3.7.2. The in-structure responses in terms of floor response spectra, building member forces, and deformations at key locations in the structure shall be obtained. The key locations for calculating the in-structure responses, proposed by the licensee, need to be evaluated to ensure that they are sufficient to represent the various locations throughout the building. Locations should include responses at peripheral locations to detect rocking and torsion, and should include responses to check overturning, torsional, and sliding stability of the structures. The

dynamic models and analysis techniques need to be sufficiently refined to be able to capture the response of the structures throughout the frequency range of interest, including the high frequency responses, typically expected in the central and eastern United States (CEUS) regions. The SSI analysis shall also consider the site-specific soil variability (i.e., best estimate, lower bound estimate, and upper bound estimate). Compare these responses at the key locations in the structure to the standard design in-structure responses. If the CSDRS responses envelop the in-structure responses from the FIRS, the standard design is acceptable assuming no other issue is identified during the review process. If the responses are not enveloped, additional analyses are required to demonstrate the acceptability of the design or the design might need to be modified. If further analyses are utilized, then the analyses must consider the potentially higher responses at all locations, not only those at the key locations described above.

- B. COL Application Referencing a DC. Follow the same steps described above under A - COL Application Referencing an ESP and DC, except that step iv. does not apply to this case.
- C. COL Application Referencing an ESP. In addition to the criteria presented below, Figure 3 in Appendix D provides additional guidance in understanding the process when a certified design is not used.
- i. Site-specific GMRS are reviewed separately under SRP 2.5.2 for adequacy. For COL application referencing an ESP, the GMRS are included in the ESP.
 - ii. Confirm that the ESP conditions have been met or review the COL applicant's approach to address any deviations.
 - iii. Follow the acceptance criteria described in subsection II.1.A (excluding subsection II.1.A.ii), of this SRP Section to develop the seismic design response spectra. The seismic SSI analysis would then follow the conventional approach for SSI analyses.
- D. COL Application not Referencing an ESP or DC. In addition to the criteria presented below, Figure 3 in Appendix D provides additional guidance in understanding the process when a certified design is not used.
- i. Site-specific GMRS are reviewed separately under SRP 2.5.2 for adequacy.
 - ii. Follow the acceptance criteria described in subsection II.1.A (excluding subsection II.1.A.ii), of this SRP Section to develop the seismic design response spectra. The seismic SSI analysis would then follow the conventional approach for SSI analyses.

Technical Rationale:

The technical rationale for application of these requirements to reviewing this SRP section is discussed in the following paragraphs:

1. GDC 2 requires, in the relevant parts, that SSCs important to safety be designed to withstand the effects of natural phenomena such as earthquakes without loss of capability to perform their intended safety functions. GDC 2 further requires that the design bases reflect appropriate consideration for the most severe natural phenomena that have been historically reported for the site and surrounding area, with sufficient margin for the limited accuracy, quantity, and period of time in which the historical data have been accumulated in the past. These data shall be used to specify the design requirements of nuclear power plant components to be evaluated as part of CP, OL, COL, ESP reviews, or for site parameters in the case of DCs, thereby ensuring that components important to safety will function in a manner that will maintain the plant in a safe condition.

SRP Section 3.7.1 describes acceptance criteria for developing seismic design parameters to assure that they are appropriate and contain sufficient margin such that seismic analyses (reviewed under other SRP sections) accurately and/or conservatively represent the behavior of SSCs during postulated seismic events. Criteria is provided for developing the seismic design ground motion, percentage of critical damping, supporting media, and the technical interface requirements for ESP, DC, and/or COL applications, as well as site acceptability determination. Reference is made to RG 1.60, and 1.208, which provide procedures that are acceptable to the staff for defining seismic ground motion response spectra for input into the seismic design analysis of nuclear power plants SSCs. In addition, RG 1.61 is referenced for guidance of acceptable damping values to be used in performing dynamic analyses of SSCs.

Meeting these requirements provides assurance that seismic Category I SSCs will be adequately designed to withstand the effects of earthquakes, and thus, will be able to perform their intended safety function.

2. 10 CFR Part 50, Appendix S is applicable to applications for a design certification or combined license to 10 CFR Part 52 or a construction permit or operating license pursuant to 10 CFR Part 50 on or after January 10, 1997. For SSE ground motions, 10 CFR Part 50, Appendix S requires that SSCs will remain functional and within applicable stress, strain, and deformation limits. The required safety functions of SSCs must be assured during and after the vibratory ground motion through design, testing, or qualification methods. The evaluation must take into account SSI effects and the expected duration of the vibratory motion. If the OBE is set at one-third or less of the SSE, an explicit analysis or design is not required. If the OBE is set at a value greater than one-third of the SSE, an analysis and design must be performed to demonstrate that the applicable stress, strain, and deformation limits are satisfied. Appendix S also requires that the horizontal component of the SSE ground motion in the free-field at the foundation level of the structures must be an appropriate response spectrum with a peak ground acceleration of at least 0.1g.

SRP Section 3.7.1 describes acceptance criteria for developing the required earthquake loadings consisting of the SSE and OBE (if applicable) and other seismic design parameters needed to perform an SSI analysis. This SRP section indicates that an explicit analysis for the OBE, in addition to the SSE, should be performed unless the magnitude of the OBE is set at one-third or less of the SSE. Criteria for the required characteristics of the earthquake motion are presented which include the duration of the seismic ground motion. SRP Section 3.7.1 also specifies that the horizontal free-field SSE ground motion at the foundation level shall be represented by an appropriate response spectrum, such as that defined in RG 1.60, with a minimum peak ground acceleration of 0.1g. The criteria presented in this SRP section provide the earthquake loadings and seismic design parameters so that the SSI analysis can determine the response of the SSCs in terms of stresses, strains, and deformations. In addition, the use of these criteria allows the SSI analysis to calculate the floor response spectra for use in qualification of equipment.

Meeting these requirements provides assurance that appropriate methods will be used to determine the required OBE and SSE loadings and the response of SSCs, which will ensure that they will remain functional within applicable acceptance limits.

III. REVIEW PROCEDURES

The reviewer will select material from the procedures described below, as may be appropriate for a particular case.

These review procedures are based on the identified SRP acceptance criteria. For deviations from these acceptance criteria, the staff should review the applicant's evaluation of how the proposed alternatives provide an acceptable method of complying with the relevant NRC requirements identified in Subsection II.

1. Design Ground Motion

- A. Design Response Spectra. For the non-standard plant design (i.e., COL application that does not reference a DC), the design response spectra for the OBE and SSE, for all applicable damping values, are checked to ensure that the response spectra are in accordance with the acceptance criteria as given in subsection II.1.A.i. For the DC, the CSDRS for the OBE and SSE for applicable damping values are checked to ensure that the CSDRS are in accordance with the acceptance criteria as given in subsection II.1.A.ii. Any deviations from the acceptance criteria applicable to the development of the design response spectra or CSDRS that have not been adequately justified are identified, and the applicant is informed of the need for additional technical justification.
- B. Design Time History. Methods of defining the design ground motion time histories are reviewed to confirm that the acceptance criteria of subsection II.1.B of this SRP section are met.

2. Percentage of Critical Damping Values. The specific percentage of critical damping values for the OBE and SSE used in the analyses of Category I SSCs are checked to

ensure that the damping values are in accordance with the acceptance criteria as given in subsection II.2 of this SRP section. Any differences in damping values that have not been adequately justified are identified, and the applicant is informed of the need for additional technical justification.

3. Supporting Media for Seismic Category I Structures. The description of the supporting media is reviewed to verify that sufficient information, as specified in the acceptance criteria of subsection II.3 of this SRP section, is included.
4. Review Considerations for DC and COL Applications. The information provided by the applicant to address the review considerations in the SRP acceptance criteria of subsection II.4 of this SRP section is reviewed. The review should conclude that the CSDRS envelop the site-specific GMRS. In addition, the review should conclude that the applicant addressed the identified COL action items. If compliance with these acceptance criteria are not achieved, then the technical basis for alternative methods need to be provided by the applicant for review and approval.

For review of a DC application, the reviewer should follow the above procedures to verify that the design, including requirements and restrictions (e.g., interface requirements and site parameters), set forth in the Final Safety Analysis Report (FSAR) meets the acceptance criteria. DCs have referred to the FSAR as the DCD. The reviewer should also consider the appropriateness of identified COL action items. The reviewer may identify additional COL action items; however, to ensure these COL action items are addressed during a COL application, they should be added to the DC FSAR.

For review of a COL application, the scope of the review is dependent on whether the COL applicant references a DC, an ESP or other NRC approvals (e.g., manufacturing license, site suitability report or topical report).

For review of both DC and COL applications, SRP Section 14.3 should be followed for the review of ITAAC. The review of ITAAC cannot be completed until after the completion of this section.

IV. EVALUATION FINDINGS

The reviewer verifies that the applicant has provided sufficient information and that the review and calculations (if applicable) support conclusions of the following type to be included in the staff's safety evaluation report. The reviewer also states the bases for those conclusions.

The staff concludes that the seismic design parameters used in the design of plant SSCs are acceptable and meet the applicable requirements of 10 CFR Part 50, Appendix A, GDC 2, 10 CFR Part 100, Subpart A and Subpart B, and 10 CFR Part 50, Appendix S. This conclusion is based on the following.

The applicant has met the relevant requirements of GDC 2, 10 CFR Part 100, Subpart A and Subpart B, and 10 CFR Part 50, Appendix S by appropriate consideration for the most severe earthquake recorded for the site with an appropriate margin and considerations for two levels of earthquakes - the SSE and OBE. The applicant has met these requirements by the use of the

methods and procedures indicated below.

The seismic design response spectra (OBE and SSE) applied in the design of seismic Category I SSCs meet or exceed the free-field response spectra provided in SRP Section 2.5.2. For the plant subject to Appendix S of 10 CFR Part 50, the horizontal component of the SSE ground motion in the free-field at the foundation level of the structures is based on an appropriate response spectrum with a peak ground acceleration of at least 0.1g. The percentage of critical damping values used in the seismic analysis of Category I SSCs is in conformance with RG 1.61, "Damping Values for Seismic Design of Nuclear Power Plants." The artificial time history used for seismic design of Category I plant SSCs is adjusted in amplitude and frequency content to obtain response spectra that envelop the design response spectra specified for the site and also exhibits sufficient energy in the frequency range of interest. Conformance with the recommendations of Section 2.5.2 and RG 1.61 ensures that the seismic inputs to the analysis of Category I SSCs are adequately defined so as to form a conservative basis for the design of such SSCs to withstand seismic loadings.

The CSDRS used in the certified design of seismic Category I SSCs meet the requirements of 10 CFR 100.23 and Appendix S to 10 CFR Part 50 by either: (1) demonstrating that the CSDRS meet or exceed the site-specific GMRS reviewed and approved in the SRP Section 2.5.2 and meet or exceed the minimum required response spectrum specified in 10 CFR Part 50, Appendix S, or (2) by showing that the design resulting from application of the CSDRS is still adequate to resist design demands resulting from the analysis conducted using the site-specific GMRS.

The design response spectra used in a non-standard plant for design of seismic Category I SSCs meet the requirements of 10 CFR 100.23 and Appendix S to 10 CFR Part 50, since they meet or exceed the site-specific GMRS reviewed and approved in the SRP Section 2.5.2 and meet or exceed the minimum required response spectrum specified in Appendix S to 10 CFR Part 50.

For DC and COL reviews, the findings will also summarize the staff's evaluation of requirements and restrictions (e.g., interface requirements and site parameters) and COL action items relevant to this SRP section.

In addition, to the extent that the review is not discussed in other SER sections, the findings will summarize the staff's evaluation of the ITAAC, including design acceptance criteria, as applicable.

V. IMPLEMENTATION

The staff will use this SRP section in performing safety evaluations of DC applications and license applications submitted by applicants pursuant to 10 CFR Part 50 or 10 CFR Part 52. Except when the applicant proposes an acceptable alternative method for complying with specified portions of the Commission's regulations, the staff will use the method described herein to evaluate conformance with Commission regulations.

The provisions of this SRP section apply to reviews of applications submitted six months or

more after the date of issuance of this SRP section, unless superseded by a later revision.

VI. REFERENCES

1. 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities."
2. 10 CFR Part 50, Appendix A, General Design Criterion 2, "Design Bases for Protection Against Natural Phenomena."
3. 10 CFR Part 50, Appendix S, "Earthquake Engineering Criteria for Nuclear Power Plants."
4. 10 CFR Part 52, "Early Site Permits; Standard Design Certifications; and Combined Licenses for Nuclear Power Plants."
5. 10 CFR Part 100, Subpart A, "Evaluation Factors for Stationary Power Reactor Site Applications before January 10, 1997 and for Test Reactors."
6. 10 CFR Part 100, Subpart B, "Evaluation Factors for Stationary Power Reactor Site Applications on or After January 10, 1997."
7. 10 CFR Part 100, Appendix A, "Seismic and Geologic Siting Criteria for Nuclear Power Plants."
8. Houston, T. W., Mertz, G. E., Costantino, M. C., Costantino, and C. J., "Investigation of the Impact of Seed Record Selection on Structural Response." Proceedings of the 2010 ASME PVP Conference, Division K, Paper 25919, Bellevue Washington, July 18-22, 2010.
9. Interim Staff Guidance 01 (DC/COL-ISG-01) on Seismic Issues Associated with High Frequency Ground Motion in Design Certification and Combined License Applications.
10. Interim Staff Guidance 17 (DC/COL-ISG-17) on Ensuring Hazard-Consistent Seismic Input for Site Response and Soil Structure Interaction Analyses.
11. NUREG/CR-6728, "Technical Basis for Revision of Regulatory Guidance on Design Ground Motions: Hazard- and Risk-consistent Ground Motion Spectra Guidelines."
12. RG 1.60, "Design Response Spectra for Seismic Design of Nuclear Power Plants."
13. RG 1.70, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants."
14. RG 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)."
15. RG 1.208, "A Performance-Based Approach to Define the Site-Specific Earthquake

Ground Motion.”

16. RG 1.61, "Damping Values for Seismic Design of Nuclear Power Plants,"

PAPERWORK REDUCTION ACT STATEMENT

The information collections contained in the Standard Review Plan are covered by the requirements of 10 CFR Part 50 and 10 CFR Part 52, and were approved by the Office of Management and Budget, approval number 3150-0011 and 3150-0151.

PUBLIC PROTECTION NOTIFICATION

The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid OMB control number.

APPENDIX A TO SRP SECTION 3.7.1

**SPECIFICATION FOR MINIMUM
POWER SPECTRAL DENSITY REQUIREMENT**

For a RG 1.60 horizontal response spectrum anchored to 1.0 g, the following minimum Power Spectral Density (PSD) requirement should be satisfied. For other peak accelerations, this PSD requirement should be scaled by the square of the peak acceleration.

The one-sided PSD is related to the Fourier amplitude $|F(f)|$ of the time history by the equation

$$S_o(f) = \frac{2|F(f)|^2}{2\pi T_D} \dots\dots\dots(1)$$

where T_D is the strong motion duration over which $F(f)$ is evaluated. This duration T_D represents the duration of near maximum and nearly stationary power of an acceleration time history record. Additional guidance on estimation of T_D for artificial time history or actual earthquake time history is provided in Appendix B of NUREG/CR-5347.

The average one-sided PSD defined by Equation (1) should exceed 80 percent of the target PSD as defined by Equation (2) from 0.3 Hz to 24 Hz.

Less than 2.5 Hz

$$S_o(f) = 0.419 \text{ m}^2/\text{sec}^3 (f / 2.5 \text{ Hz})^{0.2}$$

2.5 Hz to 9.0 Hz

$$S_o(f) = 0.419 \text{ m}^2/\text{sec}^3 (2.5 \text{ Hz} / f)^{1.8} \dots\dots\dots(2)$$

9.0 Hz to 16.0 Hz

$$S_o(f) = 418 \text{ cm}^2/\text{sec}^3 (9.0 \text{ Hz} / f)^3$$

Greater than 16 Hz

$$S_o(f) = 74.2 \text{ cm}^2/\text{sec}^3 (16.0 \text{ Hz} / f)^8$$

At any frequency f , the average PSD is computed over a frequency band width of ± 20 percent, centered on the frequency f (e.g., 4 Hz to 6 Hz band width for $f = 5$ Hz).

The power above 24 Hz for the target PSD is so low as to be inconsequential so that checks above 24 Hz are unnecessary. (However, note that the response spectrum calculations are required beyond 24 Hz as governed by RG 1.60 definitions.) Similarly, power below 0.3 Hz has no influence on stiff nuclear plant facilities, so that checks below 0.3 Hz are unnecessary. This minimum check is set at 80 percent of the target PSD so as to be sufficiently high to prevent a deficiency of power over any broad frequency band, but sufficiently low that this requirement introduces no additional conservatism over that already embodied in the RG 1.60 response spectrum.

A time history meeting this minimum PSD requirement will produce a response spectrum that lies below the RG 1.60 response spectrum at all frequencies. To produce a response spectrum that accurately fits the 2 percent damped, 1.0 g, RG 1.60 response spectrum at all frequencies above 0.25 Hz, the PSD defined by Equation (2) can be used with the resulting time history being clipped at ± 1.0 g (see NUREG/CR-3509).

To produce a response spectrum that conservatively envelops the 1.0 g, RG 1.60 response spectrum at 2 percent damping and greater, a PSD set at 130 percent of the PSD defined by Equation (2) can be used with the resulting time history being clipped at ± 1.0 g.

REFERENCES

1. NUREG/CR-3509, "Power Spectral Density Functions Compatible with NRC Regulatory Guide 1.60 Response Spectra," June 1988.
2. NUREG/CR-5347, "Recommendations for Resolution of Public Comments on USI A-40, Seismic Design Criteria," June 1989.
3. RG 1.60, "Design Response Spectra for Seismic Design of Nuclear Power Plants."

APPENDIX B TO SRP SECTION 3.7.1

**SPECIFICATION FOR MINIMUM
POWER SPECTRAL DENSITY REQUIREMENT
FOR HORIZONTAL SPECTRUM BASED ON NUREG/CR-6728**

For a horizontal response spectrum anchored to 1.0g that is based on spectrum consistent with the Magnitude and Distance bin shapes in NUREG/CR-6728, the following minimum Power Spectral Density (PSD) requirement should be satisfied. When the response spectrum is derived from an envelope of spectra from multiple Magnitude and Distance bins, the envelope of the PSD should be used. For other peak accelerations, this PSD requirement should be scaled by the square of the peak acceleration.

The power spectral density for an acceleration time history can be computed as either a two-sided function of positive and negative frequencies or a one-sided function of only positive frequencies. Since only positive frequencies are realizable, the one-sided PSD is used to define the target criterion. The one sided PSD is related to the Fourier amplitude $|F(f)|$ of the time

history by the equation

$$S_o(f) = \frac{2|F(f)|^2}{2\pi T_D} \dots\dots\dots(1)$$

where T_D is the strong motion duration over which $F(f)$ is evaluated. This duration T_D represents the duration of near maximum and nearly stationary power of an acceleration time history record. Additional guidance on estimation of T_D for artificial time history or actual earthquake time history is provided in Appendix B of NUREG/CR-5347.

The average one-sided PSD defined by Equation (1) should exceed 80 percent of the appropriate Magnitude and Distance bin target PSD as shown in Tables 1 through 4.

At any frequency f , the average PSD is computed over a frequency band width of ± 20 percent, centered on the frequency f (e.g., 4 Hz to 6 Hz band width for $f = 5$ Hz).

The power above 25 Hz for the PSD targets for Western US Sites and Central and Eastern US Soil Sites is so low as to be inconsequential so that checks above 25 Hz are unnecessary. For Central and Eastern US Rock Sites checks above 50 Hz are unnecessary. (However, note that the response spectrum calculations are required beyond 25 Hz and 50 Hz, as appropriate.) Similarly, power below 0.3 Hz has no influence on stiff nuclear plant facilities, so that checks below 0.3 Hz are unnecessary. This minimum check is set at 80 percent of the target PSD so as to be sufficiently high to prevent a deficiency of power over any broad frequency band, but sufficiently low that this requirement introduces no additional conservatism over that already embodied in the specified target response spectrum.

A time history meeting this minimum PSD requirement will produce a response spectrum that lies below the target response spectrum at all frequencies. To produce a response spectrum that accurately fits the 2 percent damped, 1.0 g, target response spectrum at all frequencies above 0.25 Hz, the PSD specified in Tables 1 through 4 can be used with the resulting time history being clipped at ± 1.0 g (see NUREG/CR-3509).

To produce a response spectrum that conservatively envelops the 1.0 g target response spectrum at 2 percent damping and greater, a PSD set at 130 percent of the PSD specified in Tables 1 through 4 can be used with the resulting time history being clipped at ± 1.0 g.

Table 1 – Central and Eastern US Rock Sites

frequency (hz)	CEUS Rock Sites									
	Magnitude 5 - 6		Magnitude 6 - 7				Magnitude 7+			
	0-50 km	50-100 km	0-10 km	10-50 km	50-100 km	100-200 km	0-10 km	10-50 km	50-100 km	100-200 km
	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³
0.3	0.73	0.05	7.72	1.76	0.88		7.72	1.76	0.88	
0.4	0.95	0.07	10.39	3.61	1.69	4.76	10.39	3.61	1.69	4.76
0.5	1.19	0.09	15.55	6.95	3.08	9.52	15.55	6.95	3.08	9.52
0.6	1.55	0.12	21.44	9.16	4.93	14.45	21.44	9.16	4.93	14.45
0.7	1.96	0.18	24.60	10.49	6.92	18.08	24.60	10.49	6.92	18.08
0.8	2.43	0.27	26.74	11.18	7.90	20.16	26.74	11.18	7.90	20.16
0.9	2.87	0.40	31.62	12.71	10.46	22.86	31.62	12.71	10.46	22.86
1	3.22	0.54	41.36	12.55	12.87	22.99	41.36	12.55	12.87	22.99
1.5	5.44	1.08	71.33	15.85	40.17		71.33	15.85	40.17	
2	9.25	1.52	70.54	14.83	49.20	50.39	70.54	14.83	49.20	50.39
3	15.94	2.58	66.75	14.67	49.94	56.52	66.75	14.67	49.94	56.52
4	14.83	5.00	46.65	13.27	46.45	52.65	46.65	13.27	46.45	52.65
5	21.66	6.24	45.32	14.97	48.43	53.32	45.32	14.97	48.43	53.32
6	22.69	6.39	46.17	18.30	47.74	50.54	46.17	18.30	47.74	50.54
7	18.27	6.23	36.84	17.56	40.28	41.35	36.84	17.56	40.28	41.35
8	13.31	5.96	28.58	16.15	30.83	33.07	28.58	16.15	30.83	33.07
9	11.30	5.65	24.82	14.48	23.39	26.97	24.82	14.48	23.39	26.97
10	9.81	5.57	22.43	12.97	19.87	23.07	22.43	12.97	19.87	23.07
15	7.03	4.32	19.68	11.14	11.78		19.68	11.14	11.78	
20	7.11	2.98	14.26	9.35	10.93	12.09	14.26	9.35	10.93	12.09
30	5.49	0.79	6.91	7.21	9.40	7.69	6.91	7.21	9.40	7.69
40	4.22	0.31	4.26	5.29	8.37	5.80	4.26	5.29	8.37	5.80
50	2.13	0.09	1.63	2.67	4.51	2.95	1.63	2.67	4.51	2.95

Table 2 – Central and Eastern US Soil Sites

frequency (hz)	CEUS Soil Sites									
	Magnitude 5 - 6		Magnitude 6 - 7				Magnitude 7+			
	0-50 km	50-100 km	0-10 km	10-50 km	50-100 km	100-200 km	0-10 km	10-50 km	50-100 km	100-200 km
	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³
0.3	0.93	0.58	61.77	2.09	2.78	2.75	56.19	14.47	5.49	12.00
0.4	1.29	0.71	106.32	3.90	5.63	6.31	79.09	20.75	12.57	18.25
0.5	1.78	1.12	127.23	4.91	9.00	10.84	84.37	27.33	19.14	24.19
0.6	2.09	1.74	120.50	7.04	10.89	12.46	86.42	37.29	27.60	30.45
0.7	2.31	2.13	132.92	8.59	14.55	18.23	84.71	44.64	34.79	37.66
0.8	2.88	2.71	169.93	10.73	19.93	25.57	86.21	44.59	40.16	47.55
0.9	4.01	3.32	193.21	14.99	25.63	34.70	90.44	44.83	43.32	57.16
1	5.95	4.56	204.17	19.09	34.81	46.07	90.27	47.70	45.25	68.00
1.5	20.86	14.59	203.55	35.88			78.32	52.17	44.29	59.19
2	23.59	22.00	162.15	47.94	85.87	108.79	56.02	37.64	25.27	35.82
3	25.08	56.53	117.61	46.88	56.88	105.51	33.69	23.82	12.49	26.25
4	27.66	47.10	102.48	47.22	41.11	75.32	22.54	15.11	8.10	21.31
5	29.33	36.96	66.93	42.94	39.94	60.52	13.54	8.98	5.55	17.68
6	28.49	27.09	40.66	31.72			8.63	5.24	3.84	13.56
7	24.49	24.25	29.94	21.71	17.40	29.31	5.97	3.72	2.92	9.14
8	22.60	20.83	21.40	17.20	13.20	23.45	3.98	2.83	2.31	7.00
9	19.33	17.75	15.03	13.34	11.01	19.48	2.67	2.20	1.85	5.65
10	16.42	7.21	10.62	10.43	9.05	14.42	1.87	1.70	1.55	4.68
15	5.06	17.73	3.12	2.93			0.48	0.57	0.65	1.93
20	1.97	3.13	1.36	1.25	2.24	4.21	0.17	0.26	0.35	0.99
30	0.45	0.78	0.40	0.31	0.86	1.27	0.04	0.08	0.12	0.33

Table 3 – Western US Rock Sites

frequency (hz)	WUS Rock Sites									
	Magnitude 5 - 6		Magnitude 6 - 7				Magnitude 7+			
	0-50 km	50-100 km	0-10 km	10-50 km	50-100 km	100-200 km	0-10 km	10-50 km	50-100 km	100-200 km
	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³
0.3	3.37	0.29	15.35	6.78	1.24	11.56	37.52	5.03	3.81	5.03
0.4	2.39	0.32	17.02	8.26	1.81	16.06	36.12	4.67	4.80	5.89
0.5	2.60	0.36	24.17	9.36	2.28	25.21	36.13	7.20	4.59	8.38
0.6	3.15	0.37	38.04	12.16	2.95	31.68	49.07	9.45	4.76	9.13
0.7	3.74	0.50	53.21	16.38	3.84	34.97	58.95	10.11	5.38	10.04
0.8	4.50	0.74	61.32	19.02	4.83	40.05	69.52	10.14	5.55	10.31
0.9	5.62	1.11	70.66	21.94	6.95	48.09	76.13	11.36	6.53	10.30
1	7.26	1.50	78.87	24.28	9.09	51.37	77.60	11.83	7.78	10.18
1.5	10.63	3.12	140.98	33.32	16.94	65.26	80.42	15.86	8.96	7.74
2	15.94	3.52	130.39	33.48	19.06	66.07	58.68	19.18	8.56	4.88
3	29.62	5.17	114.91	31.93	18.88	78.35	44.57	19.79	7.48	2.96
4	28.47	6.14	62.76	21.37	13.95	54.77	25.39	14.29	7.18	1.57
5	25.37	6.58	40.23	17.21	10.47	36.24	13.73	10.29	4.86	0.83
6	18.46	4.98	30.67	14.39	7.06	21.55	9.35	7.62	3.13	0.43
7	11.67	3.58	20.30	10.28	4.88	12.91	7.10	5.25	1.91	0.25
8	6.64	2.44	13.85	7.13	2.78	7.26	5.11	3.52	1.34	0.13
9	4.70	1.79	9.76	4.47	1.71	4.42	3.47	2.46	0.95	0.08
10	3.39	1.33	6.96	2.95	1.08	2.83	2.43	1.68	0.67	0.04
15	0.84	0.33	2.07	0.62	0.13	0.38	0.67	0.38	0.12	0.01
20	0.27	0.11	0.75	0.19	0.04	0.10	0.23	0.12	0.04	
30	0.06	0.01	0.01	0.02		0.01	0.01			

Table 4 – Western US Soil Sites

frequency (hz)	WUS Soil Sites									
	Magnitude 5 - 6		Magnitude 6 - 7				Magnitude 7+			
	0-50 km	50-100 km	0-10 km	10-50 km	50-100 km	100-200 km	0-10 km	10-50 km	50-100 km	100-200 km
	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³	in ² /sec ³
0.3	1.55	0.69	79.89	3.88	2.79	3.14	78.12	12.61	3.95	5.66
0.4	1.49	1.01	121.51	4.84	5.98	5.54	102.28	13.06	8.27	7.84
0.5	2.04	1.30	130.32	5.18	7.81	9.63	106.71	17.29	12.46	8.73
0.6	2.86	1.74	122.18	7.17	8.20	11.92	100.43	22.30	16.48	10.50
0.7	3.51	2.10	120.71	9.31	12.41	15.01	96.05	23.96	17.97	12.50
0.8	3.95	2.63	142.04	10.45	15.68	17.96	99.68	26.45	18.10	15.01
0.9	4.26	2.99	154.20	11.08	18.68	20.80	101.28	29.09	17.96	16.93
1	5.20	3.46	154.18	12.57	23.58	23.37	93.75	31.80	18.56	16.59
1.5	14.58	8.77	143.07	18.24	34.20	41.92	77.18	30.27	13.58	10.17
2	17.38	13.72	114.85	28.01	35.60	38.55	61.94	23.17	8.43	6.24
3	21.31	24.93	90.64	26.27	20.40	21.86	31.72	14.57	3.50	3.05
4	18.52	15.59	67.28	24.88	10.71	11.65	19.57	7.78	1.55	1.97
5	16.67	8.64	41.92	18.48	6.97	6.46	10.80	4.21	0.76	1.24
6	14.31	5.82	25.16	12.13	4.12	3.65	6.51	2.49	0.42	0.68
7	10.70	3.97	17.94	6.96	2.29	1.90	4.38	1.55	0.25	0.36
8	8.64	2.94	11.85	4.77	1.35	1.05	2.73	1.01	0.15	0.20
9	5.80	2.09	7.86	3.23	0.84	0.61	1.85	0.74	0.09	0.12
10	4.34	1.46	5.21	2.41	0.50	0.41	1.24	0.53	0.06	0.08
15	0.85	0.16	1.20	0.42	0.08	0.07	0.32	0.11	0.01	0.01
20	0.23	0.04	0.42	0.12	0.03	0.02	0.12	0.03		0.01
25					0.01		0.05			

As an example, the target PSD for a Western US rock site, Magnitude 6 - 7, 10 to 50 km, is extracted from Table 3 and shown in Figure 1. The PSD for the time history developed to match the design spectrum shall exceed 80% of this target for frequencies between 0.3 Hz and 25 Hz.




Figure 1

REFERENCES

1. NUREG/CR-6728, "Technical Basis for Revision of Regulatory Guidance on Design Ground Motions: Hazard- and Risk-consistent Ground Motion Spectra Guidelines."
2. NUREG/CR-5347, "Recommendations for Resolution of Public Comments on USI A-40, Seismic Design Criteria," June 1989.
3. NUREG/CR-3509, "Power Spectral Density Functions Compatible with NRC Regulatory Guide 1.60 Response Spectra," June 1988.

APPENDIX C TO SRP SECTION 3.7.1

SCALE FACTORS FOR RESPONSE SPECTRA DAMPING RATIOS RELATIVE TO THE 5 PERCENT DAMPED RESPONSE SPECTRA

The purpose of this appendix is to present the ratios of response spectra at a given damping value to the 5 percent damped response spectrum. A number of previous recommendations have been made over the years but these have generally been limited by the restricted data set of recordings used to develop the recommendations. This study performed the evaluation using all the records currently available in the data set presented with NUREG/CR-6728. These are three component data sets (two horizontal and one vertical) of both empirical (recorded) and modified time history records. For this evaluation, spectra have been computed for each of these three records individually and then the average horizontal spectrum computed by (lognormally) averaging the two horizontal spectral accelerations for each damping value considered frequency by frequency. From these sets of three, individual bin averages have been computed for damping ratios of 2 percent, 3 percent, 5 percent, 7 percent and 10 percent. Spectral ratios were then computed relative to the 5 percent damped spectra. The spectral ratios were then smoothed using a 9-point running average smoothing algorithm. The results of this process are presented and compared in the following.

The NUREG/6728 record set is binned by both magnitude and distance as well as for both rock and soil site categories. The magnitude bins are defined as magnitude 5 to 6 (M55), magnitude 6 to 7 (M65) and magnitudes greater than 7 (M75). Distance bins are typically defined as from 00 to 10 kms (000010), 10 to 50 kms (010050), 50 to 100 kms (050100) and 100 to 200 kms (100200). In addition to magnitude, distance and site binning, the record sets associated with NUREG/CR-6728 are also categorized into Western US (WUS) and Central and Eastern US (CEUS) record sets. The WUS data set is composed of empirical recorded motions while the CEUS data set is primarily composed of modified WUS recordings attempting to account for differences in source and site parameters WUS to CEUS.

Average spectral ratios were computed for each of these bin categories. Tables 1 through 4 present averages for CEUS-Rock, CEUS-Soil, WUS-Rock and WUS-Soil site categories. It should be noted that the data tables of spectral ratio generally refer to horizontal spectra only. It was found that the spectral ratios for vertical motions in the data sets were essentially the same as those of the corresponding horizontal ratios.

In Table 1, the spectral ratios for the gross bin averages for EUS Rock sites are listed for spectral ratios of 2% to 10% damping. Similarly, Tables 2 through 4 provide the spectral ratios for the gross bin averages for the CEUS-Soil, WUS-Rock, and WUS-Soil categories, of 2% to 10% damping.

REFERENCES

1. NUREG/CR-6728, "Technical Basis for Revision of Regulatory Guidance on Design Ground Motions: Hazard- and Risk-consistent Ground Motion Spectra Guidelines."

EUS ROCK SITES
AVERAGE HORIZONTAL AND VERTICAL SPECTRAL RATIOS

FREQUENCY (HZ)	EUS-ROCK 2% DAMPING		EUS-ROCK 3% DAMPING		EUS-ROCK 5% DAMPING		EUS-ROCK 7% DAMPING		EUS-ROCK 10% DAMPING	
	H/A/G	V AVG	H/A/G	V AVG	H/A/G	V AVG	H/A/G	V AVG	H/A/G	V AVG
0.500	1.1588	1.1600	1.0835	1.0843	0.9820	0.9614	0.9500	0.9484	0.9500	0.9484
0.600	1.2038	1.2038	1.1113	1.1113	0.9381	0.9381	0.8927	0.8927	0.8927	0.8927
0.700	1.2299	1.2299	1.1263	1.1263	0.9263	0.9263	0.8651	0.8651	0.8651	0.8651
0.800	1.2487	1.2487	1.1369	1.1369	0.9190	0.9190	0.8480	0.8480	0.8480	0.8480
0.900	1.2631	1.2631	1.1445	1.1445	0.9137	0.9137	0.8359	0.8359	0.8359	0.8359
1.000	1.2749	1.2749	1.1503	1.1503	0.9096	0.9096	0.8266	0.8266	0.8266	0.8266
1.100	1.2836	1.2836	1.1546	1.1546	0.9062	0.9062	0.8193	0.8193	0.8193	0.8193
1.200	1.2889	1.2889	1.1571	1.1571	0.9045	0.9045	0.8147	0.8147	0.8147	0.8147
1.300	1.2914	1.2914	1.1587	1.1587	0.9038	0.9038	0.8121	0.8121	0.8121	0.8121
1.400	1.2941	1.2941	1.1603	1.1603	0.9027	0.9027	0.8096	0.8096	0.8096	0.8096
1.500	1.2991	1.2991	1.1623	1.1623	0.9022	0.9022	0.8084	0.8084	0.8084	0.8084
1.600	1.3060	1.3050	1.1657	1.1657	0.9008	0.9008	0.8059	0.8059	0.8059	0.8059
1.700	1.3099	1.3099	1.1675	1.1675	0.9000	0.9000	0.8041	0.8041	0.8041	0.8041
1.800	1.3145	1.3145	1.1699	1.1699	0.8986	0.8986	0.8017	0.8017	0.8017	0.8017
1.900	1.3173	1.3173	1.1720	1.1720	0.8973	0.8973	0.7993	0.7993	0.7993	0.7993
2.000	1.3215	1.3215	1.1745	1.1745	0.8964	0.8964	0.7980	0.7980	0.7980	0.7980
2.100	1.3287	1.3287	1.1785	1.1785	0.8943	0.8943	0.7947	0.7947	0.7947	0.7947
2.200	1.3355	1.3355	1.1816	1.1816	0.8923	0.8923	0.7912	0.7912	0.7912	0.7912
2.300	1.3388	1.3388	1.1828	1.1828	0.8916	0.8916	0.7902	0.7902	0.7902	0.7902
2.400	1.3400	1.3400	1.1831	1.1831	0.8919	0.8919	0.7908	0.7908	0.7908	0.7908
2.500	1.3391	1.3391	1.1825	1.1825	0.8920	0.8920	0.7909	0.7909	0.7909	0.7909
2.600	1.3392	1.3392	1.1829	1.1829	0.8914	0.8914	0.7902	0.7902	0.7902	0.7902
2.700	1.3392	1.3392	1.1827	1.1827	0.8916	0.8916	0.7902	0.7902	0.7902	0.7902
2.800	1.3386	1.3386	1.1820	1.1820	0.8919	0.8919	0.7908	0.7908	0.7908	0.7908
2.900	1.3354	1.3354	1.1796	1.1796	0.8931	0.8931	0.7925	0.7925	0.7925	0.7925
3.000	1.3330	1.3330	1.1781	1.1781	0.8944	0.8944	0.7945	0.7945	0.7945	0.7945
3.150	1.3330	1.3330	1.1777	1.1777	0.8951	0.8951	0.7959	0.7959	0.7959	0.7959
3.300	1.3341	1.3341	1.1779	1.1779	0.8953	0.8953	0.7964	0.7964	0.7964	0.7964
3.450	1.3309	1.3309	1.1764	1.1764	0.8954	0.8954	0.7965	0.7965	0.7965	0.7965
3.600	1.3279	1.3279	1.1748	1.1748	0.8962	0.8962	0.7980	0.7980	0.7980	0.7980
3.800	1.3238	1.3238	1.1721	1.1721	0.8979	0.8979	0.8004	0.8004	0.8004	0.8004
4.000	1.3238	1.3238	1.1719	1.1719	0.8985	0.8985	0.8014	0.8014	0.8014	0.8014
4.200	1.3238	1.3238	1.1717	1.1717	0.8989	0.8989	0.8016	0.8016	0.8016	0.8016
4.400	1.3208	1.3208	1.1752	1.1752	0.8973	0.8973	0.7989	0.7989	0.7989	0.7989
4.600	1.3357	1.3357	1.1773	1.1773	0.8960	0.8960	0.7964	0.7964	0.7964	0.7964
4.800	1.3387	1.3387	1.1791	1.1791	0.8948	0.8948	0.7938	0.7938	0.7938	0.7938
5.000	1.3427	1.3427	1.1813	1.1813	0.8938	0.8938	0.7915	0.7915	0.7915	0.7915
5.250	1.3512	1.3512	1.1853	1.1853	0.8925	0.8925	0.7889	0.7889	0.7889	0.7889
5.500	1.3596	1.3596	1.1892	1.1892	0.8906	0.8906	0.7852	0.7852	0.7852	0.7852
5.750	1.3726	1.3726	1.1961	1.1961	0.8874	0.8874	0.7804	0.7804	0.7804	0.7804
6.000	1.3800	1.3800	1.2002	1.2002	0.8847	0.8847	0.7764	0.7764	0.7764	0.7764
6.250	1.3856	1.3856	1.2024	1.2024	0.8839	0.8839	0.7751	0.7751	0.7751	0.7751
6.500	1.3838	1.3838	1.2010	1.2010	0.8844	0.8844	0.7760	0.7760	0.7760	0.7760

Table 1: CEUS-Rock Sites Spectral Ratios

EUS ROCK SITES
AVERAGE HORIZONTAL AND VERTICAL SPECTRAL RATIOS

6.750	1.3815	1.3815	1.3815	1.1995	1.1995	0.8849	0.8849	0.7775	0.7775
7.000	1.3776	1.3776	1.3776	1.1973	1.1973	0.8862	0.8862	0.7800	0.7800
7.250	1.3723	1.3723	1.3723	1.1945	1.1945	0.8878	0.8878	0.7835	0.7835
7.500	1.3662	1.3662	1.3662	1.1917	1.1917	0.8892	0.8892	0.7867	0.7867
7.750	1.3605	1.3605	1.3605	1.1887	1.1887	0.8907	0.8907	0.7895	0.7895
8.000	1.3574	1.3574	1.3574	1.1863	1.1863	0.8921	0.8921	0.7921	0.7921
8.500	1.3566	1.3566	1.3566	1.1857	1.1857	0.8931	0.8931	0.7940	0.7940
9.000	1.3600	1.3600	1.3600	1.1877	1.1877	0.8928	0.8928	0.7942	0.7942
9.500	1.3625	1.3625	1.3625	1.1892	1.1892	0.8932	0.8932	0.7953	0.7953
10.000	1.3653	1.3653	1.3653	1.1906	1.1906	0.8942	0.8942	0.7972	0.7972
10.500	1.3668	1.3668	1.3668	1.1911	1.1911	0.8951	0.8951	0.7993	0.7993
11.000	1.3690	1.3690	1.3690	1.1920	1.1920	0.8951	0.8951	0.7994	0.7994
11.500	1.3735	1.3735	1.3735	1.1941	1.1941	0.8947	0.8947	0.7989	0.7989
12.000	1.3761	1.3761	1.3761	1.1953	1.1953	0.8945	0.8945	0.7988	0.7988
12.500	1.3758	1.3758	1.3758	1.1952	1.1952	0.8948	0.8948	0.7994	0.7994
13.000	1.3758	1.3758	1.3758	1.1946	1.1946	0.8958	0.8958	0.8011	0.8011
13.500	1.3722	1.3722	1.3722	1.1924	1.1924	0.8966	0.8966	0.8029	0.8029
14.000	1.3682	1.3682	1.3682	1.1900	1.1900	0.8977	0.8977	0.8049	0.8049
14.500	1.3622	1.3622	1.3622	1.1868	1.1868	0.8982	0.8982	0.8058	0.8058
15.000	1.3614	1.3614	1.3614	1.1866	1.1866	0.8978	0.8978	0.8053	0.8053
16.000	1.3583	1.3583	1.3583	1.1845	1.1845	0.8992	0.8992	0.8079	0.8079
17.000	1.3536	1.3536	1.3536	1.1819	1.1819	0.9003	0.9003	0.8098	0.8098
18.000	1.3501	1.3501	1.3501	1.1801	1.1801	0.9018	0.9018	0.8127	0.8127
20.000	1.3490	1.3490	1.3490	1.1796	1.1796	0.9022	0.9022	0.8135	0.8135
22.000	1.3456	1.3456	1.3456	1.1781	1.1781	0.9025	0.9025	0.8142	0.8142
25.000	1.3413	1.3413	1.3413	1.1759	1.1759	0.9040	0.9040	0.8168	0.8168
28.000	1.3402	1.3402	1.3402	1.1755	1.1755	0.9039	0.9039	0.8166	0.8166
31.000	1.3412	1.3412	1.3412	1.1764	1.1764	0.9037	0.9037	0.8165	0.8165
34.000	1.3386	1.3386	1.3386	1.1745	1.1745	0.9054	0.9054	0.8196	0.8196
40.000	1.3344	1.3344	1.3344	1.1723	1.1723	0.9066	0.9066	0.8219	0.8219
45.000	1.3240	1.3240	1.3240	1.1671	1.1671	0.9095	0.9095	0.8274	0.8274
50.000	1.3089	1.3089	1.3089	1.1592	1.1592	0.9134	0.9134	0.8350	0.8350
55.000	1.2851	1.2851	1.2851	1.1465	1.1465	0.9201	0.9201	0.8473	0.8473
60.000	1.2566	1.2566	1.2566	1.1316	1.1316	0.9279	0.9279	0.8621	0.8621
65.000	1.2289	1.2289	1.2289	1.1171	1.1171	0.9359	0.9359	0.8771	0.8771
70.000	1.1980	1.1980	1.1980	1.1009	1.1009	0.9449	0.9449	0.8944	0.8944
75.000	1.1670	1.1670	1.1670	1.0847	1.0847	0.9540	0.9540	0.9119	0.9119
80.000	1.1361	1.1361	1.1361	1.0691	1.0691	0.9621	0.9621	0.9274	0.9274

Table 1: CEUS-Rock Sites Spectral Ratios (continued)

EUS SOIL SITES
AVERAGE HORIZONTAL AND VERTICAL SPECTRAL RATIOS

FREQUENCY (HZ)	EUS-SOIL H/V AVG		EUS-SOIL V AVG		EUS-SOIL H/V AVG		EUS-SOIL V AVG		EUS-SOIL H/V AVG		EUS-SOIL V AVG	
	2% DAMPING	2% DAMPING	3% DAMPING	3% DAMPING	7% DAMPING	7% DAMPING	10% DAMPING	10% DAMPING	10% DAMPING	10% DAMPING	10% DAMPING	10% DAMPING
0.500	1.1731	1.1739	1.0915	1.0921	0.9592	0.9580	0.9475	0.9445	0.9475	0.9445	0.9475	0.9445
0.600	1.2188	1.2188	1.1193	1.1193	0.9362	0.9362	0.8921	0.8921	0.8921	0.8921	0.8921	0.8921
0.700	1.2448	1.2448	1.1341	1.1341	0.9240	0.9240	0.8632	0.8632	0.8632	0.8632	0.8632	0.8632
0.800	1.2644	1.2644	1.1445	1.1445	0.9161	0.9161	0.8442	0.8442	0.8442	0.8442	0.8442	0.8442
0.900	1.2827	1.2827	1.1540	1.1540	0.9095	0.9095	0.8286	0.8286	0.8286	0.8286	0.8286	0.8286
1.000	1.2987	1.2987	1.1624	1.1624	0.9044	0.9044	0.8179	0.8179	0.8179	0.8179	0.8179	0.8179
1.100	1.3152	1.3152	1.1704	1.1704	0.9002	0.9002	0.8093	0.8093	0.8093	0.8093	0.8093	0.8093
1.200	1.3259	1.3259	1.1763	1.1763	0.8963	0.8963	0.8013	0.8013	0.8013	0.8013	0.8013	0.8013
1.300	1.3321	1.3321	1.1793	1.1793	0.8942	0.8942	0.7962	0.7962	0.7962	0.7962	0.7962	0.7962
1.400	1.3393	1.3393	1.1833	1.1833	0.8916	0.8916	0.7901	0.7901	0.7901	0.7901	0.7901	0.7901
1.500	1.3457	1.3457	1.1867	1.1867	0.8886	0.8886	0.7841	0.7841	0.7841	0.7841	0.7841	0.7841
1.600	1.3528	1.3528	1.1904	1.1904	0.8865	0.8865	0.7802	0.7802	0.7802	0.7802	0.7802	0.7802
1.700	1.3586	1.3586	1.1941	1.1941	0.8846	0.8846	0.7768	0.7768	0.7768	0.7768	0.7768	0.7768
1.800	1.3607	1.3607	1.1953	1.1953	0.8838	0.8838	0.7757	0.7757	0.7757	0.7757	0.7757	0.7757
1.900	1.3606	1.3606	1.1950	1.1950	0.8837	0.8837	0.7746	0.7746	0.7746	0.7746	0.7746	0.7746
2.000	1.3592	1.3592	1.1942	1.1942	0.8841	0.8841	0.7751	0.7751	0.7751	0.7751	0.7751	0.7751
2.100	1.3624	1.3624	1.1955	1.1955	0.8840	0.8840	0.7756	0.7756	0.7756	0.7756	0.7756	0.7756
2.200	1.3628	1.3628	1.1959	1.1959	0.8844	0.8844	0.7767	0.7767	0.7767	0.7767	0.7767	0.7767
2.300	1.3626	1.3626	1.1948	1.1948	0.8857	0.8857	0.7793	0.7793	0.7793	0.7793	0.7793	0.7793
2.400	1.3622	1.3622	1.1939	1.1939	0.8871	0.8871	0.7832	0.7832	0.7832	0.7832	0.7832	0.7832
2.500	1.3590	1.3590	1.1924	1.1924	0.8881	0.8881	0.7840	0.7840	0.7840	0.7840	0.7840	0.7840
2.600	1.3592	1.3592	1.1919	1.1919	0.8883	0.8883	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
2.700	1.3609	1.3609	1.1925	1.1925	0.8888	0.8888	0.7852	0.7852	0.7852	0.7852	0.7852	0.7852
2.800	1.3606	1.3606	1.1923	1.1923	0.8888	0.8888	0.7856	0.7856	0.7856	0.7856	0.7856	0.7856
2.900	1.3602	1.3602	1.1919	1.1919	0.8888	0.8888	0.7850	0.7850	0.7850	0.7850	0.7850	0.7850
3.000	1.3612	1.3612	1.1923	1.1923	0.8883	0.8883	0.7832	0.7832	0.7832	0.7832	0.7832	0.7832
3.150	1.3674	1.3674	1.1952	1.1952	0.8867	0.8867	0.7800	0.7800	0.7800	0.7800	0.7800	0.7800
3.300	1.3719	1.3719	1.1978	1.1978	0.8852	0.8852	0.7769	0.7769	0.7769	0.7769	0.7769	0.7769
3.450	1.3776	1.3776	1.2007	1.2007	0.8837	0.8837	0.7740	0.7740	0.7740	0.7740	0.7740	0.7740
3.600	1.3843	1.3843	1.2037	1.2037	0.8824	0.8824	0.7720	0.7720	0.7720	0.7720	0.7720	0.7720
3.800	1.3887	1.3887	1.2059	1.2059	0.8813	0.8813	0.7696	0.7696	0.7696	0.7696	0.7696	0.7696
4.000	1.3939	1.3939	1.2083	1.2083	0.8799	0.8799	0.7664	0.7664	0.7664	0.7664	0.7664	0.7664
4.200	1.4010	1.4010	1.2123	1.2123	0.8777	0.8777	0.7627	0.7627	0.7627	0.7627	0.7627	0.7627
4.400	1.4074	1.4074	1.2158	1.2158	0.8761	0.8761	0.7602	0.7602	0.7602	0.7602	0.7602	0.7602
4.600	1.4104	1.4104	1.2173	1.2173	0.8753	0.8753	0.7593	0.7593	0.7593	0.7593	0.7593	0.7593
4.800	1.4115	1.4115	1.2182	1.2182	0.8756	0.8756	0.7601	0.7601	0.7601	0.7601	0.7601	0.7601
5.000	1.4130	1.4130	1.2187	1.2187	0.8761	0.8761	0.7608	0.7608	0.7608	0.7608	0.7608	0.7608
5.250	1.4139	1.4139	1.2190	1.2190	0.8763	0.8763	0.7614	0.7614	0.7614	0.7614	0.7614	0.7614
5.500	1.4097	1.4097	1.2170	1.2170	0.8770	0.8770	0.7626	0.7626	0.7626	0.7626	0.7626	0.7626
5.750	1.4036	1.4036	1.2134	1.2134	0.8785	0.8785	0.7654	0.7654	0.7654	0.7654	0.7654	0.7654
6.000	1.3974	1.3974	1.2104	1.2104	0.8801	0.8801	0.7690	0.7690	0.7690	0.7690	0.7690	0.7690
6.250	1.3910	1.3910	1.2060	1.2060	0.8829	0.8829	0.7739	0.7739	0.7739	0.7739	0.7739	0.7739
6.500	1.3854	1.3854	1.2022	1.2022	0.8857	0.8857	0.7787	0.7787	0.7787	0.7787	0.7787	0.7787

Table 2: CEUS-Soil Sites Spectral Ratios

EUS SOIL SITES
AVERAGE HORIZONTAL AND VERTICAL SPECTRAL RATIOS

6.750	1.3803	1.3803	1.1990	1.1990	0.8877	0.8877	0.8877	0.7825
7.000	1.3755	1.3755	1.1955	1.1955	0.8894	0.8894	0.7863	
7.250	1.3715	1.3715	1.1929	1.1929	0.8912	0.8912	0.7900	
7.500	1.3679	1.3679	1.1906	1.1906	0.8921	0.8921	0.7920	
7.750	1.3687	1.3687	1.1906	1.1906	0.8925	0.8925	0.7928	
8.000	1.3732	1.3732	1.1925	1.1925	0.8916	0.8916	0.7917	
8.500	1.3771	1.3771	1.1940	1.1940	0.8902	0.8902	0.7893	
9.000	1.3817	1.3817	1.1961	1.1961	0.8893	0.8893	0.7878	
9.500	1.3838	1.3838	1.1971	1.1971	0.8892	0.8892	0.7877	
10.000	1.3836	1.3836	1.1966	1.1966	0.8898	0.8898	0.7885	
10.500	1.3840	1.3840	1.1969	1.1969	0.8903	0.8903	0.7890	
11.000	1.3832	1.3832	1.1961	1.1961	0.8902	0.8902	0.7893	
11.500	1.3842	1.3842	1.1961	1.1961	0.8907	0.8907	0.7905	
12.000	1.3839	1.3839	1.1958	1.1958	0.8922	0.8922	0.7933	
12.500	1.3782	1.3782	1.1929	1.1929	0.8942	0.8942	0.7976	
13.000	1.3730	1.3730	1.1902	1.1902	0.8970	0.8970	0.8030	
13.500	1.3653	1.3653	1.1866	1.1866	0.8993	0.8993	0.8075	
14.000	1.3594	1.3594	1.1838	1.1838	0.9001	0.9001	0.8100	
14.500	1.3555	1.3555	1.1821	1.1821	0.9014	0.9014	0.8129	
15.000	1.3474	1.3474	1.1780	1.1780	0.9040	0.9040	0.8179	
16.000	1.3375	1.3375	1.1731	1.1731	0.9071	0.9071	0.8235	
17.000	1.3244	1.3244	1.1671	1.1671	0.9107	0.9107	0.8303	
18.000	1.3094	1.3094	1.1591	1.1591	0.9147	0.9147	0.8380	
20.000	1.2971	1.2971	1.1527	1.1527	0.9191	0.9191	0.8463	
22.000	1.2802	1.2802	1.1435	1.1435	0.9239	0.9239	0.8550	
25.000	1.2633	1.2633	1.1347	1.1347	0.9287	0.9287	0.8644	
28.000	1.2437	1.2437	1.1244	1.1244	0.9346	0.9346	0.8755	
31.000	1.2269	1.2269	1.1151	1.1151	0.9403	0.9403	0.8869	
34.000	1.2071	1.2071	1.1045	1.1045	0.9456	0.9456	0.8970	
40.000	1.1882	1.1882	1.0947	1.0947	0.9508	0.9508	0.9070	
45.000	1.1687	1.1687	1.0841	1.0841	0.9566	0.9566	0.9175	
50.000	1.1513	1.1513	1.0752	1.0752	0.9614	0.9614	0.9269	
55.000	1.1347	1.1347	1.0663	1.0663	0.9661	0.9661	0.9357	
60.000	1.1187	1.1187	1.0585	1.0585	0.9703	0.9703	0.9439	
65.000	1.1054	1.1054	1.0515	1.0515	0.9743	0.9743	0.9510	
70.000	1.0946	1.0946	1.0459	1.0459	0.9772	0.9772	0.9565	
75.000	1.0816	1.0816	1.0398	1.0398	0.9795	0.9795	0.9608	
80.000	1.0737	1.0737	1.0360	1.0360	0.9817	0.9817	0.9651	

Table 2: CEUS-Soil Sites Spectral Ratios (continued)

WUS ROCK SITES
AVERAGE HORIZONTAL AND VERTICAL SPECTRAL RATIOS

FREQUENCY (HZ)	WUS-ROCK H/V AVG		WUS-ROCK H/VG		WUS-ROCK H/VG		WUS-ROCK H/VG		WUS-ROCK H/VG		WUS-ROCK H/VG	
	2% DAMPING	2% DAMPING	3% DAMPING	3% DAMPING	7% DAMPING	7% DAMPING	7% DAMPING	7% DAMPING	10% DAMPING	10% DAMPING	10% DAMPING	10% DAMPING
0.500	1.1698	1.1690	1.0897	1.0888	0.9569	0.9577	0.9365	0.9387	0.8855	0.8855	0.8577	0.8577
0.600	1.2102	1.2102	1.1144	1.1144	0.9355	0.9355	0.8855	0.8855	0.8398	0.8398	0.8275	0.8275
0.700	1.2372	1.2372	1.1300	1.1300	0.9237	0.9237	0.8577	0.8577	0.8125	0.8125	0.8087	0.8087
0.800	1.2579	1.2579	1.1417	1.1417	0.9155	0.9155	0.8398	0.8398	0.8050	0.8050	0.8024	0.8024
0.900	1.2724	1.2724	1.1495	1.1495	0.9097	0.9097	0.8050	0.8050	0.7996	0.7996	0.7988	0.7988
1.000	1.2835	1.2835	1.1556	1.1556	0.9061	0.9061	0.8011	0.8011	0.7974	0.7974	0.7974	0.7974
1.100	1.2904	1.2904	1.1593	1.1593	0.9030	0.9030	0.7996	0.7996	0.7959	0.7959	0.7959	0.7959
1.200	1.2956	1.2956	1.1616	1.1616	0.9017	0.9017	0.7959	0.7959	0.7943	0.7943	0.7943	0.7943
1.300	1.2984	1.2984	1.1632	1.1632	0.9000	0.9000	0.7943	0.7943	0.7920	0.7920	0.7920	0.7920
1.400	1.3013	1.3013	1.1650	1.1650	0.8988	0.8988	0.7920	0.7920	0.7904	0.7904	0.7904	0.7904
1.500	1.3056	1.3056	1.1670	1.1670	0.8981	0.8981	0.7904	0.7904	0.7892	0.7892	0.7892	0.7892
1.600	1.3084	1.3084	1.1683	1.1683	0.8976	0.8976	0.7892	0.7892	0.7889	0.7889	0.7889	0.7889
1.700	1.3097	1.3097	1.1692	1.1692	0.8974	0.8974	0.7889	0.7889	0.7892	0.7892	0.7892	0.7892
1.800	1.3148	1.3148	1.1720	1.1720	0.8970	0.8970	0.7892	0.7892	0.7904	0.7904	0.7904	0.7904
1.900	1.3152	1.3152	1.1722	1.1722	0.8970	0.8970	0.7904	0.7904	0.7920	0.7920	0.7920	0.7920
2.000	1.3183	1.3183	1.1738	1.1738	0.8974	0.8974	0.7920	0.7920	0.7943	0.7943	0.7943	0.7943
2.100	1.3221	1.3221	1.1761	1.1761	0.8959	0.8959	0.7943	0.7943	0.7959	0.7959	0.7959	0.7959
2.200	1.3265	1.3265	1.1783	1.1783	0.8949	0.8949	0.7959	0.7959	0.7988	0.7988	0.7988	0.7988
2.300	1.3286	1.3286	1.1791	1.1791	0.8952	0.8952	0.7988	0.7988	0.7996	0.7996	0.7996	0.7996
2.400	1.3300	1.3300	1.1799	1.1799	0.8953	0.8953	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
2.500	1.3330	1.3330	1.1799	1.1799	0.8948	0.8948	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
2.600	1.3342	1.3342	1.1801	1.1801	0.8943	0.8943	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
2.700	1.3329	1.3329	1.1791	1.1791	0.8934	0.8934	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
2.800	1.3348	1.3348	1.1797	1.1797	0.8926	0.8926	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
2.900	1.3335	1.3335	1.1789	1.1789	0.8923	0.8923	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
3.000	1.3335	1.3335	1.1789	1.1789	0.8923	0.8923	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
3.150	1.3342	1.3342	1.1789	1.1789	0.8931	0.8931	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
3.300	1.3352	1.3352	1.1789	1.1789	0.8933	0.8933	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
3.450	1.3335	1.3335	1.1784	1.1784	0.8936	0.8936	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
3.600	1.3323	1.3323	1.1760	1.1760	0.8943	0.8943	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
3.800	1.3314	1.3314	1.1774	1.1774	0.8951	0.8951	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
4.000	1.3347	1.3347	1.1787	1.1787	0.8953	0.8953	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
4.200	1.3368	1.3368	1.1802	1.1802	0.8948	0.8948	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
4.400	1.3429	1.3429	1.1834	1.1834	0.8943	0.8943	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
4.600	1.3463	1.3463	1.1844	1.1844	0.8941	0.8941	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
4.800	1.3472	1.3472	1.1842	1.1842	0.8934	0.8934	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
5.000	1.3487	1.3487	1.1850	1.1850	0.8929	0.8929	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
5.250	1.3525	1.3525	1.1863	1.1863	0.8926	0.8926	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
5.500	1.3543	1.3543	1.1870	1.1870	0.8925	0.8925	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
5.750	1.3586	1.3586	1.1887	1.1887	0.8915	0.8915	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
6.000	1.3574	1.3574	1.1882	1.1882	0.8916	0.8916	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
6.250	1.3572	1.3572	1.1874	1.1874	0.8922	0.8922	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996
6.500	1.3554	1.3554	1.1861	1.1861	0.8923	0.8923	0.7996	0.7996	0.7996	0.7996	0.7996	0.7996

Table 3: WUS-Rock Sites Spectral Ratios

WJS ROCK SITES
AVERAGE HORIZONTAL AND VERTICAL SPECTRAL RATIOS

6.750	1.3546	1.1856	1.1856	0.8922	0.8922	0.7907
7.000	1.3539	1.1862	1.1862	0.8923	0.8923	0.7913
7.250	1.3517	1.1848	1.1848	0.8933	0.8933	0.7933
7.500	1.3471	1.1824	1.1824	0.8946	0.8946	0.7960
7.750	1.3442	1.1810	1.1810	0.8953	0.8953	0.7982
8.000	1.3413	1.1796	1.1796	0.8962	0.8962	0.8001
8.500	1.3382	1.1778	1.1778	0.8973	0.8973	0.8026
9.000	1.3375	1.1772	1.1772	0.8981	0.8981	0.8048
9.500	1.3330	1.1743	1.1743	0.8998	0.8998	0.8080
10.000	1.3305	1.1730	1.1730	0.9018	0.9018	0.8123
10.500	1.3268	1.1701	1.1701	0.9043	0.9043	0.8175
11.000	1.3225	1.1679	1.1679	0.9060	0.9060	0.8211
11.500	1.3188	1.1658	1.1658	0.9073	0.9073	0.8242
12.000	1.3120	1.1619	1.1619	0.9095	0.9095	0.8284
12.500	1.3040	1.1577	1.1577	0.9123	0.9123	0.8340
13.000	1.2980	1.1541	1.1541	0.9154	0.9154	0.8398
13.500	1.2889	1.1491	1.1491	0.9189	0.9189	0.8464
14.000	1.2802	1.1445	1.1445	0.9223	0.9223	0.8529
14.500	1.2675	1.1371	1.1371	0.9259	0.9259	0.8596
15.000	1.2549	1.1306	1.1306	0.9293	0.9293	0.8659
16.000	1.2398	1.1222	1.1222	0.9337	0.9337	0.8742
17.000	1.2214	1.1124	1.1124	0.9391	0.9391	0.8843
18.000	1.2024	1.1026	1.1026	0.9451	0.9451	0.8954
20.000	1.1817	1.0917	1.0917	0.9510	0.9510	0.9065
22.000	1.1587	1.0798	1.0798	0.9570	0.9570	0.9174
25.000	1.1346	1.0676	1.0676	0.9630	0.9630	0.9288
28.000	1.1119	1.0560	1.0560	0.9689	0.9689	0.9402
31.000	1.0891	1.0450	1.0450	0.9749	0.9749	0.9516
34.000	1.0690	1.0347	1.0347	0.9807	0.9807	0.9628
40.000	1.0528	1.0266	1.0266	0.9852	0.9852	0.9714
45.000	1.0409	1.0207	1.0207	0.9885	0.9885	0.9780
50.000	1.0305	1.0155	1.0155	0.9911	0.9911	0.9831
55.000	1.0218	1.0110	1.0110	0.9937	0.9937	0.9881
60.000	1.0152	1.0078	1.0078	0.9956	0.9956	0.9919
65.000	1.0110	1.0057	1.0057	0.9969	0.9969	0.9942
70.000	1.0085	1.0043	1.0043	0.9977	0.9977	0.9956
75.000	1.0078	1.0039	1.0039	0.9980	0.9980	0.9961
80.000	1.0067	1.0033	1.0033	0.9982	0.9982	0.9966

Table 3: WUS-Rock Sites Spectral Ratios (continued)

WUS SOIL SITES
AVERAGE HORIZONTAL AND VERTICAL SPECTRAL RATIOS

FREQUENCY (HZ)	EUS-SOIL H-AVG		EUS-SOIL V-AVG		EUS-SOIL H-AVG		EUS-SOIL V-AVG		EUS-SOIL H-AVG		EUS-SOIL V-AVG	
	2% DAMPING	10% DAMPING	2% DAMPING	10% DAMPING	3% DAMPING	7% DAMPING	10% DAMPING	3% DAMPING	7% DAMPING	10% DAMPING	3% DAMPING	7% DAMPING
0.500	1.2041	1.2042	1.1110	1.1108	0.9415	0.9423	0.9044	0.9029	0.7855	0.7855	0.7855	0.7855
0.600	1.2444	1.2444	1.1353	1.1353	0.9218	0.9218	0.8557	0.8557	0.8311	0.8311	0.8311	0.8311
0.700	1.2681	1.2681	1.1487	1.1487	0.9116	0.9116	0.8165	0.8165	0.8069	0.8069	0.8069	0.8069
0.800	1.2870	1.2870	1.1553	1.1553	0.9053	0.9053	0.8013	0.8013	0.7977	0.7977	0.7977	0.7977
0.900	1.2979	1.2979	1.1643	1.1643	0.8984	0.8984	0.7942	0.7942	0.7928	0.7928	0.7928	0.7928
1.000	1.3033	1.3033	1.1698	1.1698	0.8963	0.8963	0.7928	0.7928	0.7911	0.7911	0.7911	0.7911
1.100	1.3176	1.3176	1.1741	1.1741	0.8934	0.8934	0.7911	0.7911	0.7895	0.7895	0.7895	0.7895
1.200	1.3233	1.3233	1.1773	1.1773	0.8905	0.8905	0.7895	0.7895	0.7883	0.7883	0.7883	0.7883
1.300	1.3234	1.3264	1.1757	1.1757	0.8888	0.8888	0.7883	0.7883	0.7864	0.7864	0.7864	0.7864
1.400	1.3278	1.3278	1.1736	1.1736	0.8894	0.8894	0.7864	0.7864	0.7855	0.7855	0.7855	0.7855
1.500	1.3300	1.3300	1.1809	1.1809	0.8924	0.8924	0.7855	0.7855	0.7846	0.7846	0.7846	0.7846
1.600	1.3351	1.3361	1.1835	1.1835	0.8913	0.8913	0.7846	0.7846	0.7844	0.7844	0.7844	0.7844
1.700	1.3370	1.3370	1.1847	1.1847	0.8905	0.8905	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
1.800	1.3416	1.3406	1.1852	1.1852	0.8896	0.8896	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
1.900	1.3335	1.3385	1.1850	1.1850	0.8896	0.8896	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
2.000	1.3331	1.3381	1.1843	1.1843	0.8896	0.8896	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
2.100	1.3417	1.3417	1.1859	1.1859	0.8894	0.8894	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
2.200	1.3439	1.3439	1.1870	1.1870	0.8887	0.8887	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
2.300	1.3431	1.3491	1.1891	1.1891	0.8883	0.8883	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
2.400	1.3511	1.3541	1.1906	1.1906	0.8883	0.8883	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
2.500	1.3521	1.3521	1.1898	1.1898	0.8882	0.8882	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
2.600	1.3534	1.3534	1.1902	1.1902	0.8878	0.8878	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
2.700	1.3558	1.3558	1.1911	1.1911	0.8878	0.8878	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
2.800	1.3578	1.3578	1.1919	1.1919	0.8878	0.8878	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
2.900	1.3578	1.3578	1.1914	1.1914	0.8879	0.8879	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
3.000	1.3522	1.3552	1.1897	1.1897	0.8886	0.8886	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
3.150	1.3577	1.3567	1.1898	1.1898	0.8890	0.8890	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
3.300	1.3542	1.3542	1.1884	1.1884	0.8894	0.8894	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
3.450	1.3570	1.3500	1.1884	1.1884	0.8904	0.8904	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
3.600	1.3571	1.3501	1.1857	1.1857	0.8919	0.8919	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
3.800	1.3515	1.3515	1.1858	1.1858	0.8928	0.8928	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
4.000	1.3535	1.3505	1.1851	1.1851	0.8933	0.8933	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
4.200	1.3518	1.3538	1.1855	1.1855	0.8934	0.8934	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
4.400	1.3578	1.3578	1.1887	1.1887	0.8934	0.8934	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
4.600	1.3616	1.3616	1.1903	1.1903	0.8900	0.8900	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
4.800	1.3618	1.3618	1.1908	1.1908	0.8923	0.8923	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
5.000	1.3631	1.3631	1.1913	1.1913	0.8930	0.8930	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
5.250	1.3678	1.3678	1.1936	1.1936	0.8917	0.8917	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
5.500	1.3639	1.3689	1.1950	1.1950	0.8906	0.8906	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
5.750	1.3674	1.3674	1.1944	1.1944	0.8906	0.8906	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
6.000	1.3637	1.3687	1.1949	1.1949	0.8905	0.8905	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
6.250	1.3650	1.3660	1.1934	1.1934	0.8906	0.8906	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
6.500	1.3645	1.3645	1.1922	1.1922	0.8912	0.8912	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
6.750	1.3621	1.3621	1.1909	1.1909	0.8918	0.8918	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
7.000	1.3620	1.3620	1.1906	1.1906	0.8920	0.8920	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844
7.250	1.3625	1.3625	1.1907	1.1907	0.8923	0.8923	0.7844	0.7844	0.7844	0.7844	0.7844	0.7844

Table 4: WUS-Soil Sites Spectral Ratios

WJUS SOIL SITES
AVERAGE HORIZONTAL AND VERTICAL SPECTRAL RATIOS

7.500	1.3601	1.3601	1.1892	1.1892	0.8931	0.8931	0.7957	0.7957
7.750	1.3586	1.3586	1.1876	1.1876	0.8941	0.8941	0.7969	0.7969
8.000	1.3581	1.3581	1.1869	1.1869	0.8948	0.8948	0.7985	0.7985
8.500	1.3521	1.3521	1.1840	1.1840	0.8960	0.8960	0.8003	0.8003
9.000	1.3473	1.3473	1.1814	1.1814	0.8981	0.8981	0.8037	0.8037
9.500	1.3407	1.3407	1.1774	1.1774	0.8999	0.8999	0.8072	0.8072
10.000	1.3353	1.3353	1.1740	1.1740	0.9018	0.9018	0.8108	0.8108
10.500	1.3292	1.3292	1.1702	1.1702	0.9041	0.9041	0.8150	0.8150
11.000	1.3237	1.3237	1.1672	1.1672	0.9061	0.9061	0.8190	0.8190
11.500	1.3193	1.3193	1.1645	1.1645	0.9079	0.9079	0.8228	0.8228
12.000	1.3122	1.3122	1.1611	1.1611	0.9102	0.9102	0.8275	0.8275
12.500	1.3042	1.3042	1.1569	1.1569	0.9130	0.9130	0.8331	0.8331
13.000	1.2979	1.2979	1.1533	1.1533	0.9154	0.9154	0.8382	0.8382
13.500	1.2897	1.2897	1.1491	1.1491	0.9176	0.9176	0.8429	0.8429
14.000	1.2796	1.2796	1.1444	1.1444	0.9201	0.9201	0.8482	0.8482
14.500	1.2681	1.2681	1.1387	1.1387	0.9237	0.9237	0.8552	0.8552
15.000	1.2535	1.2535	1.1311	1.1311	0.9283	0.9283	0.8636	0.8636
16.000	1.2357	1.2357	1.1216	1.1216	0.9337	0.9337	0.8734	0.8734
17.000	1.2152	1.2152	1.1108	1.1108	0.9398	0.9398	0.8847	0.8847
18.000	1.1934	1.1934	1.0993	1.0993	0.9464	0.9464	0.8973	0.8973
20.000	1.1721	1.1721	1.0880	1.0880	0.9527	0.9527	0.9094	0.9094
22.000	1.1488	1.1488	1.0757	1.0757	0.9593	0.9593	0.9219	0.9219
25.000	1.1259	1.1259	1.0637	1.0637	0.9660	0.9660	0.9345	0.9345
28.000	1.1035	1.1035	1.0521	1.0521	0.9726	0.9726	0.9468	0.9468
31.000	1.0819	1.0819	1.0411	1.0411	0.9783	0.9783	0.9579	0.9579
34.000	1.0636	1.0636	1.0318	1.0318	0.9833	0.9833	0.9674	0.9674
40.000	1.0477	1.0477	1.0237	1.0237	0.9875	0.9875	0.9758	0.9758
45.000	1.0354	1.0354	1.0175	1.0175	0.9909	0.9909	0.9824	0.9824
50.000	1.0258	1.0258	1.0127	1.0127	0.9932	0.9932	0.9869	0.9869
55.000	1.0170	1.0170	1.0083	1.0083	0.9953	0.9953	0.9909	0.9909
60.000	1.0116	1.0116	1.0058	1.0058	0.9969	0.9969	0.9940	0.9940
65.000	1.0088	1.0088	1.0043	1.0043	0.9978	0.9978	0.9958	0.9958
70.000	1.0071	1.0071	1.0035	1.0035	0.9983	0.9983	0.9967	0.9967
75.000	1.0065	1.0065	1.0032	1.0032	0.9984	0.9984	0.9969	0.9969
80.000	1.0057	1.0057	1.0028	1.0028	0.9986	0.9986	0.9973	0.9973

Table 4: WUS-Soil Sites Spectral Ratios(continued)

APPENDIX D TO SRP SECTION 3.7.1
REVIEW PROCESS WITH AND WITHOUT REFERENCING A CERTIFIED DESIGN

3.7.1-43

Draft Revision 4 - December 2012






Figure 1 - Part 52 Process with Certified Design



**52 Process - Plant
Using Approved
Certified Design**



**Figure 2 - Part
Evaluation
Methods in the**

Figure 3 - Process When a Certified Design is Not Used

3.7.1-47

Draft Revision 4 - December 2012

SRP Section 3.7.1
“Seismic Design Parameters”

Description of Changes

This SRP section affirms the technical accuracy and adequacy of the guidance previously provided in Revision 3, dated March 2007 of this SRP. See ADAMS Accession No. ML070640306.

I. AREAS OF REVIEW

1. Revised the designation of the primary review responsibility to be the organization responsible for structural reviews.
2. Deleted reference to Regulatory Guide 1.165 because it was withdrawn.
3. Added text to reference additional interim staff guidance provided in ISG-01 and ISG 017.

II. ACCEPTANCE CRITERIA

1. Added text to reference additional interim staff guidance in ISG-01 and ISG-017.
2. Enhanced guidance in SRP Section 3.7.1 II.1.B related to design time histories. The technical rationale for this change is as follows.

When the seed recorded time history is selected based on a reasonable comparison of the spectral shape of the seed with the target design spectra, then it would facilitate and ensure that a good spectral matching can be achieved. This occurs because the magnitude of the seed record could be increased without the need for making significant adjustments at each frequency. This approach avoids increasing the input at certain frequencies too much which could lead to significant overprediction of the response at certain frequencies and cause underprediction at adjacent frequencies.

3. Enhanced guidance in SRP Section 3.7.1 II.1.B ii. (Option 1 - single set of time histories, Approach 2), item (d). The technical rationale for this change is as follows.

The first criterion in Item (d) of the SRP ensures there is no significant overprediction of the response spectrum of the artificial ground motion time history. The second criterion ensures that there will not be a significant energy gap at any frequency over the frequency range of interest. Both criteria should be satisfied to ensure that overestimation of the spectral matching at certain frequencies would not cause significant deficiencies in energy at other frequencies.

4. Enhanced guidance in SRP Section 3.7.1 II.1.B Option 2 - multiple sets of time histories. The technical rationale for this change is as follows.

In view of the complexities of performing nonlinear time history analyses, it is difficult to identify a specific number of time history input motions that should be used. To do so would require additional research that should include performing many nonlinear time history analyses on various structures and components. However, there is some guidance in other standards on selection of the number of earthquake motions and how to select the responses from the multiple nonlinear time history analyses. For seismic analysis and design of buildings, Section 1618 of the 2003 International Building Code (IBC) identifies that dynamic analysis including nonlinear time history analysis shall be performed in accordance with the requirements of the ASCE 7 Standard. Section 16.2.4 of ASCE/SEI 7-05 indicates that:

“If at least seven ground motions are analyzed, the design values of member forces, Q_E , member inelastic deformations, Ψ , and story drift, Δ , are permitted to be taken as the average of the Q_{Ei} , Ψ_i , and Δ_i values determined from the analyses. If fewer than seven ground motions are analyzed, the design member forces, Q_E , design member inelastic deformations, Ψ , and the design story drift, Δ , shall be taken as the maximum value of the Q_{Ei} , Ψ_i , and Δ_i values determined from the analyses.”

The Commentary to IBC 2003 indicates that the code’s earthquake load requirements are based on ASCE 7 and the National Earthquake Hazards Reduction Program’s (NEHRP) Recommended Provisions for the Development of Seismic Regulations for New Buildings (FEMA 368). This FEMA Standard has been superseded by the 2009 edition of FEMA P-750, entitled NEHRP Recommended Seismic Provisions for New Buildings and Other Structures. The Commentary to FEMA P-750 discusses the number of ground motions to be used in a nonlinear time history analysis and the use of the average values or maximum values of deformations in a similar manner to the ASCE 7 Standard. In addition, the Commentary to FEMA P-750 indicates that “...It is very important to note, however, that assessment of deformations in this manner should not be done without careful inspection of the story displacement histories of each analysis. It is possible that the maximum displacement or drift may be completely dominated by the response from one ground motion, and such dominance, when due to ratcheting (increasing deformations in one direction resulting in a high residual deformation), may be a sign of imminent dynamic instability. Where these kinds of dynamic instabilities are present, the analyst should attempt to determine the system characteristics that produce such effects. The ground motion that produces dynamic instability should not be replaced with one that does not.”

5. Deleted reference to Regulatory Guide 1.165 because it was withdrawn.

VI. REFERENCES

1. Deleted reference to Regulatory Guide 1.165 because it was withdrawn.
2. Added reference to Houston et al. (2010).

3. Added reference to Interim Staff Guidance 01 (DC/COL-ISG-01).
4. Added reference to Interim Staff Guidance 17 (DC/COL-ISG-17).