

C

Seismic Walkdown Checklists (SWCs)

Below are the names and signatures of the personnel who performed the seismic walkdowns.

Ben Frazier



Kevin Gantz



Mojtaba Oghbaei



Craig Swanner



James Wiggin



Caroline Schlaseman



The order of the Seismic Walkdown Checklists (SWCs) for Unit 3 is shown in Table C-1 below and the order of the SWCs for Unit 0 (common) is shown in Table C-2.

The "Anchorage Configuration Confirmation" column is described in Section 5.2.1 of this report. The last column in Tables C-1 and C-2 provides the corresponding Area Walk-By Checklist (AWC). (AWCs are included in Appendix D of this report.) AWC identifiers with asterisks (*) indicate the second or subsequent SWEL item included with a specific Area Walk-By.

Table C-1. Unit 3 Seismic Walkdown Checklists (SWCs)

| Component ID | Description | Anchor Configuration Confirmed? | AWC-Ux-YY |
|---------------------|---|--|------------------|
| 30B010 | Emergency Aux Load Center E134 Switchgear | N | U3-23* |
| 30B013 | Emergency Aux Load Center E434 Switchgear | N | U3-24* |
| 30B324 | MO-3-23-015 Motor Control Power Transfer Switch | Y | U3-15 |
| 30B325 | MO-3-13-15 Motor Control Starter Panel | Y | U3-15* |
| 30B338 | MO3-10-16A Auto Transfer Switch | Y | U3-15* |
| 30C003 | Reactor and Containment Cooling and Isolation | Y | U0-7* |
| 30C004C | RCIC Vertical Board | Y | U0-7 |
| 30C005A | Reactor Manual Control Board | Y | U0-7* |
| 30C095 | RCIC Instrument Rack | N | U3-4* |
| 30C32 | Egr Safeguard Sub-Sys I | Y | U3-22* |
| 30C33 | Egr Safeguard Sub-Sys II | Y | U3-22* |
| 30C34 | RCIC Relay Panel | Y | U3-22* |
| 30C722A | Accident Monitoring Instrumentation Panel | Y | U3-22* |
| 30C722B | Accident Monitoring Instrumentation Panel | Y | U3-22* |
| 30C87 | HPCI Instrument Rack | N | U3-4 |
| 30D043 | HPCI Aux Lube Oil Pump Starter | N | U3-8* |
| 30D37 | Static Inverter | N | U3-2 |
| 30P033, 30P038 | HPCI Booster Pump, Pump | Y | U3-8 |
| 30P036 & 30S038 | RCIC Pump & Turbine | Y | U3-12 |
| 30S037 | HPCI Turbine | Y | U3-8* |
| 30S703 | 120V Inst. Panel 30Y035 Transfer Switch | N | U3-14* |
| 30X030 | Load Center E134 Transformer | Y | U3-23 |
| 30X033 | Load Center E434 Transformer | N | U3-24 |
| 30X133 | Panel 30Y33 Transformer | N | U3-5 |
| 30Y050 | 120V AC Distribution Panel | N | U3-22 |
| 30Y35 | 3PPD 125V DC Distribution Panel 3C | N | U3-14 |
| 3AC65 | RPS Instrument Rack | N | U3-7 |
| 3AE058 | RHR Room A Cooling Coil A | Y | U3-17 |
| 3AE124 | RHR Pump 3A Seal Cooler | N | U3-16* |
| 3AE55 | RCIC Room Cooling Coil A | Y | U3-12* |
| 3AE56 | HPCI Room Cooling Coil A | Y | U3-8* |
| 3AE57 | Core Spray Room A Cooling Coil A | Y | U3-11* |
| 3AP035 | RHR Pump A | Y | U3-16 |
| 3AP037 | Core Spray Pump A | Y | U3-11 |
| 3AV083 | HPSW Pump Room Exhaust Fan | Y | U3-3* |

Table C-1. Unit 3 Seismic Walkdown Checklists (SWCs)

| Component ID | Description | Anchor Configuration Confirmed? | AWC-Ux-YY |
|---------------------|---|--|------------------|
| 3BC270 | Steam B Leak Monitor Cabinet | N | U0-6* |
| 3BC65 | RPS Instrument Rack B | N | U3-14* |
| 3BD01 | 125 VDC Battery 3B | Y | U3-10* |
| 3BD025 | 3B 125 VDC Distribution Panel | N | U3-22* |
| 3BE55 | RCIC Room Cooling Coil B | Y | U3-12* |
| 3BE57 | Core Spray Room A Cooling Coil B | Y | U3-11* |
| 3BE58 | RHR Room A Cooling Coil B | Y | U3-16* |
| 3CD001 | 125 VDC Battery 3C | Y | U3-21 |
| 3CD03 | Battery Charger 3C | Y | U3-9 |
| 3CE24 | RHR Heat Exchanger C | Y | U3-19 |
| 3CP035 | RHR Pump C | Y | U3-18* |
| 3CP042 | High Pressure Service Water Pump C | Y | U3-3* |
| 3DC068 | RPS SCRAM solenoid fuse panel D | N | U3-13* |
| 3DD01 | 125 VDC Battery 3D | Y | U3-10 |
| 3DD03 | Battery Charger 3D | Y | U3-1 |
| AO3-03-33 | Scram Discharge Volume Inboard Isolation Valve | N/A | U3-13 |
| AO3-03-36 | Scram Discharge Volume Outboard Isolation Valve | N/A | U3-13* |
| H03-23C-5512 | HPCI Turbine Governor Control Valve | N/A | U3-8* |
| HCU-06-47 | Hydraulic Control Unit | Y | U3-13* |
| HCU-14-35 | Hydraulic Control Unit | Y | U3-13* |
| LI3-2-3-113 | Reactor Water Level | N | U0-7* |
| LI-9027 | Torus Water Level | N | U0-7* |
| LR/TR-9123B | Torus Water Level/Temperature Recorder | N | U0-7* |
| LS3-23-91A | Suppression Pool Level Switch | N/A | U3-6 |
| LT3-2-3-61 | Reactor Vessel Water Level Transmitter | N | U3-7* |
| LT-9123A | Torus Water Level Transmitter | N | U3-6* |
| MO3-10-013C | RHR Pump Torus Suction Valve | N/A | U3-18 |
| MO3-10-015C | RHR Pump Shutdown Cooling Suction | N/A | U3-16* |
| MO3-10-89C | RHR HX HPSW Outlet Valve | N/A | U3-19* |
| MO3-30-3233A | Unit 3A Sluice Gate | Y | U3-25 |
| MO-3-32-3803 | HPSW Return Valve to ECT | N/A | U0-1* |
| MO3-48-3804B | HPSW Bay Inlet Inner Valve | N/A | U0-5* |
| MO-3-10-013A | RHR Pump Suction Valve A | N/A | U3-16* |
| P0D-3-40H-30223-03 | HPSW Pump Room A Loop Supply Damper | N | U3-3* |
| P0D-3-40H-30223-04 | HPSW Pump Room B Loop Exhaust Damper | N | U3-3 |

Table C-1. Unit 3 Seismic Walkdown Checklists (SWCs)

| Component ID | Description | Anchor Configuration Confirmed? | AWC-Ux-YY |
|---------------------|---|--|------------------|
| PI3-6-90A | Reactor Wide Range Pressure Indicator | N | U0-7* |
| PR/RR3-2-3-404B | Reactor Pressure/Drywell Gas Recorder | N | U0-7* |
| PR/TR-5805 | Containment Pressure/Temp | N | U0-7* |
| PS30224-2 | HPSW Pump Room B Loop Pressure Switch | N | U3-3* |
| PT3-2-3-404A | Reactor Pressure Transmitter | N | U3-7* |
| PT3-6-53A | Reactor Wide Range Pressure Transmitter | N | U3-7* |
| PT-5805 | Drywell Pressure Transmitter | N | U3-20 |
| RV3-23-034 | HPCI Pump Suction Header Relief Valve | N/A | U3-8* |
| SV3-3-33 | Instrument Air Solenoid Valve | Y | U3-13* |
| SV3-3-36 | Instrument Air Solenoid Valve | Y | U3-13* |

Seismic Walkdown Checklist (SWC)

Equipment ID No. E134 (308010) Equip. Class¹² (02) Low Voltage Swgr
 Equipment Description Emergency Aux Load Center Swgr.
 Location: Bldg. RB Floor El. 105 Room, Area R3-4116 MO 10/24/12
 Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A
Externally welded to cat welds to anchorage verified. Not shown in pictures because of small clearance between door & glout pad.

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation? Y N U N/A
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. E134 (308010) Equip. Class¹² Low Voltage Surge
Equipment Description Emergency Aux Load Center Surge

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets identified.

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

no 11/8/12 Verify masonry block wall is reinforced per Spec. M-701 Rev. 1. Lighting is secure. (south wall & west wall)

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Hoist is secure.

Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

Cabinet not opened because it is energized & hand tooling is required.

Evaluated by:


[Signature]
[Signature]

Date: 10/8/12

10/8/12



09.28.2012 22:32



09.28.2012 22:33




09.28.2012 22:32



09.28.2012 22:33

Equipment ID: 30B010



Seismic Walkdown Checklist (SWC)

Equipment ID No. 308013
E434 Equip. Class¹² (02) Low Voltage Switchgear
 Equipment Description Emergency Aux Load Center Swgr
 Location: Bldg. RB Floor El. 105 Room, Area R3-41
 Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A
Anchorage is external & verified to be in good condition

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation?
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) Y N U N/A
CBQ

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. E434 (308013) Equip. Class¹² (02) Low Voltage Switchgear
Equipment Description Emergency Aux Load Center Surge

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets identified

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

Masonry wall ^{MO 11/8/12} needs to be verified as reinforced per Spec. M-701 Rev. 1. ^{MO 10/18/12} Light Fixtures secure.

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

Cabinet not opened because hand tools required & it is energized.

Evaluated by:

[Signature]
M. Ghafari

Date:

10/8/12
10/8/2012



Equipment ID: 30B013



Seismic Walkdown Checklist (SWC)

Equipment ID No. 308324 Equip. Class¹² (1) MCC CAB
Elec. Enct.
 Equipment Description M0-3-23-015 Motor Control Power Transfer Switch
 Location: Bldg. 3 Barbours Floor El. 135 Room, Area Recirc. MG Set
 Manufacturer, Model, Etc. (optional but recommended) Turbine CAB

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U
Verified per DWG G280-E-542-2 Rev 2
2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A
3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A
4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A
5. Is the anchorage configuration consistent with plant documentation? Y N U N/A
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30B324 Equip. Class¹² (1) MCC
Equipment Description M0-3-23-05 Motor Control Power Transfer Switch

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets identified.

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

No H/E concerns

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A



10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions



11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

Evaluated by: *[Signature]* Date: 9/12/12
[Signature] 9/12/12



Equipment ID: 30B324



Seismic Walkdown Checklist (SWC)

(1) MCC *CSA*

Equipment ID No. 308325 Equip. Class¹² Elect. Encls
 Equipment Description M0-3-13-15 Motor Control Starter Panel
 Location: Bldg. Radwaste Floor El. 36' Room, Area Receiv MG Scts.
 Manufacturer, Model, Etc. (optional but recommended) Turbine *CSA*

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U
Verified per 6280-E-542-1 Rev. 2
2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A
3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A
4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A
5. Is the anchorage configuration consistent with plant documentation? (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) Y N U N/A
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30B325 Equip. Class¹² (1) MCC
Equipment Description M0-3-13-015 Motor Control Starter Panel

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets identified.

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions


11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

Evaluated by: *[Signature]* Date: 9/12/12
[Signature] 9/12/12



Equipment ID: 30B325



Seismic Walkdown Checklist (SWC)

Equipment ID No. 30B338 Equip. Class¹² (1) MCC ~~Elect. Encl.~~
 Equipment Description No 3-10-0164 Auto Transfer. Switch
 Location: Bldg. 3 Radwaste Turbine Building, CAE Floor El. 135 Room, Area Recirc. RA
 Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N
 Verified per DWG. 6280-E-542-19 Rev 2.
2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A
3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A
4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A
 Minor spalling in concrete deemed acceptable.
5. Is the anchorage configuration consistent with plant documentation? Y N U N/A
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 308338 Equip. Class¹² (1) MCC
Equipment Description MO 3-10-016A Auto Transfer Bypass Switch

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets identified.

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

Overhead light fixture is secure.

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Upper east bolt securing panel is loose. Lower east bolt is missing. Both are on hinge side. Seven other bolts are tight. Therefore, loose/missing fasteners not a

Comments (Additional pages may be added as necessary)




Substantive concern





Issue addressed in IR 1424719.

BMF 10/15/12

Evaluated by: *[Signature]*
Ben Jy

Date: *9/12/12*
9/12/12





Seismic Walkdown Checklist (SWC)

Equipment ID No. 30C003 Equip. Class¹² (20) Control Panels & Cabinets

Equipment Description Reactor and Containment Cooling and Isolation

Location: Bldg. Turbine Floor El. 165 Room, Area T3-100

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist:

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A
1 1/2" - 2" stitch weld on front of cabinet anchorage,

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A
Embedded channel in Concrete. No crack in concrete.

5. Is the anchorage configuration consistent with plant documentation? Y N U N/A
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
Anchorage configuration verified to Dwg. S-1197, Rev. 0.

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30C003 Equip. Class¹² (20) Control Panels & Cabinets

Equipment Description Reactor and Containment Cooling and Isolation

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets outside of cabinet. MO 8/31/12

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

*Damage from falling ceiling tiles not credible. MO 10/18/12
MCR ceiling consistent with Calc 26-S/Z-12, Revision 0. Calc G-106-1 could not be located. See IR 01428651.*

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

No attached lines.

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)



Evaluated by: *M. Oghbaei* Date: *8/31/12* *10/19/12* *BAM 10/11*



Ben Fry *8/31/12* *10/19/12* *BAM 10/11*






Equipment ID: 30C003







Seismic Walkdown Checklist (SWC)

Equipment ID No. 30C004C Equip. Class¹² (20) Control Panels & Cabinets

Equipment Description RCIC Vertical Board

Location: Bldg. Turbine Floor El. 165 Room, Area T3-100

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A
*8MF 2"-12" stitchweld on front of cabinet, back of cabinet, and on inside of cabinet.
 6/29/12 1 1/2"-9" Cabinet bolted to adjacent cabinets.*

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A
Embedded channel in concrete. No cracks in concrete.

5. Is the anchorage configuration consistent with plant documentation? Y N U N/A
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
verified to drawing S-1197 Rev 0 (Sheet 1 of 3)

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30C004C Equip. Class¹² (20) Control Panels & Cabinets

Equipment Description RCIC Vertical Board

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets outside of cabinet. MO 8/31/12

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

2'x4' ceiling tiles. Damage from falling tiles not visible. ~~existing on fluorescent lighting.~~ BMF 10/19/12

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

No attached lines.

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U


Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)




→ mcr ceiling consistent with Calc 26-5/2-12, Revision 0. Calc 6-106-1 could not be located. See IR 01428651.



Evaluated by: *Ben Fay* Date: *8/29/12 10/19/12* ^{BMF 10/19/12}
K. Ogilvie *8/29/12 10/19/12* ^{MO 10/19/12}



Equipment ID: 30C004C







Seismic Walkdown Checklist (SWC)

Equipment ID No. 30C005A Equip. Class¹² (20) Control Panels & Cabinets

Equipment Description Reactor Manual Control Board

Location: Bldg. Turbine Floor El. 165 Room, Area T3-100

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation? Y N U N/A
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
Anchorage verified to Div. S-1197, sheet 3 of 3 (Rev. 0).

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30C005A Equip. Class¹² (20) Control Panels & Cabinets

Equipment Description Reactor Manual Control Board

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

MCR ceiling consistent with Calc 26-5/2-12, Revision 0. Calc 6-106-1 could not be located. See IR 01428651.

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A


10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions



11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U


Comments (Additional pages may be added as necessary)

Evaluated by: *Burfy* Date: 10/19/12
H. Ghasseini 10/19/12



Equipment ID: 30C005A





Seismic Walkdown Checklist (SWC)

Equipment ID No. 30C095 Equip. Class¹² (18) Instruments on Racks
 Equipment Description RCIC Instrument Rack
 Location: Bldg. Reactor Floor El. BB Room, Area R3-15
 Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N
2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A
3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A
4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A
5. Is the anchorage configuration consistent with plant documentation?
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) Y N U N/A
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30C095 Equip. Class¹² (18) Instruments on Racks
Equipment Description RCIC Instrument Rack

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

N/A

Evaluated by: Janet Wiggins Date: 9/17/2012
X JG 9/17/2012




08.29.2012 15:45



08.29.2012 15:45

Equipment ID: 30C095



08.29.2012 15:45



08.29.2012 15:47



Seismic Walkdown Checklist (SWC)

Equipment ID No. 30C32 Equip. Class¹² (20) CONTROL PANELS AND CABINETS
 Equipment Description (3-SECTION CABINET)
 Location: Bldg. TURB Floor El. 150' Room, Area CSR
 Manufacturer, Model, Etc. (optional but recommended) EGR SAFEGUARD SUBSYS I

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation?
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
CONSISTENT w/ DWG # 6280-3-1198, SH T 3 OF 4, REV. 0 Y N U N/A

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30C32 Equip. Class¹² (20) CONTROL PANEL AND CABINETS
Equipment Description 3-SECTION CABINET

Interaction Effects

- 7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A
GAP BETWEEN THIS CABINET & ADJACENT CABINET (~1") IS FILLED WITH DAMPING MATERIAL
- 8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A
NO I/I CONCERNS
- 9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A
RIGID CONDUIT OK
- 10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions

- 11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

Evaluated by: _____

Ben Fry

Date: _____


10/8/12




[Signature]

10-8-2012



Equipment ID: 30C32





Equipment ID: 30C32

Seismic Walkdown Checklist (SWC)

Equipment ID No. 30C33 Equip. Class¹² (20) CONTROL PANELS AND CABINETS
 Equipment Description (3-SECTION CABINET)
 Location: Bldg. TRRB Floor El. 150' Room, Area CSR
 Manufacturer, Model, Etc. (optional but recommended) EGR SAFEGUARD SUB-345 II

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation?
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
CONSISTENT w/DWG # 6280-3-1198, REV. 9 SHF 30F4
PLUS EXTRA SMALL FILLETS ALONG S. BASE Y N U N/A

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30C33 Equip. Class¹² (20) CONTROL PANELS AND CABINETS
 Equipment Description 3-SECTION CABINET

Interaction Effects

- 7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A
INTERNAL BOLTS @ TOP CORNER R WELDED TO ADJACENT CABINETS

- 8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A
NO II/I CONCERNS

- 9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A
RIGID CONDUIT OK

- 10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U



Other Adverse Conditions

- 11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U


Comments (Additional pages may be added as necessary)

Evaluated by: *Ben Fry* Date: 10/8/12
[Signature] 10-8-2012





Equipment ID: 30C33



Seismic Walkdown Checklist (SWC)

Equipment ID No. 30C34 Equip. Class¹² (20) Control Panels & Cabinets

Equipment Description RCIC Relay Panel

Location: Bldg. Turbine Floor El. 150 Room, Area T3-81

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation?
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
*CONSISTENT w/ DWG # 6280-S-1192, R.Φ, SHT 3 OF 4
 EXTRA SMALL WELD ON S. BASE* Y N U N/A

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30C34 Equip. Class¹² (20) Control Panels & Cabinets

Equipment Description RCIC Relay Panel

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A
INTERNAL BOLTING TO ADJACENT CABINETS

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A
NO II/I CONCERNS

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A
RIGID CONDUIT OK


10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions


11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

Evaluated by: *Ben Fay* Date: *10/8/12*
[Signature] *10-8-2012*







Seismic Walkdown Checklist (SWC)

Equipment ID No. 30C722A Equip. Class¹² (20) Control Panels & Cabinets

Equipment Description Accident Monitoring Instrumentation Panel

Location: Bldg. Turbine Floor El. 150 Room, Area T3-81

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation? Y N U N/A
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
CONSISTENT WITH DW# 6280-5-1198 REV. 0 SHT 4 OF 4 PLUS EXTRA EXTERNAC FILLET WELDS TO EMBED CHANNEL (ONLY 3)

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30C722A Equip. Class¹² (20) Control Panels & Cabinets

Equipment Description Accident Monitoring Instrumentation Panel

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A
NO SOFT TARGETS

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A
NO H/I CONCERNS

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A
RIGID CONDUIT, SUFFICIENT DISTANCE TO SUPPORTS - ~~NOT~~

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

10-15-2012 CA BMF 10/15/12
~~#~~ LOWER ROW OF FLOW DETECTOR RACK - VISIBLE FROM SOUTH DOOR OPENING - ~~IR #~~ LOOSE SCREW ON RIGHT SIDE. IR # 1424662 NOT CONSIDERED SEISMICLY SIGNIFICANT.



Comments (Additional pages may be added as necessary)



Evaluated by: *Ben Fry* Date: 10/15/12
[Signature] 10-15-2012



Equipment ID: 30C722A







Seismic Walkdown Checklist (SWC)

Equipment ID No. 30C722B Equip. Class¹² (20) CONTROL PANELS & CABINETS
 Equipment Description ACCIDENT MONITORING INSTRUMENTATION PANEL
 Location: Bldg. TURB Floor El. 150 Room, Area CABLE SPREADING RM
 Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation?
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
CONSISTENT w/ DWG # 6280-S-1198, R.Φ, SHIT 4 OF 4
 Y N U N/A

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30C722 B Equip. Class¹² (20) CONTROL PANELS AND CABINETS
Equipment Description ACCIDENT MONITORING INSTRUMENTATION PANEL

Interaction Effects


- 7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A
 CONDUIT ~1/4" FROM W. END OF CABINET.
 E. END IS WELDED TO ADJACENT CABINET.
 - JUDGE OK
- 8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A
 NO I/I CONCERNS
- 9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A
 RIGID CONDUIT OK
- 10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions

- 11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U
 Both Power supply units are missing ^{two} mounting bolts to cabinet frame
 IR# 1424692. Remaining two mounting bolts appear to be adequate. BME 10/15/12


Comments (Additional pages may be added as necessary)

Evaluated by: *Ben Fry* Date: 10/15/12
[Signature] 10-15-2012




Equipment ID: 30C722B





Equipment ID: 30C722B



Seismic Walkdown Checklist (SWC)

Equipment ID No. 303 30C087 Equip. Class¹² (18) Instruments on Racks
 Equipment Description HPCI Instrument Rack
 Location: Bldg. Reactor Floor El. 88 Room, Area R3-15
 Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N
2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A
3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A
4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A
5. Is the anchorage configuration consistent with plant documentation?
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) Y N U N/A
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30C087 Equip. Class¹² (18) Instruments on Racks
Equipment Description HPCI Instrument Rack

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions


11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

~~Threaded fire piping~~ gmr 9/17/2012

Comments (Additional pages may be added as necessary)

N/A

Evaluated by: James Wiggins Date: 9/17/2012
JC Gb 9/17/2012



Equipment ID: 30C087

