

**J. Todd Conner**  
Site Vice President

DTE Energy Company  
6400 N. Dixie Highway, Newport, MI 48166  
Tel: 734.586.4849 Fax: 734.586.5295  
Email: connerj@dteenergy.com

**DTE Energy**



10 CFR 50.90

January 11, 2013  
NRC-13-0001

ATTN: Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington D C 20555-0001

Reference: Fermi 2  
NRC Docket No. 50-341  
NRC License No. NPF-43

Subject: License Amendment Request for Adoption of Technical  
Specifications Task Force (TSTF) Traveler TSTF-423, Revision 1,  
"Technical Specifications End States, NEDC-32988-A," Using the  
Consolidated Line Item Improvement Process

In accordance with the provisions of Title 10 of the *Code of Federal Regulations* (10 CFR) Section 50.90, DTE Electric Company (DTE) is submitting a request for an amendment to Fermi 2 Technical Specifications (TS) to incorporate the NRC-approved TSTF-423, Revision 1.

The proposed amendment would modify TS to risk-inform requirements regarding selected Required Action end states by incorporating the boiling water reactor (BWR) owners' group (BWROG) approved Topical Report NEDC-32988-A, Revision 2, "Technical Justification to Support Risk-Informed Modification to Selected Required Action End States for BWR Plants."

Additionally, the proposed amendment would modify the TS Required Actions with a Note prohibiting the use of limiting condition for operation (LCO) 3.0.4.a when entering the preferred end state (Mode 3) on startup.

- Enclosure 1 provides a description and assessment of the proposed change, the requested confirmation of applicability, and plant-specific verifications.
- Enclosure 2 summarizes the regulatory commitments made in this submittal.
- Enclosure 3 provides markup pages of existing TS to show the proposed change.

- Enclosure 4 provides revised (clean) TS pages.
- Enclosure 5 provides markup pages of existing TS Bases, for information only.

Approval of the proposed license amendment is requested by July 11, 2013. Once approved, the amendment will be implemented within 60 days.

In accordance with 10 CFR 50.91(a)(1), "Notice for public comment," the analysis about the issue of no significant hazards consideration (NSHC) using the standards in 10 CFR 50.92 is being provided to the Commission in accordance with the distribution requirements in 10 CFR 50.4.

In accordance with 10 CFR 50.91(b)(1), "State consultation," a copy of this application and the reasoned analysis about NSHC is being provided to the designated State of Michigan Official.

Should you have any questions or require additional information, please contact Mr. Zackary W. Rad of my staff at (734) 586-5076.

Sincerely,




Enclosures:


1. Description and Assessment of Proposed Change, Requested Confirmation of Applicability, and Plant-Specific Verifications.
2. Regulatory Commitments
3. Markup Pages of TS
4. Revised (Clean) TS pages
5. Markup Pages of TS Bases

cc: NRC Project Manager  
NRC Resident Office  
Reactor Projects Chief, Branch 5, Region III  
Regional Administrator, Region III  
Supervisor, Electric Operators,  
Michigan Public Service Commission

I, J. Todd Conner, do hereby affirm that the foregoing statements are based on facts and circumstances which are true and accurate to the best of my knowledge and belief.

  
\_\_\_\_\_  
J. Todd Conner  
Site Vice President, Nuclear Generation

On this 11 day of January, 2013 before me personally appeared J. Todd Conner, being first duly sworn and says that he executed the foregoing as his free act and deed.

  
\_\_\_\_\_  
Notary Public

SHARON S. MARSHALL  
NOTARY PUBLIC, STATE OF MI  
COUNTY OF MONROE  
MY COMMISSION EXPIRES Jun 14, 2013  
ACTING IN COUNTY OF Monroe

**Enclosure 1 to  
NRC-13-0001**

**Fermi 2 NRC Docket No. 50-341  
Operating License No. NPF-43**

**License Amendment Request for Adoption of Technical Specifications  
Task Force (TSTF) Traveler TSTF-423, Revision 1, "Technical Specifications End States,  
NEDC-32988-A," Using the Consolidated Line Item Improvement Process**

**Description and Assessment of Proposed Change,  
Requested Confirmation of Applicability, and  
Plant-Specific Verifications**

## 1.0 DESCRIPTION

The proposed amendment would modify technical specifications (TS) to risk-inform requirements regarding selected Required Action end states. Additionally, it would modify the TS Required Actions with a Note prohibiting the use of limiting condition for operation (LCO) 3.0.4.a when entering the preferred end state (Mode 3) on startup. The changes are consistent with Nuclear Regulatory Commission (NRC)-approved Technical Specification Task Force (TSTF) traveler TSTF-423, Revision 1, "Technical Specifications End States, NEDC-32988-A," dated December 22, 2009 (ADAMS Accession Number ML093570241) (Reference 1). The *Federal Register* notice published on February 18, 2011 (76 FR 34) (Reference 2) announced the availability of this TS improvement as part of the consolidated line item improvement process (CLIIP).

## 2.0 ASSESSMENT

### 2.1 Applicability of Topical Report NEDC-32988-A, TSTF-423, and Model Safety Evaluation

DTE Electric Company (DTE) has reviewed boiling water reactor (BWR) owners' group (BWROG) topical report (TR) NEDC-32988-A (Reference 3), TSTF-423, Revision 1 (Reference 1), and the NRC staff's model safety evaluation (SE) (Reference 4) as part of the CLIIP. DTE has concluded that the information in TR NEDC-32988, TSTF-423, and the NRC staff's model SE are applicable to Fermi 2 and justify this license amendment request (LAR) for the incorporation of the changes to the Fermi 2 TS.

### 2.2 Optional Changes and Variations

DTE is proposing variations or deviations from TR NEDC-32988-A, the TS changes described in the TSTF-423, Revision 1, or the NRC staff's model SE referenced in the *Federal Register* on February 18, 2011 (76 FR 34) as part of the CLIIP Notice of Availability. The proposed variations/deviations proposed from TR NEDC-32988-A, the TS changes described in the TSTF-423, Revision 1, or the NRC staff model SE are discussed in the table below:

No.	Fermi TS #	Title /Description	Variations / Deviations	Comments
1	3.4.3	Safety Relief Valves (SRVs)	No changes to TS 3.4.3 are proposed.	The Standard TS, Conditions A is optional and is not included in the current Fermi TS. Fermi TS, Condition A, is for one or more required SRVs inoperable. It requires being in Mode 3 in 12 hours and Mode 4 in 36 hours, which is similar to the proposed Condition C in TSTF-423; therefore, no changes are proposed to this TS.
2	3.5.1	Emergency Core Cooling Systems (ECCS) – Operating	Condition D in the Fermi TS is proposed to be revised per TSTF-423; however, it applies when Conditions A, B, or C are not met. Conditions in the Fermi TS are numbered differently from the Standard TS Conditions.	<p>The Standard TS, Condition A, is for one low pressure ECCS injection/spray subsystem or one LPCI pump in both LPCI subsystems inoperable. Fermi TS has separate Conditions: Condition A for one low pressure ECCS injection/spray subsystem inoperable and Condition B for one LPCI pump in both LPCI subsystems inoperable. Additionally, the Fermi TS includes Condition C for one Core Spray subsystem inoperable and one LPCI subsystem concurrently inoperable.</p> <p>The justification provided in the topical report and model SE for this change is also applicable to Condition C of the Fermi TS.</p>
3	3.6.1.9	Main Steam Isolation Valve (MSIV) Leakage Control System (LCS)	No changes to TS 3.6.1.9 are proposed.	Fermi TS does not include a specification for MSIV LCS.

No.	Fermi TS #	Title /Description	Variations / Deviations	Comments
4	3.6.4.1	Secondary Containment	Condition C in the Fermi TS is proposed to be revised per TSTF-423; however, it applies when Conditions A or B are not met.	<p>The Standard TS, Condition A, is for secondary containment inoperable. Fermi TS has Condition A for secondary containment inoperable due to one railroad bay access door inoperable; and Condition B for secondary containment inoperable for reasons other than Condition A.</p> <p>The justification provided in the topical report and model SE for this change is also applicable to Condition A of the Fermi TS.</p>
5	3.7.2	Emergency Equipment Cooling Water (EECW) / Emergency Equipment Service Water (EESW) System and Ultimate Heat Sink (UHS)	No changes to TS 3.7.2 are proposed.	The proposed changes in TSTF-423 affect Conditions A and B of the Standard TS. Condition A is for one pump inoperable and Condition B is for one pump in each subsystem inoperable. The Fermi TS does not include Conditions for pump inoperability. It includes Condition A for UHS inoperable due to inoperable cross-tie line(s); Condition B for one reservoir inoperable; and Condition C for one EECW/EESW subsystem inoperable for reasons other than Conditions A and B. Therefore, the proposed changes in TSTF-423 are not applicable to the Fermi TS.
6	3.7.3	Control Room Emergency Filtration (CREF) System	An obsolete footnote is proposed to be deleted.	The footnote on the current Fermi TS, page 3.7-6, describes a onetime allowed extension of the completion time that is no longer applicable; therefore, the footnote and the associated asterisk are proposed to be deleted.

No.	Fermi TS #	Title /Description	Variations / Deviations	Comments
7	3.7.4	Control Center Air Conditioning (AC) System	The proposed change is consistent with TSTF-423; however, it is applied to Condition C which is entered when Conditions A or B are not met. The Fermi TS incorporates TSTF-477; therefore, the proposed Fermi TS change reflects the TSTF-423 change as it applies after TSTF-477 has been incorporated.	<p>The Standard TS, Condition A, is for one [control room AC] subsystem inoperable. This Condition is included in the Fermi TS. The change in TSTF-423 when Required Action and Completion Time of Condition A are not met is applied with no variation.</p> <p>Condition D of the Standard TS requires entering LCO 3.0.3 immediately for two [control room AC] subsystems inoperable. The Fermi TS Condition B is for two control center AC subsystems inoperable. It requires verifying control room area temperature &lt; 90°F once per 4 hours and restoring one subsystem to operable within 72 hours. The change to the Standard TS in TSTF-423 requires being in Mode 3 within 12 hours of entering Condition D. This change is applied to the Fermi TS when Required Action and Completion Time of Condition B are not met.</p>
8	3.8.1	AC Sources - Operating	The proposed change is consistent with TSTF-423; however, the Conditions in the Fermi TS are numbered differently from the Standard TS Conditions.	<p>The Fermi TS contains all the Conditions in the Standard TS with the exception of the optional Condition F for one automatic load sequencer inoperable. The Fermi TS also includes Condition B for both EDGs in one division inoperable. The associated Required Actions and Completion Times are consistent with those for Condition B of the Standard TS (One EDG inoperable).</p> <p>The justification provided in the topical report and model SE for this change is also applicable to Condition B of the Fermi TS.</p>
9	N/A	Inverters - Operating	No changes are proposed.	Fermi TS does not include a specification for Inverters.
10	3.8.4 / 3.8.7	DC Sources – Operating / Distribution Systems - Operating	Conditions in the Fermi TS are numbered differently from the Standard TS Conditions.	Optional Conditions in the Standard TS are not included in the Fermi TS.



### 3.0 REGULATORY ANALYSIS

#### 3.1 No Significant Hazards Consideration Determination

DTE Electric Company (DTE) has evaluated the proposed changes to the TS using the criteria in 10 CFR 50.92 and has determined that the proposed changes do not involve a significant hazards consideration.

Description of Amendment Request: A change is proposed to the TS of Fermi 2, consistent with TSTF-423, Revision 1, to allow, for some systems, entry into hot shutdown rather than cold shutdown to repair equipment, if risk is assessed and managed consistent with the program in place for complying with the requirements of 10 CFR 50.65(a)(4). Changes proposed in TSTF-423 will be made to the Fermi 2 TS for selected Required Action end states.

Basis for no significant hazards consideration determination: As required by 10 CFR 50.91(a), DTE analysis of the issue of no significant hazards consideration is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No

The proposed change allows a change to certain required end states when the TS Completion Times for remaining in power operation will be exceeded. Most of the requested technical specification (TS) changes are to permit an end state of hot shutdown (Mode 3) rather than an end state of cold shutdown (Mode 4) contained in the current TS. The request was limited to: (1) those end states where entry into the shutdown mode is for a short interval, (2) entry is initiated by inoperability of a single train of equipment or a restriction on a plant operational parameter, unless otherwise stated in the applicable TS, and (3) the primary purpose is to correct the initiating condition and return to power operation as soon as is practical. Risk insights from both the qualitative and quantitative risk assessments were used in specific TS assessments. Such assessments are documented in Section 6 of topical report NEDC-32988-A, Revision 2, "Technical Justification to Support Risk Informed Modification to Selected Required Action End States for BWR Plants." They provide an integrated discussion of deterministic and probabilistic issues, focusing on specific TSs, which are used to support the proposed TS end state and associated restrictions. The NRC staff finds that the risk insights support the conclusions of the specific TS assessments. Therefore, the probability of an accident previously evaluated is not significantly increased, if at all. The consequences of an accident after adopting TSTF-423 are no different than the consequences of an accident prior to adopting TSTF-423. Therefore, the consequences of an accident previously evaluated are not significantly affected by this change. The addition of a requirement to assess and manage the risk introduced by this change will further minimize possible concerns.

Therefore, the proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No

The proposed change does not involve a physical alteration of the plant (no new or different type of equipment will be installed). If risk is assessed and managed, allowing a change to certain required end states when the TS Completion Times for remaining in power operation are exceeded (i.e., entry into hot shutdown rather than cold shutdown to repair equipment) will not introduce new failure modes or effects and will not, in the absence of other unrelated failures, lead to an accident whose consequences exceed the consequences of accidents previously evaluated. The addition of a requirement to assess and manage the risk introduced by this change and the commitment by the licensee to adhere to the guidance in TSTF-IG-05-02, "Implementation Guidance for TSTF-423, Revision 1, 'Technical Specifications End States, NEDC-32988-A,'" will further minimize possible concerns.

Thus, based on the above, this change does not create the possibility of a new or different kind of accident from an accident previously evaluated.

3. Does the proposed change involve a significant reduction in a margin of safety?

Response: No

The proposed change allows, for some systems, entry into hot shutdown rather than cold shutdown to repair equipment, if risk is assessed and managed. The BWROG's risk assessment approach is comprehensive and follows NRC staff guidance as documented in Regulatory Guides (RG) 1.174 and 1.177. In addition, the analyses show that the criteria of the three-tiered approach for allowing TS changes are met. The risk impact of the proposed TS changes was assessed following the three-tiered approach recommended in RG 1.177. A risk assessment was performed to justify the proposed TS changes. The net change to the margin of safety is insignificant.

Therefore, the proposed change does not involve a significant reduction in a margin of safety.

Based upon the reasoning presented above, DTE concludes that the requested change involves no significant hazards consideration, as set forth in 10 CFR 50.92(c), "Issuance of Amendment."

### 3.2 Verifications, Commitments, and Additional Information Needed

DTE commits to the regulatory commitments in Enclosure 2. In addition, DTE has proposed TS Bases consistent with TSTF-423, Revision 1, which provide guidance and details on how to implement the new requirements. Implementation of TSTF-423 requires that risk be managed and assessed, and DTE's configuration risk management program is adequate to satisfy this requirement. The risk assessment need not be quantified, but may be a qualitative assessment of the vulnerability of systems and components when one or more systems are not able to perform their associated function. Finally, DTE has a Bases Control Program consistent with Section 5.5 of the Standard Technical Specifications (STS).

### 4.0 ENVIRONMENTAL EVALUATION

The proposed change would change a requirement with respect to installation or use of a facility component located within the restricted area, as defined in 10 CFR Part 20, and would change an inspection or surveillance requirement. However, the proposed change does not involve (i) a significant hazards consideration, (ii) a significant change in the types or significant increase in the amounts of any effluents that may be released offsite, or (iii) a significant increase in individual or cumulative occupational radiation exposure. Accordingly, the proposed change meets the eligibility criterion for categorical exclusion set forth in 10 CFR 51.22(c)(9). Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the proposed change.

### 5.0 REFERENCES

1. TSTF-423, Revision 1, "Technical Specifications End States, NEDC-32988-A," dated December 22, 2009 (ADAMS Accession No. ML093570241).
2. *Federal Register*, Vol. 76, No. 34, p.9614, "Notice of Availability of the Proposed Models for Plant-Specific Adoption of Technical Specifications Task Force (TSTF) Traveler TSTF-423, Revision 1, 'Technical Specifications End States, NEDC-32988-A,' for Boiling Water Reactor Plants Using the Consolidated Line Item Improvement Process," dated December 22, 2009 (ADAMS Accession No. ML102730585).
3. NEDC-32988-A, Revision 2, "Technical Justification to Support Risk-Informed Modification to Selected Required Action End States for BWR Plants," December 2002 (ADAMS Package Accession No. ML030170090).
4. NRC Model Safety Evaluation of TSTF-423, Revision 1, dated February 18, 2011 (ADAMS Accession No. ML102730688).

**Enclosure 2 to  
NRC-13-0001**

**Fermi 2 NRC Docket No. 50-341  
Operating License No. NPF-43**

**License Amendment Request for Adoption of Technical Specifications  
Task Force (TSTF) Traveler TSTF-423, Revision 1, "Technical Specifications End States,  
NEDC-32988-A," Using the Consolidated Line Item Improvement Process**

**Regulatory Commitments**

### LIST OF REGULATORY COMMITMENTS

The following table identifies those actions committed to by DTE Electric Company (DTE) in this document. Any other statements in this submittal are provided for information purposes and are not considered to be regulatory commitments. Please direct questions regarding these commitments to Mr. Rodney W. Johnson at (734) 586-5076.

REGULATORY COMMITMENTS	DUE DATE/EVENT
DTE will follow the guidance established in Section 11 of NUMARC 93-01, "Industry Guidance for Monitoring the Effectiveness of Maintenance at Nuclear Power Plants" Nuclear Management and Resource Council, Revision 3, July 2000.	Ongoing.
DTE will follow the guidance established in TSTF-IG-05-02, Revision 2, "Implementation Guidance for TSTF-423, Revision 1, Technical Specifications End States, NEDC-32988-A."	To be implemented with amendment.

**Enclosure 3 to  
NRC-13-0001**

**Fermi 2 NRC Docket No. 50-341  
Operating License No. NPF-43**

**License Amendment Request for Adoption of Technical Specifications  
Task Force (TSTF) Traveler TSTF-423, Revision 1, "Technical Specifications End States,  
NEDC-32988-A," Using the Consolidated Line Item Improvement Process**

**Markup Pages of TS**

<b>3.3-74</b>	<b>3.5-2</b>	<b>3.5-3</b>
<b>3.5-3a</b>	<b>3.5-12</b>	<b>3.6-20</b>
<b>3.6-23</b>	<b>3.6-24</b>	<b>3.6-25</b>
<b>3.6-33</b>	<b>3.6-35</b>	<b>3.6-40</b>
<b>3.6-47</b>	<b>3.6-48</b>	<b>3.7-2</b>
<b>3.7-6</b>	<b>3.7-8</b>	<b>3.7-11</b>
<b>3.7-14</b>	<b>3.8-2c</b>	<b>3.8-16</b>
<b>3.8-27</b>		

3.3 INSTRUMENTATION

3.3.8.2 Reactor Protection System (RPS) Electric Power Monitoring

LCO 3.3.8.2 Two RPS electric power monitoring assemblies shall be OPERABLE for each inservice RPS motor generator set or alternate power supply.

APPLICABILITY: MODES 1, 2, and 3,  
MODES 4 and 5 with any control rod withdrawn from a core cell containing one or more fuel assemblies, or with both residual heat removal shutdown cooling (RHR-SDC) isolation valves open.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or both inservice power supplies with one electric power monitoring assembly inoperable.	A.1 Remove associated inservice power supply(s) from service.	72 hours
B. One or both inservice power supplies with both electric power monitoring assemblies inoperable.	B.1 Remove associated inservice power supply(s) from service.	1 hour
C. Required Action and associated Completion Time of Condition A or B not met in MODE 1, 2, or 3.	C.1 <u>-----NOTE-----</u> <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u> <u>-----</u> <u>Be in MODE 3.</u> <u>AND</u> <u>C.2 Be in MODE 4.</u>	12 hours  36 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>D. Required Action and associated Completion Time of Condition A, B, or C not met.</p>	<p>D.1 <u>-----NOTE-----</u> <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u> <u>-----</u></p> <hr/> <p><u>Be in MODE 3.</u></p> <p><u>AND</u></p> <p><del>D.2 Be in MODE 4.</del></p>	<p>12 hours</p> <p><del>36 hours</del></p>
<p>E. HPCI System inoperable.</p>	<p>E.1 Verify by administrative means RCIC System is OPERABLE.</p> <p><u>AND</u></p> <p>E.2 Restore HPCI System to OPERABLE status.</p>	<p>Immediately</p> <p>14 days</p>
<p>F. HPCI System inoperable.</p> <p><u>AND</u></p> <p>Condition A, or Condition B, or Condition C entered.</p>	<p>F.1 Restore HPCI System to OPERABLE status.</p> <p><u>OR</u></p> <p>F.2 Restore low pressure ECCS injection/spray subsystem(s) to OPERABLE status.</p>	<p>72 hours</p> <p>72 hours</p>
<p>G. One ADS valve inoperable.</p>	<p>G.1 Restore ADS valve to OPERABLE status.</p>	<p>14 days</p>

(continued)



ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>H. One ADS valve inoperable.</p> <p><u>AND</u></p> <p>Condition A or Condition B entered.</p>	<p>H.1 Restore ADS valve to OPERABLE status.</p> <p><u>OR</u></p> <p>H.2 Restore low pressure ECCS injection/spray subsystem(s) to OPERABLE status.</p>	<p>72 hours</p> <p>72 hours</p>
<p><u>I. Required Action and associated Completion Time of Condition E, F, G, or H not met.</u></p>	<p><u>I.1 -----NOTE-----</u> <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u> <u>-----</u> <u>Be in MODE 3.</u></p>	<p><u>12 hours</u></p>
<p><u>IJ. Two or more ADS valves inoperable.</u></p> <p><u>OR</u></p> <p><u>Required Action and associated Completion Time of Condition E, F, G, or H not met.</u></p>	<p><u>IJ.1 Be in MODE 3.</u></p> <p><u>AND</u></p> <p><u>IJ.2 Reduce reactor steam dome pressure to ≤ 150 psig.</u></p>	<p>12 hours</p> <p>36 hours</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p><u>JK</u>. Two or more low pressure ECCS injection/spray subsystems inoperable for reasons other than Condition B or C.</p> <p><u>OR</u></p> <p>HPCI System and one or more ADS valves inoperable.</p> <p><u>OR</u></p> <p>Condition C and Condition G entered.</p>	<p><u>JK</u>.1 Enter LCO 3.0.3.</p>	<p>Immediately</p>

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS) AND REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM

3.5.3 RCIC System

LCO 3.5.3 The RCIC System shall be OPERABLE.

APPLICABILITY: MODE 1,  
MODES 2 and 3 with reactor steam dome pressure > 150 psig.

ACTIONS

-----NOTE-----  
LCO 3.0.4.b is not applicable to RCIC.  
-----

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. RCIC System inoperable.	A.1 Verify by administrative means High Pressure Coolant Injection System is OPERABLE.	Immediately
	<u>AND</u> A.2 Restore RCIC System to OPERABLE status.	14 days
B. Required Action and associated Completion Time not met.	B.1 <u>-----NOTE-----</u> <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u> <u>-----</u> <u>Be in MODE 3.</u>	12 hours
	<u>AND</u> <del>B.2 Reduce reactor steam dome pressure to ≤ 150 psig.</del>	<del>36 hours</del>

3.6 CONTAINMENT SYSTEMS

3.6.1.6 Low-Low Set (LLS) Valves

LCO 3.6.1.6 The LLS function of two safety/relief valves shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One LLS valve inoperable.	A.1 Restore LLS valve to OPERABLE status.	14 days
B. Required Action and associated Completion Time of Condition A not met.  <u>OR</u>  <del>Both LLS valves inoperable.</del>	B.1 <u>.....NOTE.....</u> <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u>  <u>Be in MODE 3.</u>  <u>AND</u> <del>B.2 Be in MODE 4.</del>	12 hours  <del>36 hours</del>
<u>C. Both LLS valves inoperable.</u>	<u>C.1 Be in MODE 3.</u>  <u>AND</u> <u>C.2 Be in MODE 4.</u>	<u>12 hours</u>  <u>36 hours</u>

Reactor Building-to-Suppression Chamber Vacuum Breakers  
3.6.1.7

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<u>D.</u> Required Action and Associated Completion Time of Condition C not met.	<u>D.1</u> -----NOTE----- <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u> ----- <u>Be in MODE 3.</u>	<u>12 hours</u>
<u>DE.</u> Two lines with one or more reactor building-to-suppression chamber vacuum breakers inoperable for opening.	<u>DE.1</u> Restore all vacuum breakers in one line to OPERABLE status.	1 hour
<u>EF.</u> Required Action and Associated Completion Time of Condition A, B, or E not met.	<u>EF.1</u> Be in MODE 3. <u>AND</u> <u>EF.2</u> Be in MODE 4.	12 hours  36 hours

**SURVEILLANCE REQUIREMENTS**

SURVEILLANCE	FREQUENCY
SR 3.6.1.7.1 -----NOTES----- 1. Not required to be met for vacuum breakers that are open during Surveillances.  2. Not required to be met for vacuum breakers open when performing their intended function. -----  Verify each vacuum breaker is closed.	14 days
SR 3.6.1.7.2 Perform a functional test of each vacuum breaker.	31 days
SR 3.6.1.7.3 Verify the opening setpoint of each vacuum breaker is $\leq 0.5$ psid.	18 months

NO CHANGES TO TEXT ON THIS PAGE.  
INFORMATION MOVED FROM PREVIOUS PAGE.

3.6 CONTAINMENT SYSTEMS

3.6.1.8 Suppression Chamber-to-Drywell Vacuum Breakers

LCO 3.6.1.8 Twelve suppression chamber-to-drywell vacuum breakers shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One suppression chamber-to-drywell vacuum breaker inoperable for opening.	A.1 Restore vacuum breaker to OPERABLE status.	72 hours
<u>B. Required Action and associated Completion Time of Condition A not met.</u>	<u>B.1 -----NOTE-----</u> <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u> <u>-----</u> <u>Be in MODE 3.</u>	<u>12 hours</u>
<u>BC. One or more suppression chamber-to-drywell vacuum breaker not closed.</u>	<u>BC.1 Close the open vacuum breaker(s).</u>	2 hours
<u>CD. Required Action and associated Completion Time of Condition C not met.</u>	<u>CD.1 Be in MODE 3.</u> <u>AND</u> <u>CD.2 Be in MODE 4.</u>	12 hours  36 hours

3.6 CONTAINMENT SYSTEMS

3.6.2.3 Residual Heat Removal (RHR) Suppression Pool Cooling

LCO 3.6.2.3 Two RHR suppression pool cooling subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One RHR suppression pool cooling subsystem inoperable.	A.1 Restore RHR suppression pool cooling subsystem to OPERABLE status.	7 days
<u>B.</u> Required Action and associated Completion Time of Condition A not met.	<u>B.1</u> -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 3. ----- <u>Be in MODE 3.</u>	<u>12 hours</u>
<u>BC.</u> Two RHR suppression pool cooling subsystems inoperable.	<u>BC.1</u> Restore one RHR suppression pool cooling subsystem to OPERABLE status.	8 hours
<u>CD.</u> Required Action and associated Completion Time of Condition C not met.	<u>CD.1</u> Be in MODE 3. <u>AND</u> <u>CD.2</u> Be in MODE 4.	12 hours  36 hours



3.6 CONTAINMENT SYSTEMS

3.6.2.4 Residual Heat Removal (RHR) Suppression Pool Spray

LCO 3.6.2.4 Two RHR suppression pool spray subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One RHR suppression pool spray subsystem inoperable.	A.1 Restore RHR suppression pool spray subsystem to OPERABLE status.	7 days
B. Two RHR suppression pool spray subsystems inoperable.	B.1 Restore one RHR suppression pool spray subsystem to OPERABLE status.	8 hours
C. Required Action and associated Completion Time not met.	<p>C.1 <u>-----NOTE-----</u>  <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u></p> <hr/> <p>Be in MODE 3.</p> <p><u>AND</u></p> <p><del>C.2</del> Be in MODE 4.</p>	<p>12 hours</p> <p><del>36 hours</del></p>

3.6 CONTAINMENT SYSTEMS

3.6.4.1 Secondary Containment

LCO 3.6.4.1 The secondary containment shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,  
During movement of recently irradiated fuel assemblies in  
the secondary containment,  
  
During operations with a potential for draining the reactor  
vessel (OPDRVs).

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Secondary Containment inoperable due to one railroad bay access door inoperable.	A.1 Restore railroad bay door to OPERABLE status.	7 days
B. Secondary containment inoperable in MODE 1, 2, or 3 for reasons other than Condition A.	B.1 Restore secondary containment to OPERABLE status.	4 hours
C. Required Action and associated Completion Time of Condition A or B not met.	C.1 <u>-----NOTE-----</u> <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u>  <u>Be in MODE 3.</u> <u>AND</u> <del>C.2 Be in MODE 4.</del>	12 hours  <del>36 hours</del>

(continued)

3.6 CONTAINMENT SYSTEMS

3.6.4.3 Standby Gas Treatment (SGT) System

LCO 3.6.4.3 Two SGT subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,  
During movement of recently irradiated fuel assemblies in  
the secondary containment,  
  
During operations with a potential for draining the reactor  
vessel (OPDRVs).

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One SGT subsystem inoperable.	A.1 Restore SGT subsystem to OPERABLE status.	7 days
B. Required Action and associated Completion Time of Condition A not met in MODE 1, 2, or 3.	B.1 <u>-----NOTE-----</u> <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u>	
	<u>Be in MODE 3.</u>	12 hours
	<u>AND</u> <u>B.2 Be in MODE 4.</u>	36 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. Required Action and associated Completion Time of Condition A not met during movement of recently irradiated fuel assemblies in the secondary containment or during OPDRVs.</p>	<p>-----NOTE-----            LCO 3.0.3 is not applicable.            -----</p> <p>C.1 Place OPERABLE SGT subsystem in operation.</p> <p><u>OR</u></p> <p>C.2.1 Suspend movement of recently irradiated fuel assemblies in secondary containment.</p> <p><u>AND</u></p> <p>C.2.2 Initiate action to suspend OPDRVs.</p>	<p>Immediately</p> <p>Immediately</p> <p>Immediately</p>
<p>D. Two SGT subsystems inoperable in MODE 1, 2, or 3.</p>	<p>D.1 -----NOTE-----  <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u>            -----</p> <p><u>Enter LCO 3.0.3.</u></p> <p><u>Be in MODE 3.</u></p>	<p>Immediately</p> <p><u>12 hours</u></p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<u>D. Required Action and associated Completion Time of Condition A, B, or C not met.</u>	<u>D.1 -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 3. ----- Be in MODE 3.</u>	<u>12 hours</u>
<u>DE. Both RHRSW subsystems inoperable for reasons other than Condition B.</u>	<u>DE.1 -----NOTE----- Enter applicable Conditions and Required Actions of LCO 3.4.8 for RHR shutdown cooling made inoperable by RHRSW System. ----- Restore one RHRSW subsystem to OPERABLE status.</u>	<u>8 hours</u>
<u>EF. Required Action and associated Completion Time of Condition E not met.</u>	<u>EF.1 Be in MODE 3. AND EF.2 Be in MODE 4.</u>	<u>12 hours  36 hours</u>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.7.1.1 Verify each RHRSW manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position or can be aligned to the correct position.	31 days

3.7 PLANT SYSTEMS

3.7.3 Control Room Emergency Filtration (CREF) System

LCO 3.7.3 The CREF System shall be OPERABLE.

-----NOTE-----  
The control room boundary may be opened intermittently under administrative control.  
-----

APPLICABILITY: MODES 1, 2, and 3,  
During movement of recently irradiated fuel assemblies in  
the secondary containment,  
  
During operations with a potential for draining the reactor  
vessel (OPDRVs).

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One CREF subsystem inoperable.	A.1 Restore CREF subsystem to OPERABLE status.	7 days
B. Two CREF subsystems inoperable due to inoperable control room boundary in MODE 1, 2, or 3.	B.1 Restore control room boundary to OPERABLE status.	24 hours*
C. Required Action and associated Completion Time of Condition A or B not met in MODE 1, 2, or 3.	C.1 -----NOTE----- <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u> -----	
	<u>Be in MODE 3.</u>	12 hours
	<u>AND</u> C.2 <u>Be in MODE 4.</u>	36 hours

(continued)

\* ~~The 24 hours Completion Time is extended onetime to 48 hours to complete repairs of Division 2 Return Air Fan in May 2010.~~

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>E. Two CREF subsystems or a non-redundant component or portion of the CREF System inoperable in MODE 1, 2, or 3 for reasons other than Condition B.</p>	<p>E.1      -----NOTE-----  <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u>  -----  <u>Enter LCO 3.0.3.</u>  <u>Be in MODE 3.</u></p>	<p>Immediately <u>12 hours</u></p>
<p>F. Two CREF subsystems or a non-redundant component or portion of the CREF System inoperable during movement of recently irradiated fuel assemblies in the secondary containment, or during OPDRVs.</p>	<p>-----NOTE-----  LCO 3.0.3 is not applicable.  -----</p> <p>F.1      Initiate action to suspend OPDRVs.</p> <p><u>AND</u></p> <p>-----NOTE-----  Not required for a CREF System or subsystem inoperable due to failure to provide the required filtration efficiency, or due to replacement of charcoal filtration media.  -----</p> <p>F.2      Suspend movement of recently irradiated fuel assemblies in the secondary containment.</p>	<p>Immediately</p> <p>Immediately</p>

3.7 PLANT SYSTEMS

3.7.4 Control Center Air Conditioning (AC) System

LCO 3.7.4 Two control center AC subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.  
 During movement of recently irradiated fuel assemblies in the secondary containment,  
  
 During operations with a potential for draining the reactor vessel (OPDRVs).

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One control center AC subsystem inoperable.	A.1 Restore control center AC subsystem to OPERABLE status.	30 days
B. Two control center AC subsystems inoperable.	B.1 Verify control room area temperature <90°F.	Once per 4 hours
	<u>AND</u> B.2 Restore one control center AC subsystem to OPERABLE status.	72 hours
C. Required Action and associated Completion Time of Condition A or B not met in MODE 1, 2, or 3.	C.1 <u>-----NOTE-----</u> <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u> <u>-----</u>	
	<u>Be in MODE 3.</u>	12 hours
	<u>AND</u> C.2 <u>Be in MODE 4.</u>	<del>36 hours</del>



3.7 PLANT SYSTEMS

3.7.5 Main Condenser Offgas

LCO 3.7.5 The gross radioactivity rate of the noble gases measured at the discharge of the 2.2 minute delay piping shall be  $\leq 340$  mCi/second after decay of 30 minutes.

APPLICABILITY: MODE 1,  
MODES 2 and 3 with any main steam line not isolated and steam jet air ejector (SJAE) in operation.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Gross radioactivity rate of the noble gases not within limit.	A.1 Restore gross radioactivity rate of the noble gases to within limit.	72 hours
B. Required Action and associated Completion Time not met.	B.1 Isolate all main steam lines.	12 hours
	<u>OR</u>	
	B.2 Isolate SJAE.	12 hours
	<u>OR</u>	
	<del>B.3.1</del> <p style="text-align: center;">-----NOTE-----  <u>--- LCO 3.0.4.a is not applicable when entering MODE 3.</u>            -----</p> <p style="text-align: center;"><u>Be in MODE 3.</u></p> <p style="text-align: center;"><u>AND</u></p> <p><del>B.3.2 Be in MODE 4.</del></p>	12 hours
		<del>36 hours</del>

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>F. One offsite circuit inoperable.</p> <p><u>AND</u></p> <p>One or both EDGs in one Division inoperable.</p>	<p>-----NOTE----- Enter applicable Conditions and Required Actions of LCO 3.8.7, "Distribution Systems - Operating," when Condition F is entered with no AC power source to one or more 4160 V buses 64B, 64C, 65E or 65F. -----</p> <p>F.1     Restore offsite circuit to OPERABLE status.</p> <p><u>OR</u></p> <p>F.2     Restore both EDGs in the Division to OPERABLE status.</p>	<p>12 hours</p> <p>12 hours</p>
<p>G. Required Action and Associated Completion Time of Condition A, B, C, D, E or F not met.</p>	<p>G.1     -----NOTE----- <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u> -----</p> <p>_____ Be in MODE 3.</p> <p><u>AND</u></p> <p>G.2     Be in MODE 4.</p>	<p>12 hours</p> <p>36 hours</p>

3.8 ELECTRICAL POWER SYSTEMS

3.8.4 DC Sources—Operating

LCO 3.8.4 The Division I and Division II DC electrical power subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One battery charger inoperable.	A.1 Restore battery charger to OPERABLE status.	4 hours
B. One DC electrical power subsystem inoperable for reasons other than Condition A.	B.1 Restore DC electrical power subsystem to OPERABLE status.	2 hours
C. Required Action and Associated Completion Time not met.	<p>C.1 <u>-----NOTE-----</u>  <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u>  <u>-----</u></p> <p><u>Be in MODE 3.</u></p> <p><u>AND</u></p> <p><del>C.2 Be in MODE 4.</del></p>	<p>12 hours</p> <p><del>36 hours</del></p>

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. One or more required DC electrical power distribution subsystems inoperable.	B.1 Restore DC electrical power distribution subsystem(s) to OPERABLE status.	2 hours <u>AND</u> 16 hours from discovery of failure to meet LCO
C. Required Action and associated Completion Time of Condition A or B not met.	C.1 <u>-----NOTE-----</u> <u>LCO 3.0.4.a is not applicable when entering MODE 3.</u> <u>-----</u> <u>Be in MODE 3.</u> <u>AND</u> <del>C.2 Be in MODE 4.</del>	12 hours  <del>36 hours</del>
D. Two or more required electrical power distribution subsystems inoperable that result in a loss of function.	D.1 Enter LCO 3.0.3.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.8.7.1 Verify correct breaker alignments and voltage to required AC and DC electrical power distribution subsystems.	7 days

**Enclosure 4 to  
NRC-13-0001**

**Fermi 2 NRC Docket No. 50-341  
Operating License No. NPF-43**

**License Amendment Request for Adoption of Technical Specifications  
Task Force (TSTF) Traveler TSTF-423, Revision 1, "Technical Specifications End States,  
NEDC-32988-A," Using the Consolidated Line Item Improvement Process**

**Revised (Clean) TS pages**

<b>3.3-74</b>	<b>3.5-2</b>	<b>3.5-3</b>
<b>3.5-3a</b>	<b>3.5-12</b>	<b>3.6-20</b>
<b>3.6-23</b>	<b>3.6-24</b>	<b>3.6-25</b>
<b>3.6-33</b>	<b>3.6-35</b>	<b>3.6-40</b>
<b>3.6-47</b>	<b>3.6-48</b>	<b>3.7-2</b>
<b>3.7-6</b>	<b>3.7-8</b>	<b>3.7-11</b>
<b>3.7-14</b>	<b>3.8-2c</b>	<b>3.8-16</b>
<b>3.8-27</b>		

3.3 INSTRUMENTATION

3.3.8.2 Reactor Protection System (RPS) Electric Power Monitoring

LCO 3.3.8.2 Two RPS electric power monitoring assemblies shall be OPERABLE for each inservice RPS motor generator set or alternate power supply.

APPLICABILITY: MODES 1, 2, and 3,  
MODES 4 and 5 with any control rod withdrawn from a core cell containing one or more fuel assemblies, or with both residual heat removal shutdown cooling (RHR-SDC) isolation valves open.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or both inservice power supplies with one electric power monitoring assembly inoperable.	A.1 Remove associated inservice power supply(s) from service.	72 hours
B. One or both inservice power supplies with both electric power monitoring assemblies inoperable.	B.1 Remove associated inservice power supply(s) from service.	1 hour
C. Required Action and associated Completion Time of Condition A or B not met in MODE 1, 2, or 3.	C.1 -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 3. -----  Be in MODE 3.	12 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>D. Required Action and associated Completion Time of Condition A, B, or C not met.</p>	<p>D.1 -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 3. -----  Be in MODE 3.</p>	<p>12 hours</p>
<p>E. HPCI System inoperable.</p>	<p>E.1 Verify by administrative means RCIC System is OPERABLE.  <u>AND</u>  E.2 Restore HPCI System to OPERABLE status.</p>	<p>Immediately    14 days</p>
<p>F. HPCI System inoperable.  <u>AND</u>  Condition A, or Condition B, or Condition C entered.</p>	<p>F.1 Restore HPCI System to OPERABLE status.  <u>OR</u>  F.2 Restore low pressure ECCS injection/spray subsystem(s) to OPERABLE status.</p>	<p>72 hours    72 hours</p>
<p>G. One ADS valve inoperable.</p>	<p>G.1 Restore ADS valve to OPERABLE status.</p>	<p>14 days</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>H. One ADS valve inoperable.</p> <p><u>AND</u></p> <p>Condition A or Condition B entered.</p>	<p>H.1 Restore ADS valve to OPERABLE status.</p> <p><u>OR</u></p> <p>H.2 Restore low pressure ECCS injection/spray subsystem(s) to OPERABLE status.</p>	<p>72 hours</p> <p>72 hours</p>
<p>I. Required Action and associated Completion Time of Condition E, F, G, or H not met.</p>	<p>I.1 -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 3. ----- Be in MODE 3.</p>	<p>12 hours</p>
<p>J. Two or more ADS valves inoperable.</p>	<p>J.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>J.2 Reduce reactor steam dome pressure to ≤ 150 psig.</p>	<p>12 hours</p> <p>36 hours</p>

(continued)



ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>K. Two or more low pressure ECCS injection/spray subsystems inoperable for reasons other than Condition B or C.</p> <p><u>OR</u></p> <p>HPCI System and one or more ADS valves inoperable.</p> <p><u>OR</u></p> <p>Condition C and Condition G entered.</p>	<p>K.1 Enter LCO 3.0.3.</p>	<p>Immediately</p>

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS) AND REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM

3.5.3 RCIC System

LCO 3.5.3 The RCIC System shall be OPERABLE.

APPLICABILITY: MODE 1,  
MODES 2 and 3 with reactor steam dome pressure > 150 psig.

ACTIONS

-----NOTE-----  
LCO 3.0.4.b is not applicable to RCIC.  
-----

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. RCIC System inoperable.	A.1 Verify by administrative means High Pressure Coolant Injection System is OPERABLE.	Immediately
	<u>AND</u> A.2 Restore RCIC System to OPERABLE status.	14 days
B. Required Action and associated Completion Time not met.	B.1 -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 3. -----  Be in MODE 3.	12 hours

3.6 CONTAINMENT SYSTEMS

3.6.1.6 Low-Low Set (LLS) Valves

LCO 3.6.1.6 The LLS function of two safety/relief valves shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One LLS valve inoperable.	A.1 Restore LLS valve to OPERABLE status.	14 days
B. Required Action and associated Completion Time of Condition A not met.	B.1 .....NOTE..... LCO 3.0.4.a is not applicable when entering MODE 3. .....  Be in MODE 3.	12 hours
C. Both LLS valves inoperable.	C.1 Be in MODE 3. AND C.2 Be in MODE 4.	12 hours  36 hours

Reactor Building-to-Suppression Chamber Vacuum Breakers  
3.6.1.7

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required Action and Associated Completion Time of Condition C not met.	D.1      -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 3. -----  Be in MODE 3.	12 hours
E. Two lines with one or more reactor building-to-suppression chamber vacuum breakers inoperable for opening.	E.1      Restore all vacuum breakers in one line to OPERABLE status.	1 hour
F. Required Action and Associated Completion Time of Condition A, B, or E not met.	F.1      Be in MODE 3. <u>AND</u> F.2      Be in MODE 4.	12 hours  36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.1.7.1      -----NOTES----- 1. Not required to be met for vacuum breakers that are open during Surveillances.  2. Not required to be met for vacuum breakers open when performing their intended function. -----  Verify each vacuum breaker is closed.	14 days
SR 3.6.1.7.2      Perform a functional test of each vacuum breaker.	31 days
SR 3.6.1.7.3      Verify the opening setpoint of each vacuum breaker is $\leq 0.5$ psid.	18 months

3.6 CONTAINMENT SYSTEMS

3.6.1.8 Suppression Chamber-to-Drywell Vacuum Breakers

LCO 3.6.1.8 Twelve suppression chamber-to-drywell vacuum breakers shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One suppression chamber-to-drywell vacuum breaker inoperable for opening.	A.1 Restore vacuum breaker to OPERABLE status.	72 hours
B. Required Action and associated Completion Time of Condition A not met.	B.1 <p style="text-align: center;">-----NOTE-----                      LCO 3.0.4.a is not applicable when entering MODE 3.                      -----                       Be in MODE 3.</p>	12 hours
C. One or more suppression chamber-to-drywell vacuum breaker not closed.	C.1 Close the open vacuum breaker(s).	2 hours
D. Required Action and associated Completion Time of Condition C not met.	D.1 Be in MODE 3.  <u>AND</u> D.2 Be in MODE 4.	12 hours  36 hours

3.6 CONTAINMENT SYSTEMS

3.6.2.3 Residual Heat Removal (RHR) Suppression Pool Cooling

LCO 3.6.2.3 Two RHR suppression pool cooling subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One RHR suppression pool cooling subsystem inoperable.	A.1 Restore RHR suppression pool cooling subsystem to OPERABLE status.	7 days
B. Required Action and associated Completion Time of Condition A not met.	B.1 -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 3. -----  Be in MODE 3.	12 hours
C. Two RHR suppression pool cooling subsystems inoperable.	C.1 Restore one RHR suppression pool cooling subsystem to OPERABLE status.	8 hours
D. Required Action and associated Completion Time of Condition C not met.	D.1 Be in MODE 3. <u>AND</u> D.2 Be in MODE 4.	12 hours  36 hours

3.6 CONTAINMENT SYSTEMS

3.6.2.4 Residual Heat Removal (RHR) Suppression Pool Spray

LCO 3.6.2.4 Two RHR suppression pool spray subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One RHR suppression pool spray subsystem inoperable.	A.1 Restore RHR suppression pool spray subsystem to OPERABLE status.	7 days
B. Two RHR suppression pool spray subsystems inoperable.	B.1 Restore one RHR suppression pool spray subsystem to OPERABLE status.	8 hours
C. Required Action and associated Completion Time not met.	C.1 -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 3. ----- Be in MODE 3.	12 hours



3.6 CONTAINMENT SYSTEMS

3.6.4.1 Secondary Containment

LCO 3.6.4.1 The secondary containment shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,  
During movement of recently irradiated fuel assemblies in  
the secondary containment,  
  
During operations with a potential for draining the reactor  
vessel (OPDRVs).

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Secondary Containment inoperable due to one railroad bay access door inoperable.	A.1 Restore railroad bay door to OPERABLE status.	7 days
B. Secondary containment inoperable in MODE 1, 2, or 3 for reasons other than Condition A.	B.1 Restore secondary containment to OPERABLE status.	4 hours
C. Required Action and associated Completion Time of Condition A or B not met.	C.1 -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 3. -----  Be in MODE 3.	12 hours

(continued)

3.6 CONTAINMENT SYSTEMS

3.6.4.3 Standby Gas Treatment (SGT) System

LCO 3.6.4.3 Two SGT subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,  
During movement of recently irradiated fuel assemblies in  
the secondary containment,  
  
During operations with a potential for draining the reactor  
vessel (OPDRVs).

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One SGT subsystem inoperable.	A.1 Restore SGT subsystem to OPERABLE status.	7 days
B. Required Action and associated Completion Time of Condition A not met in MODE 1, 2, or 3.	B.1 .....NOTE..... LCO 3.0.4.a is not applicable when entering MODE 3. .....  Be in MODE 3.	12 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. Required Action and associated Completion Time of Condition A not met during movement of recently irradiated fuel assemblies in the secondary containment or during OPDRVs.</p>	<p>-----NOTE-----                      LCO 3.0.3 is not applicable.                      -----</p> <p>C.1 Place OPERABLE SGT subsystem in operation.</p> <p><u>OR</u></p> <p>C.2.1 Suspend movement of recently irradiated fuel assemblies in secondary containment.</p> <p><u>AND</u></p> <p>C.2.2 Initiate action to suspend OPDRVs.</p>	<p>Immediately</p> <p>Immediately</p> <p>Immediately</p>
<p>D. Two SGT subsystems inoperable in MODE 1, 2, or 3.</p>	<p>D.1 -----NOTE-----                      LCO 3.0.4.a is not applicable when entering MODE 3.                      -----</p> <p>Be in MODE 3.</p>	<p>12 hours</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required Action and associated Completion Time of Condition A, B, or C not met.	D.1 .....NOTE..... LCO 3.0.4.a is not applicable when entering MODE 3. .....  Be in MODE 3.	12 hours
E. Both RHRSW subsystems inoperable for reasons other than Condition B.	E.1 .....NOTE..... Enter applicable Conditions and Required Actions of LCO 3.4.8 for RHR shutdown cooling made inoperable by RHRSW System. .....  Restore one RHRSW subsystem to OPERABLE status.	8 hours
F. Required Action and associated Completion Time of Condition E not met.	F.1 Be in MODE 3.  <u>AND</u> F.2 Be in MODE 4.	12 hours  36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.7.1.1 Verify each RHRSW manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position or can be aligned to the correct position.	31 days

3.7 PLANT SYSTEMS

3.7.3 Control Room Emergency Filtration (CREF) System

LCO 3.7.3 The CREF System shall be OPERABLE.

-----NOTE-----  
The control room boundary may be opened intermittently under administrative control.  
-----

APPLICABILITY: MODES 1, 2, and 3,  
During movement of recently irradiated fuel assemblies in  
the secondary containment,  
  
During operations with a potential for draining the reactor  
vessel (OPDRVs).

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One CREF subsystem inoperable.	A.1 Restore CREF subsystem to OPERABLE status.	7 days
B. Two CREF subsystems inoperable due to inoperable control room boundary in MODE 1, 2, or 3.	B.1 Restore control room boundary to OPERABLE status.	24 hours
C. Required Action and associated Completion Time of Condition A or B not met in MODE 1, 2, or 3.	C.1 -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 3. -----  Be in MODE 3.	12 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>E. Two CREF subsystems or a non-redundant component or portion of the CREF System inoperable in MODE 1, 2, or 3 for reasons other than Condition B.</p>	<p>E.1</p> <p>-----NOTE-----            LCO 3.0.4.a is not applicable when entering MODE 3.            -----            Be in MODE 3.</p>	<p>12 hours</p>
<p>F. Two CREF subsystems or a non-redundant component or portion of the CREF System inoperable during movement of recently irradiated fuel assemblies in the secondary containment, or during OPDRVs.</p>	<p>-----NOTE-----            LCO 3.0.3 is not applicable.            -----</p> <p>F.1 Initiate action to suspend OPDRVs.</p> <p><u>AND</u></p> <p>-----NOTE-----            Not required for a CREF System or subsystem inoperable due to failure to provide the required filtration efficiency, or due to replacement of charcoal filtration media.            -----</p> <p>F.2 Suspend movement of recently irradiated fuel assemblies in the secondary containment.</p>	<p>Immediately</p> <p>Immediately</p>

3.7 PLANT SYSTEMS

3.7.4 Control Center Air Conditioning (AC) System

LCO 3.7.4 Two control center AC subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.  
During movement of recently irradiated fuel assemblies in the secondary containment,  
  
During operations with a potential for draining the reactor vessel (OPDRVs).

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One control center AC subsystem inoperable.	A.1 Restore control center AC subsystem to OPERABLE status.	30 days
B. Two control center AC subsystems inoperable.	B.1 Verify control room area temperature <90°F.	Once per 4 hours
	<u>AND</u> B.2 Restore one control center AC subsystem to OPERABLE status.	72 hours
C. Required Action and associated Completion Time of Condition A or B not met in MODE 1, 2, or 3.	C.1 -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 3. -----  Be in MODE 3.	12 hours

3.7 PLANT SYSTEMS

3.7.5 Main Condenser Offgas

LCO 3.7.5 The gross radioactivity rate of the noble gases measured at the discharge of the 2.2 minute delay piping shall be  $\leq 340$  mCi/second after decay of 30 minutes.

APPLICABILITY: MODE 1,  
MODES 2 and 3 with any main steam line not isolated and steam jet air ejector (SJAE) in operation.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Gross radioactivity rate of the noble gases not within limit.	A.1 Restore gross radioactivity rate of the noble gases to within limit.	72 hours
B. Required Action and associated Completion Time not met.	B.1 Isolate all main steam lines.	12 hours
	<u>OR</u>	
	B.2 Isolate SJAE.	12 hours
	<u>OR</u>	
	B.3 -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 3. -----	
	Be in MODE 3.	12 hours



ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>F. One offsite circuit inoperable.</p> <p><u>AND</u></p> <p>One or both EDGs in one Division inoperable.</p>	<p>-----NOTE----- Enter applicable Conditions and Required Actions of LCO 3.8.7, "Distribution Systems - Operating," when Condition F is entered with no AC power source to one or more 4160 V buses 64B, 64C, 65E or 65F. -----</p> <p>F.1 Restore offsite circuit to OPERABLE status.</p> <p><u>OR</u></p> <p>F.2 Restore both EDGs in the Division to OPERABLE status.</p>	<p>12 hours</p> <p>12 hours</p>
<p>G. Required Action and Associated Completion Time of Condition A, B, C, D, E or F not met.</p>	<p>G.1 -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 3. -----</p> <p>Be in MODE 3.</p>	<p>12 hours</p>

3.8 ELECTRICAL POWER SYSTEMS

3.8.4 DC Sources-Operating

LCO 3.8.4 The Division I and Division II DC electrical power subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One battery charger inoperable.	A.1 Restore battery charger to OPERABLE status.	4 hours
B. One DC electrical power subsystem inoperable for reasons other than Condition A.	B.1 Restore DC electrical power subsystem to OPERABLE status.	2 hours
C. Required Action and Associated Completion Time not met.	C.1 .....NOTE..... LCO 3.0.4.a is not applicable when entering MODE 3. .....  Be in MODE 3.	12 hours

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. One or more required DC electrical power distribution subsystems inoperable.	B.1 Restore DC electrical power distribution subsystem(s) to OPERABLE status.	2 hours  <u>AND</u> 16 hours from discovery of failure to meet LCO
C. Required Action and associated Completion Time of Condition A or B not met.	C.1 -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 3. -----  Be in MODE 3.	12 hours
D. Two or more required electrical power distribution subsystems inoperable that result in a loss of function.	D.1 Enter LCO 3.0.3.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.8.7.1 Verify correct breaker alignments and voltage to required AC and DC electrical power distribution subsystems.	7 days

**Enclosure 5 to  
NRC-13-0001**

**Fermi 2 NRC Docket No. 50-341  
Operating License No. NPF-43**

**License Amendment Request for Adoption of Technical Specifications  
Task Force (TSTF) Traveler TSTF-423, Revision 1, "Technical Specifications End States,  
NEDC-32988-A," Using the Consolidated Line Item Improvement Process**

**Markup Pages of TS Bases**

B 3.3.8.2-5	B 3.3.8.2-6	B 3.3.8.2-7
B 3.3.8.2-8	B 3.5.1-7	B 3.5.1-8
B 3.5.1-9	B 3.5.1-10	B 3.5.1-11
B 3.5.1-14	B 3.5.1-16	B 3.5.1-19
B 3.5.1-20	B 3.5.3-3a	B 3.5.3-6
B 3.6.1.6-3	B 3.6.1.6-4	B 3.6.1.6-5
B 3.6.1.7-5	B 3.6.1.7-6	B 3.6.1.7-7
B 3.6.1.8-4	B 3.6.1.8-5	B 3.6.1.8-7
B 3.6.2.3-3	B 3.6.2.3-4	B 3.6.2.3-5
B 3.6.2.4-3	B 3.6.2.4-4	B 3.6.2.4-5
B 3.6.4.1-3	B 3.6.4.1-3a	B 3.6.4.1-7
B 3.6.4.3-4	B 3.6.4.3-6	B 3.6.4.3-8
B 3.6.4.3-9	B 3.7.1-5	B 3.7.1-6
B 3.7.1-7	B 3.7.3-5	B 3.7.3-6
B 3.7.3-7	B 3.7.3-8	B 3.7.3-11
B 3.7.4-1	B 3.7.4-4	B 3.7.4-7
B 3.7.5-2	B 3.7.5-3	B 3.7.5-4
B 3.8.1-8	B 3.8.1-8a	B 3.8.1-10
B 3.8.1-12	B 3.8.1-13	B 3.8.1-14
B 3.8.1-15	B 3.8.1-16	B 3.8.1-17
B 3.8.1-18	B 3.8.1-19	B 3.8.1-20
B 3.8.4-1	B 3.8.4-2	B 3.8.4-4
B 3.8.4-5	B 3.8.4-7	B 3.8.4-8
B 3.8.4-9	B 3.8.7-7	B 3.8.7-8
B 3.8.7-9		

BASES

---

ACTIONS (continued)

operations personnel to take corrective actions and is acceptable because it minimizes risk while allowing time for restoration or removal from service of the electric power monitoring assemblies.

Alternately, if it is not desired to remove the power supply(s) from service (e.g., as in the case where removing the power supply(s) from service would result in a scram or isolation), Condition C or D, as applicable, must be entered and its Required Actions taken.

C.1 and C.2

If any Required Action and associated Completion Time of Condition A or B are not met in MODE 1, 2, or 3, the plant must be brought to a Mode in which overall plant risk is minimized, a plant shutdown must be performed. This places the plant in a condition where minimal equipment, powered through the inoperable RPS electric power monitoring assembly(s), is required and ensures that the safety function of the RPS (e.g., scram of control rods) is not required. The plant shutdown is accomplished by placing the plant in MODE 3 within 12 hours, and in MODE 4 within 36 hours.

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 2) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action C.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

BASES

---

ACTIONS (continued)

The allowed Completion Times ~~are~~ is reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

D.1, D.2.1, and D.2.2

If any Required Action and associated Completion Time of Condition A or B are not met in MODE 4 or 5, or with any control rod withdrawn from a core cell containing one or more fuel assemblies or with both RHR shutdown cooling valves open, the operator must immediately initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies. Required Action D.1 results in the least reactive condition for the reactor core and ensures that the safety function of the RPS (e.g., scram of control rods) is not required.

In addition, action must be immediately initiated to either restore one electric power monitoring assembly to OPERABLE status for the inservice power source supplying the required instrumentation powered from the RPS bus (Required Action D.2.1) or to isolate the RHR Shutdown Cooling System (Required Action D.2.2). Required Action D.2.1 is provided because the RHR Shutdown Cooling System may be needed to provide core cooling. All actions must continue until the applicable Required Actions are completed.

---

SURVEILLANCE  
REQUIREMENTS

SR 3.3.8.2.1

A CHANNEL FUNCTIONAL TEST is performed on each overvoltage, undervoltage, and underfrequency channel to ensure that the entire channel will perform the intended function. Any setpoint adjustment shall be consistent with the assumptions of the current plant specific setpoint methodology.

As noted in the Surveillance, the CHANNEL FUNCTIONAL TEST is only required to be performed while the plant is in a condition in which the loss of the RPS bus will not jeopardize steady state power operation (the design of the system is such that the power source must be removed from service to conduct the Surveillance). The 24 hours is intended to indicate an outage of sufficient duration to allow for scheduling and proper performance of the Surveillance.

The 184 day Frequency and the Note in the Surveillance are

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

based on guidance provided in Generic Letter 91-09 (Ref. 23).

SR 3.3.8.2.2

CHANNEL CALIBRATION is a complete check of the instrument loop and the sensor. This test verifies that the channel responds to the measured parameter within the necessary range and accuracy. CHANNEL CALIBRATION leaves the channel adjusted to account for instrument drifts between successive calibrations consistent with the plant specific setpoint methodology.

The Frequency is based on the assumption of a  $\geq 18$  month calibration interval in the determination of the magnitude of equipment drift in the setpoint analysis.

SR 3.3.8.2.3

Performance of a system functional test demonstrates that, with a required system actuation (simulated or actual) signal, the logic of the system will automatically trip open the associated power monitoring assembly. Only one signal per power monitoring assembly is required to be tested. This Surveillance overlaps with the CHANNEL CALIBRATION to provide complete testing of the safety function. The system functional test of the Class 1E circuit breakers is included as part of this test to provide complete testing of the safety function. If the breakers are incapable of operating, the associated electric power monitoring assembly would be inoperable.

The 18 month Frequency is based on the need to perform this Surveillance under the conditions that apply during a plant outage and the potential for an unplanned transient if the Surveillance were performed with the reactor at power. Operating experience has shown that these components usually pass the Surveillance when performed at the 18 month Frequency.

BASES

---

REFERENCES

1. UFSAR, Section 7.2.1.1.2.
2. NEDC-32988-A, Revision 2, Technical Justification to Support Risk-Informed Modification to Selected Required End States for BWR Plants, December 2002.
- 2-3. NRC Generic Letter 91-09, "Modification of Surveillance Interval for the Electrical Protective Assemblies in Power Supplies for the Reactor Protection System."



## BASES

## ACTIONS (continued)

of allowed outage times (i.e., Completion Times). With one LPCI pump inoperable in both subsystems, the LPCI loop select design provides essentially equivalent core flooding capability when compared to the inoperability of both LPCI pumps in one subsystem when no additional single failure is assumed.

C.1 and C.2

If one CSS subsystem and one LPCI subsystem is inoperable, one inoperable subsystem must be restored to OPERABLE status within 72 hours. In this Condition, the remaining OPERABLE subsystems provide adequate core cooling during a LOCA. However, overall ECCS reliability is reduced, because a single failure in one of the remaining OPERABLE subsystems, concurrent with a LOCA, may result in the ECCS not being able to perform its intended safety function. The Completion Time is based on a previously approved amendment (Amendment 80, dated March 9, 1992), which approved a 72 hour Completion Time for one CSS and one LPCI inoperable due to lack of EECW cooling. However, the 72 hour Completion Time now applies to any mechanism of inoperability. Differing mechanisms for the cause of ECCS inoperabilities does not result in a basis for differing allowed outage times.

D.1 and D.2

If the inoperable low pressure ECCS subsystem(s) cannot be restored to OPERABLE status within the associated Completion Time, the plant must be brought to a MODE in which ~~the LCO does not apply~~ overall plant risk is minimized. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours and to MODE 4 within 36 hours.

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 13) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

## BASES

## ACTIONS (continued)

Required Action D.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Times ~~are~~ is reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

E.1 and E.2

If the HPCI System is inoperable and the RCIC System is verified to be OPERABLE, the HPCI System must be restored to OPERABLE status within 14 days. In this Condition, adequate core cooling is ensured by the OPERABILITY of the redundant and diverse low pressure ECCS injection/spray subsystems in conjunction with ADS. Also, the RCIC System will automatically provide makeup water at most reactor operating pressures. Verification of RCIC OPERABILITY is therefore required when HPCI is inoperable. This may be performed as an administrative check by examining logs or other information to determine if RCIC is out of service for maintenance or other reasons. It does not mean to perform the Surveillances needed to demonstrate the OPERABILITY of the RCIC System. If the OPERABILITY of the RCIC System cannot be immediately verified, however, Condition I must be immediately entered. If a single active component fails concurrent with a design basis LOCA, there is a potential, depending on the specific failure, that the minimum required ECCS equipment will not be available. A 14 day Completion Time is based on a reliability study cited in Reference 12 and has been found to be acceptable through operating experience.

BASES

---

## ACTIONS (continued)

F.1 and F.2

If any one low pressure ECCS injection/spray subsystem, or one LPCI pump in both LPCI subsystems, or one CSS and one LPCI subsystem is inoperable in addition to an inoperable HPCI System, the inoperable low pressure ECCS injection/spray subsystem(s) or the HPCI System must be restored to OPERABLE status within 72 hours. In this Condition, adequate core cooling is ensured by the OPERABILITY of the ADS and the remaining low pressure ECCS subsystems. However, the overall ECCS reliability is significantly reduced because a single failure in one of the remaining OPERABLE subsystems concurrent with a design basis LOCA may result in the ECCS not being able to perform its intended safety function. Since both a high pressure system (HPCI) and a low pressure subsystem(s) are inoperable, a more restrictive Completion Time of 72 hours is required to restore either the HPCI System or the low pressure ECCS injection/spray subsystem(s) to OPERABLE status. This Completion Time is based on a reliability study cited in Reference 12 and has been found to be acceptable through operating experience.

G.1

The LCO requires five ADS valves to be OPERABLE in order to provide the ADS function. The ECCS analyses are performed with the initial condition of one ADS valve out of service (Ref. ~~1314~~). Per this analysis, operation of only four ADS valves will provide the required depressurization. However, overall reliability of the ADS is reduced, because a single failure in the OPERABLE ADS valves could result in a reduction in depressurization capability. Therefore, operation is only allowed for a limited time. The 14 day Completion Time is based on a reliability study cited in Reference 12 and has been found to be acceptable through operating experience.

## BASES

## ACTIONS (continued)

H.1 and H.2

If any one low pressure ECCS injection/spray subsystem, or one LPCI pump in both LPCI subsystems, is inoperable in addition to one inoperable ADS valve, adequate core cooling is ensured by the OPERABILITY of HPCI and the remaining low pressure ECCS injection/spray subsystem. However, overall ECCS reliability is reduced because a single active component failure concurrent with a design basis LOCA could result in the minimum required ECCS equipment not being available. Since both a high pressure system (ADS) and low pressure subsystem(s) are inoperable, a more restrictive Completion Time of 72 hours is required to restore either the low pressure ECCS subsystem(s) or the ADS valve to OPERABLE status. This Completion Time is based on a reliability study cited in Reference 12 and has been found to be acceptable through operating experience.

I.1 and I.2

If any Required Action and associated Completion Time of Condition E, F, G, or H is not met, ~~or if two or more ADS valves are inoperable,~~ the plant must be brought to a condition MODE in which the LCO does not apply overall plant risk is minimized. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours and reactor steam dome pressure reduced to  $\leq 150$  psig within 36 hours.

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 13) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action I.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate.

BASES

---

ACTIONS (continued)

LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Times ~~are~~ is reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

J.1 and J.2

If two or more ADS valves are inoperable, there is a reduction in the depressurization capability. The plant must be brought to a condition in which the LCO does not apply. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours and reactor steam dome pressure reduced to  $\leq 150$  psig within 36 hours. The allowed Completion Times ~~is~~ are reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

J.1 K.1

When multiple ECCS subsystems are inoperable, as stated in Condition ~~J~~K, the plant is in a condition outside of the accident analyses. Therefore, LCO 3.0.3 must be entered immediately.

## BASES

## SURVEILLANCE REQUIREMENTS (continued)

verification that those valves capable of potentially being mispositioned are in the correct position. This SR does not apply to valves that cannot be inadvertently misaligned, such as check valves. For the HPCI System, this SR also includes the steam flow path for the turbine and the flow controller position.

The 31 day Frequency of this SR was derived from the Inservice Testing Program requirements for performing valve testing at least once every 92 days. The Frequency of 31 days is further justified because the valves are operated under procedural control and because improper valve position would only affect a single subsystem. This Frequency has been shown to be acceptable through operating experience.

This SR is modified by a Note that allows LPCI subsystems to be considered OPERABLE during alignment and operation for decay heat removal with reactor steam dome pressure less than the RHR cut in permissive pressure in MODE 3, and for 4 hours after exceeding the RHR cut-in permissive pressure in MODE 3, if capable of being manually realigned (remote or local) to the LPCI mode and not otherwise inoperable. This allows operation in the RHR shutdown cooling mode during MODE 3, if necessary and sufficient time to restore the system line up to the LPCI mode of operation.

SR 3.5.1.5

Verification every 31 days that ADS primary containment pneumatic supply pressure is  $\geq 75$  psig ensures adequate air or nitrogen pressure for reliable ADS operation. The accumulator on each ADS valve provides pneumatic pressure for valve actuation. The design pneumatic supply pressure requirements for the accumulator are such that, following a failure of the pneumatic supply to the accumulator, at least five valve actuations can occur with the drywell at the long term drywell pressure of the design basis small break LOCA analysis (Ref. 1415). The ECCS safety analysis assumes only one actuation to achieve the depressurization required for operation of the low pressure ECCS. This minimum required pressure of  $\geq 75$  psig is provided by the primary pneumatic supply system. The 31 day Frequency takes into consideration administrative controls over operation of the pneumatic system and alarms for low pneumatic pressure.

## BASES

## SURVEILLANCE REQUIREMENTS (continued)

SR 3.5.1.8, SR 3.5.1.9, and SR 3.5.1.10

The performance requirements of the low pressure ECCS pumps are determined through application of the 10 CFR 50, Appendix K criteria (Ref. 8). This periodic Surveillance is performed (in accordance with the ASME Code, Section XI, requirements for the ECCS pumps) to verify that the ECCS pumps will develop the flow rates required by the respective analyses. The low pressure ECCS pump flow rates ensure that adequate core cooling is provided to satisfy the acceptance criteria of Reference 10. The pump flow rates (for Core Spray, 2 pumps in parallel operation) are verified against a system head equivalent to the RPV pressure expected during a LOCA. The total system pump outlet pressure is adequate to overcome the elevation head pressure between the pump suction and the vessel discharge, the piping friction losses, and RPV pressure present during a LOCA. These values may be established during preoperational testing. Actual testing is performed via the test flow path against test line pressures established in Reference -1718.

The flow tests for the HPCI System are performed at two different pressure ranges such that system capability to provide rated flow is tested at both the higher and lower operating ranges of the system. Additionally, adequate steam flow must be passing through the main turbine or turbine bypass valves to continue to control reactor pressure when the HPCI System diverts steam flow. Reactor steam pressure must be  $\geq 945$  psig to perform SR 3.5.1.9 and  $\geq 165$  psig to perform SR 3.5.1.10. Adequate steam flow is represented by main turbine generator on line or turbine bypass valves open at least 15% in auto-pressure control. Therefore, sufficient time is allowed after adequate pressure and flow are achieved to perform these tests. Reactor startup is allowed prior to performing the low pressure Surveillance test because the reactor pressure is low and the time allowed to satisfactorily perform the Surveillance test is short. The reactor pressure is allowed to be increased to normal operating pressure since it is assumed that the low pressure test has been satisfactorily completed and there is no indication or reason to believe that HPCI is inoperable.

## BASES

## SURVEILLANCE REQUIREMENTS (continued)

flow are achieved to perform this SR. Adequate pressure at which this SR is to be performed is  $\geq 850$  psig (the pressure recommended by the valve manufacturer). Adequate steam flow is represented by turbine bypass valves open at least 20%. Reactor startup is allowed prior to performing this SR because valve OPERABILITY and the setpoints for overpressure protection are verified, per ASME requirements, prior to valve installation. Therefore, this SR is modified by a Note that states the Surveillance is not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test. The 12 hours allowed for manual actuation after the required pressure and flow are reached is sufficient to achieve stable conditions and provides adequate time to complete the Surveillance. SR 3.5.1.12 and the LOGIC SYSTEM FUNCTIONAL TEST performed in LCO 3.3.5.1 overlap this Surveillance to provide complete testing of the assumed safety function.

The Frequency is based on the need to perform the Surveillance under the conditions that apply just prior to or during a startup from a plant outage. Operating experience has shown that these components usually pass the SR when performed at the 18 month Frequency, which is based on the refueling cycle. Therefore, the Frequency was concluded to be acceptable from a reliability standpoint.

SR 3.5.1.14

This SR ensures that the individual channel response times are less than or equal to the maximum values assumed in the accident analysis. Response time testing acceptance criteria are included in Reference 1516. This SR is modified by a Note stating that the ECCS instrumentation response times are not required to be measured. The contribution of the instrument response times to the overall ECCS response time are assumed based on guidance of Reference 16.

The 18 month Frequency is based on the need to perform this Surveillance under the conditions that apply during a plant outage and the potential for an unplanned transient if the Surveillance were performed with the reactor at power. Operating experience has shown that these components usually pass the Surveillance when performed at the 18 month Frequency.



BASES

---

- REFERENCES
1. UFSAR, Section 6.3.2.2.3.
  2. UFSAR, Section 6.3.2.2.4.
  3. UFSAR, Section 6.3.2.2.1.
  4. UFSAR, Section 6.3.2.2.2.
  5. UFSAR, Section 15.2.7.
  6. UFSAR, Section 15.6.4.
  7. UFSAR, Section 15.6.5.
  8. 10 CFR 50, Appendix K.
  9. UFSAR, Section 6.3.3.
  10. 10 CFR 50.46.
  11. UFSAR, Section 6.3.3.3.
  12. Memorandum from R.L. Baer (NRC) to V. Stello, Jr. (NRC), "Recommended Interim Revisions to LCOs for ECCS Components," December 1, 1975.
  13. NEDC-32988-A, Revision 2, Technical Justification to Support Risk-Informed Modification to Selected Required End States for BWR Plants, December 2002.
  - ~~13~~14. UFSAR, Table 6.3-6.
  - ~~14~~15. UFSAR, Section 5.2.2.2.3.
  - ~~15~~16. Technical Requirements Manual.
  - ~~16~~17. NEDO-32291, "System Analyses for Elimination of Selected *Response* Time Testing Requirements," January 1994; and Fermi-2 SER for Amendment 111, dated April 18, 1997.
  - ~~17~~18. DC-5079 Vol I, RHR & CSS Technical Specification Surveillance Pump Discharge Pressures.

BASES

---

ACTIONS (Continued)

B.1 and B.2

If the RCIC System cannot be restored to OPERABLE status within the associated Completion Time, or if the HPCI System is simultaneously inoperable, the plant must be brought to a condition in which overall plant risk is minimized, the LCO does not apply. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours, and reactor steam dome pressure reduced to  $\leq 150$  psig within 36 hours.

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 4) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action B.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Times isare reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

SR 3.5.3.5

The RCIC System is required to actuate automatically in order to verify its design function satisfactorily. This Surveillance verifies that, with a required system initiation signal (actual or simulated), the automatic initiation logic of the RCIC System will cause the system to operate as designed, including actuation of the system throughout its emergency operating sequence; that is, automatic pump startup and actuation of all automatic valves to their required positions. This test also ensures that the RCIC System will automatically restart on an RPV low water level (Level 2) signal received subsequent to an RPV high water level (Level 8) trip and that the suction is automatically transferred from the CST to the suppression pool. The LOGIC SYSTEM FUNCTIONAL TEST performed in LCO 3.3.5.2 overlaps this Surveillance to provide complete testing of the assumed safety function.

The 18 month Frequency is based on the need to perform the Surveillance under the conditions that apply during a plant outage and the potential for an unplanned transient if the Surveillance were performed with the reactor at power. Operating experience has shown that these components usually pass the SR when performed at the 18 month Frequency, which is based on the refueling cycle. Therefore, the Frequency was concluded to be acceptable from a reliability standpoint.

This SR is modified by a Note that excludes vessel injection during the Surveillance. Since all active components are testable and full flow can be demonstrated by recirculation through the test line, coolant injection into the RPV is not required during the Surveillance.

---

REFERENCES

1. 10 CFR 50, Appendix A, GDC 33.
2. UFSAR, Section 5.5.6.
3. Memorandum from R.L. Baer (NRC) to V. Stello, Jr. (NRC), "Recommended Interim Revisions to LCOs for ECCS Components," December 1, 1975.
4. NEDC-32988-A, Revision 2, Technical Justification to Support Risk Informed Modification to Selected Required End States for BWR Plants, December 2002.

BASES

---

ACTIONS (continued)

B.1 and B.2

If both LLS valves are inoperable or if the an inoperable LLS valve cannot be restored to OPERABLE status within the required Completion Time, the plant must be brought to a MODE in which the LCO does not apply overall plant risk is minimized. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours and to MODE 4 within 36 hours.

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 2) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action B.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Times are is reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

C.1 and C.2

If two or more LLS valves are inoperable, there could be excessive short duration SRV cycling during an overpressure event. The plant must be brought to a condition in which the LCO does not apply. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours and MODE 4 within 36 hours. The allowed Completion Times are reasonable, based on operating experience, to reach the

BASES

---

ACTIONS (continued)

required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

---

SURVEILLANCE  
REQUIREMENTS

SR 3.6.1.6.1

A manual actuation of each LLS valve is performed to verify that the valve and solenoids are functioning properly and no blockage exists in the valve discharge line. This can be demonstrated by the response of the turbine control or bypass valve, by a change in the measured steam flow, or by any other method that is suitable to verify steam flow. Adequate reactor steam dome pressure must be available to perform this test to avoid damaging the valve. Adequate pressure at which this test is to be performed is  $\geq 850$  psig (the pressure recommended by the valve manufacturer). Also, adequate steam flow must be passing through the main turbine or turbine bypass valves to continue to control reactor pressure when the LLS valves divert steam flow upon opening. Adequate steam flow is represented by turbine bypass valves open at least 20%. The 18 month Frequency was based on the SRV tests required by the ASME Boiler and Pressure Vessel Code, Section XI (Ref. 23). Operating experience has shown that these components usually pass the Surveillance when performed at the 18 month Frequency. Therefore, the Frequency was concluded to be acceptable from a reliability standpoint.

Since steam pressure is required to perform the Surveillance, however, and steam may not be available during a unit outage, the Surveillance may be performed during the startup following a unit outage. Unit startup is allowed prior to performing the test because valve OPERABILITY and the setpoints for overpressure protection are verified by Reference 23 prior to valve installation. After adequate reactor steam dome pressure and flow are reached, 12 hours is allowed to prepare for and perform the test.

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

SR 3.6.1.6.2

The LLS designated SRVs are required to actuate automatically upon receipt of specific initiation signals. A system functional test is performed to verify that the mechanical portions (i.e., solenoids) of the LLS function operate as designed when initiated either by an actual or simulated automatic initiation signal. The LOGIC SYSTEM FUNCTIONAL TEST in SR 3.3.6.3.4 overlaps this SR to provide complete testing of the safety function.

The 18 month Frequency is based on the need to perform this Surveillance under the conditions that apply during a plant outage and the potential for an unplanned transient if the Surveillance were performed with the reactor at power. Operating experience has shown these components usually pass the Surveillance when performed at the 18 month Frequency. Therefore, the Frequency was concluded to be acceptable from a reliability standpoint.

This SR is modified by a Note that excludes valve actuation. This prevents a reactor pressure vessel pressure blowdown.

---

REFERENCES

1. UFSAR, Section 5.2.2.5.
2. NEDC-32988-A, Revision 2, Technical Justification to Support Risk-Informed Modification to Selected Required End States for BWR Plants, December 2002.
23. ASME, Boiler and Pressure Vessel Code, Section XI.

BASES

---

ACTIONS (continued)

D.1

If one line has one or more reactor building-to-suppression chamber vacuum breakers inoperable for opening and they are not restored within the Completion Time in Condition C, the remaining breakers in the remaining lines can provide the opening function. The plant must be brought to a condition in which overall plant risk is minimized. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours.

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 2) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action D.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Time is reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

BASES

---

ACTIONS (continued)

DE.1

With two lines with one or more vacuum breakers inoperable for opening, the primary containment boundary is intact. However, in the event of a containment depressurization, the function of the vacuum breakers is lost. Therefore, all vacuum breakers in one line must be restored to OPERABLE status within 1 hour. This Completion Time is consistent with the ACTIONS of LCO 3.6.1.1, which requires that primary containment be restored to OPERABLE status within 1 hour.

EF.1 and EF.2

If ~~all~~ the vacuum breakers in one or more lines cannot be closed or restored to OPERABLE status within the required Completion Time, the plant must be brought to a MODE in which the LCO does not apply. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours and to MODE 4 within 36 hours. The allowed Completion Times are reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

---

SURVEILLANCE  
REQUIREMENTS

SR 3.6.1.7.1

Each vacuum breaker is verified to be closed to ensure that a potential breach in the primary containment boundary is not present. This Surveillance is performed by observing local or control room indications of vacuum breaker position or by verifying a differential pressure of 0.5 psid is maintained between the reactor building and suppression chamber. The 14 day Frequency is based on engineering judgment, is considered adequate in view of other indications of vacuum breaker status available to operations personnel, and has been shown to be acceptable through operating experience.

Two Notes are added to this SR. The first Note allows reactor-to-suppression chamber vacuum breakers opened in conjunction with the performance of a Surveillance to not be considered as failing this SR. These periods of opening vacuum breakers are controlled by plant procedures and do not represent inoperable vacuum breakers. The second Note is included to clarify that vacuum breakers open due to an



BASES

---

SURVEILLANCE REQUIREMENTS (continued)

actual differential pressure are not considered as failing this SR.

SR 3.6.1.7.2

Each vacuum breaker must be cycled to ensure that it opens properly to perform its design function and returns to its fully closed position. This ensures that the safety analysis assumptions are valid. The 31 day Frequency of this SR was developed based upon Inservice Testing Program requirements to perform valve testing at least once every 92 days. A 31 day Frequency was chosen to provide additional assurance that the vacuum breakers are OPERABLE.

SR 3.6.1.7.3

Demonstration of vacuum breaker opening setpoint is necessary to ensure that the safety analysis assumption regarding vacuum breaker full open differential pressure of  $\leq 0.5$  psid is valid. This verification may be performed by measurement of the equivalent force to move the pullet. The 18 month Frequency is based on the need to perform this Surveillance under the conditions that apply during a plant outage and the potential for an unplanned transient if the Surveillance were performed with the reactor at power. The 18 month Frequency has been shown to be acceptable, based on operating experience, and is further justified because of other surveillances performed at shorter Frequencies that convey the proper functioning status of each vacuum breaker.

---

REFERENCES

1. UFSAR, Section 6.2.
2. NEDC-32988-A, Revision 2, Technical Justification to Support Risk-Informed Modification to Selected Required End States for BWR Plants, December 2002.

BASES

---

ACTIONS (continued)

B.1

If a required suppression chamber-to-drywell vacuum breaker is inoperable for opening and is not restored to OPERABLE status within the required Completion Time, the plant must be brought to a condition in which overall plant risk is minimized. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours.

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 2) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action B.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Time is reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

B.1C.1

An open vacuum breaker allows communication between the drywell and suppression chamber airspace, and, as a result, there is the potential for suppression chamber overpressurization due to this bypass leakage if a LOCA were to occur. Therefore, the open vacuum breaker must be closed (confirmation of the closed status would follow procedures as outlined in the Bases for SR 3.6.1.8.1). The 2 hour completion time is allowed to close the vacuum breaker due

BASES

---

ACTIONS (continued)

to the low probability of an event that would pressurize primary containment.

GD.1 and ~~GD.2~~

If the ~~inoperable open~~ suppression chamber-to-drywell vacuum breaker cannot be closed or restored to OPERABLE status within the required Completion Time, the plant must be brought to a MODE in which the LCO does not apply. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours and to MODE 4 within 36 hours. The allowed Completion Times are reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

---

SURVEILLANCE  
REQUIREMENTS

SR 3.6.1.8.1

Each vacuum breaker is verified closed to ensure that this potential large bypass leakage path is not present. This Surveillance is performed by observing the vacuum breaker position indication or by verifying that a differential pressure of 0.5 psid between the suppression chamber and drywell is maintained for 1 hour without makeup. However, if vacuum breaker position indication is not reliable, either due to: 1) dual or open indication while able to establish a torus-to-drywell differential pressure, or 2) closed indication while not able to establish a torus-to-drywell differential pressure, alternate methods of verifying that the vacuum breaker is closed are detailed in Technical Requirements Manual (TRM).

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

SR 3.6.1.8.3

Verification of the vacuum breaker opening setpoint is necessary to ensure that the safety analysis assumption regarding vacuum breaker full open differential pressure of 0.5 psid is valid. The 18 month Frequency is based on the need to perform this Surveillance under the conditions that apply during a plant outage and the potential for an unplanned transient if the Surveillance were performed with the reactor at power. The 18 month Frequency has also been shown to be acceptable, based on operating experience, and is further justified because of other surveillances performed at shorter Frequencies that convey the proper functioning status of each vacuum breaker.

---

REFERENCES

1. UFSAR, Section 6.2.
2. NEDC-32988-A, Revision 2, Technical Justification to Support Risk-Informed Modification to Selected Required End States for BWR Plants, December 2002.

BASES

---

ACTIONS (continued)

overall reliability is reduced because a single failure in the OPERABLE subsystem could result in reduced primary containment cooling capability. The 7 day Completion Time is acceptable in light of the redundant RHR suppression pool cooling capabilities afforded by the OPERABLE subsystem and the low probability of a DBA occurring during this period.

B.1

If one RHR suppression pool cooling subsystem is inoperable and is not restored to OPERABLE status within the required Completion Time, the plant must be brought to a condition in which overall plant risk is minimized. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours.

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 2) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action B.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Time is reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

BASES

---

ACTIONS (continued)

BC.1

With two RHR suppression pool cooling subsystems inoperable, one subsystem must be restored to OPERABLE status within 8 hours. In this condition, there is a substantial loss of the primary containment pressure and temperature mitigation function. The 8 hour Completion Time is based on this loss of function and is considered acceptable due to the low probability of a DBA and the potential avoidance of a plant shutdown transient that could result in the need for the RHR suppression pool cooling subsystem to operate.

CD.1 and -CD.2

If the Required Action and associated Completion Time of Condition C cannot be met, the plant must be brought to a MODE in which the LCO does not apply. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours and to MODE 4 within 36 hours. The allowed Completion Times are reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

---

SURVEILLANCE  
REQUIREMENTS

SR 3.6.2.3.1

Verifying the correct alignment for manual, power operated, and automatic valves in the RHR suppression pool cooling mode flow path provides assurance that the proper flow path exists for system operation. This SR does not apply to valves that are locked, sealed, or otherwise secured in position since these valves were verified to be in the correct position prior to locking, sealing, or securing. A valve is also allowed to be in the nonaccident position provided it can be aligned to the accident position within the time assumed in the accident analysis. This is acceptable since the RHR suppression pool cooling mode is

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

manually initiated. This SR does not require any testing or valve manipulation; rather, it involves verification that those valves capable of being mispositioned are in the correct position. This SR does not apply to valves that cannot be inadvertently misaligned, such as check valves.

The Frequency of 31 days is justified because the valves are operated under procedural control, improper valve position would affect only a single subsystem, the probability of an event requiring initiation of the system is low, and the subsystem is a manually initiated system. This Frequency has been shown to be acceptable based on operating experience.

SR 3.6.2.3.2

Verifying that each RHR pump develops a flow rate  $\geq 10,000$  gpm while operating in the suppression pool cooling mode with flow through the associated heat exchanger ensures that pump performance has not degraded during the cycle. Flow is a normal test of centrifugal pump performance required by ASME Code, Section XI (Ref. 23). This test confirms one point on the pump design curve, and the results are indicative of overall performance. Such inservice inspections confirm component OPERABILITY, trend performance, and detect incipient failures by indicating abnormal performance. The Frequency of this SR is in accordance with the Inservice Testing Program.

---

REFERENCES

1. UFSAR, Section 6.2.
2. NEDC-32988-A, Revision 2, Technical Justification to Support Risk-Informed Modification to Selected Required End States for BWR Plants, December 2002.
23. ASME, Boiler and Pressure Vessel Code, Section XI.

BASES

---

ACTIONS (continued)

failure in the OPERABLE subsystem could result in reduced primary containment bypass mitigation capability. The 7 day Completion Time was chosen in light of the redundant RHR suppression pool spray capabilities afforded by the OPERABLE subsystem and the low probability of a DBA occurring during this period.

B.1

With both RHR suppression pool spray subsystems inoperable, at least one subsystem must be restored to OPERABLE status within 8 hours. In this Condition, there is a substantial loss of the primary containment bypass leakage mitigation function. The 8 hour Completion Time is based on this loss of function and is considered acceptable due to the low probability of a DBA and because alternative methods to remove heat from primary containment are available.

C.1 and C.2

If the inoperable RHR suppression pool spray subsystem cannot be restored to OPERABLE status within the associated Completion Time, the plant must be brought to a MODE in which the LCO does not apply overall plant risk is minimized. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours and MODE 4 within 36 hours.

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 2) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action C.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability



BASES

---

ACTIONS (continued)

that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Times ~~are~~ is reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

---

SURVEILLANCE  
REQUIREMENTS

SR 3.6.2.4.1

Verifying the correct alignment for manual, power operated, and automatic valves in the RHR suppression pool spray mode flow path provides assurance that the proper flow paths will exist for system operation. This SR does not apply to valves that are locked, sealed, or otherwise secured in position since these valves were verified to be in the correct position prior to locking, sealing, or securing. A valve is also allowed to be in the nonaccident position provided it can be aligned to the accident position within the time assumed in the accident analysis. This is acceptable since the RHR suppression pool cooling mode is manually initiated. This SR does not require any testing or valve manipulation; rather, it involves verification that those valves capable of being mispositioned are in the correct position. This SR does not apply to valves that cannot be inadvertently misaligned, such as check valves.

The Frequency of 31 days is justified because the valves are operated under procedural control, improper valve position would affect only a single subsystem, the probability of an event requiring initiation of the system is low, and the subsystem is a manually initiated system. This Frequency has been shown to be acceptable based on operating experience.

SR 3.6.2.4.2

Verifying each RHR pump develops a flow rate  $\geq 500$  gpm while operating in the suppression pool spray mode with flow through the heat exchanger ensures that pump performance has not degraded during the cycle. Flow is a normal test of centrifugal pump performance required by Section XI of the ASME Code (Ref. 23). This test confirms one point on the pump design curve and is indicative of overall performance. Such inservice inspections confirm component OPERABILITY,

---

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

trend performance, and detect incipient failures by indicating abnormal performance. The Frequency of this SR is in accordance with the Inservice Testing Program.

---

REFERENCES

1. UFSAR, Section 6.2.
2. NEDC-32988-A, Revision 2, Technical Justification to Support Risk-Informed Modification to Selected Required End States for BWR Plants, December 2002.
23. ASME, Boiler and Pressure Vessel Code, Section XI.

BASES

---

APPLICABILITY (continued)

of recently irradiated fuel assemblies in the secondary containment. Due to radioactive decay, secondary containment is only required to be OPERABLE during fuel handling involving recently irradiated fuel. "Recently irradiated fuel" is fuel that has occupied part of a critical reactor core within the previous 6.3 days. Handling new (non-irradiated) fuel bundles over the open reactor core or the spent fuel pool is subject to the same requirements of handling recently irradiated fuel, as long as any fuel in the core or fuel pool is recently irradiated.

---

ACTIONS

A.1

With a Secondary Containment railroad bay access door inoperable there remains a redundant access door in an OPERABLE status. This door is capable of maintaining the Secondary Containment function. Therefore, the 7 day Completion Time gives a reasonable period of time to correct the problem given the availability of the other access door and the low probability of an event occurring that will challenge the Secondary Containment during this time period.

B.1

If secondary containment is inoperable for reasons other than Condition A, it must be restored to OPERABLE status within 4 hours. The 4 hour Completion Time provides a period of time to correct the problem that is commensurate with the importance of maintaining secondary containment during MODES 1, 2, and 3. This time period also ensures that the probability of an accident (requiring secondary containment OPERABILITY) occurring during periods where secondary containment is inoperable is minimal.

C.1 and C.2

If secondary containment cannot be restored to OPERABLE status within the required Completion Time, the plant must be brought to a MODE in which overall plant risk is minimized~~the LCO does not apply~~. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours ~~and to MODE 4 within 36 hours~~.

BASES

---

ACTIONS (continued)

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 3), because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action C.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Times ~~are~~ is reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

BASES

---

REFERENCES

1. UFSAR, Section 15.6.5.
2. UFSAR, Section 15.7.4.
3. NEDC-32988-A, Revision 2, Technical Justification to Support Risk-Informed Modification to Selected Required End States for BWR Plants, December 2002.

BASES

---

ACTIONS (continued)

availability of the OPERABLE redundant SGT System and the low probability of a DBA occurring during this period.

B.1 and B.2

If the SGT subsystem cannot be restored to OPERABLE status within the required Completion Time in MODE 1, 2, or 3, the plant must be brought to a MODE in which ~~the LCO does not apply~~ overall plant risk is minimized. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours ~~and to MODE 4 within 36 hours.~~

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 3) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action B.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Times are is reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

BASES

---

## ACTIONS (continued)

Therefore, in either case, inability to suspend movement of recently irradiated fuel assemblies would not be a sufficient reason to require a reactor shutdown.

D.1

If both SGT subsystems are inoperable in MODE 1, 2, or 3, the SGT System may not be capable of supporting the required radioactivity release control function. Therefore, actions are required to enter LCO 3.0.3 immediately. Therefore, the plant must be brought to a MODE in which overall plant risk is minimized. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours.

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 3) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action D.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Time is reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

SR 3.6.4.3.2

This SR verifies that the required SGT filter testing is performed in accordance with the Ventilation Filter Testing Program (VFTP). The SGT System filter tests are in accordance with Regulatory Guide 1.52 (Ref. 34). The VFTP includes testing HEPA filter performance, charcoal adsorber efficiency, minimum system flow rate, and the physical properties of the activated charcoal (general use and following specific operations). Specific test frequencies and additional information are discussed in detail in the VFTP.

SR 3.6.4.3.3

This SR verifies that each SGT subsystem starts and associated dampers open on receipt of an actual or simulated initiation signal. While this Surveillance can be performed with the reactor at power, operating experience has shown that these components usually pass the Surveillance when performed at the 18 month Frequency. The LOGIC SYSTEM FUNCTIONAL TEST in SR 3.3.6.2.5 overlaps this SR to provide complete testing of the safety function. Therefore, the Frequency was found to be acceptable from a reliability standpoint.

SR 3.6.4.3.4

This SR verifies that the filter cooler bypass damper can be remote manually opened and the fan remote manually started. This ensures that the ventilation mode of SGT System operation is available. While this Surveillance can be performed with the reactor at power, operating experience has shown that these components usually pass the Surveillance when performed at the 18 month Frequency, which is based on the refueling cycle. Therefore, the Frequency was found to be acceptable from a reliability standpoint.



BASES

---

REFERENCES

1. 10 CFR 50, Appendix A, GDC 41.
2. UFSAR, Section 6.2.3.
3. NEDC-32988-A, Revision 2, Technical Justification to Support Risk-Informed Modification to Selected Required End States for BWR Plants, December 2002.
34. Regulatory Guide 1.52, Rev. 2.

BASES

---

ACTIONS (continued)

Required Actions taken if the inoperable RHRSW subsystem results in inoperable RHR shutdown cooling. This is an exception to LCO 3.0.6 and ensures the proper actions are taken for these components.

D.1

If one RHRSW subsystem is inoperable or one RHRSW pump in one or two subsystems is inoperable and not restored within the provided Completion Time, the plant must be brought to a condition in which overall plant risk is minimized. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours.

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 6) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action D.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Time is reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

DE.1

With both RHRSW subsystems inoperable for reasons other than Condition B (e.g., both subsystems with inoperable flow paths, or one subsystem with an inoperable pump and one

BASES

---

ACTIONS (continued)

subsystem with an inoperable flow path), the RHRSW System is not capable of performing its intended function. At least one subsystem must be restored to OPERABLE status within 8 hours. The 8 hour Completion Time for restoring one RHRSW subsystem to OPERABLE status, is based on the Completion Times provided for the RHR suppression pool cooling function.

The Required Action is modified by a Note indicating that the applicable Conditions of LCO 3.4.8, be entered and Required Actions taken if the inoperable RHRSW subsystem results in inoperable RHR shutdown cooling. This is an exception to LCO 3.0.6 and ensures the proper actions are taken for these components.

EF.1 and -EF.2

If the RHRSW subsystems cannot be not restored to OPERABLE status within the associated Completion Times of Condition E, the unit must be placed in a MODE in which the LCO does not apply. To achieve this status, the unit must be placed in at least MODE 3 within 12 hours and in MODE 4 within 36 hours. The allowed Completion Times are reasonable, based on operating experience, to reach the required unit conditions from full power conditions in an orderly manner and without challenging unit systems.

BASES

---

SURVEILLANCE  
REQUIREMENTS

SR 3.7.1.1

Verifying the correct alignment for each manual, power operated, and automatic valve in each RHRSW subsystem flow path provides assurance that the proper flow paths will exist for RHRSW operation. This SR does not apply to valves that are locked, sealed, or otherwise secured in position, since these valves are verified to be in the correct position prior to locking, sealing, or securing. A valve is also allowed to be in the nonaccident position, and yet considered in the correct position, provided it can be realigned to its accident position. This is acceptable because the RHRSW System is a manually initiated system. This SR does not require any testing or valve manipulation; rather, it involves verification that those valves capable of being mispositioned are in the correct position. This SR does not apply to valves that cannot be inadvertently misaligned, such as check valves.

The 31 day Frequency is based on engineering judgment, is consistent with the procedural controls governing valve operation, and ensures correct valve positions.

---

REFERENCES

1. UFSAR, Section 9.2.5.
2. UFSAR, Chapter 6.
3. UFSAR, Chapter 9.
4. UFSAR, Chapter 15.
5. UFSAR, Section 6.3.2.14.
6. NEDC-32988-A, Revision 2, Technical Justification to Support Risk-Informed Modification to Selected Required End States for BWR Plants, December 2002.

BASES

ACTIONS (Continued)

B.1

If the control room boundary is inoperable in MODE 1, 2, or 3, the CREF system cannot perform its intended function. Actions must be taken to restore an OPERABLE control room boundary within 24 hours. During the period that the control room boundary is inoperable, appropriate compensatory measures (consistent with the intent of GDC 19) should be utilized to protect control room operators from potential hazards such as radioactive contamination, toxic chemicals, smoke, temperature and relative humidity, and physical security. Preplanned measures should be available to address these concerns for intentional and unintentional entry into the condition. The 24-hour Completion Time is reasonable based on the low probability of a DBA occurring during this time period, and the use of compensatory measures. The 24-hour Completion Time is a typically reasonable time to diagnose, plan and possibly repair, and test most problems with the control room boundary.

C.1 and C.2

In MODE 1, 2, or 3, if the inoperable CREF subsystem or control room boundary cannot be restored to OPERABLE status within the associated Completion Time, the unit must be placed in a MODE that minimizes overall plant risk. To achieve this status, the unit must be placed in at least MODE 3 within 12 hours and in MODE 4 within 36 hours.

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 5) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action C.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk

BASES

---

ACTIONS (Continued)

management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Time ~~s~~ are ~~is~~ reasonable, based on operating experience, to reach the required unit conditions from full power conditions in an orderly manner and without challenging unit systems.

D.1, D.2.1 and D.2.2

The Required Actions of Condition D are modified by a Note indicating that LCO 3.0.3 does not apply. If moving recently irradiated fuel assemblies while in MODE 1, 2, or 3, the fuel movement is independent of reactor operations. Therefore, inability to suspend movement of recently irradiated fuel assemblies is not sufficient reason to require a reactor shutdown.

During movement of recently irradiated fuel assemblies in the secondary containment or during OPDRVs, if the inoperable CREF subsystem cannot be restored to OPERABLE status within the required Completion Time, the OPERABLE CREF subsystem may be placed in the recirculation mode. This action ensures that this remaining subsystem is OPERABLE, that no failures that would prevent automatic actuation will occur, and that any active failure will be readily detected.

An alternative to Required Action D.1 is to immediately suspend activities that present a potential for releasing radioactivity that might require isolation of the control room. This places the unit in a condition that minimizes risk.

If applicable, movement of recently irradiated fuel assemblies in the secondary containment must be suspended immediately. Suspension of these activities shall not preclude completion of movement of a component to a safe position. Also, if applicable, actions must be initiated immediately to suspend OPDRVs to minimize the probability of

BASES

ACTIONS (Continued)

a vessel draindown and the subsequent potential for fission product release. Actions must continue until the OPDRVs are suspended.

A Note is applied to Required Action D.2.2. This Note allows these Required Actions to not be required when the system charcoal filter train filter media cannot provide the required efficiency or is being replaced. Dose calculations have shown that the CREF system is not needed during the activities that would otherwise be suspended by these Required Actions.

E.1

If both CREF subsystems or a non-redundant component or portion of the CREF System are inoperable in MODE 1, 2, or 3 for reasons other than an inoperable control room boundary (i.e., Condition B), the CREF System may not be capable of performing the intended function and the unit is in a condition outside the accident analyses. Therefore, LCO 3.0.3 must be entered immediately. Therefore, the plant must be brought to a MODE in which overall plant risk is minimized. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours.

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 5) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action E.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of

BASES

---

ACTIONS (continued)

a shutdown of the unit.

The allowed Completion Time is reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

F.1 and F.2

The Required Actions of Condition F are modified by a Note indicating that LCO 3.0.3 does not apply. If moving recently irradiated fuel assemblies while in MODE 1, 2, or 3, the fuel movement is independent of reactor operations. Therefore, inability to suspend movement of recently irradiated fuel assemblies is not sufficient reason to require a reactor shutdown.

During movement of recently irradiated fuel assemblies in the secondary containment or during OPDRVs, with two CREF subsystems or a non-redundant component or portion of the CREF System inoperable, action must be taken immediately to suspend activities that present a potential for releasing radioactivity that might require isolation of the control room. This places the unit in a condition that minimizes risk.

If applicable, movement of recently irradiated fuel assemblies in the secondary containment must be suspended immediately. Suspension of these activities shall not preclude completion of movement of a component to a safe position. If applicable, actions must be initiated immediately to suspend OPDRVs to minimize the probability of a vessel draindown and subsequent potential for fission product release. Actions must continue until the OPDRVs are suspended.

A Note is applied to Required Action F.2. This Note allows these Required Actions to not be required when the system charcoal filter train filter media cannot provide the required efficiency or is being replaced. Dose calculations have shown that the CREF system is not needed during the activities that would otherwise be suspended by these Required Actions.



BASES

---

SURVEILLANCE REQUIREMENTS (continued)

outside of the control room to prevent unfiltered inleakage. The CREF System is designed to maintain this positive pressure with a makeup flow rate of  $\leq 1800$  cfm to the control room in the recirculation mode. The Frequency of 18 months on a STAGGERED TEST BASIS is consistent with industry practice and other filtration systems SRs.

---

REFERENCES

1. UFSAR, Chapter 6.
2. UFSAR, Chapter 9.
3. UFSAR, Chapter 15.
4. Regulatory Guide 1.52, Revision 2, March 1978.
5. NEDC-32988-A, Revision 2, Technical Justification to Support Risk-Informed Modification to Selected Required End States for BWR Plants, December 2002.

## B 3.7 PLANT SYSTEMS

### B 3.7.4 Control Center Air Conditioning (AC) System

#### BASES

---

##### BACKGROUND

The Control Center AC System provides temperature control for the control room during normal operation and following isolation of the control room.

The Control Center AC System consists of two independent, redundant subsystems that provide cooling and heating of recirculated control room air. Each subsystem consists of heating coils, cooling coils, fans, chillers, ductwork, dampers, and instrumentation and controls to provide for control center temperature control. Non-redundant ductwork from the Control Room Emergency Filtration System (LCO 3.7.3) is used to supply recirculated air to each subsystem and return air from each subsystem to the control room.

The Control Center AC System is designed to provide a controlled environment under both normal and accident conditions. The design conditions for the control room environment are 75°F and 60% relative humidity. The Control Center AC System operation in maintaining the control room temperature is discussed in the UFSAR, Sections 6.4 (Ref. 1) and 9.4.1 (Ref. 23).

---

##### APPLICABLE SAFETY ANALYSES

The design basis of the Control Center AC System is to maintain the control room temperature for a 30 day continuous occupancy.

The Control Center AC System components are arranged in redundant safety related subsystems. During emergency operation, the Control Center AC System maintains a habitable environment and ensures the OPERABILITY of components in the control room. A single active failure of a component of the Control Center AC System, assuming a loss of offsite power, does not impair the ability of the system to perform its design function. Redundant detectors and controls are provided for control room temperature control. The Control Center AC System is designed in accordance with Seismic Category I requirements. The Control Center AC System is capable of removing sensible and latent heat loads from the control center, including consideration of

BASES

---

ACTIONS (continued)

the control room is not adversely affected. With the control room temperature being maintained within the temperature limit, 72 hours is allowed to restore a Control Center AC subsystem to OPERABLE status. This Completion Time is reasonable considering that the control room temperature is being maintained within the temperature limit and the low probability of an event occurring requiring control room isolation.

C.1 and C.2

In MODE 1, 2, or 3, if the inoperable control center AC subsystem(s) cannot be restored to OPERABLE status within the associated Completion Time, the unit must be placed in a MODE that minimizes overall plant risk. To achieve this status, the unit must be placed in at least MODE 3 within 12 hours and in MODE 4 within 36 hours.

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 2) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action C.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Times ~~are~~ is reasonable, based on operating experience, to reach the required unit conditions from full power conditions in an orderly manner and without

BASES

---

SURVEILLANCE  
REQUIREMENTS

SR 3.7.4.1

This SR verifies that the heat removal capability of the system is sufficient to remove the control room heat load. The SR consists of a verification of the control room temperature. The 12 hour Frequency is appropriate since significant degradation of the Control Center AC System is not expected over this time period.

---

REFERENCES

1. UFSAR, Section 6.4.
2. NEDC-32988-A, Revision 2, Technical Justification to Support Risk-Informed Modification to Selected Required End States for BWR Plants, December 2002.
23. UFSAR, Section 9.4.1.

BASES

---

LCO To ensure compliance with the assumptions of the turbine SJAE line failure event (Ref. 1), the fission product release rate should be consistent with a noble gas release to the reactor coolant of 100  $\mu\text{Ci}/\text{Mwt}\text{-second}$  after decay of 30 minutes. The LCO is established consistent with this requirement ( $3430 \text{ Mwt} \times 100 \mu\text{Ci}/\text{Mwt}\text{-second} = 340 \text{ mCi}/\text{second}$ ).

---

APPLICABILITY The LCO is applicable when steam is being exhausted to the main condenser and the resulting noncondensibles are being processed via the Main Condenser Offgas System. This occurs during MODE 1, and during MODES 2 and 3 with any main steam line not isolated and the SJAE in operation. In MODES 4 and 5, steam is not being exhausted to the main condenser and the requirements are not applicable.

---

ACTIONS

A.1

If the offgas radioactivity rate limit is exceeded, 72 hours are allowed to restore the gross radioactivity rate to within the limit. The 72 hour Completion Time is reasonable, based on engineering judgment, the time required to complete the Required Action, the large margins associated with permissible dose and exposure limits, and the low probability of a Main Condenser Offgas System or SJAE line rupture.

B.1, B.2, and B.3.1, and ~~B.3.2~~

If the gross radioactivity rate is not restored to within the limits in the associated Completion Time, all main steam lines or the SJAE must be isolated. This isolates the Main Condenser Offgas System from the source of the radioactive steam. The main steam lines are considered isolated if at least one main steam isolation valve in each main steam line is closed, and at least one main steam line drain valve in each drain line is closed. The 12 hour Completion Time is reasonable, based on operating experience, to perform the actions from full power conditions in an orderly manner and without challenging unit systems.

---

BASES

---

ACTIONS (continued)

An alternative to Required Actions B.1 and B.2 is to place the unit in a MODE in which the LCO does not apply overall plant risk is minimized. To achieve this status, the unit must be placed in at least MODE 3 within 12 hours. ~~and in MODE 4 within 36 hours.~~

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 3) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action B.3 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Times are is reasonable, based on operating experience, to reach the required unit conditions from full power conditions in an orderly manner and without challenging unit systems.

BASES

---

SURVEILLANCE  
REQUIREMENTS

SR 3.7.5.1 and SR 3.7.5.2

This SR, on a 31 day Frequency, requires an isotopic analysis of an offgas sample to ensure that the required limits are satisfied. The noble gases to be sampled are Xe-133, Xe-135, Xe-138, Kr-85, Kr-87, and Kr-88. If the measured rate of radioactivity increases significantly (by  $\square$  50% after correcting for expected increases due to changes in THERMAL POWER), an isotopic analysis is also performed within 4 hours after the increase is noted, to ensure that the increase is not indicative of a sustained increase in the radioactivity rate. The 31 day Frequency is adequate in view of other instrumentation that continuously monitor the offgas, and is acceptable, based on operating experience.

SR 3.7.5.1 is modified by a Note indicating that the SR is not required to be performed until 31 days after any main steam line is not isolated and the SJAE is in operation. Only in this condition can radioactive fission gases be in the Main Condenser Offgas System at significant rates.

---

REFERENCES

1. UFSAR, Section 15.7.1.
2. 10 CFR 100.
3. NEDC-32988-A, Revision 2, Technical Justification to Support Risk-Informed Modification to Selected Required End States for BWR Plants, December 2002.

## BASES

## ACTIONS (continued)

According to Regulatory Guide 1.93 (Ref. 6), operation may continue in Condition F for a period that should not exceed 12 hours. In Condition F, individual redundancy is lost in both the offsite electrical power system and the onsite AC electrical power system. Since power system redundancy is provided by two diverse sources of power, however, the reliability of the power systems in this Condition may appear higher than that in Condition E (loss of both required offsite circuits). This difference in reliability is offset by the susceptibility of this power system configuration to a single bus or switching failure. The 12 hour Completion Time takes into account the capacity and capability of the remaining AC sources, reasonable time for repairs, and the low probability of a DBA occurring during this period.

G.1 and G.2

If the inoperable AC electrical power sources cannot be restored to OPERABLE status within the associated Completion Time, the unit must be brought to a MODE in which overall plant risk is minimized~~the LCO does not apply~~. To achieve this status, the unit must be brought to at least MODE 3 within 12 hours ~~and to MODE 4 within 36 hours~~.

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 8) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action G.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.



BASES

---

ACTIONS (continued)

The allowed Completion Times are is reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

---

SURVEILLANCE  
REQUIREMENTS

The AC sources are designed to permit inspection and testing of all important areas and features, especially those that have a standby function, in accordance with 10 CFR 50, GDC 18 (Ref. 89). Periodic component tests are supplemented by extensive functional tests during refueling outages (under simulated accident conditions). The SRs for demonstrating the OPERABILITY of the EDGs are based on the recommendations of Regulatory Guide 1.9 (Ref. 3), Regulatory Guide 1.108 (Ref. 910), and Regulatory Guide 1.137 (Ref. 1011), as addressed in the UFSAR.

Where the SRs discussed herein specify voltage and frequency tolerances, the following summary is applicable. The minimum steady state output voltage of 3873 V corresponds to the Division I emergency bus degraded voltage minimum limit.

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

For the purposes of SR 3.8.1.2 testing, the EDGs are started anywhere from standby to hot conditions by using one of the following signals:

- Manual,
- Simulated loss-of-offsite power by itself,
- Simulated loss-of-offsite power in conjunction with an ESF actuation test signal, or
- An ESF actuation test signal by itself.

In order to reduce stress and wear on diesel engines, the EDG manufacturer recommends a modified start in which the starting speed of EDGs is limited, warmup is limited to this lower speed, and the EDGs are gradually accelerated to synchronous speed prior to loading. These start procedures are the intent of Note 2, which is only allowed to satisfy SR 3.8.1.2 but are not applicable when performing SR 3.8.1.7.

SR 3.8.1.7 requires that, at a 184 day Frequency, the EDG starts from standby conditions and achieves required voltage and frequency within 10 seconds. Standby conditions for an EDG mean that the diesel engine coolant and oil are being continuously circulated and temperature is being maintained consistent with manufacturer recommendations. The 10 second start requirement supports the assumptions in the design basis LOCA analysis of UFSAR, Section 6.3 (Ref. 1213). The 10 second start requirement is not applicable to SR 3.8.1.2. Since SR 3.8.1.7 does require a 10 second start, it is more restrictive than SR 3.8.1.2, and it may be performed in lieu of SR 3.8.1.2. In addition to the SR requirements, the time for the EDG to reach steady state operation, unless the modified EDG start method is employed, is periodically monitored and the trend evaluated to identify degradation of governor and voltage regulator performance.

The normal 31 day Frequency for SR 3.8.1.2 is consistent with Regulatory Guide 1.9 (Ref. 3). The 184 day Frequency for SR 3.8.1.7 is a reduction in cold testing consistent with Generic Letter 84-15 (Ref. 7). These Frequencies provide adequate assurance of EDG OPERABILITY, while minimizing degradation resulting from testing.

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

SR 3.8.1.4

This SR provides verification that the level of fuel oil in the day tank is at or above the level at which fuel oil is automatically added. The level is expressed as an equivalent volume in gallons, and is selected to ensure adequate fuel oil for a minimum of 1 hour of EDG operation at full load.

The 31 day Frequency is adequate to ensure that a sufficient supply of fuel oil is available, since low level alarms are provided and facility operators would be aware of any large uses of fuel oil during this period.

SR 3.8.1.5

Microbiological fouling is a major cause of fuel oil degradation. There are numerous bacteria that can grow in fuel oil and cause fouling, but all must have a water environment in order to survive. Removal of water from the fuel oil day tanks once every 31 days eliminates the necessary environment for bacterial survival. This is the most effective means of controlling microbiological fouling. In addition, it eliminates the potential for water entrainment in the fuel oil during EDG operation. Water may come from any of several sources, including condensation, ground water, rain water, contaminated fuel oil, and breakdown of the fuel oil by bacteria. Frequent checking for and removal of accumulated water minimizes fouling and provides data regarding the watertight integrity of the fuel oil system. The Surveillance Frequencies are established by Regulatory Guide 1.137 (Ref. 1011). This SR is for preventive maintenance. The presence of water does not necessarily represent a failure of this SR provided that accumulated water is removed during performance of this Surveillance.

SR 3.8.1.6

This Surveillance demonstrates that each required fuel oil transfer pump operates and transfers fuel oil from its associated storage tank to its associated day tank. It is required to support continuous operation of standby power sources. This Surveillance provides assurance that the fuel oil transfer pump is OPERABLE, the fuel oil piping system is intact, the fuel delivery piping is not obstructed, and the

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

controls and control systems for automatic fuel transfer systems are OPERABLE.

The design of fuel transfer systems is such that pumps operate automatically in order to maintain an adequate volume of fuel oil in the day tank during or following EDG testing. As such, a 31 day Frequency is appropriate, since proper operation of fuel transfer systems is an inherent part of EDG OPERABILITY.

SR 3.8.1.7

See SR 3.8.1.2.

SR 3.8.1.8

Each EDG is provided with an engine overspeed trip to prevent damage to the engine. Recovery from the transient caused by the loss of a large load could cause diesel engine overspeed, which, if excessive, might result in a trip of the engine. This Surveillance demonstrates the EDG load response characteristics and capability to reject the largest single load while maintaining a specified margin to the overspeed trip. The largest single load for each EDG is a residual heat removal pump (1684 kW). This Surveillance may be accomplished by:

- a. Tripping the EDG output breaker with the EDG carrying greater than or equal to its associated single largest post-accident load while paralleled to offsite power, or while solely supplying the bus; or
- b. Tripping its associated single largest post-accident load with the EDG solely supplying the bus.

As required by IEEE-308 (Ref. 1415), the load rejection test is acceptable if the increase in diesel speed does not exceed 75% of the difference between synchronous speed and the overspeed trip setpoint, or 15% above synchronous speed, whichever is lower. This represents 66.75 Hz, equivalent to 75% of the difference between nominal speed and the overspeed trip setpoint.

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

The frequency tolerances specified in this SR are derived from Regulatory Guide 1.9 (Ref. 3) recommendations for response during load sequence intervals. The 18 month Frequency is consistent with the recommendation of Regulatory Guide 1.108 (Ref. 910).

SR 3.8.1.9

This Surveillance demonstrates the EDG capability to reject a full load without overspeed tripping or exceeding the predetermined voltage limits. The EDG full load rejection may occur because of a system fault or inadvertent breaker tripping. This Surveillance ensures proper engine generator load response under the simulated test conditions. This test simulates the loss of the total connected load that the EDG experiences following a full load rejection and verifies that the EDG does not trip upon loss of the load. These acceptance criteria provide EDG damage protection. While the EDG is not expected to experience this transient during an event, and continues to be available, this response ensures that the EDG is not degraded for future application, including reconnection to the bus if the trip initiator can be corrected or isolated.

The 18 month Frequency is consistent with the recommendation of Regulatory Guide 1.108 (Ref. 910) and is intended to be consistent with expected fuel cycle lengths.

SR 3.8.1.10

As required by Regulatory Guide 1.108 (Ref. 910), paragraph 2.a.(1), this Surveillance demonstrates the as designed operation of the standby power sources during loss of the offsite source. This test verifies all actions encountered from the loss of offsite power, including shedding of the nonessential loads and energization of the emergency buses and respective loads from the EDG, including automatic start of the EDG cooling water pump. It further demonstrates the capability of the EDG to automatically achieve the required voltage and frequency within the specified time.

The EDG auto-start time of 10 seconds is derived from requirements of the accident analysis for responding to a design basis large break LOCA. The Surveillance should be continued for a minimum of 5 minutes in order to demonstrate

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

that all starting transients have decayed and stability has been achieved.

The requirement to verify the connection and power supply of permanent and auto-connected loads is intended to satisfactorily show the relationship of these loads to the EDG loading logic. In certain circumstances, many of these loads cannot actually be connected or loaded without undue hardship or potential for undesired operation. For instance, Emergency Core Cooling Systems (ECCS) injection valves are not desired to be stroked open, or systems are not capable of being operated at full flow, or RHR systems performing a decay heat removal function are not desired to be realigned to the ECCS mode of operation. In lieu of actual demonstration of the connection and loading of these loads, testing that adequately shows the capability of the EDG system to perform these functions is acceptable. This testing may include any series of sequential, overlapping, or total steps so that the entire connection and loading sequence is verified.

The Frequency of 18 months is consistent with the recommendations of Regulatory Guide 1.108 (Ref. 910), paragraph 2.a.(1), takes into consideration plant conditions required to perform the Surveillance, and is intended to be consistent with expected fuel cycle lengths.

This SR is modified by a Note allowing EDG starts to be preceded by an engine prelube period. The reason for the Note is to minimize wear and tear on the EDGs during testing.

SR 3.8.1.11

This Surveillance demonstrates that the EDG (including its associated cooling water pump) automatically starts and achieves the required minimum voltage and frequency within the specified time (10 seconds) from the design basis actuation signal (LOCA signal) and operates for  $\geq 5$  minutes. The 5 minute period provides sufficient time to demonstrate stability.

The Frequency of 18 months takes into consideration plant conditions required to perform the Surveillance and is intended to be consistent with the expected fuel cycle lengths. Operating experience has shown that these

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

components usually pass the SR when performed at the 18 month Frequency. Therefore, the Frequency is acceptable from a reliability standpoint.

This SR is modified by a Note allowing EDG starts to be preceded by an engine prelube period. The reason for the Note is to minimize wear and tear on the EDGs during testing.

SR 3.8.1.12

This Surveillance demonstrates that EDG non-critical protective functions (e.g., high jacket water temperature) are bypassed on an actual or simulated emergency start (LOCA or loss of offsite power) signal. The non-critical trips are bypassed during DBAs and provide an alarm on an abnormal engine condition. This alarm provides the operator with sufficient time to react appropriately. The EDG availability to mitigate the DBA is more critical than protecting the engine against minor problems that are not immediately detrimental to emergency operation of the EDG.

The 18 month Frequency is based on engineering judgment, takes into consideration plant conditions required to perform the Surveillance, and is intended to be consistent with expected fuel cycle lengths. Operating experience has shown that these components usually pass the SR when performed at the 18 month Frequency. Therefore, the Frequency was concluded to be acceptable from a reliability standpoint.

SR 3.8.1.13

Regulatory Guide 1.108 (Ref. 910), paragraph 2.a.(3), requires demonstration once per 18 months that the EDGs can start and run continuously at full load capability for an interval of not less than 24 hours—22 hours of which is at a load equivalent to the continuous rating of the EDG, and 2 hours of which is at a load equivalent to 110% of the continuous duty rating of the EDG. Fermi-2 has taken an exception to this requirement and performs the 22 hour run at approximately 90% of the continuous rating (2500 kW-

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

2600 kW), and performs the 2 hour run at approximately the continuous rating (2800 kW-2900 kW). The EDG starts for this Surveillance can be performed either from standby or hot conditions. The provisions for prelube and warmup, discussed in SR 3.8.1.2, and for gradual loading, discussed in SR 3.8.1.3, are applicable to this SR.

Although no power factor requirements are established by this SR, the EDG is normally operated at a power factor between 0.8 lagging and 1.0. The 0.8 value is the design rating of the machine, while the 1.0 is an operational limitation to ensure circulating currents are minimized. A load band is provided to avoid routine overloading of the EDG. Routine overloading may result in more frequent teardown inspections in accordance with vendor recommendations in order to maintain EDG OPERABILITY.

The 18 month Frequency is consistent with the recommendations of Regulatory Guide 1.108 (Ref. 910), paragraph 2.a.(3); takes into consideration plant conditions required to perform the Surveillance; and is intended to be consistent with expected fuel cycle lengths.

This Surveillance has been modified by a Note. The Note states that momentary transients due to changing bus loads do not invalidate this test.

SR 3.8.1.14

This Surveillance demonstrates that the diesel engine can restart from a hot condition, such as subsequent to shutdown from normal Surveillances, and achieve the minimum required voltage and frequency within 10 seconds and maintain a steady state voltage and frequency range. The 10 second time is derived from the requirements of the accident analysis to respond to a design basis large break LOCA. The 18 month Frequency is consistent with the recommendations of Regulatory Guide 1.108 (Ref. 910), paragraph 2.a.(5).

This SR is modified by two Notes. Note 1 ensures that the test is performed with the diesel sufficiently hot. The requirement that the diesel has operated for at least 2 hours near full load conditions prior to performance of this Surveillance is based on manufacturer recommendations for achieving hot conditions. Routine overloads may result in more frequent teardown inspections in accordance with



BASES

---

SURVEILLANCE REQUIREMENTS (continued)

vendor recommendations in order to maintain EDG OPERABILITY. Momentary transients due to changing bus loads do not invalidate this test. Note 2 allows all EDG starts to be preceded by an engine prelube period to minimize wear and tear on the diesel during testing.

SR 3.8.1.15

As required by Regulatory Guide 1.108 (Ref. 910), paragraph 2.a.(6), this Surveillance ensures that the manual synchronization and load transfer from the EDG to the offsite source can be made and that the EDG can be returned to standby status when offsite power is restored. It also ensures that the auto-start logic is reset to allow the EDG to restart and reload if a subsequent loss of offsite power occurs. The EDG is considered to be in standby status when the EDG is shutdown with the output breaker open, the load sequence timers are reset, and is able to restart and reload on a subsequent bus under voltage.

The Frequency of 18 months is consistent with the recommendations of Regulatory Guide 1.108 (Ref. 910), paragraph 2.a.(6), and takes into consideration plant conditions desired to perform the Surveillance.

SR 3.8.1.16

Under accident conditions with loss of offsite power loads are sequentially connected to the bus by the automatic load sequencer. The sequencing logic controls the permissive and starting signals to motor breakers to prevent overloading of the EDGs due to high motor starting currents. The 10% load sequence time interval tolerance ensures that sufficient time exists for the EDG to restore frequency and voltage prior to applying the next load and that safety analysis assumptions regarding ESF equipment time delays are not violated. Reference 2 provides a summary of the automatic loading of ESF buses.

The Frequency of 18 months is consistent with the recommendations of Regulatory Guide 1.108 (Ref. 910), paragraph 2.a.(2); takes into consideration plant conditions required to perform the Surveillance; and is intended to be consistent with expected fuel cycle lengths.

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

SR 3.8.1.17

In the event of a DBA coincident with a loss of offsite power, the EDGs are required to supply the necessary power to ESF systems so that the fuel, RCS, and containment design limits are not exceeded.

This Surveillance demonstrates EDG operation, as discussed in the Bases for SR 3.8.1.10, during a loss of offsite power actuation test signal in conjunction with an ECCS initiation signal. In lieu of actual demonstration of connection and loading of loads, testing that adequately shows the capability of the EDG system to perform these functions is acceptable. This testing may include any series of sequential, overlapping, or total steps so that the entire connection and loading sequence is verified.

The Frequency of 18 months takes into consideration plant conditions required to perform the Surveillance and is intended to be consistent with an expected fuel cycle length of 18 months.

This SR is modified by a Note allowing EDG starts to be preceded by an engine prelube period. The reason for the Note is to minimize wear and tear on the EDGs during testing.

SR 3.8.1.18

This Surveillance demonstrates that the EDG starting independence has not been compromised. Also, this Surveillance demonstrates that each engine can achieve proper speed within the specified time when the EDGs are started simultaneously.

The 10 year Frequency is consistent with the recommendations of Regulatory Guide 1.108 (Ref. 910).

This SR is modified by a Note allowing EDG starts to be preceded by an engine prelube period. The reason for the Note is to minimize wear on the EDG during testing.

BASES

---

- REFERENCES
1. 10 CFR 50, Appendix A, GDC 17.
  2. UFSAR, Sections 8.2 and 8.3.
  3. Regulatory Guide 1.9.
  4. UFSAR, Chapter 6.
  5. UFSAR, Chapter 15.
  6. Regulatory Guide 1.93.
  7. Generic Letter 84-15.
  8. NEDC-32988-A, Revision 2, Technical Justification to Support Risk-Informed Modification to Selected Required End States for BWR Plants, December 2002.
  - ~~8~~9. 10 CFR 50, Appendix A, GDC 18.
  - ~~9~~10. Regulatory Guide 1.108.
  - ~~10~~11. Regulatory Guide 1.137.
  - ~~11~~12. Deleted.
  - ~~12~~13. UFSAR, Section 6.3.
  - ~~13~~14. ASME Boiler and Pressure Vessel Code, Section XI.
  - ~~14~~15. IEEE Standard 308.

## B 3.8 ELECTRICAL POWER SYSTEMS

### B 3.8.4 DC Sources—Operating

#### BASES

---

##### BACKGROUND

The DC electrical power system provides the AC emergency power system with control power. It also provides both motive and control power to selected safety related equipment. As required by 10 CFR 50, Appendix A, GDC 17 (Ref. 1), the DC electrical power system is designed to have sufficient independence, redundancy, and testability to perform its safety functions, assuming a single failure. The DC electrical power system also conforms to the recommendations of Regulatory Guide 1.6 (Ref. 2) and IEEE-308 (Ref. 3).

The DC power sources provide both motive and control power to selected safety related equipment, as well as circuit breaker control power for the nonsafety related 480 V loads that are connected to 480 V ESF buses. Two center-tapped 260 VDC batteries are provided for Class 1E loads. They are designated 2PA for Division I and 2PB for Division II. Each 260 VDC battery is divided into two 130 VDC batteries connected in series. Each 130 VDC battery section has a battery charger connected in parallel with their respective battery. Each 260 VDC battery has a spare battery charger that can replace either of the normal 130 VDC connected chargers. Each division's two 130 VDC batteries and their chargers are the source of DC control power for that respective division, including the respective EDG. Each 260 VDC source furnishes power to DC motors necessary for shutdown conditions.

During normal operation, the DC loads are powered from the battery chargers with the batteries floating on the system. In case of loss of normal power to the battery charger, the DC loads are automatically powered from the batteries.

The DC power distribution system is described in more detail in Bases for LCO 3.8.7, "Distribution System—Operating," and LCO 3.8.8, "Distribution System—Shutdown."

Each battery has adequate storage capacity to carry the required load continuously for approximately 4 hours (Ref. ~~11~~12).

BASES

---

BACKGROUND (continued)

Each DC battery subsystem is separately housed in a ventilated room apart from its charger and distribution centers. Each subsystem is located in an area separated physically and electrically from the other subsystems to ensure that a single failure in one subsystem does not cause a failure in a redundant subsystem. There is no sharing between redundant Class 1E subsystems such as batteries, battery chargers, or distribution panels.

The batteries for DC electrical power subsystems are sized to produce required capacity at 80% of nameplate rating, corresponding to warranted capacity at end of life cycles and the 100% design demand. The minimum design voltage limit is 105/210 V.

Each battery charger of DC electrical power subsystem has ample power output capacity for the steady state operation of connected loads required during normal operation, while at the same time maintaining its battery bank fully charged. Each battery charger has sufficient capacity to restore the battery from the design minimum charge to its fully charged state within 24 hours while supplying normal steady state loads (Ref. 1112).

---

APPLICABLE  
SAFETY ANALYSES

The initial conditions of Design Basis Accident (DBA) and transient analyses in the UFSAR, Chapter 6 (Ref. 4) and Chapter 15 (Ref. 5), assume that Engineered Safety Feature (ESF) systems are OPERABLE. The DC electrical power system provides normal and emergency DC electrical power for the EDGs, emergency auxiliaries, and control and switching during all MODES of operation. The OPERABILITY of the DC subsystems is consistent with the initial assumptions of the accident analyses and is based upon meeting the design basis of the unit. This includes maintaining sufficient DC sources OPERABLE during accident conditions in the event of:

- a. An assumed loss of all offsite AC power or all onsite AC power; and
- b. A worst case single failure.

The DC sources satisfy Criterion 3 of 10 CFR 50.36(c)(2)(ii).

BASES

ACTIONS (continued)

division. The 4 hour Completion Time (Required Action A.1) for restoration of an inoperable battery charger allows time to replace the inoperable charger with an OPERABLE spare battery charger, if available. The four hour limit is reasonable based on the remaining capability of the battery to carry the loads for this period. The 2 hour limit for Required Action B.1 is consistent with the allowed time for an inoperable DC Distribution System division. The 2 hour Completion Time is based on Regulatory Guide 1.93 (Ref. 6) and reflects a reasonable time to assess unit status as a function of the inoperable DC electrical power subsystem and, if the DC electrical power subsystem is not restored to OPERABLE status, to prepare to effect an orderly and safe unit shutdown.

C.1 and C.2

If the station service DC electrical power subsystem cannot be restored to OPERABLE status within the required Completion Time, the unit must be brought to a MODE in which ~~the LCO does not apply overall plant risk is minimized.~~ To achieve this status, the unit must be brought to at least MODE 3 within 12 hours ~~and to MODE 4 within 36 hours.~~

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 8) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

Required Action D.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Times ~~are~~ is reasonable, based on

BASES

---

ACTIONS (continued)

operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems. ~~The Completion Time to bring the unit to MODE 4 is consistent with the time required in Regulatory Guide 1.93 (Ref. 6).~~

---

SURVEILLANCE  
REQUIREMENTS

SR 3.8.4.1

Verifying battery terminal voltage while on float charge for the batteries helps to ensure the effectiveness of the charging system and the ability of the batteries to perform their intended function. Float charge is the condition in which the charger is supplying the continuous charge required to overcome the internal losses of a battery (or battery cell) and maintain the battery (or a battery cell) in a fully charged state. The voltage requirements are based on the nominal design voltage of the battery and are consistent with the initial voltages assumed in the battery sizing calculations. The 7 day Frequency is consistent with manufacturer recommendations and IEEE-450 (Ref. 7).

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

SR 3.8.4.4 and SR 3.8.4.5

Visual inspection and resistance measurements of inter-cell and terminal connections provides an indication of physical damage or abnormal deterioration that could indicate degraded battery condition. The anti-corrosion material is used to help ensure good electrical connections and to reduce terminal deterioration. The visual inspection for corrosion is not intended to require removal of and inspection under each terminal connection.

The removal of visible corrosion is a preventive maintenance SR. The presence of visible corrosion does not necessarily represent a failure of this SR, provided visible corrosion is removed during performance of this Surveillance.

The connection resistance limits procedurally established for this SR are no more than 20% above the resistance as measured during installation, and not above the ceiling value established by the manufacturer. This provides conservative measures to assure the Technical Specification limit is not exceeded.

The 18 month Frequency is based on engineering judgement, taking into consideration the desired plant conditions to perform the Surveillance. Operating experience has shown that these components usually pass the SR when performed at the 18 month Frequency. Therefore, the Frequency is considered acceptable from a standpoint of maintaining reliability.

SR 3.8.4.6

Battery charger capability requirements are based on the design capacity of the chargers (Ref. 3). According to Regulatory Guide 1.32 (Ref. 89), the battery charger supply is required to be based on the largest combined demands of the various steady state loads and the charging capacity to restore the battery from the design minimum charge state to the fully charged state, irrespective of the status of the unit during these demand occurrences. The minimum required amperes and duration ensures that these requirements can be satisfied.

The Frequency is acceptable, given the unit conditions required to perform the test and the other administrative



BASES

---

SURVEILLANCE REQUIREMENTS (continued)

controls existing to ensure adequate charger performance during these 18 month intervals. In addition, this Frequency is intended to be consistent with expected fuel cycle lengths.

SR 3.8.4.7

A battery service test is a special test of the battery's capability, as found, to satisfy the design requirements (battery duty cycle) of the DC electrical power system. The discharge rate and test length corresponds to the design duty cycle requirements as specified in Reference 4.

The Frequency of 18 months is consistent with the recommendations of Regulatory Guide 1.32 (Ref. 89) and Regulatory Guide 1.129 (Ref. 910), which state that the battery service test should be performed during refueling operations or at some other outage, with intervals between tests not to exceed 18 months.

This SR is modified by a Note that allows the performance of a performance discharge test in lieu of a service test once per 60 months.

SR 3.8.4.8

A battery performance discharge test is a test of constant current capacity of a battery, normally done in the as found condition, after having been in service, to detect any change in the capacity determined by the acceptance test. The test is intended to determine overall battery degradation due to age and usage.

The battery performance discharge test is acceptable for satisfying SR 3.8.4.7 as noted in SR 3.8.4.7.

The acceptance criteria for this Surveillance is consistent with IEEE-450 (Ref. 7) and IEEE-485 (Ref. 1011). These references recommend that the battery be replaced if its capacity is below 80% of the manufacturer's rating. A capacity of 80% shows that the battery rate of deterioration is increasing, even if there is ample capacity to meet the load requirements.

The Frequency for this test is normally 60 months. If the battery shows degradation, or if the battery has reached 85%

BASES

---

SURVEILLANCE REQUIREMENTS (continued)

of its expected life, the Surveillance Frequency is reduced to 18 months. Degradation is indicated, according to IEEE-450 (Ref. 7), when the battery capacity drops by more than 10% relative to its capacity on the previous performance test or when it is 10% below the manufacturer's rating. The 60 month Frequency is consistent with the recommendations in IEEE-450 (Ref. 7); however, the 18 month Frequency is based on previously accepted industry practice, and the need to perform this test during an outage.

This SR is modified by a Note. The reason for the Note is that performing the Surveillance would remove a required DC electrical power subsystem from service, perturb the electrical distribution system, and challenge safety systems. Credit may be taken for unplanned events that satisfy the Surveillance.

---

REFERENCES

1. 10 CFR 50, Appendix A, GDC 17.
2. Regulatory Guide 1.6.
3. IEEE Standard 308, 1978.
4. UFSAR, Chapter 6.
5. UFSAR, Chapter 15.
6. Regulatory Guide 1.93.
7. IEEE Standard 450.
8. NEDC-32988-A, Revision 2, Technical Justification to Support Risk-Informed Modification to Selected Required End States for BWR Plants, December 2002.
89. Regulatory Guide 1.32, February 1977.
910. Regulatory Guide 1.129, December 1974.
1011. IEEE Standard 485, 1983.
1112. UFSAR, Section 8.3.2.

BASES

---

ACTIONS (continued)

The 2 hour Completion Time for DC distribution subsystems is consistent with Regulatory Guide 1.93 (Ref. 3).

The second Completion Time for Required Action B.1 establishes a limit on the maximum time allowed for any combination of required distribution subsystems to be inoperable during any single contiguous occurrence of failing to meet the LCO. If Condition B is entered while, for instance, an AC bus is inoperable and subsequently restored OPERABLE, the LCO may already have been not met for up to 8 hours. This situation could lead to a total duration of 10 hours, since initial failure of the LCO, to restore the DC distribution system. At this time, an AC division could again become inoperable, and DC distribution could be restored OPERABLE. This could continue indefinitely.

This Completion Time allows for an exception to the normal "time zero" for beginning the allowed outage time "clock." This allowance results in establishing the "time zero" at the time the LCO was initially not met, instead of at the time Condition B was entered. The 16 hour Completion Time is an acceptable limitation on this potential of failing to meet the LCO indefinitely.

C.1 and C.2

If the inoperable distribution subsystem cannot be restored to OPERABLE status within the associated Completion Time, the unit must be brought to a MODE in which ~~the LCO does not apply overall plant risk is minimized~~. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours ~~and to MODE 4 within 36 hours~~.

Remaining in the Applicability of the LCO is acceptable because the plant risk in MODE 3 is similar to or lower than the risk in MODE 4 (Ref. 4) and because the time spent in MODE 3 to perform the necessary repairs to restore the system to OPERABLE status will be short. However, voluntary entry into MODE 4 may be made as it is also an acceptable low-risk state.

BASES

---

ACTIONS (continued)

Required Action C.1 is modified by a Note that states that LCO 3.0.4.a is not applicable when entering MODE 3. This Note prohibits the use of LCO 3.0.4.a to enter MODE 3 during startup with the LCO not met. However, there is no restriction on the use of LCO 3.0.4.b, if applicable, because LCO 3.0.4.b requires performance of a risk assessment addressing inoperable systems and components, consideration of the results, determination of the acceptability of entering MODE 3, and establishment of risk management actions, if appropriate. LCO 3.0.4 is not applicable to, and the Note does not preclude, changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

The allowed Completion Times are is reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

D.1

Condition D corresponds to a level of degradation in the electrical distribution system that causes a required safety function to be lost. When more than one AC or DC electrical power distribution subsystem is lost, and this results in the loss of a required function, the plant is in a condition outside the accident analysis. Therefore, no additional time is justified for continued operation. LCO 3.0.3 must be entered immediately to commence a controlled shutdown.

BASES

---

SURVEILLANCE  
REQUIREMENTS

SR 3.8.7.1

This Surveillance verifies that the AC and DC, electrical power distribution systems are functioning properly, with the correct circuit breaker alignment. The correct breaker alignment ensures the appropriate separation and independence of the electrical subsystems are maintained, and the appropriate voltage is available to each required bus, MPU, DC distribution cabinet, or DC MCC. The verification of proper voltage availability on the buses ensures that the required voltage is readily available for motive as well as control functions for critical system loads connected to these distribution subsystems. The 7 day Frequency takes into account the redundant capability of the AC and DC electrical power distribution subsystems, and other indications available in the control room that alert the operator to subsystem malfunctions.

---

REFERENCES

1. UFSAR, Chapter 6.
2. UFSAR, Chapter 15.
3. Regulatory Guide 1.93, December 1974.
4. NEDC-32988-A, Revision 2, Technical Justification to Support Risk-Informed Modification to Selected Required End States for BWR Plants, December 2002.