Davis-BesseNPEm Resource

From: dorts@firstenergycorp.com

Sent: Thursday, December 20, 2012 11:16 AM

To: CuadradoDeJesus, Samuel

Subject: Re: FW: DB High Strength Bolt Inspection Deferrals

Thanks, Sam.

Steve Dort

Davis-Besse License Renewal

From: "CuadradoDeJesus, Samuel" < <u>Samuel.CuadradoDeJesus@nrc.gov</u>>

To: "Larry S. Hinkle" < larry.hinkle@embargmail.com>

Cc: Davis-BesseHearingFile Resource Davis-BesseHearingFile Resource@nrc.gov>, "Doutt, Clifford Cci Davis-BesseHearingFile Resource@nrc.gov>, "Doutt, Clifford Cci Clifford Doutt@nrc.gov>,

"dorts@firstenergycorp.com" <dorts@firstenergycorp.com>

Date: 12/20/2012 11:04 AM

Subject: FW: DB High Strength Bolt Inspection Deferrals

Larry,

Below is the staff's position.

From: Holston, William

Sent: Wednesday, December 19, 2012 3:52 PM

To: CuadradoDeJesus, Samuel

Subject: DB High Strength Bolt Inspection Deferrals

Sam – our position is that if evidence of contamination is found, a deferral of the UT inspections until he next refueling outage would only be acceptable if visual inspections of the coatings demonstrate that the liquid could not have penetrated to the base metal of the stud. For example, coatings are intact on the stud and nut on all surfaces, coatings on the base plate are intact between the wall/column and the base plate.

------ The information contained in this message is intended only for the personal and confidential use of the recipient(s) named above. If the reader of this message is not the intended recipient or an agent responsible for delivering it to the intended recipient, you are hereby notified that you have received this document in error and that any review, dissemination, distribution, or copying of this message is strictly prohibited. If you have received this communication in error, please notify us immediately, and delete the original message.

Hearing Identifier: Davis_BesseLicenseRenewal_Saf_NonPublic

Email Number: 3998

Mail Envelope Properties

(OF3571D3F4.A810BE4F-ON85257ADA.005957AD-85257ADA.00595C3D)

Subject: Re: FW: DB High Strength Bolt Inspection Deferrals

 Sent Date:
 12/20/2012 11:16:02 AM

 Received Date:
 12/20/2012 11:16:08 AM

 From:
 dorts@firstenergycorp.com

Created By: dorts@firstenergycorp.com

Recipients:

"CuadradoDeJesus, Samuel" <Samuel.CuadradoDeJesus@nrc.gov>

Tracking Status: None

Post Office: FirstEnergyCorp.com

Files Size Date & Time

MESSAGE 1734 12/20/2012 11:16:08 AM

Options

Priority:StandardReturn Notification:NoReply Requested:NoSensitivity:Normal

Expiration Date: Recipients Received: