

Davis-BesseNPEm Resource

From: CuadradoDeJesus, Samuel
Sent: Wednesday, January 16, 2013 3:14 PM
To: custerc@firstenergycorp.com; dorts@firstenergycorp.com
Cc: Davis-BesseHearingFile Resource
Subject: Draft Teleconference Summary 10 23 2012
Attachments: 10 23 2012 DB NRC Telecon Summary.docx

Importance: High

Cliff and Steve,

Attached is the draft summary of our 10/23/2012 teleconference. Please let me know if you have any comment.

Regards,

Samuel Cuadrado de Jesús

Project Manager

Projects Branch 1

Division of License Renewal

U.S. Nuclear Regulatory Commission

Phone: 301-415-2946

Samuel.CuadradoDeJesus@nrc.gov

Hearing Identifier: Davis_BesseLicenseRenewal_Saf_NonPublic
Email Number: 4017

Mail Envelope Properties (377CB97DD54F0F4FAAC7E9FD88BCA6D0B9F26CEBC7)

Subject: Draft Teleconference Summary 10 23 2012
Sent Date: 1/16/2013 3:14:25 PM
Received Date: 1/16/2013 3:14:27 PM
From: CuadradoDeJesus, Samuel

Created By: Samuel.CuadradoDeJesus@nrc.gov

Recipients:

"Davis-BesseHearingFile Resource" <Davis-BesseHearingFile.Resource@nrc.gov>
Tracking Status: None
"custerc@firstenergycorp.com" <custerc@firstenergycorp.com>
Tracking Status: None
"dorts@firstenergycorp.com" <dorts@firstenergycorp.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	400	1/16/2013 3:14:27 PM
10 23 2012 DB NRC Telecon Summary.docx		29711

Options

Priority: High
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

LICENSEE: FirstEnergy Nuclear Operating Company

FACILITY: Davis-Besse

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON OCTOBER 23, 2012 BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND FIRSTENERGY NUCLEAR OPERATING COMPANY, CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE DAVIS-BESSE NUCLEAR POWER STATION, LICENSE RENEWAL APPLICATION (TAC. NO. ME4640)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of FirstEnergy Nuclear Operating Company (FENOC or the applicant) held a telephone conference call on October 23, 2012, to discuss and clarify the applicant's responses to the staff's requests for additional information (RAIs) concerning the Davis-Besse license renewal application.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a description of the staff concerns discussed with the applicant. A brief description on the status of the items is also included.

The applicant had an opportunity to comment on this summary.

Samuel Cuadrado de Jesús, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Number:50-346

Enclosures:

1. List of Participants
2. List of Requests for Additional Information

cc w/encls: See next page

LICENSEE: FirstEnergy Nuclear Operating Company

FACILITY: Davis-Besse

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON OCTOBER 23, 2012 BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND FIRSTENERGY NUCLEAR OPERATING COMPANY, CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE DAVIS-BESSE NUCLEAR POWER STATION, LICENSE RENEWAL APPLICATION (TAC. NO. ME4640)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of FirstEnergy Nuclear Operating Company (FENOC or the applicant) held a telephone conference call on October 23, 2012, to discuss and clarify the applicant's responses to the staff's requests for additional information (RAIs) concerning the Davis-Besse license renewal application.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a description of the staff concerns discussed with the applicant. A brief description on the status of the items is also included.

The applicant had an opportunity to comment on this summary.

Samuel Cuadrado de Jesús, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-346

Enclosures:

1. List of Participants
2. List of Requests for Additional Information

cc w/encls: See next page

DISTRIBUTION: See next page

ADAMS Accession No.:

DOCUMENT NAME: Insert document name and full path.

OFFICE	LA:DLR	PM:RPB1:DLR	BC:RPB1:DLR
NAME		S Cuadrado de Jesús	D Morey
DATE	/ /	/ /	/ /

OFFICIAL RECORD COPY

SUMMARY OF TELEPHONE CONFERENCE CALL
DAVIS-BESSE
LICENSE RENEWAL APPLICATION

LIST OF PARTICIPANTS
October 23, 2012

PARTICIPANTS

Samuel Cuadrado de Jesús

Chris Sydnor

Allen Hiser

Steven Dort

Larry Hinkle

Dennis Blakely

Mark Rinckel

AFFILIATIONS

U.S. Nuclear Regulatory Commission (NRC)

NRC

NRC

FirstEnergy Nuclear Operating Company (FENOC)

FENOC

FENOC

AREVA

SUMMARY OF TELEPHONE CONFERENCE CALL
DAVIS-BESSE
LICENSE RENEWAL APPLICATION
October 23, 2012

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of FirstEnergy Nuclear Operating Company (FENOC or the applicant) held a telephone conference call on October 23, 2012, to discuss and clarify the following **response to requests for additional information (RAIs)** concerning the Davis-Besse license renewal application (LRA).

Response to RAI 4.2.4-1: Pressure-Temperature (P-T) Limits

Discussion: The purpose of the call was to discuss the applicant's response to the staff request for additional information (RAI) 4.2.4-1 submitted by FENOC letter dated August 24, 2012.

The staff stated that it could not find information in the applicant's response that addressed how future P-T limit curves would be developed for the period of extended operation taking into account the neutron embrittlement effects on the extended beltline region and the localized stresses of the inlet and outlet nozzles. The staff also stated that this information needs to be provided in LRA Sections 4.2.4 and A.2.2.4 (USAR Supplement).

The applicant stated that the Davis-Besse P-T limit curves are currently limited to 32 effective full power years, and that additional analysis is required to extend the curves in the future. The applicant also stated that in order to provide clarification and address the staff's concern it will submit a supplemental response to RAI 4.2.4-1 and as part of the supplemental response it will incorporate the clarification into LRA Sections 4.2.4 and A.2.2.4, both titled "Pressure-Temperature Limits." The staff agreed with the applicant determination of providing a supplemental response to RAI 4.2.4-1.

Action: The applicant will provide a supplemental response to RAI 4.2.4-1

SUBJECT: Summary of Telephone Conference Call conducted on October 23, 2012

ENCLOSURE 2

DISTRIBUTION:

HARD COPY:

DLR RF

E-MAIL:

PUBLIC [or NON-PUBLIC, if applicable]

RidsNrrDir Resource
RidsNrrDirRpb1 Resource
RidsNrrDirRpb2 Resource
RidsNrrDirRarb Resource
RidsNrrDirRapb Resource
RidsNrrDirRasb Resource
RidsNrrDirRerb Resource
RidsNrrDirRpob Resource

PCooper
BHarris
SCuadrado
EMiller
MMahoney
D.McIntyre, OPA
TRiley, OCA
BHarris, OGC