

Davis-BesseNPEm Resource

From: dorts@firstenergycorp.com
Sent: Thursday, January 24, 2013 8:51 AM
To: CuadradoDeJesus, Samuel
Cc: custerc@firstenergycorp.com
Subject: FENOC Telephone Conference Summary 1/23/2013 -- Shield Building RAIs
Attachments: NRC telecon 20130123 RAIs Shield Bldg.pdf

Sam..... attached is a copy of the FENOC telecon summary from the discussion on the Davis-Besse License Renewal Shield Building Monitoring Program request for additional information (RAI) B.2.43-3a, held on January 23, 2013.

Please contact Cliff Custer or me with questions on the attached telecon summary.

Steve Dort
FENOC License Renewal

----- The information contained in this message is intended only for the personal and confidential use of the recipient(s) named above. If the reader of this message is not the intended recipient or an agent responsible for delivering it to the intended recipient, you are hereby notified that you have received this document in error and that any review, dissemination, distribution, or copying of this message is strictly prohibited. If you have received this communication in error, please notify us immediately, and delete the original message.

Hearing Identifier: Davis_BesseLicenseRenewal_Saf_NonPublic
Email Number: 4025

Mail Envelope Properties

(OF020E6C7C.A562FCFF-ON85257AFD.004BE95B-85257AFD.004C0E4B)

Subject: FENOC Telephone Conference Summary 1/23/2013 -- Shield Building RAIs
Sent Date: 1/24/2013 8:50:43 AM
Received Date: 1/24/2013 8:50:49 AM
From: dorts@firstenergycorp.com

Created By: dorts@firstenergycorp.com

Recipients:

"custer@firstenergycorp.com" <custer@firstenergycorp.com>

Tracking Status: None

"CuadradoDeJesus, Samuel" <Samuel.CuadradoDeJesus@nrc.gov>

Tracking Status: None

Post Office: FirstEnergyCorp.com

Files	Size	Date & Time
MESSAGE	942	1/24/2013 8:50:49 AM
NRC telecon 20130123 RAIs Shield Bldg.pdf		23394

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received:

TO: File **DATE:** January 23, 2013
FROM: Steven Dort
SUBJECT: NRC Telecon Regarding Davis-Besse License Renewal –
Shield Building Requests for Additional Information

NRC Attendees: Sam Cuadrado de Jesús, Michael Marshall, Bryce Lehman,
Abdul Sheikh

FENOC Attendees: Cliff Custer, Steven Dort, Don Kosloff, Jon Hook,
Greg Michael, Thomas Henry

This telephone conference call (telecon) was initiated by Sam Cuadrado de Jesús, NRC Project Manager for Davis-Besse License Renewal. The telecon took place at 1500 hours on January 23, 2013. The purpose of the call was to discuss and clarify NRC follow-up request for additional information (RAI) B.2.43-3a regarding the Davis-Besse Shield Building Monitoring Program, as follows:

RAI B.2.43-3a

Regarding request #1 of the RAI, NRC Staff stated that the discussion is not about aging mechanisms. Rather, more detail is needed to justify why the other structures within the scope of license renewal are not susceptible to the same laminar cracking phenomenon as the Shield Building. In response to the RAI, FENOC agreed to address the other structures within the scope of license renewal to state why those structures are not susceptible to laminar cracking such as that which occurred in the Shield Building.

Regarding request #2 of the RAI, NRC Staff stated that the wording of commitments made regarding the use of American Concrete Institute (ACI) Report 349.3R, "Evaluation of Existing Nuclear Safety-Related Concrete Structures," for the inspection of coatings were inconsistent. FENOC agreed that the commitment wording was not clear, and that FENOC intends to follow ACI 349.3R for the inspection of coatings. In response to the RAI, FENOC agreed to revise the wording of the commitments to make it clear that ACI 349-3R will be followed for inspections of coatings on structures within the scope of license renewal.

Following the discussion, NRC Staff and FENOC agreed that, instead of addressing the RAI as written, FENOC should respond to requests #1 and #2 of the RAI by providing information as clarified during this telecon. NRC Staff and FENOC agreed to a revised due date for the submittal of FENOC responses to the RAIs of February 28, 2013.

There was no further discussion, and the call was concluded.