

8:00 AM Reactor Oversight Coordination Meeting - August 23, 2012

	Date Added	Lead Branch	Plant/Issue/Status
Events, Significant Safety Issues, and Operational Challenges	8/13/12	PB5	<u>MS</u> - U2 Tech Spec required shutdown due to ultimate heat sink exceeding temp limit of 75 degrees, Mode 3
	8/13/12	PB6	<u>TMI</u> - Flood Barrier Seals could not be verified installed in the Air Intake Tunnel
	8/23/12	PB6	<u>TMI</u> – TS shutdown PZR Heater Leakage; Rx trip for high RCS pressure
IMC 0309 Reviews	8/13/12	PB6	<u>TMI</u> - Flood Barrier Seals could not be verified installed in the Air Intake Tunnel
Plant Status Items of Interest	6/21/12	PB1	<u>NMP</u> – U1 AL3 UIL 0.34 gpm
	8/07/12	PB4	<u>SQ</u> – U1 UIL 0.39 gpm (first 90 days)
	8/13/12	PB4	<u>LM</u> - U1 LP Turbine Blade Inspection 8/31
	8/20/12	PB2	<u>IP</u> – U2 21CP Freeze Seal/Operator Performance
Team Inspections	<u>HC</u> – CDBI 7/30, 8/13, 8/27		
	<u>Salem/HC</u> – 95002 8/27		
	<u>OC</u> – PI&R 8/13 & 8/27		
	<u>MS</u> - 95001 9/10		
High Profile Coordination Activities	1/03/12	EB1/PB3	<u>SB</u> – ASR resolution: 1) CAL Follow-up INSP in progress; 2) Working group priority Issues: TIA, deviation memo, technical issues position papers
	7/02/12	ORA/DRP	Meeting w/ NJ OC Oversight Panel 8/23
	7/12/12	PB1	<u>CC</u> – Magwood visit to site 8/23
	7/31/12	PB2	<u>IP</u> – Magwood visit 9/13
	8/02/12	DRM	<u>Region</u> – Chairman visit 9/13

	8/16/12	PB1	<u>CC</u> – GAO visit to site 9/25
	8/16/12	PB4	<u>PB</u> – Apostolakis visit 10/3
	8/21/12	PB4	<u>SQ</u> – Lou Barletta visit 8/24; licensee sponsored visit
	8/23/12	PB2	<u>IP</u> – Chairman visit 10/9

Daily Notes & One-Week Look Aheads	PN for TMI Shutdown 8/23/12		

FOIA Requests			

TI Status (1 st Tuesday of the Month)	2515/177	ECCS Gas Accumulation – 96% complete, pending at BV	Due 12/31/12
	2515/185	Follow-up on Industry's Groundwater Protection Initiative	Due 12/31/12
	2516/001	Review of License Renewal Activities (IP2)	Due 12/31/13
	2515/187	Inspection of Near-Term Task Force Recommendations 2.3 Flooding Walkdowns	Due 12/31/13
	2515/188	Inspection of Near-Term Task Force Recommendation 2.3 Seismic Walkdowns	Due 12/31/13
	2515/182	Review of the Implementation of the Industry Initiative to Control Degradation of Underground Piping and Tanks –50%	Due 06/30/14

General Announcements and Other Items of Interest	

Weekend Coverage <i>(Thursdays)</i>	DRP: Clifford		DRS: Miller	SLO:	RDO: Cook	PAO: Screnci
Long-Term Items of Interest <i>(discussed if there are updates)</i>	10/2011	PB6	<u>TMI</u> – Flood evaluation review (PI&R sample)			
	5/29/12	PB4	<u>LM</u> & <u>SQ</u> – Siemens Turbine Blade Cracking			
	7/30/12	PB2	<u>IP</u> – ASLB license renewal oral testimony 10/15-18; 10/22-24; 12/10-14			
	7/31/12	PB2	<u>FP</u> – Increasing tritium in RB perimeter sump; TI inspection in August			
	8/16/12	PSB2	<u>NMP</u> – U1 Tritium leak, no identified source			

- **NRR/OpE**
- **Off-line security issues**

Following the meeting please select file and send email to George.Wilson@nrc.gov