



David H. Corlett  
Supervisor – Licensing/Regulatory Programs  
Harris Nuclear Plant  
5413 Shearon Harris Rd  
New Hill NC 27562-9300

919-362-3137

FEB 4 2013

Serial: HNP-13-016

United States Nuclear Regulatory Commission  
ATTENTION: Document Control Desk  
Washington, DC 20555

Shearon Harris Nuclear Power Plant  
Docket No. 50-400

Subject: Annual Report in Accordance with Technical Specification 6.9.1.2

Ladies and Gentlemen:

In accordance with Harris Nuclear Plant (HNP) Technical Specification 6.9.1.2, Carolina Power & Light Company is providing the following information regarding reactor coolant specific activity limits for 2012.

During 2012, activity levels in the HNP reactor coolant did not exceed 1.0  $\mu\text{Ci}/\text{gram}$  dose equivalent I-131 or 100/E-bar  $\mu\text{Ci}/\text{gram}$  gross radioactivity as set forth in HNP Technical Specification 3.4.8.

If you have any questions regarding this submittal, please contact me at (919) 362-3137.

Sincerely,

DHC/mgw

c: Mr. J. D. Austin (NRC Senior Resident Inspector, HNP)  
Mr. V. M. McCree (NRC Regional Administrator, Region II)  
Ms. A. T. Billoch Colón (NRC Project Manager, HNP)

A001  
MRR