Enclosure 3 ASME and Reactor Vessel & Internals Update (Redacted)

.

babcock & wilcox mPower, Inc., a Babcock & Wilcox company

# generation



#### ASME Code Update & Reactor Vessel and Internals Overview

February 28, 2013 (Redacted Version)

© 2013 Babcock & Wilcox mPower, Inc. All Rights Reserved. This document is the property of Babcock & Wilcox mPower, Inc. (B&W mPower)



- Objectives
- ASME Code Update
  - Key Design Features Overview
  - Component Design perspective
    - Code cases
  - Systems Design perspective
  - 48 Month Fuel Cycle Impacts on Testing and Inspections
- Reactor Vessel Update
  - Changes to support arrangement
- Reactor Internals Update
  - Core Support
  - Upper Internals
  - CRDM update
  - FIV Testing and Evaluation
- Conclusions

2

Agenda



#### **Objectives**

3

- Update the NRC staff on B&W interactions with ASME Committees
- Provide an overview of key changes to the reactor vessel and internals design and testing plans



#### ASME Code Update

© 2013 B&W mPower Inc. All rights reserved.

4



#### **Key Design Features Overview**

а и на таки на на "Каки Славани

-31,500 14 PC 141,941 4 17327 4 14 PC 14

© 2013 B&W mPower Inc. All rights reserved.



#### **B&W** mPower<sup>™</sup> Reactor





#### **B&W mPower Reactor**



7



#### **B&W mPower Reactor**



**Pressure Boundary** 



generation



#### Interactions with ASME

- mPower Reactor Overviews for ASME
  - Keep ASME informed of mPower reactor design
- Presentations
  - ASME Executive Committee on Strategy (8/11/11)
  - ASME 2011 SMR Symposium, Plenary Session (9/29/11)
  - ASME Section XI Committee (2/6/12)
  - ANSI-NIST NESCC Meeting (7/17/12)
- ASME Engagement
  - B&W mPower continues to increase participation on ASME Code committees
- Component Code Jurisdiction Established



#### Interactions with ASME (cont.)

- Anticipated Code Cases
  - Case N-782, Use of Code Editions, Addenda, and Cases Section III, Division 1
- Possible Code Cases
  - Case N-60-5, Material for Core Support Structures Section III, Division 1
  - Case N-62-7 Internal and External Valve Items, Classes 1, 2, and 3 Section III, Division 1
  - Case N-284-2 Metal Containment Shell Buckling Design Methods, Class MC Section III, Division 1
  - Case N-71-18, Additional Materials for Subsection NF, Class 1, 2, 3, and MC Supports Fabricated by Welding Section III, Division I
  - Case N-249-14 Additional Materials for Subsection NF, Class 1, 2, 3, and MC Supports Fabricated Without Welding Section III, Division 1



#### **48 Month Surveillance Cycle**



#### Background

- Regulations, Codes, Technical Specifications, etc. Stipulate a Variety of Periodic Surveillances – for Example:
  - Instrument Calibrations and Channel Checks
  - Condition (Parameter) Verifications
  - Component Operability Tests
  - Weld Examinations
  - Leak Rate Tests
  - System Functional Tests
  - Steam Generator Tube Inspections
- Current Outage Related Surveillance Frequencies Based on Standard 24-Month Fuel Cycle
- B&W mPower Reactor Designed for 48-Month Fuel Cycle



#### **Applicable Requirements**

- Technical Specifications
- ASME Section XI
- 10 CFR 50, Appendix J (Containment Leak Rate Testing)
- EPRI (Steam Generator Tube Inspection Guidelines)
- ASME O&M Code



#### **Technical Specifications**

- Safety Systems Surveillances
  - Instrument Channel Calibrations
  - Instrument Response Time Testing
  - Instrument Channel Functional Tests
  - Visual Inspections
  - Component Functional Tests
  - System Functional Tests
- Potential Path Forward



#### **ASME Section XI**

- Additional Surveillances
  - Pressure Boundary Visual and Non-Destructive Examinations
  - Component Support Visual and Non-Destructive Examinations
  - $\Rightarrow$  Typically @ 100% / 10-Years
- Potential Path Forward



#### **Containment Leak Rate Testing**

- Containment Surveillances
  - Appendix J, Option A
    - Type A (Containment Integrated Leak Rate) = 3 / 10-Years
    - Types B & C (Local Leak Rate) = Each Refueling Shutdown, Not to Exceed 2 Years
  - Appendix J, Option B (Via RG 1.163)
    - Type A ≤ 10 Years, Following Two Consecutive Successful Tests
    - Type B ≤ 10 Years, Following Two Consecutive Successful Tests
    - Type C ≤ 5 Years, Following Two Consecutive Successful Tests
- Potential Path Forward



### **Steam Generator Inspection**

#### Steam Generator Surveillances

- Typical Operating Plant Programs Are Based on Inspecting 33% of Tubes Every 24 EFPM or Each Refueling Outage (Whichever Occurs First), Such that 100% of Tubes Are Inspected Every 60 EFPM
- Current EPRI Guidelines for Replacement Steam Generators Require Inspection of 100% of Tubes at First Refueling Outage following SG Replacement (Within 18-24 EFPM of SG Replacement), then 100% of Tubes Sequentially Thereafter at 144, 108, 72 and 60 EFPM
- Potential Path Forward



# ASME O&M

- Additional Surveillances
  - Pump and Valve Testing
  - Snubber Testing
  - Risk-Informed Inservice Inspections

 $\Rightarrow$  Complex Frequency Specifications

Potential Path Forward



#### Conclusion

20

B&W mPower Reactor 48-Month Surveillance Cycle Is Consistent with Current Practice and Requirements, with Limited Exceptions:

- Some Standard TS 24-Month Intervals  $\Rightarrow$  48-Months
- Some ASME O&M Code Changes (TBD)



#### **Reactor Vessel Update**



#### **B&W mPower Reactor**

22

| Design Chara       | acteristics           |
|--------------------|-----------------------|
| Reactor Type       | PWR                   |
| Core Outlet        | 530 MWt               |
| Reactor Height     |                       |
| Reactor Diameter   | 13ft (At the Flanges) |
| Reactor Dry Weight |                       |
| Fuel Cycle         | 4 Years               |
| Design Life        | 60 Years              |
| RCP Quantity       | 8                     |
| Rail Shippable     | Factory built         |

#### **Reactor Component Breakdown**





#### **Lower Vessel**





#### **Lower Reactor Vessel Support**

Vessel support arrangement [

- Improved ease of fabrication / cost reduction
- Improved ease of installation
- Preferable seismic responses
- Inclusion of additional [ enables revised arrangement

#### **Upper Reactor Vessel Support**

#### **Lower Reactor Vessel Support**



© 2013 B&W mPower Inc. All rights reserved.

27



#### **Reactor Internals Update**

#### **Reactor Component Breakdown**





#### **Core Support Structure**







#### **In-core Detector Testing**





#### **mPower Upper Internals**

33



generation

### *mPower* Control Rod Drive Mechanism Update

- [ ] Control Rod Drive Mechanism
  - 69 internal CRDMs, [ ] inches of stroke
- [ ] latching mechanism
- High temperature motor
- Lead screw [

• [

l

Overall Mechanism Fully Inserted

© 2013 B&W mPower Inc. All rights reserved.

1

35



Overall Mechanism Fully Withdrawn

© 2013 B&W mPower Inc. All rights reserved.

]





Latching System Fully Inserted - Disengaged ]



[

1



Latching System Fully Withdrawn

© 2013 B&W mPower Inc. All rights reserved.

39

Latching System

Fully Scrammed

© 2013 B&W mPower Inc. All rights reserved.

40



• [

#### **CRDM Program Status**

#### **CRDM** Testing

4 4 4

42



#### **CRDM** Testing

ſ

© 2013 B&W mPower Inc. All rights reserved.

L

43

#### **CRDM Testing**<sup>[</sup>

@ 2013 B&W mPower Inc. All rights reserved.

- - n -<sup>2</sup>, w man - e- <sup>2</sup>

]



#### **FIV Evaluation and Testing**

© 2013 B&W mPower Inc. All rights reserved.

45



# **FIV Evaluation and Testing**

#### FIV Evaluation and Testing Approach

- Conform to RG 1.20
- Design with FIV in mind
- Analytical evaluation
  - CFD prediction of velocity distribution
  - B&W FIV codes
  - Commercial structural codes + manual calculations
- Test Program
  - Test at increasingly prototypical conditions
  - Vessel model flow tests
  - FOAK reactor instrumentation
- Comprehensive program document is being written
- Generally, FIV is less an issue in mPower because of lower coolant velocities
- Plan to engage industry FIV experts



.

>

#### **FIV Related Testing**

- Integral Control Rod Drive Line (ICRDL)
  - Increasingly prototypical test conditions
- Vessel model flow tests
  - Primarily to validate CFD predictions
- FOAK Reactor Instrumentation
  - Accelerometers, strain gauges, etc. installed in first reactor for hot functional testing



#### **ICRDL Test Program**





#### **ICRDL Test Program**



#### **Static Test Facility**



#### Cold Flow Test Loop (CFTL)

51





#### **Autoclave 3 Test Facility**





#### Hot Flow Test Loop (HFTL)



#### **Component Test Locations**

| Location  | Testing  | D/(                         |
|---|--|-----------------------------|
| Barberton, OH<br>• Cold Flow Test Loop<br>• Small autoclaves<br>• Vessel Model Flow<br>• Hot Flow Test Loop (tentative) | <ul> <li>Penetrations / Connectors</li> <li>ICRDL Test Program</li> <li>Fuel assembly hydraulic<br/>testing</li> <li>In-core insertion testing</li> </ul>  | Barberton, OH<br>Euclid, OH |
| Euclid, OH<br>• Large autoclaves (Air & Hot Tests)  | <ul> <li>CRDM Motor and Latch</li> <li>ICRDL Test Program</li> <li>ICRDL life &amp; wear testing</li> <li>Fuel assembly life &amp; wear testing</li> </ul> |                             |
| Lynchburg, VA<br>• Static Test Facility<br>• Fuel Assembly mechanical test<br>system<br>• Instron & Fixtures            | <ul> <li>ICRDL Test Program</li> <li>Fuel assembly and component mechanical testing</li> <li>Integrated Systems</li> </ul>                                 | Lynchburg, VA               |
| • CAER - Integrated System Testing (IST)  | Operational simulations  |                             |



#### Vessel Model Flow Test (VMFT) Program

| Lower Vessel<br>Model Flow Test<br>Program | •   | ſ | uitial Planning Stage | Barberton Researc                     |
|--|-----|---|-----------------------|---------------------------------------|
|  |     |   |                       | Center or Vendor                      |
| Upper Vessel<br>Model Flow Test<br>Program | •[  |   | nitial Planning Stage | Barberton Researc<br>Center or Vendor |
|  | REC |   |                       |                                       |
|  |     |   |                       |                                       |



#### **B&W VMFT History**

- B&W 177 and 205 VMFT facilities existed at the Alliance Research Center
- 1/6<sup>th</sup> geometrically scaled model of the B&W 177 and 205 PWRs
- 2-2,000 GPM pumps used giving a total flow capacity of 4,000 GPM @ a total head of 350 feet
- Extensive testing conducted: Gross Flow Distribution, Pressure Drop, FIV, Gross Mixing of Fluid Entering Core, Vent Valve Closing Forces
- Testing started ~1968 and ended ~1980
- Unit decommissioned after the B&W 205 program ended



generation

#### **VMFT Focus Areas**

#### Pump Plenum Area

- First of a Kind Design
- Verification of Computational Fluid Dynamic (CFD) model flow characteristics
- Verification of anticipated pressure drops in the area
  - Instrumentation type and location in vessel

#### Lower Vessel Assembly

- First of a Kind Design
- Verification of Computational Fluid Dynamic (CFD) model flow characteristics.
- Verification of anticipated pressure drops in the area
- Identification of areas of interest in regards to Flow Induced Vibrations (FIV)
- Instrumentation type and location in vessel

© 2013 B&W mPower Inc. All rights reserved.



### Conclusions

- B&W ASME Interfaces Active and Focused
- Vessel and Internals Design Progress Progressing as Planned
- Key Testing has been Identified, Prioritized and Plans are Active