

OUTLINE SUBMISSION AND OPERATING TEST COMMENTS

1	JPM Admin RO 1. Look at the parts marked non-critical. Shouldn't these be critical? Change Terminating Cue to ...examinee states he has completed his review of the proposed schedule.	Determined the writeup was correct. Last button was the critical portion of the JPM.
2	Control Room JPM g.: "Bulk D/W Temperature Manual Calculation," appears to be an admin JPM. Verify at on-site validation.	After validation, the JPM was replaced. NRC determined the proposed JPM was an admin JPM.
3	Scenario 2, Event 4, a low condenser vacuum switch will fail with RPS failing to inset a ½ scram. The OATC will need to insert a ½ scram and the CRS will address Technical Specifications. The SRO may not implement the action statement until the time clock has expired. Replace if necessary	Replaced scenario event with an event involving APRMs. This new event required the SRO to insert a ½ scram so the RO could get the required event.