

Tier / Group	Randomly Selected K/A	Reason for Rejection
RO PORTION		
1/1	295005 AK3.02	Not applicable to MNGP. A recirculation pump trip does not occur when a main turbine trip occurs. Reselected AK3.08 which was also rejected because it only applies to a BWR-2 unit. Reselected AK3.07.
1/1	295021 2.2.4	Not applicable to MNGP. Dual unit K/A only. Reselected 2.2.36.
1/1	295028 EA2.06	MNPG do not have a means of monitoring Torus air space temperature. Rejected EA2.06 and reselected EA2.03.
1/1	295006 AA1.03	Rejected to prevent double jeopardy with RO question #4 (295005 AK3.07). Reselected AA1.02.
1/2	295034 EK3.01	Rejected the 295034 E/APE due to double jeopardy with question 18 (295038 EK3.03) and question 24 (295033 EK2.04). Reselected 295020 AK3.05.
2/1	205000 K6.06	Not applicable to MNGP and low importance rating (<2.5). Reselected K6.04.
2/1	211000 A3.05	MNGP does not have SLC flow indication in the control room. Reselected A3.04.
2/1	212000 A4.03	MNGP does not have the ability for manual select rod insertion as it relates to RPS. Reselected A4.05
2/1	223002 K5	No K5 K/As exist for this topic. Reselected K6 for Tier/Group balance and reselected K6.04.
2/1	259002 A1.06	MNGP does not use FWCI. Reselected A1.01.
2/1	261000 A2.12	MNGP does not utilize fuel pool ventilation radiation monitors. Reselected A2.04.
2/1	263000 2.2.39	There are no ≤ 1 hour technical specification actions associated with the DC distribution system. Reselected 2.1.28.
2/1	215003 2.4.35	MNGP does not have local auxiliary operator tasks performed in an emergency associated with the IRM system. Reselected 2.2.38.
2/1	264000 K2	K2 K/As for this topic all have low importance rating (<2.5). Reselected K5 for Tier/Group balance and reselected K5.06.
2/2	201003 K2	No K2 K/As exist for this topic. Reselected K1 for Tier/Group balance and reselected K1.02.
2/2	215001 K6.03	Low importance rating (<2.5). Reselected K6.04.

Tier / Group	Randomly Selected K/A	Reason for Rejection
2/2	233000 A1.05	Low importance rating (<2.5). Reselected A1.07.
3	Generic 2.2.5	Low importance rating (<2.5). Reselected 2.2.2.
3	Generic 2.3.6	Low importance rating (<2.5). Reselected 2.3.15.

SRO PORTION		
1/1	295021 AA2.05	Unable to write operationally valid SRO-ONLY question specific to reactor vessel metal temperatures as it relates to a loss of shutdown cooling. Reselected AA2.04.
1/1	295030 EA2.04	Rejected the 295030 topic as all EA2 K/As would result in an SRO ONLY question similar to the previous question in the 295026 topic. This could result in a potential double jeopardy or question compromise situation. Reselected 600000 AA2.16.
½	295012 2.4.9	Rejected 2.4.9 due to the inability to write a question specific to low power / shutdown conditions as it applies to high drywell temperature. Reselected 2.1.25.
2/1	262002 A2.04	Not applicable to MNGP. BWR-1 only. Reselected A2.01.
2/2	201001 A2	Rejected the 201001 topic. Unable to write SRO ONLY question that is operationally valid and that contains all plausible distracters. Reselected 202001 A2.06