



Omaha Public Power District

444 South 16th Street Mall

Omaha, NE 68102-2247

LIC-13-0022

February 28, 2013

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

- References:
1. Docket No. 50-285
 2. Letter from OPPD (D. J. Bannister) to NRC Document Control Desk (DCD) dated August 6, 2012 (LIC-12-0117)

Subject: Withdrawal of Licensee Event Report 2012-011, Revision 0, for the Fort Calhoun Station

By letter dated August 6, 2012, Omaha Public Power District (OPP) submitted Licensee Event Report (LER) 2012-011, Revision 0, "Emergency Diesel Inoperability Due to Bus Loads During a LOOP," for the Fort Calhoun Station (FCS). A vendor study of peak current due to dead load pickup has determined that the FCS emergency diesel generators are capable of performing their design function even if non-safety related contactors are not credited for isolating power to associated loads. As a result, OPPD is withdrawing LER 2012-011 and this number will not be reused.

No commitments are being made in this letter.

If you should have any questions, please contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "LPC", is written over a white background.

Louis P. Cortopassi
Site Vice President and CNO

LPC/EPM

Attachment

- c: E. E. Collins, Jr., NRC Regional Administrator, Region IV
L. E. Wilkins, NRC Project Manager
J. C. Kirkland, NRC Senior Resident Inspector