

4

3

2

1

SPEC.	TYPE	PROD. ORDER	P.O. QUAN.	SCHEDULE DATE
REVISIONS				
ZONE	SYM	DESCRIPTION	DATE	APPROVED

8 POINT HELVETICA ROMAN

3.00

10 PT HELVETICA
BOLD

CAUTION: CONTAINS RADIOACTIVE MATERIAL
AMERICIUM 241 1.0 μ Ci
FOR REPAIR OR DISPOSAL OF DETECTOR RETURN TO
SQUARE D CO. OR ITS AUTHORIZED REPRESENTATIVE

INSTALL PER THE EGD-4S OPERATION AND INSTAL-
LATION MANUAL AND NFPA STANDARD 74. AVAILABLE
FOR A NOMINAL CHARGE FROM NFPA. 470 ATLANTIC
AVE, BOSTON MASS. 02210

Earli-Gard®

SINGLE STATION SMOKE DETECTOR

CATALOG NUMBER EGD-4S

120 VAC 60 HZ 12 WATTS MAX

PUSHING TEST BUTTON PERFORMS A CIRCUIT TEST
WHEN INSTALLING ROUTE WIRING AWAY FROM SHARP
PROJECTIONS, EDGES AND INTERNAL COMPONENTS. CON-
NECT THE WHITE LEAD TO THE POWER CIRCUIT "NEU-
TRAL" AND THE BLACK LEAD TO THE CIRCUIT "HOT" WIRE.

SQUARE D COMPANY

MADE IN U.S.A.

DO NOT REMOVE THIS LABEL 63060-049-01

88

SEE NOTE 1

8 PT HELVETICA
ROMAN10 PT HELVETICA
BOLD8 PT HELVETICA
ROMAN

SEE NOTE 1

8 PT HELVETICA
ROMAN

NOTES:

1-ART FOR SQUARE D COMPANY AND EARLI-GARD
TO BE SUPPLIED BY SQUARE D COMPANY.

2-UNLESS OTHERWISE SPECIFIED ALL CHARACTERS
ARE 6 PT HELVETICA ROMAN.

3-CHARACTERS TO BE BLACK ON WHITE FASSON
LITHO PRESSURE SENSITIVE PAPER LABEL
STOCK OR EQUAL ALL MATERIALS TO BE UL
RECOGNIZED

NOV 28 1977

PART NO. 63060-049-01

e ELECTROMAGNETIC INDUSTRIES, INC.
CLEARWATER FLORIDA
SUBSIDIARY OF SQUARE D COMPANY

LABEL, SMOKE DETECTOR
EGD-4S

CODE IDENT. NO.	SIZE	DWG. NO.
12670	C	63060-049
SCALE 2/1	WT	SHEET 1 OF 1

UNLESS OTHERWISE SPECIFIED
DIMENSIONS ARE IN INCHES
TOLERANCES FRACTIONAL $\pm$
ANGLES $\pm$
3 PLACE DECIMALS $\pm$
2 PLACE DECIMALS $\pm$.02

AUTHENTICATION

NAME DATE

DRAWN BY C. Danner 11-7-77

CHECKED BY

APPROVED BY

PROJECT ENGINEER 11-22-77

MATERIAL

SEE NOTE 3

FINISH

EGD-4S
NEXT ASS'Y USED ON
APPLICATION