

2.1.4 Radioactive Waste Building

Design Description

1.0 System Description

The Radioactive Waste Building (RWB) is a reinforced concrete structure that houses non-safety related liquid waste storage tanks, storage facilities, and associated support systems required for normal power operation. There are no SSC required for safe shutdown in the RWB. The RWB is located adjacent to the Nuclear Auxiliary Building (NAB) as shown on Figure 2.1.4-1. Information in tables and figures in this section are for information only with the exception of the specific features listed in the ITAAC for verification.

2.0 Arrangement

2.1 The basic configuration of the RWB is shown on Figure 2.1.4-1—Radioactive Waste Building Location.

3.0 Mechanical Design Features

3.1 Separation is provided between the RWB and EPGB 3/4 as shown on Figure 2.1.4-1 to preclude interaction between the RWB and EPGB 3/4.

3.2 The RWB is a Radwaste Seismic (RW-IIa) structure and will withstand a seismic design basis load of $\frac{1}{2}$ SSE without loss of structural integrity.

Inspections, Tests, Analyses, and Acceptance Criteria

Table 2.1.4-1 lists the RWB ITAAC.

Table 2.1.4-1—Radioactive Waste Building ITAAC

	Commitment Wording	Inspections, Tests, Analyses	Acceptance Criteria
2.1	The basic configuration of the RWB is shown on Figure 2.1.4-1.	An inspection of the basic configuration of the as-built RWB will be performed.	The basic configuration of the RWB is as shown on Figure 2.1.4-1.
3.1	Separation is provided between the RWB and EPGB 3/4 as shown on Figure 2.1.4-1 to preclude interaction between the RWB and EPGB 3/4.	An inspection will be performed to verify the as-built physical separation between the RWB and EPGB 3/4.	The RWB is separated from EPGB 3/4 as shown on Figure 2.1.4-1. A minimum separation distance of 49.5 ft exists between the RWB and EPGB 3/4.
3.2	The RWB is a RW-IIa structure and will withstand a seismic design basis load of ½ SSE without loss of structural integrity.	An inspection and analysis will be performed to verify the as-built RWB will withstand the design basis load of ½ SSE without loss of structural integrity.	A report concludes that the RWB will withstand the design basis load of ½ SSE without loss of structural integrity.