

Table 7.1-2—I&C System Requirements Matrix
Sheet 1 of 7

Applicable Regulations and Guidance	50.55a(a)(1)	10 CFR 50									
		IEEE Std 603-1991 (1)(2)	50.55a(h)(3)	50.34(f)(2)(v)	50.34(f)(2)(xi)	50.34(f)(2)(xii)	50.34(f)(2)(xiv)	50.34(f)(2)(xvii)	50.34(f)(2)(xviii)	50.34(f)(2)(xix)	50.34(f)(2)(xx)
Industry Standard											
Safety Information and Control System (S)	x	x		x	x		x	x	x	x	x
Process Information and Control System (NS-AQ)			x	x	x		x	x	x	x	
Protection System (S)	x	x	x		x	x		x		x	
Safety Automation System (S)	x	x	x								
Priority and Actuator Control System (S)	x	x	x	x	x	x				x	x
Reactor Control, Surveillance & Limitation System (NS)											
Process Automation System (NS)			x	x	x		x	x	x		
Turbine Generator I&C (NS)											
Control Rod Drive Control System (NS)	x	x	x								
Incore Instrumentation System (S)	x	x	x					x	x		
Excore Instrumentation System (S)	x	x	x						x		
Boron Concentration Measurement System (S)	x	x	x						x		
Radiation Monitoring System (S)	x	x	x			x	x		x		
Hydrogen Monitoring System (NS-AQ)	x	x	x				x		x		
Reactor Pressure Vessel Level Measurement System (NS-AQ)	x	x	x					x	x		
Seismic Monitoring System (NS)											
Loose Parts Monitoring System (NS)											
Vibration Monitoring System (NS)											
Fatigue Monitoring System (NS)											
Leak Detection System (NS)											
Signal Conditioning and Distribution System (S)	x	x	x		x	x	x	x	x	x	x
Diverse Actuation System (NS-AQ)											x
Rod Position Measurement System (S)	x	x									

Table 7.1-2—I&C System Requirements Matrix
Sheet 2 of 7

Notes on Tables 7.1–2; Sheet 1 of 7:

1. With correction sheet dated January 30, 1995.
2. The U.S. EPR uses IEEE Std 603-1998, which meets or exceeds the requirements of IEEE Std 603-1991.

Table 7.1-2—I&C System Requirements Matrix
Sheet 3 of 7

Applicable Regulations and Guidance	General Design Criteria											
	GDC 1	GDC 2	GDC 4	GDC 10	GDC 13	GDC 15	GDC 16	GDC 19	GDC 20	GDC 21	GDC 22	GDC 23
Industry Standard												
Safety Information and Control System (S)	x	x	x		x			x				
Process Information and Control System (NS-AQ)					x			x				
Protection System (S)	x	x	x	x	x	x	x	x	x	x	x	x
Safety Automation System (S)	x	x	x	x	x							
Priority and Actuator Control System (S)	x	x	x	x	x	x	x	x	x	x	x	x
Reactor Control, Surveillance & Limitation System (NS)				x	x	x						
Process Automation System (NS)				x	x	x		x				
Turbine Generator I&C (NS)					x			x				
Control Rod Drive Control System (NS)	x	x	x	x	x			x				
Incore Instrumentation System (S)	x	x	x	x	x			x	x	x	x	x
Excore Instrumentation System (S)	x	x	x	x	x			x	x	x	x	x
Boron Concentration Measurement System (S)	x	x	x	x	x			x	x	x	x	x
Radiation Monitoring System (S)	x	x	x		x			x	x	x	x	x
Hydrogen Monitoring System (NS-AQ)	x	x	x		x			x				
Reactor Pressure Vessel Level Measurement System (NS-AQ)	x	x	x		x			x				
Seismic Monitoring System (NS)		x			x			x				
Loose Parts Monitoring System (NS)					x			x				
Vibration Monitoring System (NS)					x			x				
Fatigue Monitoring System (NS)					x			x				
Leak Detection System (NS)		x			x			x				
Signal Conditioning and Distribution System (S)	x	x	x	x	x	x	x	x	x	x	x	x
Diverse Actuation System (NS-AQ)					x							
Rod Position Measurement System (S)	x	x	x	x	x			x	x	x	x	x
Notes:												

Table 7.1-2—I&C System Requirements Matrix
Sheet 4 of 7

	General Design Criteria										SRM to SECY 93-087	
	GDC 24	GDC 25	GDC 28	GDC 29	GDC 33	GDC 34	GDC 35	GDC 38	GDC 41	GDC 44	II.Q	II.T
Applicable Regulations and Guidance												
Industry Standard												
Safety Information and Control System (S)											x	x
Process Information and Control System (NS-AQ)												x
Protection System (S)	x	x	x	x	x	x	x	x	x	x		
Safety Automation System (S)					x	x	x	x		x		
Priority and Actuator Control System (S)	x	x			x	x	x	x	x	x	x	
Reactor Control, Surveillance & Limitation System (NS)			x	x								
Process Automation System (NS)			x									
Turbine Generator I&C (NS)												
Control Rod Drive Control System (NS)			x	x								
Incore Instrumentation System (S)	x	x			x							
Excore Instrumentation System (S)	x	x			x							
Boron Concentration Measurement System (S)	x	x		x								
Radiation Monitoring System (S)	x	x		x								
Hydrogen Monitoring System (NS-AQ)												
Reactor Pressure Vessel Level Measurement System (NS-AQ)												
Seismic Monitoring System (NS)												
Loose Parts Monitoring System (NS)												
Vibration Monitoring System (NS)												
Fatigue Monitoring System (NS)												
Leak Detection System (NS)												
Signal Conditioning and Distribution System (S)	x	x	x	x	x	x	x	x	x		x	
Diverse Actuation System (NS-AQ)											x	
Rod Position Measurement System (S)	x	x		x								
Notes:												

Table 7.1-2—I&C System Requirements Matrix
Sheet 5 of 7

Applicable Regulations and Guidance	Regulatory Guides																
	1.22	1.47	IEEE Std 379-2000	1.53	1.62	IEEE Std 384-1992	1.75	IEEE Std 497-2002	1.97	ISA-67-04- 1994(1)	1.105	IEEE Std 338-1987	1.118	ISA-S67.02- 1980	1.151	IEEE Std 7-4.3.2-2003	1.152
Industry Standard																	
Safety Information and Control System (S)	x		x	x	x	x		x			x	x			x		x
Process Information and Control System (NS-AQ)		x						x									
Protection System (S)	x	x	x	x	x	x		x	x	x	x	x	x	x	x	x	
Safety Automation System (S)		x	x	x		x										x	
Priority and Actuator Control System (S)	x	x	x	x	x	x		x			x						
Reactor Control, Surveillance & Limitation System (NS)													x				
Process Automation System (NS)		x						x					x		x		
Turbine Generator I&C (NS)																	
Control Rod Drive Control System (NS)	x	x	x	x	x	x											
Incore Instrumentation System (S)	x	x	x			x		x		x							
Excore Instrumentation System (S)	x	x	x			x		x									
Boron Concentration Measurement System (S)	x	x	x			x		x									
Radiation Monitoring System (S)	x	x	x			x		x		x							
Hydrogen Monitoring System (NS-AQ)		x	x			x		x		x				x			
Reactor Pressure Vessel Level Measurement System (NS-AQ)		x	x			x		x		x							
Seismic Monitoring System (NS)																	
Loose Parts Monitoring System (NS)																	
Vibration Monitoring System (NS)																	
Fatigue Monitoring System (NS)																	
Leak Detection System (NS)																	
Signal Conditioning and Distribution System (S)	x	x	x			x		x		x		x	x	x	x		
Diverse Actuation System (NS-AQ)																	
Rod Position Measurement System (S)	x	x	x			x		x		x						x	

Notes: on Table 7.1-2; Sheet 5 of 7

1. U.S. EPR follows ISA-67.04.01-2006.

Table 7.1-2—I&C System Requirements Matrix
Sheet 6 of 7

Applicable Regulations and Guidance	Regulatory Guides									
	IEEE Std 1012-1998 IEEE Std 1028-1997 1.168	IEEE Std 828-1990 IEEE Std 1042-1987 1.169	IEEE Std 829- 1983 1.170	IEEE Std 1008-1987 1.171	IEEE Std 830- 1993 1.172	IEEE Std 1074-1995 1.173	Various Standards 1.180	1.189	IEEE Std 1050-1996 1.204	IEEE Std 323-2003 1.209
Industry Standard										
Safety Information and Control System (S)	x	x	x	x	x	x	x	x	x	x
Process Information and Control System (NS-AQ)								x		
Protection System (S)	x	x	x	x	x	x	x	x	x	x
Safety Automation System (S)	x	x	x	x	x	x	x		x	x
Priority and Actuator Control System (S)							x	x	x	
Reactor Control, Surveillance & Limitation System (NS)										
Process Automation System (NS)								x		
Turbine Generator I&C (NS)										
Control Rod Drive Control System (NS)							x		x	
Incore Instrumentation System (S)							x		x	
Excore Instrumentation System (S)							x	x	x	
Boron Concentration Measurement System (S)							x		x	
Radiation Monitoring System (S)							x		x	
Hydrogen Monitoring System (NS-AQ)							x		x	
Reactor Pressure Vessel Level Measurement System (NS-AQ)							x		x	
Seismic Monitoring System (NS)										
Loose Parts Monitoring System (NS)										
Vibration Monitoring System (NS)										
Fatigue Monitoring System (NS)										
Leak Detection System (NS)										
Signal Conditioning and Distribution System (S)							x	x	x	
Diverse Actuation System (NS-AQ)										
Rod Position Measurement System (S)	x	x	x	x	x	x	x		x	x
Notes:										

Table 7.1-2—I&C System Requirements Matrix
Sheet 7 of 7

	Branch Technical Positions																	
	7-1	7-2	7-3	7-4	7-5	7-8	7-9	7-10	7-11	7-12	7-13	7-14	7-17	7-18	7-19	7-21		
Applicable Regulations and Guidance																		
Industry Standard																		
Safety Information and Control System (S)		x				x		x	x			x		x	x	x		
Process Information and Control System (NS-AQ)		x						x										
Protection System (S)	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x		
Safety Automation System (S)									x			x	x	x	x	x	x	
Priority and Actuator Control System (S)	x	x		x		x		x	x				x		x		x	
Reactor Control, Surveillance & Limitation System (NS)					x													
Process Automation System (NS)									x									
Turbine Generator I&C (NS)																		
Control Rod Drive Control System (NS)					x					x								
Incore Instrumentation System (S)						x			x	x								
Excore Instrumentation System (S)						x			x	x								
Boron Concentration Measurement System (S)						x			x	x								
Radiation Monitoring System (S)						x			x	x								
Hydrogen Monitoring System (NS-AQ)									x	x								
Reactor Pressure Vessel Level Measurement System (NS-AQ)									x	x								
Seismic Monitoring System (NS)																		
Loose Parts Monitoring System (NS)																		
Vibration Monitoring System (NS)																		
Fatigue Monitoring System (NS)																		
Leak Detection System (NS)																		
Signal Conditioning and Distribution System (S)	x	x		x	x	x	x	x	x	x	x	x		x				
Diverse Actuation System (NS-AQ)														x				
Rod Position Measurement System (S)					x			x	x			x	x	x	x	x	x	
Notes:																		