

March 19, 2013

Mr. Peter W. Smith, Director
Nuclear Development
Licensing and Engineering
337 WCB
DTE Electric Company¹
One Energy Plaza
Detroit, MI 48226-1221

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 84 RELATED TO
CHAPTERS 01.05 FOR THE FERMI 3 COMBINED LICENSE APPLICATION

Dear Mr. Smith:

By letter dated September 18, 2008, Detroit Edison Company (Detroit Edison¹) submitted for approval a combined license application pursuant to Title 10 of the *Code of Federal Regulations* (10 CFR) Part 52. The U.S. Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter. In order to minimize delays to the current licensing schedule, we request that you respond within 30-days of receipt of this RAI.

If changes are needed to the safety analysis report, the staff requests that the RAI response include the proposed wording changes. If you have any questions or comments concerning this matter, I can be reached at 301-415-6197 or by e-mail at tekia.govan@nrc.gov.

Sincerely,

/RA Michael Eudy for/

Tekia Govan, Project Manager
Licensing Branch 3
Division of New Reactor Licensing
Office of New Reactors

Docket No.: 052-033

eRAI Tracking No. 7046 and 7051

Enclosure: Request for Additional Information

¹On December 21, 2012, the Detroit Edison company sent the NRC a letter indicating that, effective January 1, 2013, the name of the company would be changed to "DTE Electric Company." The legal entity will remain the same (see ML12361A437).

Mr. Peter W. Smith, Director
Nuclear Development
Licensing and Engineering
337 WCB
DTE Electric Company
One Energy Plaza
Detroit, MI 48226-1221

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 82 RELATED TO
CHAPTERS 01.05 FOR THE FERMI 3 COMBINED LICENSE APPLICATION

Dear Mr. Smith:

By letter dated September 18, 2008, Detroit Edison Company (Detroit Edison) submitted for approval a combined license application pursuant to Title 10 of the *Code of Federal Regulations* (10 CFR) Part 52. The U.S. Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter. In order to minimize delays to the current licensing schedule, we request that you respond within 30-days of receipt of this RAI.

If changes are needed to the safety analysis report, the staff requests that the RAI response include the proposed wording changes. If you have any questions or comments concerning this matter, I can be reached at 301-415-6197 or by e-mail at tekia.govan@nrc.gov.

Sincerely,

/RA Michael Eudy for/

Tekia Govan, Project Manager
Licensing Branch 3
Division of New Reactor Licensing
Office of New Reactors

Docket No.: 052-033

eRAI Tracking No.: 7046 and 7051

Enclosure:
Request for Additional Information

DISTRIBUTION:

PUBLIC BWR R/F
RidsNroDnrlLb3 RidsNroDnrl

ADAMS Accession No.: ML

NRO-002

OFFICE	TR: DSRA/BPFP	TR: DSRA/BPFP	BC: DSRA/BPFP	OGC	LPM: DNRL/LB3	PM: DNRL/LB3
NAME	RHernandez	AStubbs	SLee	MCarpentier	AMuniz	TGovan
DATE	02/28/2013	02/28/2013	02/28/2013	03/08/2013	03/18/2013	03/18/2013

*Approval captured electronically in the electronic RAI system.

OFFICIAL RECORD COPY

Request for Additional Information 84

Issue Date: 3/18/2013

Application Title: Fermi Unit 3 - Docket Number 52-033

Operating Company: Detroit Edison

Review Section: 01.05 - Other Regulatory Considerations

QUESTIONS

01.05-5

Three-Phase Approach for Mitigating Beyond-Design-Basis External Events

For operating plants the NRC issued order EA-12-049, Order Modifying Licenses with Regard to Requirements for Mitigation Strategies for Beyond-Design-Basis External Events. The order included a requirement to implement a three-phase approach that enables mitigation assuming loss of all AC power for an indefinite period. The first phase (initial phase) requires the use of installed equipment and resources to maintain or restore core cooling, containment, and spent fuel pool cooling. The second phase (transition phase) requires providing sufficient, portable, equipment and consumables to maintain or restore these functions on site until they can be accomplished with resources brought from off site. The third phase (final phase) allows for offsite assistance.

The new requirements were put into place to provide greater assurance that the plant could cope with the challenges posed by beyond-design-basis external events by incorporating into the plant design and operation greater mitigation capabilities consistent with the overall defense-in-depth philosophy.

1. Describe how the initial and transition phase mitigation is accomplished for Fermi 3. Include a discussion of how installed equipment and resources are used for core, containment, and spent fuel cooling to provide Fermi 3 the ability to cope without power until offsite resources and assistance are available (final phase).
2. Define the site-specific FLEX capabilities, identify what type of FLEX equipment will be used and when it will be required. Also discuss the connection points incorporated in the Fermi 3 design that will allow for use of the FLEX equipment.
3. Revise the FSAR to provide a summary of how Fermi 3 accomplishes core, containment, and spent fuel cooling prior to availability of offsite assistance without any AC power or makeup to the UHS (Initial and transition phase), and how Fermi 3 will maintain core, containment, and spent fuel cooling for an indefinite period of time (final phase).

Enclosure

Request for Additional Information 84

Issue Date: 3/18/2013

Application Title: Fermi Unit 3 - Docket Number 52-033

Operating Company: Detroit Edison

Review Section: 01.05 - Other Regulatory Considerations

QUESTIONS

01.05-6

For operating plants the NRC issued order EA-12-051, "*Order Modifying Licenses with Regard to Reliable Spent Fuel Pool Instrumentation*" (ML12054A679). The order included a requirement to provide safety enhancements in the form of reliable spent fuel pool instrumentation for beyond-design-basis external events. On August 29, 2012 the staff published Interim Staff Guidance JLD-ISG-2012-03, "Compliance with Order EA-12-051, Reliable Spent Fuel Pool Instrumentation." This ISG endorses, with exceptions, the methodologies described in the industry guidance document, Nuclear Energy Institute (NEI) 12-02, Industry Guidance for Compliance with NRC Order EA-12-051, "To Modify Licenses with Regard to Reliable Spent Fuel Pool Instrumentation" (NEI 12-02), Revision 1 dated August, 2012.

In response to the staff's RAI 1.5-4, the applicant proposed to create a license condition to address the instruments requirements that were not explicitly addressed by the ESBWR DCD. The staff determined that compliance with Order EA-12-051 must be addressed in greater detail prior to licensing to determine how each of the Order's instrument requirements are addressed or not addressed by the existing ESBWR DCD information, and to propose changes to the FERMI COL FSAR that address the required instrument design information that is not explicitly addressed in the ESBWR DCD.

Therefore, the staff requests the applicant to:

- a. Provide a description of how the SFP level instruments design information provided in the ESBWR DCD addresses or does not address the design criteria requirements described in Order EA-12-051, for reliable instrumentation able to withstand design-basis natural phenomena and monitor spent fuel pool water level, and
- b. Provide a description, including proposed FSAR changes, explaining how the FERMI COL FSAR will address the design criteria requirements for SFP instrumentation described in Order EA-12-051, for reliable instrumentation able to withstand design-basis natural phenomena and monitor spent fuel pool water level, that were not completely addressed by the ESBWR DCD design information.