

# Background

- LaSalle ISFSI pad seismic dynamic load
  - Evolving SSL analysis approach
  - HI-STORM 100 casks deployment configuration
  - Holtec informed the staff of the proposed ISFSI pad SSL analysis approach (07/12/12)



## Holtec Request for Guidance

- Holtec 07/19/12 letter
  - Essentials of the ISFSI pad qualification requirements per the FSAR
  - 11 elements outlined
- Staff comments on Holtec request (10/26/12)
  - 7 out of 11 elements technically consistent with the staff positions
  - Elements 4, 6, 7, and 10 require additional Holtec characterization