Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
US-APWR Subcommittee: Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Thursday, February 21, 2013

Work Order No.: NRC-3096 Pages 1-356

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

MEETING OF THE US-APWR SUBCOMMITTEE

+ + + + +

THURSDAY

FEBRUARY 21, 2013

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear Regulatory Commission, Two White Flint North, Room T2B1, 11545 Rockville Pike, at 8:30 a.m., John W. Stetkar, Chairman, presiding.

COMMITTEE MEMBERS:

JOHN W. STETKAR, Subcommittee Chairman

J. SAM ARMIJO, Member

DENNIS C. BLEY, Member

CHARLES H. BROWN, JR. Member

JOY REMPE, Member

STEPHEN P. SCHULTZ, Member

WILLIAM J. SHACK, Member

NRC STAFF PRESENT:

GIRIJA SHUKLA, Designated Federal Official

C-O-N-T-E-N-T-S

C-O-N-T-E-N-T-S (CONTINUED)

C-O-N-T-E-N-T-S (CONTINUED)

C-O-N-T-E-N-T-S (CONTINUED)

P R O C E E D I N G S

8:31 a.m.

CHAIRMAN STETKAR: The meeting will come to order.

This is a meeting of the United States Advanced Pressurized Water Reactor Subcommittee. I am John Stetkar, Chairman of the Subcommittee.

Members in attendance are Steve Schultz, Dennis Bley, Sam Armijo, Bill Shack, Charlie Brown, and Joy Rempe.

Mr. Girija Shukla of the ACRS staff is the Designated Federal Official.

The Subcommittee will discuss the US-APWR Design Certification Document and the Comanche Peak Combined License Application, Chapter 17, "Quality Assurance and Reliability Assurance," and Chapter 19, "Probabilistic Risk Assessment and Severe Accident Evaluation". The Subcommittee will also discuss Combined License Application Chapter 16, "Technical Specifications" and the loss of large areas of the plant due to explosions or fires related to the Comanche Peak Combined License Application.

We will hear presentations from Mitsubishi Heavy Industries, Luminant Generation Company, and the NRC staff.

We have received no written comments or requests for time to make oral statements from the public regarding today's meeting.

The Subcommittee will gather information, analyze relevant issues and facts, and formulate proposed positions and actions, as appropriate for deliberation by the full Committee.

The rules of participation in today's meeting have been announced as part of this notice of this meeting previously published in The Federal Register.

Parts of this meeting may need to be closed to the public to protect information proprietary to MHI or other parties. I am asking the NRC staff and the applicant to identify the need to close the meeting before we enter into such discussions and to verify that only people with a required clearance and need to know are present. So, please, especially MHI, be aware of that.

A transcript of the meeting is being kept and will be made available as stated in The Federal Register notice. Therefore, we request that participants in this meeting use the microphones located throughout the meeting room when addressing the Subcommittee. The participants should first identify themselves and speak with sufficient clarity and volume, so that they may be readily heard.

A telephone bridge line has also been established for this meeting. To preclude interruption of the meeting, the phone will be placed in a listen-in mode during the presentations and Committee discussion.

And I will ask you all please to silence your cell phones during the meeting.

We will now proceed, Hossein or Jeff or someone.

MR. MONARQUE: Hi. My Name is Stephen Monarque.

CHAIRMAN STETKAR: Oh, Steve?

MR. MONARQUE: I am substituting for Jeff for the next two days.

CHAIRMAN STETKAR: You know the right ones to come to, don't you?

(Laughter.)

MR. MONARQUE: So, anyway, I wanted to thank the Committee members.

My name is Stephen Monarque with the Office of New Reactors.

I wanted to thank the Committee members for giving us the opportunity to present three-four chapters over the next two days. I realize it will be a busy two days for us. I want to point out we have made substantial progress in our ACRS reviews for both applications, and we certainly look forward to our future meetings with you.

With that, thank you. I will go ahead and turn it over to MHI.

CHAIRMAN STETKAR: Thanks, Stephen.

Yes, let's turn it over to MHI.

Ryan?

MR. SPRENGEL: Good morning again.

This is Ryan Sprengel, MNES.

It is nice to see everyone again.

CHAIRMAN STETKAR: Oh, sure.

(Laughter.)

MR. SPRENGEL: Everyone is wide awake this morning, which is nice.

We will follow similar protocols as previous. Any follow ups, we will either get back to you in the meeting or following the meeting. So, nothing new or different there.

And with that brief introduction, I will go ahead and turn it over to Kevin.

CHAIRMAN STETKAR: I know one of our members, Sam Armijo, is going to have to leave this morning.

So, Sam, I hate to put you on the spot, but if you have anything specific that you wanted to mention --

MEMBER ARMIJO: No, no.

CHAIRMAN STETKAR: Okay. I just wanted to make sure in case you did have something, if we passed your departure time.

MEMBER ARMIJO: No, no.

CHAIRMAN STETKAR: Okay. Thank you.

And with that, we will let MHI start.

MR. LYNN: Okay. Good morning.

My name is Kevin Lynn, and we are here today representing Mitsubishi Heavy Industries. Today we will be discussing Chapter 17 of the US-APWR DCD, which is "Quality Assurance and Reliability Assurance".

So, seated along with me, we have several MHI technical experts today: Osami Watanabe, Takashi Kurisaki, Dr. Futoshi Tanaka, and, also, Takayuki Nirasawa. We also have several members of MAS here to support us, as necessary.

This slide is just a list of acronyms that may be helpful for you today during our presentation.

So, this shows the table of contents for DCD Chapter 17. Chapter 17 includes the quality assurance, or QA, during the design phase; QA during the construction and operation phase; QA Program; Reliability Assurance Program; QA Program description, and the description of the applicant's program for implementation of 10 CFR 50.65, the Maintenance Rule.

Next, this slide shows the relationship between DCD Chapter 17 and any reference, Topical or Technical Reports. The only Topical Report reference in Chapter 17 is the quality assurance program description for the design certification of the US-APWR. And that is referenced from several of the QA sections of Chapter 17.

And then, the only Technical Report reference in Chapter 17 is the US-APWR Probabilistic Risk Assessment Technical Report, which is referenced from Section 17.4 for the Reliability Assurance Program.

Okay. We will start with Section 17.1, the quality assurance during the design phase. The QA for the design phase certification for the standard plant design, we are going to defer all of that discussion into 17.5, which we will cover in a minute.

But for the site-specific portion of the design activities, the responsibility for QA during that portion is the responsibility of the COL applicants.

Next is quality assurance during

construction/operation phases. During those phases, the responsibility for QA is to the COL applicants and it is not covered in the DCD.

Next, the Quality Assurance Program, again, as I said, we are going to discuss all of those aspects in 17.5, which will be covered in a few minutes, for the design certification. Just to reiterate, the Quality Assurance Program for the site-specific design or the construction operation is deferred to the COL applicants.

So, now we will move into the Reliability Assurance Program discussion. The purpose of the Reliability Assurance Program, or RAP, activities is to provide reasonable assurance, first, that the US-APWR is designed, constructed, and operated in a manner that is consistent with the assumptions that we have made for the risk insights, for the risk-significant SSCs. Second, that the risk-significant SSCs do not degrade unacceptably during plant operation. Third, that the frequency of transients that challenge these risk-significant SSCs is minimized. And fourth, that the risk-significant SSCs function reliably when they are challenged.

So, all of the Design Reliability Assurance Program, or D-RAP, activities for the US-APWR are implemented in accordance with Section 17.4 of the Standard Review Plan, the SRP, and, also, the Interim Staff Guidance that has been provided on the reliability assurance.

And we divide the D-RAP activities into three phases. The first phase being the design certification phase, which is obviously the focus of the DCD and will be the focus of our presentation. The next two phases, the site-specific phase and the procurement fabrication, construction, and pre-operational testing phase, will come later.

Next, we will talk about how the D-RAP is implemented. So, we have a process for identifying the SSCs that fall under the scope of the RAP. That process uses a combination of several sources to identify those SSCs. So, we use the Probabilistic Risk Assessment, the PRA; the Severe Accident Evaluation; industry operating experience, and use of an expert panel, all of which will be addressed in the following slide.

So, we use the PRA, as just mentioned. And this slide shows the scope of the PRA that is used for identifying the risk-significant SSCs. So, first, the Level 1 and Level 2 interval events at power. Then, the Level 1 and Level 2 external events at power, which includes internal fires and internal flooding. Third, the low-power shutdown operations. And finally, the seismic, which is the PRA-based seismic margin analysis.

This slides shows how the PRA is used to identify the risk-significant SSCs. So, we have the components that are modeled in the US-APWR, and then we judge them against certain importance criteria which are the Risk Achievement Worth and the Fussell-Vesely importance criteria.

So, those two criteria are used with certain values that are used to separate these components into a list of risk-significant SSCs based on the PRA, and, then, also a list of SSCs that are not risk-significant. So, we have those two lists.

Next, then, the PRA-based seismic margin analysis is used to identify additional SSCs that are risk-significant.

And, then, finally, key insights from the PRA and insights from the severe accident evaluation are used to identify additional risk-significant SSCs.

Next, we move on to the role of the Expert Panel in this process. So, the previous slide demonstrated how we got a list of risk-significant and, then, not-risk-significant SSCs. Then, the Expert Panel will use those results, including the PRA results, to review and then finalize the list of SSCs.

And it is important to point out that the Expert Panel doesn't just look at the ones that are deemed to be risk-significant, but also looks at the SSCs that are deemed to be not-risk-significant when they review and finalize the list. And, of course, the Expert Panel also considers operating experience from the nuclear industry when they make the finalization of the list.

MEMBER BLEY: Can the Expert Panel remove items that scored high on the risk indicators from the list?

MR. LYNN: Can they remove items?

MR. WATANABE: Yes, they can, but, actually, they didn't do that.

MEMBER BLEY: I would expect they would need a pretty good justification and, essentially, need to say the PRA is wrong in some sense.

(Laughter.)

CHAIRMAN STETKAR: That would be bigger problems.

MEMBER ARMIJO: What about the other way; the Expert Panel sees things that didn't come close in the selection? Is it difficult for them to put something and redefine it as risk-significant, even though the PRA work showed it wasn't?

DR. TANAKA: No.

MEMBER ARMIJO: Just purely on judgment?

DR. TANAKA: No, the Expert Panel can add SSCs to the list, even if it has not been determined risk-significant based on the PRA.

MEMBER ARMIJO: But, typically, would that be sort a consensus opinion of the panel or --

DR. TANAKA: Yes.

MEMBER SCHULTZ: Does that lead to any discussion or is it the opinion of the Expert Panel is taken as additional input as it is? And if the Expert Panel makes the decision that something needs to be added or removed from the list, then it is done? Or is discussion/elaboration associated with the decision of the panel? What type of interaction is held with the panel?

DR. TANAKA: Okay. What kind of discussion is held with the panel? Yes, first, they check the equipment, of course, that has been identified not to be risk-significant based on PRA. They also have a equipment list that has not been captured to be risk-significant. They go through the list. If they identify any equipment that potentially could be risk-significant, based on their expert opinion, they will have a discussion, and if they agree, they will put that item in the D-RAP list.

MEMBER SCHULTZ: And the rank ordering, it is associated with the different types of risk that is associated with the risk of the facility; in other words, early release frequency, large early release frequency, the core melt frequency? What elements are identified as consisting of the risk?

DR. TANAKA: Okay. Yes.

MEMBER SCHULTZ: Or is it looked at from different directions and associated with the risk evaluation?

DR. TANAKA: Yes. Also, consideration is taken from the viewpoint of core damage risk, large release, and plant trip. These are considered during the Expert Panel, and if any SSCs add impact to that and increase the risk, they are candidates to be included in the list, yes.

MEMBER SCHULTZ: So, there has been experience. The panel has not taken anything from the list of significant items. What has been added by the Expert Panel? What types of things have been added?

MR. WATANABE: The penetration vent of the main control room is the one SSC that the Expert Panel added to the risk-significant incidences.

MEMBER SCHULTZ: Okay. That is a good

example. Thank you.

MEMBER BLEY: Is there anything in the process that, should the Expert Panel identify something, like the example you cited, that reflects that back to the PRA to see if something was missing in the PRA model?

DR. TANAKA: Sir, can you --

MEMBER BLEY: Yes. The Expert Panel decides to add some aspect, ventilation perhaps. Is there anything in the process that, then, refers that information back to the PRA to look and see if the PRA modeled that system at all or they modeled it properly? If there is some reason we suspect the risk is significant enough to add, maybe there is something missing in the PRA. Is there a process to track that?

DR. TANAKA: Yes. The Expert Panel looks at the list, and in that way, maybe they can find an SSC that has been identified risk-significant. They will question to the PRA experts why is it risk-significant. It could be opposite: why is this not risk-significant? And we have communication with the PRA expert.

MEMBER BLEY: Okay. I didn't see anything in the process that indicated that step was really there, but I hope it is.

DR. TANAKA: Part of the discussion, yes.

MEMBER BLEY: Okay.

CHAIRMAN STETKAR: Let me follow up on that particular example that you mentioned. The main control room ventilation system is not modeled in the PRA, period. It is not modeled in the PRA. The Expert Panel identified it as something that was worthy of adding to the D-RAP list. Why is the main control room ventilation system not modeled in the PRA?

That is Dennis' question, a specific example, a very specific example.

MEMBER BLEY: Right. Or did it work and not get there?

CHAIRMAN STETKAR: Why was it not modeled in the PRA?

DR. TANAKA: The PRA considered the control ventilation system as a function to remove heat, including the control room. The PRA did analysis in control room heat up. Also, they have identified that they can also remove to the no-shutdown panel.

CHAIRMAN STETKAR: Okay. Let me stop you there. Where is that analysis documented? You mentioned the PRA did an analysis. I couldn't find that analysis documented anywhere. Where is that analysis, the room heat up analysis, for the main control room?

DR. TANAKA: That should be in the PRA Technical Report or --

CHAIRMAN STETKAR: Fifteen -- I will look it up later.

DR. TANAKA: Yes.

CHAIRMAN STETKAR: I couldn't find it.

You also mentioned that the operators -- and I read this -- that the operators, if it got too hot in the main control room, could leave and go to the remote shutdown center that is cooled by what you classify as a diverse HVAC system and, indeed, it is cooled by the same chilled water system as the main control room.

That abandonment of the main control room, if it gets too hot, is not modeled in the PRA. So, if you are taking credit in these words that you tell us for things that the operators will need to do, why aren't they modeled in the PRA? They are not modeled in the PRA, you know; trust me. I looked.

(Laughter.)

DR. TANAKA: When you say "modeled," it is a specific value is not --

CHAIRMAN STETKAR: They are not modeled at all. The likelihood that ventilation fails, the likelihood that the operators may need to leave the control room at a certain time, the likelihood that they successfully leave, the likelihood that they control from the remote shutdown center, the likelihood that the remote shutdown center has cooling, the likelihood that the equipment may fail because it overheats, none of that is included in the PRA.

MEMBER BLEY: Nor the effect on the operators.

CHAIRMAN STETKAR: Nor the effect on the operators. None of it is modeled in the PRA. And yet, the Expert Panel said, "Well, we think the main control room ventilation system is pretty important. So, we want it to be reliable."

There are many, many, many examples like this of things that are not at all modeled in the PRA, many examples of things that are not modeled in the PRA that it is not clear the Expert Panel even thought about, because they are not at all modeled in the PRA. Non-safety-related systems are not modeled in the PRA, by and large. I see things for essential chilled water that the Expert Panel agreed specific valves because they are modeled in the PRA should be included. I don't see anything about the chillers or, for example, the train. I think it is a decondenser water pump that actually provides the water. It is not listed on this list.

So, I am really curious about how the Expert Panel used the information to populate this list. I see things on here that were not modeled in the PRA.

But I don't know how they addressed things that weren't modeled at all in the PRA that might be important. Now I am sure they did, and I am sure that process must be documented somewhere. So, I am curious to see where the documentation is of their discussion about disposition of specific systems that are not modeled in the PRA that they said, "Well, let's think about." They thought, obviously, about the main control room ventilation and added it. They must have thought about other things and decided not to add them, for some reason.

Is there a report from the Expert Panel that documents their deliberations that we could see, so that we understand better why they decided that things that are not modeled in the PRA are not important?

DR. TANAKA: There is an internal report, only for MHI. There is no report that has been submitted.

CHAIRMAN STETKAR: We will ask the staff if they looked at any of that backup documentation when they come up.

Thank you.

MR. LYNN: Okay. We will continue. We were discussing the Expert Panels. The members who make up the Expert Panel have to meet certain qualification standards, including level of education and experience. And the Expert Panel is also made up of members who have sufficient knowledge of PRA, plant operations, plant maintenance, design engineering, and QA, in order to represent multiple areas of expertise.

MEMBER REMPE: So, did the NRC review who was selected and their qualifications as part of this process, too?

MR. WATANABE: Does the NRC check the qualifications of all Expert Panel members?

MEMBER REMPE: They did?

MR. WATANABE: I don't think so.

MEMBER ARMIJO: I guess my question was really getting to the point, is the Expert Panel a decisionmaking body or is it simply an advisory body to some design manager, let's say?

MR. WATANABE: Excuse me. Can you explain again?

MEMBER ARMIJO: Yes. Is the Expert Panel, when they do their review --

MR. WATANABE: Yes.

MEMBER ARMIJO: -- do they have the

authority to make a decision to add something and make it risk-significant on their own or are they advising someone else that it should be done, and that other person can either accept the recommendation or reject it? Are they advisors or are they decisionmakers?

MR. WATANABE: How --

DR. TANAKA: Yes, they can make a decision.

MEMBER ARMIJO: They can?

DR. TANAKA: Yes.

MEMBER ARMIJO: Okay.

MEMBER SCHULTZ: Does the Expert Panel's responsibility go beyond identification of the SSCs that are important to safety? In other words, with regard to the Reliability Assurance Program, do they also weigh-in on elements of the Reliability Assurance Program, looking at degradation of SSCs, how the degradation of the SSCs is monitored, and the goal of the Reliability Assurance Program of assuring that the SSCs do not degrade within the operation or lifetime of the facility? I mean, do they go into the Reliability Assurance Program to a greater depth than just the identification of importance?

MR. WATANABE: So far, they just apply certain issues. They do not discuss so deeply into the operation phase of things.

MEMBER SCHULTZ: Okay.

MR. LYNN: I think, as we discussed earlier, there are several phases, on this slide, there are several phases of the D-RAP activities.

MEMBER SCHULTZ: Right.

MR. LYNN: And this phase is the design certification. So, it is selecting the list. But I think what you are asking about, the following of these would fall under the other phases here, the construction and pre-operational testing. Maybe those I think is what you are asking about.

MEMBER SCHULTZ: Well, that is part of it. That is part of it, but the Reliability Assurance Program itself, there is a requirement and a need to identify what is suitable, what is a suitable measure of degradation for these important components.

MEMBER SHACK: Or in the design phase, what are the design requirements --

MEMBER SCHULTZ: Right.

MEMBER SHACK: -- and the appropriate quality controls to put on especially those non-safety systems that get somehow included in the D-RAP list? Does the panel identify those? Or that is sent back, again, to the design engineering group?

MEMBER SCHULTZ: Why I am asking the

question is that you indicated that the Expert Panel is very familiar with operational experience. And I was thinking that this was what they would bring to the table, not only identifying what components are important, but what operational experience has demonstrated equipment degradation, other features that are related to the assurance of important to safety in the Reliability Assurance Program. In other words, not only this needs to be on the list, but here are some things to watch out for with regard to this particular component, safety. This is the operational experience that is important for reliability assurance, just another level of details or depth associated with assuring the performance of a component by pointing out the operational experience that has likely affected the PRA results.

CHAIRMAN STETKAR: We have seen things from other designs, and the capacity designs generate a -- my mind is slipping --

MEMBER SHACK: RTNSS.

CHAIRMAN STETKAR: -- RTNSS -- thank you, Dr. Shack -- a Regulatory Treatment of Non-Safety Systems list, and that is an acronym that is used specifically for the passive designs. The so-called active designs, like the US-APWR, are developed with the so-called Design Reliability Assurance Program list. I kind of think of those in parallel.

We have seen applicants come in with separate reliability control documents, if you will, for RTNSS systems, that look a lot like a technical specifications, but are administered and managed separately from technical specifications. We have been told that they control at a high level the availability of those additional systems that are outside the tech specs, and that, on a more detailed level, that equipment is also folded into the Maintenance Rule Program from a normal operational maintenance perspective.

I haven't seen any of those types of controls documented for your D-RAP equipment that is not safety-related equipment, that it is not in the technical specifications. And there are some items on your list that are like that, I think. I am not sure. It is a long list, and I didn't go through every item and think about it.

Are you developing that type of, let's call it, a parallel set of reliability control guidelines? I want to try to avoid the use of technical specifications because they are different than the technical specifications. They feel a lot like them, but they are different.

I didn't see any of that proposed. Is there? Are you planning to do that? In particular, for anything on the D-RAP list that is not already covered by the technical specifications?

MEMBER SCHULTZ: That is what I was looking for.

CHAIRMAN STETKAR: Yes.

MEMBER SCHULTZ: And also, did the Expert Panel advise on how that --

CHAIRMAN STETKAR: Well, they can put things on the D-RAP.

MEMBER SCHULTZ: Right.

CHAIRMAN STETKAR: Once it is on there, how it is treated, that is, I think, what we are trying to understand. Once it is on the D-RAP list, and it is not in the technical specifications, a lot of the equipment that is in this big, long list are already covered by the tech specs --

MEMBER SCHULTZ: Would be covered, right.

CHAIRMAN STETKAR: -- and, by implications, would be covered under the Maintenance Rule, and so forth.

What I am curious about is anything that is on that list that is not already covered by the technical specifications, if there is anything like that. And I think there may be. How will the reliability of that equipment, those SSCs, be controlled going forward? Because I don't see any commitments to programs to do that. Maybe I missed something, but since Steve raised it, I think we are both asking about the same thing.

DR. TANAKA: Yes, we do not intend to add any requirements to the tech spec based on the D-RAP.

CHAIRMAN STETKAR: And I understand that. I think in consistency with all of the other design centers, that is perfectly consistent. I am careful what words I use.

What I am asking about is that in many of the design centers we have the technical specifications on the one hand that cover all of the safety-related equipment, and we have another set of parallel, let's call them reliability assurance control documents that govern the reliability, again, at a high level of equipment that is on the D-RAP list, but not included in the technical specifications.

An example would be -- and it is not on the list -- an example would be a main feedwater pump. Suppose, for example, the Expert Panel decided that the main feedwater pump should be included on the D-RAP list. They are obviously not part of the technical specifications. They are non-safety-related equipment. But, for some reason, they are on the D-RAP list. How will the reliability of that type of component be assured going forward, at two levels? One in terms of something that looks like the technical specifications but is different, that says if you have a main feedwater pump out of service, you should do something. And at another level, a more detailed level, that controls what I call the fine structure reliability, maintenance of that equipment, the testing of that equipment to assure its reliability, which would be equivalent to the Maintenance-Rule-type applications for safety-related equipment that is included in the tech specs. That is, in principle, what we are asking about.

So, if you use this sort of thought experiment about a main feedwater pump, if that type of a component were included in the D-RAP list, how would its reliability be controlled moving forward? And I don't see that type of program in here.

MR. WATANABE: We only have the risk-significant SSC list as provided in the DCD.

CHAIRMAN STETKAR: Okay.

MR. WATANABE: But we know that we to break down or categorize the more detailed component list and designate which kind of a component is classified as the risk-significant. But those kinds of procedures or documents are under development.

CHAIRMAN STETKAR: It is still under development?

MR. WATANABE: Yes.

CHAIRMAN STETKAR: Okay.

MR. HAMZEHEE: John?

CHAIRMAN STETKAR: Let me follow up for a second.

Does that mean -- and I am looking at a line item right now that just says "main feedwater system," okay? And what I am hearing from you is that you still need to do some work to subdivide at least that into individual components, and so forth.

However, I am still left with in the DCD there is a line item that says the main feedwater system, whatever that means, is on the D-RAP list. And I don't see the programs that will control the reliability of that system, or parts of that system, after you finally finish the analysis. I don't see commitments to those types of programs here in Chapter 17.

And I was curious; I think that is what we are asking about, not necessarily the fine detail of exactly which component may or may not be on the list today. But I am assuming because the main feedwater system is on there, there will be at least one main feedwater pump on it that survives.

MEMBER BLEY: Given it is on the list, what kind of special treatment, special following is required? That is what he is asking.

CHAIRMAN STETKAR: And, Hossein, now you can --

MR. HAMZEHEE: It has been a while since I wrote on this. So, just in concept, as you know, I think he mentioned that, when the staff developed the RAP program, we put them into three phases. We said design phase, construction phase, and operational phase.

CHAIRMAN STETKAR: Right.

MR. HAMZEHEE: You now somehow jump into the operation phase. What they are supposed to do under design is to appropriately define what they believe, based on risk and operating experience, risk-significant SSCs are, and try to set some reliability goals and targets for these.

When we get to the construction phase, then we have to ensure that, when we do the fabrication, installation, and construction, they pay attention to what kind of reliability or equipment they should use.

And when it gets to the operational phase, then the COL applicant has the responsibility to make sure that they maintain the reliability of these SSCs either consistent with the PRA assumptions or assign and come up with their own assumptions.

So, hopefully, once you follow those three phases, you should cover all these things that you are bringing up right now.

MEMBER BLEY: Yes, but, okay, this phase has those reliability targets you spoke of.

MR. HAMZEHEE: Correct.

MEMBER BLEY: And I think that is part of what --

MR. HAMZEHEE: They should identify the SSCs and some target reliabilities for the COL applicant.

CHAIRMAN STETKAR: Yes. And the way that has been done -- again, each design center can be somewhat different -- the way that that has been done in some of the other design centers is to specify this kind of special treatment. I like that term better than my alternate reliability control programs.

MR. HAMZEHEE: Yes. Now you may also be remembering something from RTNSS which is very close but a little different.

CHAIRMAN STETKAR: Well, I am, in particular. And as I said in my introduction, conceptually, I don't think of those two things differently. I am not an attorney. So, I just think of these things as --

MR. HAMZEHEE: All together.

CHAIRMAN STETKAR: -- non-safety-related things that are not in the technical specifications that ought to be reliable because somebody thinks they are important.

MR. HAMZEHEE: Yes.

MEMBER SHACK: See, I think of it in terms of 50.69 where I am looking in the design phase for special fabrication and requirements --

MR. HAMZEHEE: Correct.

MEMBER SHACK: -- that belong here even though they are not necessarily safety-significant components that suddenly fall under all the Appendix B stuff.

MR. HAMZEHEE: Right. Yes. That's right. Now the challenge here, again, the staff has talked about this, and the SRP is in place, and the Guidance Document is in place. But the concern was, as I think John articulated very well, that the SSCs that are identified risk-significant, a number of them are safety-related. Those are covered under the Appendix B requirements. So, you don't worry.

MEMBER SHACK: Right.

MR. HAMZEHEE: A number of them that are non-safety-related, they are covered under the Maintenance Rule. So, we have programs in place that would handle those.

MEMBER SHACK: Well, Maintenance Rule is fine for operational.

CHAIRMAN STETKAR: Right.

MEMBER SHACK: You know, we are back here in design-land where they are supposed to have ITAAC, I think.

MR. HAMZEHEE: We do have ITAAC for RAP.

MEMBER SHACK: For the D-RAP. And that was what I was sort of missing here, was a detailed description of where those ITAAC were for these components. You know, there is a statement that I need ITAAC, but I wasn't sure what the ITAAC looked like or where they would be documented.

MR. HAMZEHEE: Yes, and they will talk about it. When the staff gets here, I think they can explain the process that they follow to review and ensure that these are all reviewed and the proper ITAAC is identified for us.

But I just wanted to mention that the three phases will, hopefully, if done correctly, cover all these concerns.

MEMBER SHACK: Well, there is this notion that everything on the D-RAP list becomes a high safety-significant component in the Maintenance Rule, which sort of tells you how it gets carried over to the Maintenance Rule and the O-RAP program.

MR. HAMZEHEE: But there is a small population that may not be under the Maintenance Rule. Then, you need to make sure that these are also --

MEMBER SHACK: Well, as I understand it, everything on the D-RAP is going to become a high safety-significant component in the Maintenance Rule.

CHAIRMAN STETKAR: In principle, that is the way I read that it is supposed to work. But that still doesn't necessarily solve your question about --

MEMBER SHACK: What do you do in the design phase, right.

CHAIRMAN STETKAR: -- design and procurement.

MEMBER BLEY: I have a point of clarification for me. I can guess, but I would rather have you tell me.

In the text and in the table, you speak of things identified by Engineering Judge. Can you tell me what that is? That is clearly delineated separately from the Expert Panel. Who? Who is the Judge? Who gets things on this list? Who is not part of the Expert Panel?

DR. TANAKA: Some of the Engineering Judge was done by the PRA team because some components were not modeled, basically, in the PRA, but they knew that the structure or the component should have similar risk importance compared to components that support the function.

For instance, the accumulator, this is a structure. The structure didn't have a failure mode in the PRA. It was not modeled as an event. But, of course, the failure of the function was modeled, but I think it, essentially, was not modeled in the PRA as a basic event. It did not have the RAW values or the Fussell-Vesely values which you use as a criteria to pick the --

MEMBER BLEY: So, these would be things they included in the model in a functional way without actually trying to deconstruct it into detailed items of failure? Now there are pumps and other things that are here by EJ as well, but those all come from the PRA team and they are things that they didn't model directly, but they still think are important?

DR. TANAKA: I can't say whether it is all, but, yes, some come from the PRA team and some were Judge because it provides a function to -- it is necessary to prevent some specific events. Like hydrogen igniters were put in there because of an engine judgment. The risk significance could have been small, but the team judged that to prevent hydrogen explosion; that is a necessary component and, therefore, it should be covered by the D-RAP. So, those kinds of judgments were done, some by the PRA team, who knew the model and who knew what was not in the model.

MEMBER BLEY: Given I didn't know that, I didn't think hard about whether I would think they should be in the PRA model or not, but I will have to go home and think about that.

(Laughter.)

DR. TANAKA: Igniters are in the PRA model.

MEMBER BLEY: I'm sorry?

DR. TANAKA: Igniters are in the PRA model.

MEMBER BLEY: Okay. So, some of these things are there, but they turned out not to have high RAW or Fussell-Vesely importance?

DR. TANAKA: Yes, yes. Of course, when they think about the uncertainties, they thought they should be in there.

MEMBER BLEY: Okay.

DR. TANAKA: In this case, this is because of the structure. It is not modeled in the PRA of the structure failure.

MEMBER BLEY: I think that is an interesting story. It is too bad it is not in the report, how that happened.

Thanks.

CHAIRMAN STETKAR: That is what I was asking for. It would be nice to see who sat down with all of these things and systematically went through, in principle, everything in the plant and said, "This is in," for these reasons; "This is out," for these reasons.

MEMBER BLEY: In principle, there should be a document that records these judgments --

CHAIRMAN STETKAR: Right.

MEMBER BLEY: -- and what the bases were for them.

CHAIRMAN STETKAR: For posterity or if the PRA changes, as it evolves, for example, some of those judgments might be supported more clearly by numerical results from the PRA, if things are added to the PRA, or some of the judgments might actually change if the

PRA, you know, models the equipment and shows that it is really not as important as some experts perhaps it to be qualitatively.

MEMBER SCHULTZ: But again, John, to Dennis' point, if that is documented, then the rationale is there for a PRA team to look at later and say, "Well, I know quantitatively I can demonstrate that it might not be so important," but looking back at the rationale that was done by the design team, they may understand why it is there.

CHAIRMAN STETKAR: Not just the PRA team; I mean people who actually have to run the tests and maintain this equipment going forward for 60 years.

MEMBER SCHULTZ: Exactly. Exactly. And we have had experiences where decisions were changed because they didn't have the rationale of the original team that made that decision. And another team looks at it and says, "Shouldn't have done that."

CHAIRMAN STETKAR: Well, I think what we heard earlier is that they have --

MEMBER SCHULTZ: It is important to document it.

CHAIRMAN STETKAR: -- an internal report that did that. It is just that it has not been submitted, and at the moment it is not available to us.

MEMBER SCHULTZ: Well, it needs to be available to the construction team and the operation team.

MEMBER BLEY: I guess anytime one does an analysis based on expert judgment, expert elicitation, it seems incumbent to document the basis, so that one who is on the staff perhaps, or somebody else, can evaluate the reasonableness of it, and as Steve said, later, even people from the same organization or even the same people can remember just why these things have been judged the way they have been. It seems like that ought to be part of the record somewhere.

I'm done.

MEMBER BROWN: Can I ask a question now, if you are all done?

MEMBER BLEY: I'm not running the show, Charlie.

(Laughter.)

CHAIRMAN STETKAR: I can't say no, either. So, go on.

(Laughter.)

MEMBER BROWN: This doesn't sound quite as complicated as your all's questions. Mine is more simpleminded. I was trying to figure out -- to me, I am and I&C guy. So, I looked through the list on Chapter

17 of all the D-RAP or all the -- I guess it is 17, Table 17.4-1. And there is a particular component within the I&C systems called the MILTAC platform, which is a very, very critical component in terms of its overall operation.

At a fairly high level, it has three fundamental areas. You have got hardware. You have got a basic operating system. And then, you have got application code that gets run to generate all your trips and safeguard functions and monitoring information.

I don't see the MILTAC platform listed in there. Now, in the SE that the staff did, they commented that the probability of failure of the CCF, Common Cause Failure mode, I guess is based on -- I don't know -- based on 20 million hours of operation of this platform in Japanese nuclear power plants, which is a nice number to have.

And on that, you would come up with a reliability number -- and I might be quoting this wrong; I am not a reliability guy -- of something like 5, either 1 or 5 times 10 to the minus 8, but you assumed 1 times 10 to the minus 7th in the analysis.

How long has the MILTAC platform been in operation? I mean, is this 10 years, 15 years? To take 20 million hours, you have got to be in a lot of plants and be running for --

CHAIRMAN STETKAR: It is like 2300 years, if you do the math.

MEMBER BROWN: Okay.

CHAIRMAN STETKAR: Twenty million hours is like 2300 years.

MEMBER BROWN: But that is a lot of hours.

CHAIRMAN STETKAR: That means they probably installed one back, you know, in --

MEMBER BROWN: 1850.

(Laughter.)

CHAIRMAN STETKAR: No, that would only be about 1500 years.

MEMBER BROWN: Okay. That is what I thought.

CHAIRMAN STETKAR: We have got to go back into the 1700's.

(Laughter.)

MEMBER BROWN: You calibrated it. So, the 20 million hours is a lot of hours, and that seems like a big number. There was no discussion of the basis for it, at least in the staff's -- and as I said, the applicant them with that information.

And I suspect that, if you look at the initial application of the MILTAC platform, whenever it was, 10 years ago, it had --

CHAIRMAN STETKAR: Oh, no, I am going to stop you. You are on a roll.

MEMBER BROWN: I am on a roll. Do you want to stop me?

CHAIRMAN STETKAR: Yes.

MEMBER BROWN: I'm old.

CHAIRMAN STETKAR: Well, I was going to say, write simple notes to yourself. I think this is probably a better discussion when we get into the PRA because the folks upfront here may not necessarily be the right people to ask those questions.

MEMBER BROWN: I am going to segue down to why this one.

CHAIRMAN STETKAR: Okay.

MEMBER BROWN: Okay? I was looking for, when I went through the list, there was stuff like valves and little pumps and all kinds of other doohickuses on the D-RAP list. But, yet, when I looked for I&C, there is virtually not a single component that is considered a fundamental component that needs to be assured that it has the appropriate reliability assigned to it and maintained during its design and its application, and its development for this specific project.

I suspect that the basic operating software is not going to be exactly the same as it was 10 or 15 years ago, and that the application code for this is not going to be exactly the same as it was for the previous plants. And yet, I see no indication that it is included in the Reliability Assurance Program at all.

So, I brought up the other parts just to emphasize the point of why I thought that looked like it was absent.

CHAIRMAN STETKAR: That is fair. And a good example would be a line item that says "diverse actuation system".

MEMBER BROWN: No, but that is another subject.

CHAIRMAN STETKAR: No, but that is fine. Where Charlie is headed is there is a simple line item that just says "diverse actuation system" that was added based on engineering judgment. It certainly -- I hesitate to use the word "modeled in the PRA". There is a basic event in the PRA for failure of diverse actuation. In fact, in the note here it says that it is assumed to be 1-in-100 demands that would fail.

What Charlie is asking about is, for everything else, the doohickuses -- I like to drive our recorder crazy; so I hope he has that, the doohickuses (laughter) --

MEMBER BROWN: That is a Kentucky phrase.

CHAIRMAN STETKAR: -- for the doohickuses, individual valves. They are very, very precise; this valve leaks; this valve does not open.

For something that is like either the PSMS or the DAS, there is simply a line item that says "diverse actuation system" or, in some cases, not even addressed at all.

MEMBER BROWN: Yes. So, anyway, that was --

CHAIRMAN STETKAR: And I guess that is part of the question of, do you plan to develop more details regarding the digital I&C, either the hardware or -- I will see if I can stay away from the software for the moment -- at least the hardware in terms of the D-RAP list?

MR. WATANABE: In terms of the D-RAP list?

CHAIRMAN STETKAR: Right.

The PRA actually has fairly-detailed models if you delve down into the PSMS, sensors, and things like that. I didn't look at them in detail, but there is certainly a lot more detail than DAS. But Charlie is right that none of that equipment appears on this current list.

MEMBER BROWN: One of my basic concerns is, how do you set targets for reliability of something that is amorphous like basic operating system software and application software? It is pretty difficult to do that. I tried doing that for 20 years in the Naval Nuclear Program and found that -- I mean, you almost always defaulted to line-by-line examinations of code by multiple teams of people who were independent and in separate laboratories to ensure they didn't allow them to talk to each other, as well as developing engineering systems where you set up the entire I&C system and then challenged it by having simulator-type inputs and ran it through so many combinations of switch inputs, operator actions, and everything else, to see what results you got in terms of the performance, and did it really trip when it was supposed to and all that, which took two and three years in some circumstances.

And that was just to get us to say, "Well, yes, for the most part is going to work pretty well." But we never could figure out how to assign a 1-times-10-to-the-minus-8 or 10-to-the-minus-7 probability.

And the other problem is you say, "Well, we have had 20 millions." Forget whether that is too many hours, or whatever, wherever that number comes from. If you had even said 10,000 hours or a million hours -- let's take a million hours, okay? -- how do you know what has been reported? What is a failure when it comes to a software glitch?

CHAIRMAN STETKAR: It is still 100 years.

MEMBER BROWN: I mean, is it every time -- and I am being facetious, not facetious really, but, I mean, if you look at a computer operation, every time you move your mouse and the little arrow doesn't move, is that a software error because the interrupt didn't pick it up and allow something to be done? Or is that "I guess, well, I will just wait a second and I can go ahead and do something."? There are tons of little things that go on that are unnoticed and may not be registered as software failures.

So, it is just how do you develop targets for that is a question I had. I don't know whether I am offbase on that. I am just trying to figure out a way to get the platform into this basic Reliability Assurance Program somehow.

I'm done for this part.

CHAIRMAN STETKAR: Thank you.

I mean, I think you hear some of our concerns about a lot of this does come back to, I think, some of the things that you are hearing from all of us about the process that was used to populate this list. Why are certain things on it? Why are certain other things not on it? Why are some things at a very, very, very fine-structure detail while other things are really, really broad or perhaps not even there?

So, I think we are interested in learning more about that. I don't know how we do that, but maybe we will ask the staff when they come up to see how deeply they have delved into it, also.

In the interest of time, we will see if you can actually get through what you thought was probably going to be easy.

(Laughter.)

MR. LYNN: Well, now that we have moved on to this slide, we might as well continue here. So, when we get to the end, the last of RAP SSCs are identified in the DCD in Table 17.4-1. And this shows an excerpt of that table, as you are clearly familiar with and have looked at.

So, in addition to providing the name of the SSC, it also provides its rationale for inclusion, the risk-significant failure mode, and then, the risk insights and key assumptions.

And I think there was some question earlier about, you know, where is some of this stuff captured? And we mentioned some documentation that was not submitted to the staff. But in this list, as you can see, in the far right column we do provide some description of why it was included. Granted, this is a short summary, but it does provide some -- and this is part of the DCD, and this will obviously be carried forward. So, it does provide, for the future, it does give people a sense of why this thing ended up on there. And also, the rationale provides a list of why it ended up on there.

And so, you can see that those items that are, say, engineering judgment here, and then, you can look and see, okay, well, why did someone think this was an important, and it gives you that sense. So, I think it does capture some of those things that you are looking for. Maybe you are interested in more detail, but this is just a summary of that. And there is additional documentation internally.

CHAIRMAN STETKAR: This does provide, as you said, some insights about why particular items are included in the list, to some level of detail. Some of us were asking questions about the equivalent rationale for EJ or Expert Panel, why something was not included on the list, which obviously doesn't exist here; it doesn't' show here. And it is both sides of that, both sides of the ledger.

MEMBER BLEY: And these notes apply to a whole range of things that were put on the list for different reasons. So, they don't really get into why in a particular case the expert who was judging this, be it the panel or the expert judge, decided to go further than the RAW and the Fussell-Vesely. But you are right, it does give a statement of why it is important.

MR. LYNN: Yes.

So, now moving on to Section 17.5, which is the QA Program description. And as I discussed earlier, the basis for the Quality Assurance Program description is a Topical Report that has been submitted to the NRC, and it is Document PQD-HD-19005. And the QAPD is based on the requirements of 10 CFR 50, Appendix B; 10 CFR 52, and NQA-1, and MHI developed it using the NEI template.

So, the most recent revision of this Topical Report was Revision 4, which was submitted April 2011. That version was reviewed and approved by the NRC on November 9th of 2011. And that is documented in the staff's SE for Chapter 17.

Finally, covering the description of the 10 CFR 50.65, the Maintenance Rule, that implementation of that program is the responsibility for the COL applicants.

This slide discusses the open items from the staff's Safety Evaluation for Chapter 17. This does list an open item, but, as you read further in the SE, it is clear that that open item has been resolved, so that there are, in fact, no open items in the SE.

And there were five confirmatory items in the SE. In each case, it tracks an item where MHI proposed a change to the DCD, and that change has been approved, and we are only just waiting to incorporate in the next revision of the DCD, which will be later this summer. And then, these can be closed.

And that concludes our presentation today for Chapter 17. Are there any other questions?

CHAIRMAN STETKAR: Any questions from any of the members?

(No response.)

If not, thank you very much. You weathered the storm quite well.

I am going to ask the staff, Brian --

MR. SPRENGEL: I think I have a question.

CHAIRMAN STETKAR: Oh, okay.

MR. SPRENGEL: There was lots of discussion about additional detail and interest in the processes that MHI went through and described in the high-level detail. So, we have provided certain information on the docket and provided it to the members, but I am not clear if additional detail was needed for the review itself.

CHAIRMAN STETKAR: Let's wait and hear from the staff first.

MR. SPRENGEL: Okay.

CHAIRMAN STETKAR: Okay.

MR. SPRENGEL: Thanks.

CHAIRMAN STETKAR: We will get back to that.

If nothing else for MHI, again, thank you very much.

And we will ask the staff to come up on Chapter 17 for the DCD.

MR. SHUKLA: Please take your name tags.

CHAIRMAN STETKAR: Yes, hold onto your name tags. We are a low-budget operation, becoming lower-budget by the minute, as best I can tell.

(Laughter.)

MR. ROY: Hello. My name is Tarun Roy. I am an NRO Project Manager responsible for US-APWR Chapter 17, Design Certification Application.

I have been at the NRC for the last seven years and worked in different places, as an operation engineer, structural engineer, and project manager.

I have several years of experience in the nuclear industry. I worked in the design, construction, Quality Assurance Program. I worked in the Bechtel Corporation and several utility companies.

Presenting this to the ACRS Subcommittee, Chapter 17, we have in this program the Construction Electrical Vendor Branch, Greg Galletti. He is absent today, but Branch Chief Kerri Kavanagh. I will call her if any question comes up. And we have Todd Hilsmeier, PRA and Severe Accident Branch.

We have no open items in this associated with Chapter 17, fortunately. That is all I can say. If you have any question, Todd or Kerri will answer that.

MEMBER ARMIJO: Well, just listening to the discussion earlier, I am surprised you don't have a lot of open items, based on the questions that Committee members have asked. What am I missing?

MR. HILSMEIER: I should say our conclusions are not finalized because they are dependent on a lot of supporting sections, like Chapter 19 and the Seismic Margins Analysis. But as those open items are closed, it may impact the RAP. But, based on DCD as it is now, we have no open items.

CHAIRMAN STETKAR: Okay. Todd, let me

follow up, though, because recognize that there may be another iteration, or more perhaps, on the PRA itself, and iterations on the PRA will, obviously, or could, change numerical importance measures for specific items, which could either insert them into the existing RAP list or, in principle, they might be removed.

But the Expert Panel assessment is not part of Chapter 19.

MR. HILSMEIER: Correct.

CHAIRMAN STETKAR: Those judgments are made outside -- they are informed by the PRA to some extent, but they are made outside of the context. So, in my understanding, that Expert Panel assessment belongs to Chapter 17. Is that right?

MR. HILSMEIER: Correct.

CHAIRMAN STETKAR: Okay. And what I am hearing from you is you are saying, if there were no other changes to the PRA itself, you are satisfied with the results from that Expert Panel assessment because that is documented in Chapter 17, and this slide says you have no open items on Chapter 17.

MR. HILSMEIER: Right, but there are open items in Chapter 19. So, in essence, I mean, that can change the PRA. Now if the PRA doesn't change as a result of those open items --

CHAIRMAN STETKAR: That's right. Let's say all of the open items that are in there right now are resolved to the PRA team's satisfaction, that, indeed, what is in there is modeled correctly, the data, the models, et cetera. So, that the PRA does not change. Or, even if the PRA does change, you know, some data value is changed that changing a Risk Achievement Worth from 1,760 and reduces it down to 85 or increases something that is now 6 to 15. That doesn't affect whether or not that particular component will be included in the D-RAP list because it still has a Risk Achievement Worth --

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: -- greater than two.

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: Given all of that, the Expert Panel still reviewed all of that equipment, all of the Risk Achievement Worth values, all of the Fussell-Vesely importance values, and made decisions to in some cases include additional equipment, and I am assuming in many cases active decisions to exclude equipment from the D-RAP list.

And I think what you heard us asking MHI is, what is the rationale that was used for those decisions, either to include something because it is not modeled in the PRA or its Risk Achievement Worth was somewhat less than 2.0, but the Expert Panel decided it was important enough to add.

And on the other side of the ledger, what decisions were made to exclude something because it either wasn't modeled in the PRA or was modeled in the PRA and had a low numerical importance value, and the Expert Panel said, "Yes, we believe it is not important enough to be on the list."?

And I think what we are asking now in the context of Chapter 17 is, what level of -- you can't do an audit; I'm sorry, you can't do a review of that decision process because, as we heard, the documentation was not submitted on the docket. So, did you do any audits of the Expert Panel evaluations to assure yourself that, indeed, they are reasonably comprehensive and that the experts applied appropriate judgment, in your opinion, to include or exclude specific SSCs from that list?

MR. HILSMEIER: I think about two summers ago -- the timing kind of slips my mind because this has been going on for five years, four or five years -- that we did do a mini-audit in conjunction with a PRA audit. During the audit, the applicant provided a presentation on the changes to the PRA model, which led into Revision 3, I believe. And they also discussed how it impacted the RAP program.

And also, as far as doing the formal, detailed audit, I feel that is done through the review process itself. What I mean by that is the PRA staff in Chapter 19 reviews a PRA and confirms that the PRA is consistent with the design. That essentially addresses what we call central elements in the RAP. Central elements in the RAP ensure that there is a process and controls to ensure that the plant is designed consistent with the PRA. That is pretty much done under Chapter 19.

The QA staff performs their audits to ensure that the SSCs are subjected to the appropriate quality controls, and that addresses that part of their RAP.

And then, the part that is left over is assuring that the RAP list is complete. I feel that the approach that we used to review the RAP list is sufficient, such that a detailed audit is not necessary. The applicant does provide the details of the PRA, all the rolled-up tables, Fussell-Vesely tables, PRA assumptions.

And then, if I may go on, I can describe to you our approach for reviewing the RAP list.

CHAIRMAN STETKAR: We have time.

MR. HILSMEIER: Okay. I will do that.

CHAIRMAN STETKAR: I am interested, by the way -- everything that you have said so far is focused on what is there in the PRA -- I am interested in what is not in the PRA --

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: -- and why the expert panel added some additional things. Now let me give you two very specific examples, so that we can keep these in mind.

We already noted that the Expert Panel added the main control room ventilation system to the D-RAP list. It is on the list. It is not modeled in the PRA. The Expert Panel did not add the essential chilled-water system chillers or circulating water pumps. I couldn't find them on the D-RAP list, and they are not modeled in the PRA.

So, there must have been some active decision made by the Expert Panel -- and they are safety-related equipment -- there must have been some active decision made by the Expert Panel that said, "Ah, yes, the essential chilled-water system, it is safety-related, it cools the main control room, it cools the switchgear rooms, it cools the I&C rooms, it cools a lot of pump rooms out in the plant, but we don't think it's important."

Now it is modeled in the PRA, but only for the motor-driven emergency feedwater pump rooms. It is not in the tech specs.

So, what I am looking for and trying to understand is, for those two examples, how did you in your determination say that, "Yes, indeed, we think it is reasonable to include the main control room ventilation system in the D-RAP list, and we think it is reasonable to exclude the essential chilled-water system."? And I am actually more interested in the second part.

MR. HILSMEIER: When I was in the audience listening to the questions, you brought up the question -- and I am not sure if I am restating it as you said it -- but, basically, there's a lot of SSCs that are not in the PRA that the Expert Panel should look at.

And I could have sworn that that process was in the SER, that the Expert Panel does look at all SSCs to see if they are risk-significant or not. And I was diligently back there looking through the SER. I was looking for that statement, although I couldn't find it; like I think you were looking for it, too.

CHAIRMAN STETKAR: I couldn't find it, but, believe me, I have read a lot of stuff over the last couple of weeks, and I could have missed it.

MR. HILSMEIER: Yes. I know other applicants have included that: the Expert Panel looks at all SSCs that are not in the PRA. Well, basically, there is a quote in the DCD: "The Expert Panel also reviews the categorization of SSCs determined to be not risk-significant." So, I am quantifying the result.

When I read that the first time, I interpreted that as being they look at all SSCs outside of PRA. Reading it a second time, it might not be so clear.

So, based on your comment and based on rereading this comment, I do plan to write an RAI for them to clarify this statement. So, it is important that the Expert Panel sees all SSCs.

CHAIRMAN STETKAR: And when we were questioning MHI, I thought that I heard from them that they had an internal report that, I thought what I heard, actually went through that process, reviewed all SCCs --

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: -- and said, "These are on the list for this reason," which appear now in the list with an abbreviated rationale, but at least some rationale of why they are on the list, and by implication, since they reviewed everything, the list of equipment that is not on the list, and why it is not on the formal D-RAP list.

MR. HILSMEIER: That's right.

MR. SPRENGEL: I have a clarification.

CHAIRMAN STETKAR: Okay.

MR. SPRENGEL: The chilled-water system and essential chiller units, essential chilled-water pumps, et cetera, are in the D-RAP list.

CHAIRMAN STETKAR: They are? Where?

MR. LYNN: Are you looking at DCD Rev. 3?

CHAIRMAN STETKAR: I am looking at DCD Rev. 3. Point me to the page of Table 17.4-1. It is easier for me to flip to that because --

MR. LYNN: Well, start with sheet 45. I am looking at a different version.

CHAIRMAN STETKAR: I will get down to sheet 45. VSW, essential chilled-water, I see valves. I see cooling-line flow meters.

MR. HILSMEIER: The acronym used for chilled-water system is actually VSW, if you are doing an acronym search.

CHAIRMAN STETKAR: I didn't do that acronym search. And in the interest of time, why don't we just, rather than both of us looking real-time on the record, if you can --

MR. LYNN: It is on sheet 42.

MEMBER SCHULTZ: It is on sheet 48 on the version I am looking --

MR. SPRENGEL: I'm sorry. Page 48, but --

MEMBER SCHULTZ: Oh, okay, you're right.

MR. SPRENGEL: -- it is sheet 42 --

MEMBER SCHULTZ: You're right.

MR. SPRENGEL: -- for Table 17.4-1.

MEMBER SCHULTZ: I just found it.

CHAIRMAN STETKAR: Thank you. I stand corrected. The chiller units and the pumps are on there. They are, only two of them, though. Only two of them because those are the only two that were modeled for the two emergency feedwater pump rooms. This specifically calls out chiller units B and C and pumps B and C. And I guess I knew those were on there from the emergency feedwater. I am asking about why A and D are not on there.

MEMBER BLEY: Todd, you were going to tell us about the process you go through, and I would be interested in that because --

CHAIRMAN STETKAR: Yes, that is more important.

MEMBER BLEY: You know, we had both the EJ things and the EP things, which are both judgment. And how did you gain confidence that they did a thorough job, given the documentation I have seen, but maybe you saw more and deeper?

And I just had a thought. You know, when we talked with the thermal hydraulic guys, they did some comparison calcs on their own just to see if things line up. Do you do anything like that? Do you go through and say, "Gee, what are the things I would expect that Expert Panel to find," and then look and see if they have done some of that? So, if you could tell us a little of the process, I think it would be helpful.

MR. HILSMEIER: Yes. If I could quickly address --

MEMBER BLEY: Sure.

MR. HILSMEIER: -- for the chiller-ware system, B and C trains are included; A and D are not. There is a reason for that; I can't remember offhand.

CHAIRMAN STETKAR: No, I know why only B and C are modeled because the only ventilation water-cooling dependence that is explicitly modeled in the PRA is cooling for the motor-driven emergency feedwater pump rooms, which are the B and C rooms. A and D, it is -- I have to be careful what words I use. Room cooling is not modeled for the turbine-driven emergency feedwater pumps, which are the A and D pumps. It is stated that those pumps will survive through the PRA mission time without cooling for that room. I have other questions about that, but those are PRA questions.

Given the fact, though, that the Expert Panel, now the Expert Panel, added some systems that were not modeled in the PRA because they felt they were important -- and, in particular, for example, they added the main control room ventilation system, which is, indeed, cooled by essential chilled water. But the panel did not add essential chilled water trains A and D. They don't appear on here. Only B and C appear on here.

So, that tells me that the Expert Panel must have thought about chilled-water trains A and D and said, "Oh, there is some reason they should not be on this list, and here is the reason," beyond the fact that they are not modeled in the PRA, because the HVAC, the main control room HVAC system is not modeled in the PRA. And yet, the Expert Panel folded that into the list.

And getting back to Dennis' -- I bring up specific examples to kind of get people focused, but I think we are more concerned about your process of delving into that thought process --

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: -- you, as a reviewer for Chapter 17.

MR. HILSMEIER: I am sorry, Dennis, for not addressing the question right away.

MEMBER BLEY: That is all right. You had lots of things on your plate.

MR. HILSMEIER: The approach we use for identifying risk-significant SSCs, first of all, studying and learning the design, the US-APWR design, for this new plant for me. And then, studying and learning the PRA models, what they modeled, what information is available as far as RAW tables, Fussell-Vesely tables, studying the assumptions made in the model -- that is very important -- especially the fault tree assumptions.

The data assumptions and the event tree assumptions were somewhat important. I found the fault tree assumptions were much more important because it made assumptions about system alignments or train alignments and what SSCs were considered inherently reliable. And that is really not modeled in the PRA.

All that impacted how I looked at the RAP list. And then, when I did the detailed review of the RAP list, I also wrote out all of the systems of the plant. And I will get to that, why I wrote the two lists of systems, in a little bit.

And so, as far as the PRA model, what we looked at were the RAW Fussell-Vesely tables in the PRA, making sure that all the RAWs and Fussell-Veselys exceed the criteria of those SSCs that were included in the RAP list. And that was a huge task because there was like thousands. Actually, I used an Excel spreadsheet to import all the RAWs and Fussell-Veselys and do sorting. I did that for Revision 1 and Revision 2. For Revision 3, I didn't do that detailed look at the RAW and Fussell-Veselys because I am saving it for the next revision because it is so intensive, and there weren't enough changes in Revision 3 to justify looking at all the RAW and Fussell-Veselys again.

I also looked at the PRA insights and results. Those risk insights are very useful in identifying SSCs that may be risk-important. And again, looking at the PRA assumptions and the fault tree assumptions was very valuable.

An example of the assumptions and use of engineering judgment is for the essential service water system trains, it was assumed that one of the strainer trains were out of service, that the cross-tie valves were closed, and the water is not flowing through it, and the other train was in service.

So, when the PRA model ran, the RAWs and Fussell-Veselys for the train that is in-service were very high; the RAWs and Fussell-Veselys for the trains that were out of service was low. So, based on an engineering judgment, Mitsubishi knew that the out-of-service trains must have the same RAWs and the Fussell-Veselys. So, they included those SSCs. That is an example of the engineering judgment that they applied.

So, we looked for things like that. We also looked at the severe accidents, insights and assumptions. Also, I spent a lot of time looking at the risk-significant human interactions. In that, I needed to go into understanding what components were manipulated during those risk-significant given actions to make sure those are included in the RAP list.

And then, also, Mitsubishi applied the Seismic Margins Analysis identifying risk-significant SSCs in their Seismic Margins Analysis. They applied the NEI 00-04 document, which addresses risk categorization for 50.69. They used the approach in that document. So, I applied that approach to the Seismic Margin Analysis, also to confirm the list.

My primary focus is looking for SSCs that are not on the list that should be on the list. If an

SSC is on the list and I feel it shouldn't be on the list, that is okay; it is conservative. Mostly, we are concerned about SSCs that are not on the list.

And so, as I discussed earlier, I created a whole list of systems at the plant. And for any of those systems that are not included in the RAP list, I looked at and applied my 23 years of nuclear power plant/PRA experience. And I worked at nuclear power plants for 13 years -- no, actually, more than that. You know, time flies.

(Laughter.)

CHAIRMAN STETKAR: It is really sad, isn't it, when you start thinking about that?

MR. HILSMEIER: I felt like as a kid that a summer day would last forever. Nowadays the days fly by.

(Laughter.)

So, at least 15 years, 16 years, 17 years, working at nuclear power plants, working on risk-significant lists because we did it for the Maintenance Rule, and risk-ranking of valves. And I applied by plant experience, my PRA experience, and analyzed the systems that were not on the list and determined whether or not they should be risk-significant or not.

I might have misunderstood you, John. You were saying that the remote shutdown panel is not modeled in the PRA? Am I correct on that?

CHAIRMAN STETKAR: You know, Todd, I didn't go look at the hardware, but in the rationale for heat up of the main control room --

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: -- I read words that said, "Well, the operators can always go to the remote shutdown point."

MR. HILSMEIER: Right, right, right.

CHAIRMAN STETKAR: That, since the ventilation system is not modeled, failures of the ventilation system are not modeled, so there is nothing in the PRA that says, if the ventilation system fails, the operators have to go to the remote shutdown panel, and what is the likelihood that they either do that or don't do that successfully, you know? So, in that sense, that whole evolution is not modeled in the PRA. And yet, words are written saying, well, they could do that.

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: People could do a lot of things that sometimes they do and sometimes they don't.

But, again, back to, I think, Dennis' question, those are all specifics. I think you were starting to talk about the process that you, in particular, used to assure yourself that, if something wasn't on the list, that it was reasonable that it was not on the list.

MR. HILSMEIER: And two other things that I have done was look at RAP lists from previous design certifications and just do a sanity check to see if those lists included SSCs or systems that Mitsubishi didn't include.

And lastly -- and this is a very important part of the review of the list, because the people who know the PRA the best are the Chapter 19 reviewers, Hanh Phan, Marie Pohida -- Nick Soltis is no longer with us today; he retired -- and Ed Fuller, he was a severe accidents guy.

And when they reviewed Chapter 19, they were very attentive of the RAP list and making sure that, as they did review, that the RAP list captured important SSCs, as they saw it. Based on that approach, I feel that the RAP list that Mitsubishi has is effectively complete.

And we did ask about RAIs, but, then, they include some SSCs, and we provided justification why we thought it was risk-significant.

And also, comparing Mitsubishi's RAP list other DC RAP lists, I feel this RAP list is much more extensive than the others.

Regarding, Charles, the instrumentation and controls, the instrumentation and control systems were left at the system level. And that means all SSCs inside the instrumental and control system are specific in the RAP. They are involved certainly as far as PRA modeling of digital I&C. And I felt that was the best system, including the whole system into the RAP list. Like the engineering safety feature system, the gas system, the reactor protector system, the entire system is in the RAP list.

Now, as far as how reliability performance criteria, availability performance criteria would be developed for SSCs in those systems, that would fall under the Maintenance Rule. I am not familiar with how the Maintenance Rule process right now is for the new plants.

MEMBER BROWN: But that Maintenance Rule is downstream of --

MR. HILSMEIER: Right.

MEMBER BROWN: -- the design process.

MR. HILSMEIER: Right. And it is through

the Maintenance Rule that -- it is true that, under the RAP program, building control manuals or like pseudo-tech-specs are not developed for the RAP SSCs, unless they are enriched. And the reason for that is because the RAP guidance, as provided in SECY-95-132, does not specify to provide these pseudo-tech-specs for RAP SSCs.

They rely on the Maintenance Rule to ensure that the reliability and availability of these SSCs are maintained. Because under the Maintenance Rule, all the RAP SSCs are declared high-safety-significant. And therefore, they are given specific performance, reliability/availability performance criteria, and they are monitored against that criteria. And those criteria are consistent with the PRA.

Me, personally, I think -- and this is just my personal opinion -- I think it is a good idea to have, since written SSCs to have pseudo-tech-specs, it would be a good idea for RAP SSCs to be similar, to have pseudo-tech-specs. That is just my personal opinion.

But, based on the current guidance given to us by the Commission for RAP --

MEMBER BROWN: When was that issued?

MR. HILSMEIER: I believe 1995.

MEMBER BROWN: Okay. I mean, if you look

at all -- that is blacksmith technology days. For the civilian nuclear power industry, that is blacksmith technology. I mean, you go out and pound a few transistors or you have got switches and lights and relays, and that kind of stuff.

Software falls so far outside that realm of what I call "blacksmith technology" -- and I am not saying that in a pejorative manner; I happen to like a lot of blacksmith technology --

MR. HILSMEIER: Right.

MEMBER BROWN: -- from its reliability and ease of understanding its ability to operate when you want it to operate it and to test it and know that you are going to get the right result.

But the software is different. And I understand what the direction is, but, as we have witnessed already in almost all the new design projects, the requirements we look at, based on the Reg Guides and even the Rule, 603, 1991 -- did I get the year right? -- 1993, or something like that, those fundamental, independence and the other issues that are encompassed in that, and electrical independence, kind of gave you a certain amount of inherit functionality independence.

With software and communication between channels and performance of software, you don't get that. It is just absent. And so, at some point, you have got to think about what do I do? In the absence of formal processes that I have used in the past, how do I do something now that gives me the performance and reliability that I want out of the software-type applications?

And I love those applications. They are very, very, very good and give you a lot of flexibility and allow you to do things with the plants that you couldn't otherwise. But you still have to recognize that it is different.

MR. HILSMEIER: Oh, yes.

MEMBER BROWN: And so, when you say, "Well, this is all we are allowed to do" --

MR. HAMZEHEE: If I may, let me just help Todd here.

MEMBER BROWN: I am not making that as a nasty comment. That is not the point.

MR. HILSMEIER: No, I fully --

MR. HAMZEHEE: If I may, let me just help my friend Todd there. You are right, these are not unknown issues, and we had a lot of activities ongoing with respect to digital I&C. But when he is working on RAP, he is not trying to resolve all the issues that are associated with digital I&C, but, rather, to make sure that at least on the RAP that system is defined and enough attention will be given.

And as we learn more and develop more in the area of software reliability, then at least that system is appropriately identified. And when it becomes the maintenance of digital I&C reliability, then under the Maintenance Rule and other operational programs, we are going to incorporate those into those programs and, then, find out and make sure that we monitor the reliability.

But we do not want someone like Todd -- or on the RAP program, we try to resolve all the other issues that we have with ongoing --

MEMBER BROWN: That is not what I am looking for, my point being that the D-RAP program is set up, at least based on what I understand from the multiple meetings I have listened to this over the last few years, to identify targets during the design stage that help ensure that you have a reliable component or system, whatever it is.

MR. HAMZEHEE: Yes.

MEMBER BROWN: And my concern is that, for hardware-based things, there is a lot of clear targets. You do this test; you do that. You test the materials. There are all kinds of things you can do to what I call the blacksmith technology, okay, hammer and tongs and metal and stuff like that, wire.

But for software, where is the oversight? Where are the things for people to do in the design stage that the NRC can be confident that these targets that are set are set with respect to the technology with which we are dealing, the software itself, the basic operating system and the application code?

That is all I am trying to figure out. We can't solve all those downstream issues, but how do you set targets for these things where you all haven't just passed it down -- and this is not a nasty, negative comment -- where it has been passed into the process, where it is all done at the vendor or the design guy that is building the stuff and the applicant, or the design agent that is overseeing the guy that is building the stuff, without any understanding of what those targets are by the NRC? Whereas, you know what those are because you can quote all the ASME codes and everything else that is cranked into the older technology. That is my only point on this stuff. Okay?

MR. HAMZEHEE: Yes, I agree.

MEMBER BROWN: So, you can go on. You answered my question. I just tried to articulate a little bit of my thought process. I won't remember this tomorrow, but I am trying to get it into the transcript today.

(Laughter.)

Well, that is the truth.

MR. HILSMEIER: I think that is all I had to say about the approach.

MEMBER SCHULTZ: Todd, I would like to follow up with regard to the approach. I appreciate your description of the thorough review that was done by several elements of the staff with regard to the application.

And you mentioned that one of the results of the work that was done by the staff was identification of some additional items that ought to be incorporated in the D-RAP.

MR. HILSMEIER: Uh-hum.

MEMBER SCHULTZ: And you provided that listing to the applicant.

MR. HILSMEIER: Uh-hum.

MEMBER SCHULTZ: And in the applicant's presentation, we didn't go over it in detail, but in their presentation it was noted that, when they received the list, they went in to review the items that were provided, and they agreed to add to those to the list.

MR. HILSMEIER: Correct.

MEMBER SCHULTZ: I am not sure what your expectations were with respect to that, and that is what I wanted to explore. In the thinking of a Quality Assurance Program, my expectations would have been, if I was the originating organization and I received such a list from the reviewer suggesting that these additional items be added, I would have put in my corrective action program two things. One, an evaluation of that list to determine whether each of those should be added to the program, but I would also add a corrective action program that would be programmatic. In other words, given that an organization, after all the work was done, identified these additional things, was there something programmatic that led me to provide an original list that was not complete? In other words, that the reviewing organization found lacking in some respects.

Now you have reassured that you really feel that the list that was provided is exceptional, but I am still wondering whether your expectations were that that second element would also have been done by the applicant; that is, to review their process to determine why they didn't identify these themselves through the process of their analysis, the Engineering Judge, and the Expert Panel.

MR. HILSMEIER: Yes, when I identify an SSC that I think is risk-significant, my approach is in the RAI I provide justification why I feel it should be risk-significant, and then, see what the applicant's response is.

And a handful of SSCs were added. Also, there is a handful of SSCs that I thought should be risk-significant, but the applicant justified that and convinced me that they are not risk-significant. And that is not reflected in the SER, just to keep the SER more simplified.

Now this issue as far as applicants not including certain SSCs in the RAP list is actually common amongst other design certifications, and the reason being is because NRC's expectations for RAP which is in the current revision of SRP 17.4 is very unclear. It is unclear as far as what the essential elements of RAP are. It is unclear as far as how to identify risk-significant SSCs. It is unclear to the staff. It is unclear to the applicants.

As a result, Mitsubishi's application was submitted based on that current SRP revision, and along with the other design certifications. And so, the unclearness of the SRP led to risk-significant methodologies being broadly different amongst all the design certifications.

Like, for example, Mitsubishi didn't initially include consideration of Seismic Margins Analysis in identifying risk-significant SSCs. Now it is NRC's expectation that they do include Seismic Margins Analysis, but that wasn't in our guidance.

So, several years ago, we updated the SRP through an Interim Staff Guidance to clarify to industry what our expectations are in RAP, including what we expect the applicant to look at in identify risk-significant SSCs.

And actually, as a result of this ISG, Mitsubishi, along with other DC applicants that were still under review, updated their methodology to meet NRC's expectations. In the process of updating this methodology, new additional SSCs have been communicated, I mean had to be added to the RAP list.

Now, in the case of Mitsubishi, I started asking RAIs -- I communicated our expectations through RAIs because the Interim Staff Guidance wasn't published yet. It was on the verge of being published, but it wasn't published yet. To avoid delaying the communication of our expectations, through the RAIs, I communicated our expectations. And a year or so later, the Interim Staff Guidance was published.

So, most of the SSCs that they added was mostly due to clarification of NRC's expectations on the RAP list. As I said, this was an issue across all design certifications due to our unclear guidance in SRP 17.4.

Now the Interim Staff Guidance on SRP is now in the process of being incorporated into the SRP 17.4. In a few months, it will be released for public comment.

But, just to summarize, much of the SSCs that I requested, that I communicated to Mitsubishi that should be included, I felt were the result of unclear guidance, NRC guidance, in the SRP section.

MEMBER SCHULTZ: Then, in conclusion, do you believe that the applicant has adequately satisfied the process as you have gone through the RAI process and provided that clarity to them --

MR. HILSMEIER: Yes.

MEMBER SCHULTZ: -- and that they are, if you will, ahead of the game? In other words, what is coming out in two or three months, that has been addressed by this applicant?

MR. HILSMEIER: Correct.

MEMBER SCHULTZ: Thank you.

MR. HILSMEIER: I see you putting your

glasses on, John.

(Laughter.)

CHAIRMAN STETKAR: Well, you know, no, you are talking about getting old. Don't get me started about vision and aging and getting depressed.

(Laughter.)

Let me ask, do any of the other members have any questions for the staff?

(No response.)

Let me ask members -- what I was doing, we don't normally see the RAIs. I always say this. And we don't normally ask for the RAIs because, if we ask for them, they are sent to us, and it simply adds, you know, many, many more pages that we don't have enough time to read.

In this particular instance, on pages 17 through 19 of the SER, there is a long list of RAI questions that address specifically some of the issues that we have been asking here in terms of they are the RAIs that Todd was just mentioning regarding questions to the applicant about specific SSCs that are on the list, right? I am hoping that that list captures everything. It is?

MR. HILSMEIER: All the SSCs that we felt were risk-significant got added to the list. There's a bunch of other SSCs that we thought may be risk-significant, but Mitsubishi --

CHAIRMAN STETKAR: But at least this is the list of RAIs that sort of captures that process --

MR. HILSMEIER: Yes, right.

CHAIRMAN STETKAR: -- that you were just explaining?

Is there any interest among the members to get copies of these RAIs and skim through them? I think I would be interested. Girija or the staff, just go through -- they are in bullet form, and some of the RAI numbers are repeated. And I have no idea what volume of material we are talking about, but I think we would like to see those, if you could. That will give us at least a little bit more of the detail of not only the questions that the staff asked, but also the responses that came back from HMI.

And, Todd, I think you said that in some cases they had a good rationale for why something --

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: -- ought not to be on the list?

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: So, that may help some of our questions.

MR. HILSMEIER: Some of the RAIs, because they are supplemental --

CHAIRMAN STETKAR: Oh, okay.

MR. HILSMEIER: So, it gets confusing.

CHAIRMAN STETKAR: Well, that is why we have people who can help sort that out for us.

(Laughter.)

If you could follow up, I think that would be pretty useful.

MR. HAMZEHEE: We will get them to you.

CHAIRMAN STETKAR: Okay.

MEMBER BLEY: I think what I have heard -- and I really appreciated your walking through the process; that helps me out. It gives me more confidence than I had before.

And I think what I have heard is that you didn't rely so heavily on the applicant's description of their Expert Judge and Expert Panel rationales as on your own parallel review to see if you came up with a similar list as they had or found differences. Is that a fair statement?

MR. HILSMEIER: In some of the RAIs I asked, thought some SSCs were risk-significant, and they responded back; they would use the PRA. Also, they would use their Expert Panel.

MEMBER BLEY: So, you actually saw more of their rationales when you asked specific questions?

MR. HILSMEIER: Right, right.

CHAIRMAN STETKAR: That is why I thought maybe the RAI's might ferret out a little bit more of that exchange, provided they are not 2,000 pages of material.

MEMBER BLEY: I guess where I was hanging up is I have thought, I still think, that that process has to be well-documented internally or somewhere. But maybe reviewing that isn't as important as a parallel process that looks for discrepancies and, then, digs into specific cases. This might be the best way to go at it. But I really hope they have the documentation of that process in-house.

MR. HILSMEIER: Right. Part of the essential elements of D-RAP is to maintain records. As a result of your questions, I will be writing an RAI to confirm that the Expert Panel looked at all risk-significant SSCs.

I mean, based on this statement in the DCD, I interpret it as --

CHAIRMAN STETKAR: All SSCs.

MR. HILSMEIER: Right. But, looking at it when I was back in the audience, maybe I am misunderstanding the statements. I am going to ask for an RAI for clarification on that.

And it may be a good idea to look at their D-RAP records. I mean, we looked at their D-RAP procedures. We had asked an RAI for them to not provide the procedures because there was a lot of procedures, but to describe their procedures in detail.

It may be a good idea to do an audit to actually look at the procedures and look at their D-RAP.

MEMBER BLEY: It seems to me, I mean, we have gotten into an area where it is not just this, but other areas where we are almost licensing by process rather than by direct examination, which makes me always uncomfortable because within that process you may do unusual things that get you into trouble. So, having looked at those to make sure they are doing their process the way they tell you seems an appropriate activity.

MR. HILSMEIER: Right. Yes. I was on the fence about doing an audit or not, but you have convinced me enough that I should do the audit.

The other thing is there is, I don't want to let the cat out of the bag, but there is a recent design modification that will be discussed under Chapter 19. And I am just going to make sure to see how they address that design modification in view of that.

CHAIRMAN STETKAR: Cooling water or others?

MR. HILSMEIER: Hydrogen igniters.

CHAIRMAN STETKAR: Oh. Oh, yes.

MR. HILSMEIER: The design modification. And to see if that is addressed appropriately in D-RAP, that is kind of like a test for me to see if they are in the mini-D-RAP proposal or not.

CHAIRMAN STETKAR: Okay.

MEMBER SCHULTZ: It would be useful, as Dennis has indicated, to provide a review to assure that the guidance -- I presume there is guidance associated with the documentation of the rationale, that the follow-through is there.

MR. HILSMEIER: Right, yes.

MEMBER SCHULTZ: And the example you gave, RAIs and responses are not good ways to document or retain records. I mean, they are there in the record, and it is indicated in the applicant's response that they are going to incorporate what the result of the dialog you have had through the RAIs into the program description --

MR. HILSMEIER: Right.

MEMBER SCHULTZ: -- for the DCD. So, it would be worthwhile to assure that that has been done appropriately to document the rationale.

MR. HILSMEIER: Right.

MEMBER SCHULTZ: And that would lead to further reviews of other items also.

MR. HILSMEIER: Right.

MEMBER SCHULTZ: It could be very valuable to make sure all of the rationale is appropriately captured --

MR. HILSMEIER: Right.

MEMBER SCHULTZ: -- again, for construction, operation, implementations.

MR. HILSMEIER: I agree.

CHAIRMAN STETKAR: Any members have anything else for the staff?

(No response.)

If not, thank you very much.

What I would like to do, because there are so many different topics and we are bouncing back and forth between the design certification and the COL application, I think what I am going to do is ask if we have any public comments after each topic, so that we don't stray too far afield before I ask for any kind of public feedback.

Girija, you said that the bridge line is open.

MR. SHUKLA: Yes.

CHAIRMAN STETKAR: Do we know if we have any members of the public on the bridge line.

MR. SHUKLA: No, it was only for MHI.

CHAIRMAN STETKAR: Only for MHI? Okay.

If that is the case, then I will ask, are there any members of the public in the room that have any comments or questions you would like to make regarding, in particular, the topic of the design certification, Chapter 17?

(No response.)

If not, thank you very much.

MR. HILSMEIER: Thank you.

CHAIRMAN STETKAR: You also weathered the storm rather well.

And what we will do is we will recess, and I am going to be difficult about this, until 10:40.

(Whereupon, the above-entitled matter went off the record at 10:26 a.m. and resumed at 10:41 a.m.)

CHAIRMAN STETKAR: Okay. We are back in session.

Now we are going to hear about Chapter 17 of the Combined License Application. And as I understand it, we have the bridge line open now. Is that for people from Luminant or do we know we have members of the public on the line.

MR. WOODLAN: We have one individual from MNES who may jump as necessary.

CHAIRMAN STETKAR: Okay. It is just to orient me when I go ask for public comments and things like that. So, thank you very much.

And you said it is open all the way?

MR. SHUKLA: Yes.

CHAIRMAN STETKAR: So, whoever the person on the other end, please be very careful. Either mute your phone or just be very, very quiet because we have a very, very sensitive sound system here. When you make any sounds out there, it kind of explodes on this end and it really wreaks havoc with our court reporter. So, if you could try to be as quiet as you can, unless we ask questions. Thank you.

MR. HICKS: I understand.

CHAIRMAN STETKAR: Don, it is all yours.

MR. WOODLAN: Thank you.

Good morning, everyone.

I am Don Woodlan. I am the Luminant licensing lead for Comanche Peak Units 3 and 4. It is a pleasure to be back here again making more briefings.

We are here today to cover Chapter 17. We have Ron Carver who is the Luminant QA lead for Comanche

Peak Units 3 and 4, and we have John Conly who is the Luminant COLA Manager for Comanche Peak Units 3 and 4. And we have several individuals from Mitsubishi in the audience who are here to support us if we need help on some of these questions. And as mentioned, we have Tom Hicks, also representing MNES, who is on the telephone.

With that, I am going to turn it over to Ron, who is going to start the presentation for us.

MR. CARVER: Thank you, Don.

Well, good morning, everyone.

I am Ron Carver, and I will begin with our standard agenda, which includes an introduction, a proposed license condition, and topped-off with site-specific assets. So, let us begin with the introduction.

This chapter of the Comanche Peak FSAR uses the "incorporated-by-reference" methodology, of which there are no departures from the US-APWR Design Control Document. All COL items are addressed in the FSAR. The Chapter 17 Safety Evaluation Report does not contain any open or confirmatory items. We do have one proposed license condition to cover, and I am pleased to say we have no contentions pending before the ASLB.

As I said, the NRC did propose one license condition for Chapter 17 which states, "No later than

12 months after issuance of the COL, the licensee shall submit to the Director of NRO a schedule that supports planning for, in conduct of, NRC inspection of the Maintenance Rule Program. The schedule shall be updated every six months until 12 months before scheduled fuel loading and every month thereafter until the Maintenance Rule Program has been fully implemented.

Luminant has previously placed in Part 10 default proposed license conditions, in an effort to address all operational programs, including the NRC proposal or Maintenance Rule we just discussed. Our proposal states, "The licensee shall submit to the Director of NRO a schedule no later than 12 months after issuance of the COL or at the start of construction, as defined in 10 CFR 50.10(a), whichever is later, that supports planning for and conduct of NRC inspections of operational programs listed in FSAR Table 13.4-201, with the exceptions of the Fitness-for-Duty Program. The schedule shall be updated every six months until 12 months before scheduled fuel loading and every month thereafter for each applicable operational program until either the operational program has been fully implemented or the plant has been placed in commercial service, whichever comes first."

Okay. Moving on to site-specific assets, Section 17.1 and 17.2 are really just pointers to the Quality Assurance Program spelled out in Section 17.3 and 17.5.

Section 17.3 states, "Luminant is responsible for establishing and implementing a Quality Assurance Program for design, construction, and operations, and that we have delegated quality-related work to others, but ultimately retain responsibility for the QA Program."

Our Quality Assurance Program for preparation to review the COLA is governed by the NuBuild Quality Assurance Project Plan, which invokes elements of our two operating units' Quality Assurance Program. This program is based on ANSI N45.2 and meets the requirements of 10 CFR 50, Appendix B, requirements.

Now Luminant, the safety-related contract has required our primary contractor to have a Quality Assurance Program based on NQA-1 and to meet the 10 CFR 50, Appendix B, requirements along with Part 21.

MEMBER BROWN: Excuse me. By "primary contractor," do you mean the --

MR. CARVER: MNES.

MEMBER BROWN: MNES?

MR. CARVER: Yes, sir.

MEMBER BROWN: Okay. Thank you.

They got the design, the plant design contractors.

MR. CARVER: Yes.

MEMBER BROWN: Okay.

And at this time, I will turn it over to John to discuss Section 17.4

John?

MR. CONLY: Thank you, Ron.

As we discussed earlier this morning, the US-APWR D-RAP is implemented in phases. The first is the design certification phase; Phase II, site-specific, and the third phase, procurement fabrication, construction, and pre-operational testing program or phase. Phases II and III programs continue the structure and quality controls put into place in Phase I by MNES/MHI, and Phases II and III will be complete before fuel load. Luminant is responsible for the D-RAP Phases II and III and for the Operational Reliability Assurance Program.

The only site-specific Phase II risk-significant SSCs are the UHS cooling tower fans, as presented in FSAR Table 13.4-201.

MR. WOODLAN: Seventeen.

MR. CONLY: I'm sorry, 17.4-201. Thank you.

The Operational Reliability Assurance Program will be conducted by the System Engineering Department and Maintenance Engineering Department in combination. The Operational Reliability Assurance Program will be integrated into the Maintenance Rule Program as well as other operational programs, such ISI, IST, and reactor vessel material surveillance programs.

Are there any questions?

MEMBER SHACK: Will you do your own review of the Maintenance Rule Program for components or are you going to assume the D-RAP list essentially gets everything that should be in the Maintenance Rule?

MR. CONLY: We have IDRed the D-RAP from the US-APWR, and this is the only addition.

CHAIRMAN STETKAR: John, go back -- I am sure you were listening intently to our questions of MHI and the staff. Since you are now responsible for procurement and installation of all of the equipment, on the D-RAP list right now that has been reviewed and accepted by the staff, and unless anything changes, the only information we have is it is complete. There are line items like main feedwater system. How are you going to address that in your procurement process? Does that mean a drain valve problem, some main feedwater heater, because it is part of the main feedwater system, will be assigned higher quality requirements during your procurement of that drain valve? Because the whole system is in there. That tells me everything from the outlet of the condenser to the inlet to the steam generator is in the D-RAP program.

MR. CONLY: And I would have to say that in Phase II we will use our prime contractor, MNES, to develop all of that program for us.

CHAIRMAN STETKAR: But, right now, I am trying to address this kind of thing we are struggling with of how is that list, that table that is in the certified design that I have been reminded is part of the D-RAP list transition to you now, the applicant, who must actually go out and buy this equipment and install in the plant and test it and maintain it as part of the what you are calling Phase II and Phase III or the transition from the design to the operational programs, because right now you have accepted, by reference, that table in the design certification, which to me says every bit of equipment that is associated. Now I am assuming it is also the main condensate system because it is hard to get feedwater from the condenser to the steam generators without main condensate, although only main feedwater is listed. How do you resolve all of that?

MR. WOODLAN: Let me take a shot at it. The basic answer is we don't have those procedures and processes in place yet. So, I can't give you an absolute answer. I can say that, for sure, the D-RAP list, including, as you say, some very general items, is the starting point. The end point is probably this D-RAP and the Maintenance Rule at the other end, and the work in between is really new. Applying this approach to the procurement, fabrication, construction process is something that we will have to take on.

I believe we will adopt processes and procedures very similar to what we use in the Maintenance Rule area. We will be looking at, as we are developing the procurement, pretty much, I assume, most, let's say the safety-related component; the specs will be there in the DCD and the FSAR of how we should be applying that, and it will be a full Appendix B QA Program. And that is how we will enter maintaining the quality for a given component, assuming it is a typical safety-related component.

CHAIRMAN STETKAR: That's safety component, but --

MR. WOODLAN: Yes.

CHAIRMAN STETKAR: -- but I am talking about this amorphous stuff called the main feedwater system, for example.

MR. WOODLAN: And you are absolutely right; that will be a bigger challenge. I can only look at what we do in the Maintenance Rule arena today. We have that same challenge in the operating plants where we are implementing the Maintenance Rule. And we generally know the range of components we are dealing with, and we usually look at trigger or trip wires that kick us into reliability questions. Either we get condition reports that indicate there have been challenges in the plant, the equipment has had failures, and we start evaluating those against the reliability. And when that happens, we will bring in whatever tools we need, including PRA, Expert Panel, typically, what is required for the Maintenance Rule.

Now how we are going to apply that to the non-safety components during the procurement and construction phase, I don't have the answer to that yet. We will need to develop those processes.

CHAIRMAN STETKAR: Is that process -- and I probably should be asking the staff rather than you because I am not familiar with the details of the process -- are those decisions made, in other words, is what I will call the O-RAP list, which from what you are saying probably has more specificity than the D-RAP list. And I will use this main feedwater system as an example.

MR. WOODLAN: Well, yes, we will start with the current list, but it will evolve as we go and become more specific, yes.

CHAIRMAN STETKAR: But is that O-RAP list generated and examined by the staff before the COL is issued or is that after issuance of the COL? That is my question. It is a process question.

MR. WOODLAN: I believe they are not staff-approved, if you will, but they are inspected, just like they do for the operating plants. In fact, it gets a lot of inspection attention, and I suspect we have to have the program in place, as we say in the last slide there.

But it doesn't require NRC approval. I expect it will be a significant part of the inspection programs as we approach fuel load.

CHAIRMAN STETKAR: But that is after issuance of the COL?

MR. WOODLAN: That is after issuance of the license.

CHAIRMAN STETKAR: It is not a --

MR. WOODLAN: Yes.

CHAIRMAN STETKAR: -- requirement for

issuance of the COL --

MR. WOODLAN: Correct.

CHAIRMAN STETKAR: -- that any more detail than what is currently shown on the D-RAP --

MR. WOODLAN: Yes.

CHAIRMAN STETKAR: -- is available? Okay. Thank you.

MR. WOODLAN: Well, let me expand one more area. I was thinking about this as the DCD was making their presentation. How we would do this implementation, and again, looking back at what we have done in other areas.

What I suspect is, as we are looking at fabrication, design, and construction for the non-safety components, in the past we have done things like someone mentioned the special treatments of Part 69, and we have also looked at what we call an augmented quality program. In fact, I think we specifically mention that in the FSAR.

So, there are some tools that exist there in the industry, and we have used them at Comanche Peak. It is my belief that we will probably bring those tools into these processes as we develop them.

MR. HICKS: Hey, Don, this is Tom. Can I just say one thing?

CHAIRMAN STETKAR: Yes. Tom, make sure you state your full name, so that we have it on the record.

MR. HICKS: Sure. This is Tom Hicks with MNES.

CHAIRMAN STETKAR: Thank you.

MR. HICKS: Just one other thing I want to add is that all the risk-significant items -- and this is described in the DCD as well -- that are non-safety related do get the augmented quality controls applied, and those are described in Part 3 of the Quality Assurance Program description.

CHAIRMAN STETKAR: Thank you.

MR. HICKS: So, the safety-related things get the Appendix B program; the non-safety, risk-significant get the Part 3 quality controls from the QAPD.

MR. WOODLAN: Thank you, Tom.

CHAIRMAN STETKAR: We understand that, but, from our purposes right now, if I were to understand the D-RAP list and what I just heard, they would tell me that every vent and drain valve from every piece of piping along the entire main feedwater path will have that augmented quality applied to it.

MR. WOODLAN: I guess I wouldn't assume

that. I would say it would be evaluated for augmented quality. As we are developing the detail design, the procurement, fabrication details, we will make that assessment: does it need augmented quality and, if so, we would add it.

MEMBER SHACK: Yes, and in what respect? I mean, it is a typical 50.69 kind of a questioning.

MR. WOODLAN: Yes.

MEMBER SHACK: And there is guidance for that, which I assume will look a whole lot like the guidance you will --

MR. WOODLAN: Yes, I agree.

CHAIRMAN STETKAR: Okay. Thanks, Don.

MR. WOODLAN: Are there other questions?

MEMBER BROWN: Yes.

MR. WOODLAN: Please.

MEMBER BROWN: I am trying to understand a little bit -- and this carries over from the previous discussion, so I just love to mouth-note this stuff -- the reactor trip system is a system that you will be procuring. And I presume you will be procuring that, then, through MNES? Is that -- based on your previous comments?

MR. WOODLAN: Yes, yes.

MEMBER BROWN: So, they are your primary

contractor?

MR. WOODLAN: That is correct.

MEMBER BROWN: There is a set of design certification requirements that, once the NRC approves and issues the license, that are incorporated in the DCD that, then, have to be passed down to the vendors. And then, the MNES will then, I guess, approve the design as it is developed by the vendors, so that it meets the architecture and the rest of the output and other type requirements that are specified in the DCD.

Now that is part of the design program. You make two comments in here, if you go back to -- let me get the right slide. No, maybe it is the wrong slide.

Luminant is responsible for establishing/ implementing the QAP for design, construction, and operation. You have delegated work that retained responsibility.

I guess my question here is relative to the PSMS or the reactor trip SFAS and the rest of the systems that come under that hierarchy, is that going to be relative, since you have delegated that to MNES in terms of procuring it, designing it, testing it? Is that a turnkey back to you? I mean, in other words, they design it and they say, "Okay, now we have built in accordance with this. Here it is. Go put it in and have fun."?

Or does your Quality Assurance Program actually provide an oversight of the MNES development process to ensure that they actually incorporate the design details that are critical to the performance of those systems?

MR. WOODLAN: Let me try to answer that.

MEMBER BROWN: Was I clear, No. 1?

MR. WOODLAN: I believe so. I think I understand.

First of all, let me say, although Mitsubishi/MNES is probably going to be the contractor, as you say, we don't have contracts in place yet.

MEMBER BROWN: No, it is just an example; that's all.

MR. WOODLAN: Yes. I am just trying to be clear on that point.

But whoever it is, whoever our prime contractor is, I would hesitate to use the word "turnkey". We have never done it that way at Luminant, and I don't believe we will ever do it that way in the future.

Just like we are doing now with the FSAR, we use MNES as our prime contractor. They do a tremendous amount of work, but we do maintain oversight of what they would do. We interject ourselves where we feel it is appropriate, and we make sure we understand at an appropriate level what is going on and we agree with the approach.

So, I suspect that that will be the process going forward as well. The technical expertise, the background will probably be with our prime contractor.

The MNES will maintain a staff that does not oversight that and confirms that we are comfortable with what they are doing. Even in the I&C area today, in the design area, we have maintained an oversight.

MEMBER BROWN: Luminant has?

MR. WOODLAN: Luminant has maintained an oversight of the DCD work, because it is so important going forward, and has advised and reviewed what Mitsubishi is doing to make sure that we are comfortable with it and that we have our input.

MEMBER BROWN: And the reason I ask is that we haven't done Chapter 7 yet as part of the DCD. That is still an upcoming task.

MR. WOODLAN: Yes.

MEMBER SHACK: Treat.

(Laughter.)

MEMBER BROWN: Treat, yes.

And if you have at least absorbed, or if the staff has passed information that run through the previous new projects that have gone through, you can probably anticipate some questions and desire for certain information to be available in the DCD that addresses the newness of the application of computer-based systems using CPU-type platforms.

And so, if architectures are very, very important in order to maintain the performance and the reliability in the reactor trip and SFAS systems, I mean some things such as watchdog timers and other type things which would initiate trips in certain trains if everything locks up are critical and have been addressed in previous designs.

My question is, how deep do you go in terms of looking at those. I mean, you say you have a staff at Luminant that oversees the MNES, MHI, whoever it is. Is that just a process review or is it actually a real hardware review as well, part of our software review in terms of the digital I&C?

MR. WOODLAN: I don't think there is a simple answer to that because, just like we have done here thus far in the application part, we vary our depth of review and our detail of review based on, first of all, what value we think we can add to the process and where we think there are challenges that we should be aware of and that we can participate in.

So, in the case of I&C, we have had an

individual who has spent ultimate time. Now I don't know all the details, so I can't answer which details that we actually got into. But I know we participated in most of the public meetings, a lot of the audits, and we looked at a lot of the material.

If something affects operations like tech specs, we did a lot and we went very deep because those --

MEMBER BROWN: I am looking at tech specs. I mean, there are lists and lists of when you do these checks and that check.

MR. WOODLAN: Yes.

MEMBER BROWN: But I am looking at the QA Program itself in terms of how you take delivered systems and the architecture of those systems, and their compliance with DCD, not necessarily how each software line is done or sensor, or how many wires can from Point A to Point B, and all that kind of stuff, but fundamental principles such as independence, redundancy, all those types of things that you can look at without being a designer, for instance, that are supposed to be incorporated in the design in terms of how it is set up and designed.

So, there is some level, it seems to me, of technical understanding of the system you are getting that Luminant should have to ensure that it at least meets whatever the final license certification approves from the NRC. And staff won't be doing that; you all will be doing that. Maybe they will be auditing you, but that is a different -- I am not working on the audit part of the NRC, just your responsibility.

Just because you have talked about this differentiation of delegating certain things, which I understand -- I don't disagree with -- but it is a matter of matter sure you get what you have ordered. And that is why I asked the question.

MR. WOODLAN: Okay. And again, I am going to have to be kind of general. I may ask for some help here. But I can go back to what was done on 1 and 2. Now it is not digital, but it is similar, having to get into the depth of detail.

In the early stages in the procurement and the design, Luminant was not intimately involved, let me say. Again, it was a very high-level overview. But, as you proceed through the receipt, the testing, the verification, Luminant becomes more and more involved. And by the time you get to the end-point where you are doing the pre-operational testing and the startup testing, then Luminant is intimately involved. And I suspect that is exactly what will happen on 3 and 4.

MEMBER BROWN: Okay, but there is some

design-type characteristics, such as independence, which you don't really -- by the time you get to the pre-operational test, it is too late. If the design doesn't compensate --

MR. WOODLAN: I understand.

MEMBER BROWN: -- for certain failure modes, it is too late by then, okay? So, that is kind of my question. It is a leading question.

For instance, if all your processors lock up in the reactor trip system, you ought to SCRAM the plant, fundamentally. You ought to shut down. Now that has been the discussions in previous design certification discussions, and that will probably be a part of the discussion in the upcoming Chapter 7 review.

So, my point being that there are certain architectural features that, once you get the pre-operational checks, it is installed in the plants and the wires are run, it is too late. You now have a system that is fundamentally not suitable for operation. You can't change it without a lot of difficulty in cost.

MEMBER SHACK: So, won't those issues be dealt with in the design certification?

MEMBER BROWN: Well, it is in the DCD.

Hopefully, it is will be specified, but it is a matter of Luminant making sure that MNES delivers that feature in the design. They don't have to go down to the nuts and bolts, but does it meet these particular high-level requirements?

And so, I was just trying to probe to see a little bit about what your all's technical level of involvement is.

MR. WOODLAN: Well, it is my projection that the testing we do will be to confirm that those key elements are in there and are working.

MEMBER BROWN: By the time do it, it is installed in the plant, it is too late. I guess that is my only --

MR. WOODLAN: Well, I would disagree that it is too late. If it is wrong, if it is broken, if it doesn't do, we will fix it. We will have to do something to fix it. We won't operate a plant that doesn't do what it is supposed to do.

MEMBER BROWN: Well, I wouldn't think so, but --

MR. WOODLAN: We will do it.

MEMBER BROWN: All right. Well, that is enough. I have beat this horse to death.

MEMBER SCHULTZ: But let's back up a bit

because you mentioned, Don, that the implementation plan is something that you expect MNES, or whoever it is going to be, to develop, that it is not developed now. It needs to be developed for the reliability assurance program and to go into the next phase and procurement and construction, and so forth.

MR. WOODLAN: There is an area where I suspect Luminant will have a lot of involvement, the development of a plan and the process.

MEMBER SCHULTZ: And that is what I wanted to hear.

MR. WOODLAN: Is that what you are talking about? Yes.

MEMBER SCHULTZ: I didn't hear that when you first mentioned it.

MR. WOODLAN: Yes. Okay. I'm sorry.

MEMBER SCHULTZ: You said that it hadn't been developed and MNES was going to be given some part of that task, is what I am hearing now.

MR. WOODLAN: And they will, but, much like we have done here in the application phase, many activities, like how we write the FSAR, how we amend the FSAR, we looked to MNES, as our contractor, and said, "Give us a procedure that says how this is going to happen." But, then, Luminant, because of the importance of that going forward, did get intimately involved in reviewing that procedure, making sure that we felt this process was going to support what was needed and making comments at getting the procedure revised until both parties were satisfied.

And I suspect that is exactly what will happen on the key processes here, on how we are going to handle D-RAP, how we are going to handle this augmented quality going forward. We will turn to our prime contractor and say, "Tell us how you are going to do that." We will review that closely, make sure we are onboard and we are comfortable that that will achieve the purpose.

MEMBER SCHULTZ: So, we had talked earlier this morning about the documentation that is being developed and now available to identify the rationale and the expectations with regard to the SSC equipment, and coming out of the design-related program, the PRA and the Expert Panel, and the other areas that have contributed to that listing.

Do you feel comfortable with the documentation that has been developed to move forward with the implementation plan?

MR. WOODLAN: Do I feel comfortable?

MEMBER SCHULTZ: Yes.

MR. WOODLAN: We were just talking about that, another gentleman from Luminant, Todd Evans and I, while Mitsubishi was making their presentation. We have an ongoing interaction with Mitsubishi about what documentation will be turned over and/or available to Luminant when we move forward.

MEMBER SCHULTZ: Good.

MR. WOODLAN: And we were saying this is something that we clearly want to make sure is on that list of documentation that is available. We don't know, as was discussed this morning, exactly what form that will be in. Hopefully, it will be in a form that is easily acceptable, so that, as our Expert Panel moves in and we start dealing with these challenges, we will be able to go back and find out what the basis was. Anybody that has worked in licensing knows, to make a change, you have got to know why it was there in the first place.

MEMBER SCHULTZ: Right, right.

MR. WOODLAN: And that is a key of what those discussions were and what that documentation will have in it. Unfortunately, frequently, this documentation is in the form of minutes of the Expert Panel, which makes it difficult to delve into. But we have dealt with that before. And if that is what it is, we will find a way to make that more accessible and readable.

MEMBER SCHULTZ: We can see that this is a very important handoff.

MR. WOODLAN: Yes, we agree.

MEMBER SCHULTZ: Especially when it is one organization to another. And so, I am glad those discussions have already happened and will continue.

MR. WOODLAN: Well, it is in process. They are continuing, yes.

MEMBER SCHULTZ: Thank you.

MR. CONLY: Are there other questions?

(No response.)

Let me turn it back to Ron to continue the discussion of the Quality Assurance Program.

MR. CARVER: Thanks, John.

Section 17.5 discusses the implementation of the Quality Assurance Program and how we will transition, on issuance of the COLA and as the project progresses, from the Quality Assurance Project Plan to the Quality Assurance Program description that is provided in Part 11. When that has committed, then we will fully transition to the QA Program description no later than 30 days prior to fuel load.

The nuclear operations for Comanche Peak

Units 3 and 4 will be governed by the fully-implemented QA Program description, which is based upon NEI 06-14A.

Any questions on that section?

MEMBER SCHULTZ: One question, Ron. The words that you have used are typical in terms of "no later than 30 days prior to fuel load".

MR. CARVER: Sure.

MEMBER SCHULTZ: But in terms of Luminant's thinking, do you have a different target than what is qualified here for latest to be done?

MR. CARVER: Well, that is a variant answer. There are several programs, at least 22 operational programs that we don't have listed.

MEMBER SCHULTZ: Right.

MR. CARVER: They will be implemented as we go along and just prior to needing them. We want to have some of these a little bit more mature when we implement them. So, it really depends on the particular program we are talking about. So, over probably a three-year period that we are developing our staff with the operational piece, those people will come in, write those, put them together.

So, yes, our intent would be sometime before 30 days prior to fuel load. That will probably be a moving target as we get closer, but it will be varying dates, probably three years out up to that date.

MEMBER SCHULTZ: Okay. You mentioned a couple of things, and certainly in terms of the programmatic element, but you are likely to require not only -- and it is part of this program -- but you are requiring not only the documentation, but also the personnel training and development --

MR. CARVER: Absolutely.

MEMBER SCHULTZ: -- and positioning associated with having an executable program on the ground running at 30 days prior to. So, that is all in your planning?

MR. CARVER: That is just an absolute drop-dead date.

MEMBER SCHULTZ: Okay. Thank you.

MR. CARVER: Okay. Anything else?

(No response.)

Okay. This subsection incorporates by reference the NEI 07-02A document that is entitled, "Generic FSAR Template Guidance for Maintenance Rule Program Description". This is a mature industry program that we are familiar with. There are operating units. And we plan to leverage this experience as we move into operations at the new units.

So, this really concludes all of the Chapter

17 presentation, unless there are some more questions.

CHAIRMAN STETKAR: Any members have any questions for Luminant?

(No response.)

If not, thank you very, very much. We appreciate it.

MR. SHUKLA: Tom, are you still on the phone?

MR. HICKS: Yes.

MR. SHUKLA: Yes, this is Girija Shukla from the ACRS. Do you plan to be on the phone later today or tomorrow, or you are done?

MR. HICKS: I will probably be on the afternoon session today.

MR. SHUKLA: Okay. All right. Thank you.

MR. HICKS: You're welcome.

CHAIRMAN STETKAR: Thank you.

We will have the staff come up for their lengthy presentation.

(Laughter.)

This has to be really important if Stephen is actually going to run the slides for us.

(Laughter.)

Tarun, just be really careful of not hitting that microphone. They are really, really sensitive.

Thank you.

MR. ROY: That's right.

Okay. We are starting again this Comanche Peak Nuclear Power Plant COLA application review for Chapter 17. Or maybe I should elaborate on the program.

I am Tarun Roy, and I gave you my brief biographical last time. And here we have Todd again for PRA and the Severe Accident Branch, and Greg Galletti is absent. But Branch Chief Kerri Kavanagh will support that for 17.5, which is a Quality Assurance Program.

This is another place we have no open items. As I said, it is Chapter 17.

So, any PRA questions for PRA-related targets here again?

(Laughter.)

The same team; we can repeat that maybe.

(Laughter.)

CHAIRMAN STETKAR: I hate to let you guys just sit here with three slides and say nothing. So, let me see what I can shoot from the hip a little bit.

(Laughter.)

There is a requirement that says, by the time of the fuel load, there must be -- I don't know what term is used -- let me call it a plant-specific PRA that is developed to satisfy all of the standards and guidance that are in effect one year prior to fuel load. I probably paraphrased that incorrectly, but you get the message.

There are also a lot of statements, and we will address those in more detail when we talk about the PRA, that say, well, there were many key sources of uncertainty -- and I think that is the term that is used -- identified in the Design Certification PRA that the COL licensee or applicant, I am not sure which, will need to address before you can actually use the PRA for anything.

Those refinements of the PRA, whenever they are done, could, in principle, affect the population of the -- I will just call it the RAP list for now because I am not quite sure which one it means. It is certainly not the D-RAP list because that is finalized, which could obviously affect the programs that the licensee puts into place in terms of procurement, quality for procurement, and everything that we have been discussing.

How does all of that play out? That is all post-COL, is that right?

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: Okay. How does it play out in real-time? Because prior to fuel load, they must develop this, I will call it, the plant-specific PRA, and addressing all of these key sources of uncertainty from the Certified Design PRA. But that means just it says prior to fuel load.

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: So, in principle, it could be the day before I start to load fuel. Now I know there has to be some lead time for some audit function, things like that. But, by that time, all of the equipment has been procured and installed in the plant.

Suppose the plant-specific PRA identifies equipment that should have been on the D-RAP list from day one or day zero or should have been on the O-RAP list from day zero plus 10 years, but weren't.

MR. HILSMEIER: Right, right. That is a very good question.

(Laughter.)

CHAIRMAN STETKAR: Thank you.

MR. HILSMEIER: First, the PRA should be updated to meet the current standards a year, in effect, well before initial fuel load because they need it for Maintenance Rule to help to identify the SSCs and scope of Maintenance Rule.

But, also, part of the essential elements of RAP is updating -- as we talked about before, that RAP list is a live list. And so, part of the essential elements of RAP is ensuring the process continually updates the RAP list.

It is to the COL applicant or licensee's advantage to ensure that RAP list is as complete as possible. Because if they identify a new RAP SSC right before initial fuel load, they would need to ensure that that SSC meets the quality controls. If it is safety-related, it needs to meet quality assurance controls, Appendix B, because it is safety-related.

CHAIRMAN STETKAR: But it safety, yes. Again, I am not too concerned about the safety-related. I am concerned about the other stuff.

MR. HILSMEIER: If it is not safety-related, they would need to ensure that that SSC meets the quality assurance controls in accordance with the provisions of SRP 17.5, Part B.

MEMBER SHACK: Let me just come back that. I mean, isn't the D-RAP list frozen with the certification, and anything else would, then, come under the Maintenance Rule?

CHAIRMAN STETKAR: But that is operational. I don't mind adding --

MEMBER SHACK: That is another question.

Is the O-RAP list a different list or is it just a follow up on the D-RAP, and everything else comes under the -- that was sort of the question I was asking. Now I have the PRA; it seems to me I should be going through this again from the Maintenance Rule, asking very much the same kinds of questions I do when I develop the D-RAP list, except I have now got a more complete, up-to-date PRA with more design details available.

So, I mean, I wouldn't call it a D-RAP anymore because it is not D-RAP. That is why I called it "RAP". Now is the O-RAP a living list or is that just part of the Maintenance Rule? I mean, that is how I envisioned it, that once you were done with the D-RAP, you were onto Maintenance Rule, but do you think the O-RAP itself is a living list?

MR. HILSMEIER: Yes. When we were developing this Staff Guidance for RAP, we were questioning the same thing. Do we call it D-RAP list, RAP list? And we ended up calling it what John calls it, which is a RAP list.

(Laughter.)

Because we don't care if it is during design certification or the Maintenance Rule operation phase, the RAP lists or SSCs are subjected to the RAP process. And it is a live list because, like during the design certification phase, the PRA only covers the design within the design certification envelope.

MEMBER SCHULTZ: But describe, Todd, what you mean by a "live list".

MR. HILSMEIER: Oh, a live list means, as a PRA changes, it may identify new risk-significant SSCs and those need to be incorporated into a list. And if they are new SSCs incorporated into a list, QA controls, they need to be ensured they meet the QA controls and incorporated into the Maintenance Rule.

Now it is expected, and very much expected, that most of the risk-significant SSCs will be identified -- they are currently identified now -- but because of design changes that may occur during the design construction process, cable routing may identify new SSCs, SSCs that were previously not considered risk-significant, and they have become risk-significant, and they are added to the list.

MEMBER SCHULTZ: But it --

MR. HILSMEIER: Once the -- I'm sorry, go ahead.

MEMBER SCHULTZ: Does the live list suggest, then, that not only is the list updated, but also the quantification that results from a change is performed?

MR. HILSMEIER: You mean the PRA quantification?

MEMBER SCHULTZ: Yes.

MR. HILSMEIER: No. Usually, the updated PRA and updated PRA quantification may identify additional or new risk-significant SSCs. But once the PRA for the operational phase is developed, after that, it is unlikely that new risk-significant SSCs will be identified after that initial operation.

CHAIRMAN STETKAR: It might. There is a requirement -- and I have forgotten the periodicity; it is either three or four years --

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: -- right, that the PRA must be updated for operational experience?

MR. HILSMEIER: Yes. I not saying there won't be any, but it will be minimal -- minimal.

CHAIRMAN STETKAR: The thing I was just thinking about is I am back to the main feedwater system, but, in principle -- I have to be careful about wording here -- but, in principle, for example, the heater drain pumps might be procured under some quality requirement. And you might find after operation that, indeed, you have a fairly-significant problem with your heater drain pumps.

The heater drain pumps are certainly not safety-related. They are certainly not modeled in the PRA. However, loss of heater drain flow can lead to loss of feedwater events, which can lead to reactor trips, which can lead to potentially risk-significant transients.

So, in principle, in retrospect, you might add the heater drain pumps to your Maintenance Rule requirements and say, "Gee, we ought to enhance the maintenance on our heater drain pumps or" -- you know, maybe not buy new ones, but do something to improve their reliability. And I think every plant goes through that process. You know, they look at operational experience.

On the other hand, if I knew about that beforehand, maybe I would have put in a better design specification for the heater drain pumps or a better quality requirement for my initial purchase, so I didn't have to go deal with this issue.

And that is a little bit of what I am trying to probe in terms of this transition.

MR. HILSMEIER: Right. I don't quite understand your question.

(Laughter.)

CHAIRMAN STETKAR: The question is

Luminant is going to go out with a bid spec, or MNES, or somebody is going to go out with a bid spec and say, "We need a couple of, two or three" -- I don't know how many heater drain pumps you have -- "and heater drain pumps that are of a certain size and a certain quality, and they deliver a certain amount of flow. You don't necessarily need any reliability of them because they are not important. They are only heater drain pumps, for crying out loud.

So, that bid spec for the procurement of those heater drain pumps will have that information. And somebody will design and construct and sell them some heater drain pumps.

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: If I later determined that those heater drain pumps, because, indeed, there is some risk-significance to loss of feedwater flow, which could be caused by loss of heater drain flow, if those heater drain pumps might actually be risk-importance, Fussell-Vesely importance .005 or Risk Achievement Worth 2, then perhaps that bid spec for the procurement of those heater drain pumps would have been written differently --

MR. HILSMEIER: Correct.

CHAIRMAN STETKAR: -- either the quality

of construction of the pump itself or some reliability assurance requirements from the vendor of the pump. And I don't see that happening.

I understand, once they are in the plant, if my operational experience says, "Gee, I have a problem with them," and it is leading to loss of feedwater events, they may, then, evolve into treatment under the Maintenance Rule.

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: But some of the stuff -- and I think Bill was approaching it from this same perspective -- there is a gap.

MR. HILSMEIER: Those components would be included in the Maintenance Rule, given specific reliability, availability, performance criteria.

CHAIRMAN STETKAR: Right.

MR. HILSMEIER: Now, if they are not meeting that criteria, it would enter a corrective action process to resolve the issue that is causing them to be unreliable or not meeting the availability performance criteria. And I don't know the specifics of the cause of the failures, but if they are not able to correct the failure through the corrective action program, according to the Maintenance Rule, they would need to continually apply the corrective action program until they can meet the performance criteria.

CHAIRMAN STETKAR: Right. In principle, they might have to go out and buy new pumps --

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: -- or something like that. I understand that, how that process works, essentially, after the fact, after you have the equipment installed in your plant and you now have to operate and maintain it.

MR. HILSMEIER: Regarding your question about like the feedwater system, it could incorporate the feedwater systems in RAP, and that means all the SSCs of a feedwater system, including the drain valves are in RAP. There may be advantages to the applicant to identify specifically what components are risk-significant, so, then, they don't have to apply the drain valves. And because it is a live list and it could be continually updated, that process is available for them to do that.

CHAIRMAN STETKAR: But that is okay in terms of winnowing down a subset of this nebulous thing that is called main feedwater.

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: It doesn't necessarily add things to the list that, again, aren't on the list right now.

MR. HILSMEIER: They add new SSCs to a list, even if it is during the operation phase.

CHAIRMAN STETKAR: But operations, I am not interested in the operations right now, and I can't be interested in design certification because that is cast in stone. I am interested in that middle ground, though.

When they go out with a bid spec for a pump or a valve, how will that be treated, and how do they determine how it will be treated?

MEMBER SCHULTZ: The new opportunity here is in procurement, construction, installation.

CHAIRMAN STETKAR: That's right. That's right.

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: Because once it is installed, the operational experience will tell them whether it is meeting adequate reliability for the purpose.

MEMBER SCHULTZ: That's right. But the improvement opportunity that we are trying to achieve here is to get a better start for the process --

CHAIRMAN STETKAR: Yes. Right.

MEMBER SCHULTZ: -- as we set it up to do.

MR. HILSMEIER: And those RAP SSCs would be subjected to the QA controls in SRP 17.5. I am not an expert to talk about those QA controls. The QA folks, who are not here right now, would need to address that.

MR. HAMZEHEE: But, Todd, also, John mentioned the Maintenance Rule appropriately controls this, because if it is not design-related, but rather performance-related, then you don't worry about it. If you worry about design of it, now under the Maintenance Rule the focus is on maintenance, preventable functional failure. But if it is outside maintenance, such as design issues, design deficiencies, or human errors, then there is another place in the Maintenance Rule that would highlight those, and then they have to take some appropriate corrective action.

So, there is a small chance that you are right; we may miss that opportunity that something could be a design-type issue that has nothing to do with performance. And if those small cases happen, then the Maintenance Rule would identify them --

CHAIRMAN STETKAR: Sure.

MR. HAMZEHEE: -- and then, the plants have to either replace the component or correct the deficiency.

CHAIRMAN STETKAR: Okay.

MR. HILSMEIER: Yes, thank you, Hossein. That is an excellent point.

MR. HAMZEHEE: Am I right, though, Todd?

MR. HILSMEIER: Yes, yes.

CHAIRMAN STETKAR: Yes. Okay. I was just trying to understand -- I understand that part of the process, but I was trying to understand whether there was an opportunity to essentially further refine the understanding of this risk-significance between the list in the certified design, whatever specificity that exists, and the actual loading of fuel and the supporting information that is developed for that loading of fuel, which is what I am calling plant-specific PRA, which may have more detail in it than the design certification PRA.

But I hear what you are saying.

MR. HAMZEHEE: You know this better than I do, but one of the main reasons that the staff decided to put it in the rule under Part 52, that prior to the fuel load, the COL PRA should be upgraded and updated was because there are still a few areas for which we don't have a standard, such as fire, seismic PRA, shutdown PRA.

So, we wanted to make sure that as soon as those standards are developed, then the COL applicants have to go back and upgrade their PRAs and include those.

CHAIRMAN STETKAR: That I understand, but it says before a fuel load; it doesn't say before I go out with my first bid spec for the piece of equipment.

MEMBER SHACK: But I think that is the problem.

CHAIRMAN STETKAR: That is.

MEMBER SHACK: The current requirements don't provide that window that you would like.

CHAIRMAN STETKAR: Right.

MEMBER SHACK: Now my guess is, if they have it in hand, they would do it. Otherwise, it will be caught, I would guess, in the Maintenance Rule, yes.

CHAIRMAN STETKAR: No, it should be; you know, you have to have confidence that it will be caught as part of the Maintenance Rule program because of either additional information from the PRA in a predictive sense or actual operating experience from a plant after it is operated.

MR. HAMZEHEE: Also, I think the staff, as what Todd mentioned earlier, that, for instance, since we don't have seismic PRA for many of these things, we do have qualitative Seismic Margins Analysis.

CHAIRMAN STETKAR: Uh-hum.

MR. HAMZEHEE: And as Todd mentioned, when they do the risk-significant, they try to be conservative enough so that, once you do have a seismic PRA, the probability of missing something is smaller because we are very conservative. So, that is the approach that the staff has put forward, and I believe it is working well, don't you?

MR. HILSMEIER: And we will see the updated RAP list several times during design construction, when we do the inspection of the D-RAP ITAAC, see the updated RAP list, and, also, when we do the initial inspection of the Maintenance Rule to make sure the Maintenance Rule process has been set up properly. We will see the RAP list and make sure it is incorporated into the Maintenance Rule.

CHAIRMAN STETKAR: That is a good point. So, under those inspection activities, you do get several opportunities to think about it anyway.

MR. HILSMEIER: Right.

CHAIRMAN STETKAR: Good.

Any members have anything else for the staff?

(No response.)

If not, again, I will thank the staff very much.

And I will ask if there are any members of the public here in the room who have any comments to make about the COL applicants, Chapter 17.

(No response.)

If not, thanks again. Thanks to you all.

We will recess until 12:30.

MR. MONARQUE: Oh, John, no open items or no takeaways from the staff on this?

CHAIRMAN STETKAR: I didn't hear anything on this one, Steve.

MR. MONARQUE: Okay. All right.

CHAIRMAN STETKAR: We are recessed until 12:30.

(Whereupon, the above-entitled matter went off the record at 11:37 a.m. and resumed at 12:34 p.m.)

A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

12:34 p.m.

CHAIRMAN STETKAR: We are back in session, and we will hear from Luminant about Chapter 16, "Technical Specifications".

We have already hear, I will refresh everyone's memory -- we had a presentation on the Design Certification Document for Chapter 16 many, many months, probably more than two years ago. So, we are finally getting back around closing the loop on the COLA, Chapter 16.

I guess we still have the bridge line reopened?

MEMBER BROWN: One point on the chapter. That one we did was not -- the SER said it had a ton of open items in it. So, that was not the one we did a year-and-a-half ago.

CHAIRMAN STETKAR: Yes, and that is fine. That is fine.

MEMBER BROWN: We have done it already, and it was not like that when --

CHAIRMAN STETKAR: Well, this phase of our review --

MEMBER BROWN: Yes.

CHAIRMAN STETKAR: -- the SER with open

items, that is true, but --

MR. MONARQUE: Correct. And the reason this took a lot longer is because it was tied into our review in Chapter 19.

CHAIRMAN STETKAR: Exactly. Exactly. Which is why we are discussing it today.

Don, back to you.

MR. WOODLAN: All right. Good afternoon.

I am still Don Woodlan. That was supposed to be a joke. I told everyone I was going to say that.

CHAIRMAN STETKAR: Yes, but you haven't updated your resume. You have like two more hours than the last time you spoke.

(Laughter.)

MR. WOODLAN: With me today I have Tim Clouser, who is our Acting Luminant Operations Lead here for Comanche Peak Units 3 and 4. He brings a wealth of operating experience with him. And we also have George Wadkins from MNES.

And, Mr. Hicks, are you on the phone?

MR. HICKS: I am, yes.

MR. WOODLAN: All right. We have Mr. Hicks from MNES again on the phone, in case we need him.

And with that, I am going to turn it over to Tim to do the presentation.

MR. CLOUSER: Okay. And as Don said, I am Tim Clouser.

And, Don, are you going to operate the slides there?

We will do our standard agenda, introduction, talk about the open items, confirmatory items, and site-specific issues.

So, by way of an introduction, the FSAR uses, incorporated by reference, a methodology with no departures from the US-APWR DCD. All of the COL items are addressed in the FSAR. We have one Safety Evaluation open item and one confirmatory item. License deficiencies are applicable to the tech specs and there are no contentions before the ASLB.

So, our one open item is RAI 90. That is request to a provide a full list of site-specific surveillance requirements affected by the Surveillance Frequency Program and the deterministic values for those frequency assignments.

So, the resolution for that is that the FSAR will be revised with all the deterministic values that are currently in the DCD tech specs, in addition to the plant-specific items, which is just the ultimate heat site.

Next slide.

One confirmatory item, and that is to incorporate the methodology and adequacy requirements in our PRA to support the risk-managed tech specs. The resolution for that is that we will or we do have in tech specs now a requirement in Section 5 to meet the requirements of NEI 06-09 and NEI 04-10, which are the NEI documents that implement a configuration risk-management program and surveillance frequency control program.

That's it, Don. The next one.

MEMBER SHACK: But you are going to have slightly-amended versions of those, right? That was the discussion in the letter that you had back in June of 2011, and I think that is committed to here. It is sort of vaguely described in some sort of program, but those conditions we saw in the June letter are going to be carried forth into the program?

MR. WOODLAN: Yes, and you may remember we did a briefing in the fall on this.

MEMBER SHACK: Yes, probably in October.

MR. WOODLAN: And you are exactly right, we are adopting the NEI documents, but they had to be updated to cover new plants. They were good property plants, and those are the changes we are making.

MEMBER BROWN: Which NEI document are you referring to, 04-10, for the surveillance?

MR. WOODLAN: Yes, right.

MEMBER BROWN: Frequency --

MR. CLOUSER: 06-09 for the --

MEMBER BROWN: 06-09?

MR. CLOUSER: -- for the risk-managed aspects.

MEMBER BROWN: So, I mean, the version of those that I have is like November of 2006 for 04-10. I think that is the date. I don't remember the date for the other one. I may have them reversed. So, you are all waiting for those NEIs, updating those?

MR. WOODLAN: Not yet. I talked to NEI, and it is in the plans to do it. We are the only new plant thus far who is adopting this.

MEMBER BROWN: The risk-managed as well as the SFCP?

MR. WOODLAN: Yes. So, although they haven't updated it yet, what we did was incorporated it with changes, and our methodology documents all those changes, just like pointed out.

MEMBER BROWN: Yes, I don't know whether right now is the right time, but I did have a question. I was reading, it was an old SER from a year-and-a-half ago, or Rev. 8 of the SER with open items. And there was a statement in there that talked about, page 16-29, that talked about -- and this is staff now saying -- "Continuous self-testing" --

CHAIRMAN STETKAR: This is for the design certification SER, though.

MEMBER BROWN: Yes, but --

CHAIRMAN STETKAR: Okay.

MEMBER BROWN: -- it is relative to my comment on the tech specs. I mean, it is the tech specs.

CHAIRMAN STETKAR: I just wanted to make sure that, for the record --

MEMBER BROWN: Oh, this is not in the code. Yes. No, I am using that to ask about a COLA, I think.

CHAIRMAN STETKAR: Okay.

MEMBER BROWN: These are mixed and matched. This seems to be where it is going to be executed.

It said, "Continuous self-testing and online diagnostic monitoring capabilities will be evaluated in Chapter 7 of this report to determine the extent to which these features" -- continuous self-testing and diagnostic monitoring -- "may be credited towards completion times and surveillance testing."

And I guess the PRA is supposed to develop some part of that as the risk-informed application of some of the surveillance comes out of the PRA, I guess. I mean, I am not a PRA person.

But it goes on to say that, "The Probabilistic Risk Analysis will provide detailed explanations and fault trees" for the next revisions and to support the PSMS Reliability Analyses and the surveillance stuff.

And so, I just wondered what that was. So, I went off and looked at the tech specs in Chapter 16. And I will just pick an example, and I happen to have it. Ah, where did it go? Here it is.

In Section 3.3.1, where it talks about reactor trip systems and other instrumentation-type stuff, for calibration checks and other type things, they refer to like 24-months periodicity or intervals or as defined by the SFCP, the Surveillance Frequency Control Program. And that is developed via this risk- and PRA-type-based stuff, based on NEI 04-10 and 06-10, whatever.

And I guess what I wanted to know was 24 months for, say, a calibration check? Is the PRA and the SFCP now going to come through and say, "Well, we don't have to do that for five years."? I am trying to figure out what is the relation between adjusting these surveillance frequencies when, yes, I can't wrap my head around testing and confirming that a sensor actually provides calibrated signals on something more than a year or two basis. I can understand a refueling interval, just because the plants are operating continuously, but extending it to two or three refuelings --

MR. WOODLAN: Well, let me try, first, to give you the licensing understanding, and then, Tim maybe can fill in.

The Surveillance Frequency Control Program is primarily a performance-based program. It looks at your success and what kind of challenges you have had on an individual component, and you adjust based on that for the PRA.

MEMBER BROWN: Okay. Now let me go backwards.

MR. WOODLAN: Okay.

MEMBER BROWN: Okay? Twenty-four months, you are saying, say we do three 24-month ones, and you say, "Gee, we haven't failed any of those. Therefore, we will go two refueling outages." That is what I would envision you telling me. We would extend the periodicity based on the performance. Is that --

MR. CLOUSER: I guess it is possible, but it is highly unlikely because the two or three successor satisfactorily surveillances, depending on what the length of time is, it is just the entering proof you have got to go through to start the process to look at it. Then, you have got to look at the PRA, make sure that the core damage frequency doesn't go up and the larger early-release frequency. And then, you have to look at whether, if that equipment does fail, how that is going to affect the PRA. And then, there is just a whole long laundry list of things that you have to go through, looking at all those surveillances. And then, it has got to go through an independent or an integrated decisionmaking panel, in other words, an Expert Panel, to make sure that it all makes sense after you meet all those other hoops.

So, just satisfactorily completing a couple of those surveillances doesn't get you there. It just barely gets you started.

I don't know if that --

MEMBER BROWN: All I am trying to do is get a feel for what you are -- I am just not familiar with the civilian stuff as much as I am the program that I came out of after many, many decades. Because there is a differentiation between the availability to do certain types of checks on ships than there are in the civilian plants, just based on mode of operation.

Some things, I mean, I could totally understand it because we did it. I mean, channel checks, for instance, they refer to as 12 hours, every 12 hours. I mean, if you have got channels that don't meet their channel check three or five times, you have got a bigger problem than what you thought, if you are doing testing on a 12-hour basis.

I mean, we used to do weekly checks of that type, and we actually tried, we actually did evaluate our weekly checks and determine, geez, we can do them monthly because of the multiplicity or the redundancy that you have, that we could do that and do that fairly -- so I don't have a problem with it. It is just when I get out to -- and the digital stuff is, by and large, better than the analog stuff past this detector, you know, the amplifiers and everything else. I was just trying to get a feel for what that meant relative to the critical calibration-type functions, which are time-intensive and are very much a function of when the plant is shut down as opposed to those that you can do in place with your test signals or other type stuff.

So, I am just saying there is a lot of other hoops to go through. Has this been implemented in any operating plants?

MR. WOODLAN: Yes. How many? Two?

Three?

MR. CLOUSER: Many.

MR. WOODLAN: Many, and there's a lot more applying it. Most of the industry is going this way.

CHAIRMAN STETKAR: When you say "many," there are a few, I think, on surveillance frequencies. There is a lot more on misinformed outage times.

Come up to the microphone.

MR. TJADER: Bob Tjader, NRO, Tech Specs.

It is actually the other way around.

MR. WOODLAN: I thought that the frequencies were --

MR. TJADER: The Surveillance Frequency Control Program is an offline application of PRA and risk assessments. And Doc is absolutely right, as is Mr. Tim Clouser. To revise surveillance frequencies requires going through an accuracy form of the back of 04-10 that has to be filled out and complied with.

And there are -- I don't know the number; NRO Tech Specs would know the number -- but I think probably over 50 percent of the plants have applied for a Surveillance Frequency Control Program. I know probably the vast majority are going to do that.

Limerick was the first. Diablo Canyon has it. I would say probably a quarter of the plants probably have it right now.

CHAIRMAN STETKAR: Is it? Okay. Thanks.

MEMBER BROWN: Excuse me. Go ahead. I didn't mean to interrupt you.

MR. TJADER: And there is only one plant that has risk-informed completion times at the moment, and that is South Texas.

MEMBER BROWN: What do you mean by the completion times? Do you mean how long --

MR. TJADER: Allowed outage times.

MEMBER BROWN: Allowed outages?

MR. TJADER: Yes.

MR. WOODLAN: LCOs.

MEMBER BROWN: Oh, outage, a system or a set of equipment or something? Okay.

MR. TJADER: Yes.

CHAIRMAN STETKAR: I had it reversed somehow. I had heard differences, but I am wrong.

MEMBER BROWN: When you say "outage," do you mean like the 72 hours with the channels out of service, something like that, and trying to extend those periods?

MR. TJADER: If the condition statement allows you to enter -- in the case of Comanche Peak, it would be Tech Spec 5518 -- if that specific required action allows you to enter that, then you can do the online risk assessment and determine what an appropriate completion time would be.

MEMBER BROWN: You do that in real-time? So, if the outage occurs, then you start applying -- that is what I mean by real-time, that you have a problem, and you start doing this risk assessment to see if you have to comply with the 72 or you can stretch it to 128, or whatever, some other number.

MR. TJADER: You cannot stretch it beyond 30 days. That is the backstop.

MEMBER BROWN: Well, 3 days to 30 days is a fairly --

MR. TJADER: I mean, well --

MEMBER BROWN: No, that is okay. I understand that. I wasn't thinking of it in terms of outage times. I was really look at it in terms of what I was looking for was the calibration, both the analog/digital-style calibrations and basic instrumentation channels, as well as normal channel check.

One I could see moving based on a performance-based response, and the other, go after two years and, then, stretch it out to four years to check that your detectors are actually doing what they are supposed to be doing. It seems to be --

DR. TANAKA: I think they would have to really justify extending it based on only two or three --

MEMBER BROWN: Do they have to get NRC approval, concurrence to do that?

MR. TJADER: No.

MEMBER BROWN: They can do it within their own --

MR. TJADER: We can audit it.

MEMBER BROWN: Okay.

MR. TJADER: Our inspectors can review it and audit it.

MEMBER BROWN: But they can make that decision on their own, to extend those surveillance periods, based on this program?

MR. TJADER: Right.

MEMBER BROWN: Has NRC formally endorsed that surveillance program?

MR. TJADER: Absolutely.

MEMBER BROWN: Okay. I had thought I had read something that it had. I just thought I would --

MR. TJADER: There are Safety Evaluations for 04-10 and 06-09, which I think you referred to as 2006 or something.

MEMBER BROWN: The 04-10 I think was 2006.

MR. TJADER: Yes, right.

And then, the NRC, NRR has endorsed it through the granting of license amendments that adopt these.

MEMBER BROWN: Okay. So, in order for a licensee to do it, you have to give agreement to proceed to do it, right? It is a license amendment request to get that, so they can actually implement that program?

Okay. Thank you.

MR. TJADER: Yes, I don't have any more on that.

MR. CLOUSER: Okay. Moving on to site-specific aspects -- go back one; you moved on a little too quickly -- US-APWR tech specs bases are adopted by Comanche Peak Nuclear Power, Units 3 and 4, COLA, Part 4, and the site-specific information is provided in previously-bracketed areas.

Comanche Peak Nuclear Power Plant, Units 3 and 4, have adopted risk-managed tech specs and a Surveillance Frequency Control Program developed under the Initiatives 4B and 5B, as we just discussed.

Luminant will be establishing a Configuration Risk-Management Program and the a Surveillance Frequency Control Program to be completed, reviewed, and approved by the NRC prior to fuel load, and that is out of Tech Spec 5518 and 19 which Bob just mentioned.

And Luminant is following the DCD tech spec changes that are still under discussion to see how it will affect the COLA.

CHAIRMAN STETKAR: Just so we are clear on that second bullet on that slide, it says, "CPNPP adopt risk-managed tech specs and a Surveillance Frequency Control Program". You are not proposing to change any LCO times or surveillance frequencies from the design certification tech specs prior to issuance of the COL, are you?

MR. CLOUSER: That is correct; we are not.

CHAIRMAN STETKAR: You are not? You will adopt verbatim, that last bullet discussion verbatim, the design certification tech spec. So, that second bullet actually is post-COL issuance, with the exception of the structure of the tech spec that says either do this --

MR. CLOUSER: Right.

CHAIRMAN STETKAR: -- or option whatever?

MR. CLOUSER: But it would be a section of the client-specific, which is the ultimate heat sink.

CHAIRMAN STETKAR: Yes. Okay. Thank you.

MR. CLOUSER: Okay.

COLA, Part 4, Section A, justifies to the plant-specific information that has been replaced in the bracketed areas of the DCD, and there are 25 of those specific items. And Section B adopts the entire plant-specific or shows the entire plant-specific tech spec.

And that would be it.

MEMBER BROWN: I do have one more question.

MR. CLOUSER: Okay.

MEMBER BROWN: This is just an information thing, I think. I saw the test for channel checks. I saw the ones for calibration checks. There is another one called channel operational tests, which are different than calibration checks where you are dealing with the sensor directly or just the channel checks which kind of sees -- it is a qualitative test that just sees that the signal propagates from input to output.

The channel operational test put in a simulated signal to represent, so you could kind of test the memory of the amplifiers, whatever else. That is also 24 months, and I guess that must be consistent with what you do on your Units 1 and 2. Otherwise, you probably wouldn't have it in here, I guess.

But you don't have to shut the plant down to do that. And if you have got multiple trains for reactor trip and SFAS-type systems, it just seemed like that was a pretty long time to do what I would call a simulated input, either by whether it is computer-done or whether it is done by manual switches. And it can be done either manually or automatically for the other words in here somewhere.

That 24 months for just doing a check with, say, a resistor, you know, for a temperature channel or an LPT, or something like that, for a pressure channel seems like a fairly long time.

MR. CLOUSER: And I do understand your question and concerns. I am not sure I can address it.

MEMBER BROWN: I am just looking, is that consistent with your all's other plants or for other commercial plants, that that is, quote, "simulated input to a channel" in redundant systems, and the protection of the trip system and the SFAS system are two years? That doesn't seem to have to wait for an outage to do that.

MR. CLOUSER: I have been away from our Unit 1 and 2 tech specs for six years. So, I can't tell you for sure what it is currently.

MEMBER BROWN: Can the staff answer that?

MR. MONARQUE: What was your question

again?

(Laughter.)

MEMBER BROWN: You were an operator, John. I thought you would know this.

CHAIRMAN STETKAR: You said "the staff," and I was an operator before most of the people in this room were born.

(Laughter.)

MEMBER BROWN: Channel operational tests called COTs are specified in the tech spec -- this is in Chapter 16, the DCD -- to be performed every 24 months or in accordance with the SFCP. Okay? That is the same for all of them. But the 24 months, the channel operational test is where you actually insert a test device at the input as opposed to, even on the microprocessor-based systems where you introduce a digital signal upstream of the analog-to-digital converter, not downstream of the analog-to-digital converter. And you check that you get the proper calibrated signal via a number of resistance inputs or LBDT inputs, or whatever they are.

Channel checks are just qualitative. You say do this, and does it trip? And then, the calibration check is where you actually go check the detectors, the sensors themselves.

Twenty-four months on the equipment I am familiar with, we had the capability while you were in operation to test each thing with a simulated signal that would pass through that particular channel and tell you, did you generate the proper trip, was it calibrated, et cetera. You didn't have the detector in it, but it did go into the analog-to-digital converter to make sure that talked, the digital part, the digital stuff, or in the old systems it was in the bridges that took the output to the LBDTs and the resistance places, and check that those were still operating satisfactorily.

We did that much more frequently, okay? Like weekly initially, and then, we finally went to monthly or something like that. But 24 months just seemed to be a long stretch for checking the analog-to-digital conversion part of these things, when it can be done in-service when you have multiple trains.

So, I don't know what they do today in the civilian plant. My question is, if that 24 months is consistent with what is done in the commercial plants today, that you all have accepted that? Then, I don't have -- well, I couldn't complain -- I don't have much basis for saying you ought to change. Okay?

But it popped up here, and I don't remember seeing that anyplace else. So, that is why I asked.

MR. MONARQUE: Okay. Let me --

MEMBER BROWN: You don't have to answer it right now. You can get back to me. You don't have to answer that right now. If you want to get back to me later sometime --

MR. MONARQUE: Okay.

MEMBER BROWN: -- that is okay. So, we can go on.

MR. MONARQUE: Okay. We will take that away as an action item, and we will get back to you on that.

MEMBER BROWN: Okay. Thank you.

CHAIRMAN STETKAR: Thanks, Steve.

MR. MONARQUE: Thank you.

MEMBER BROWN: I'm done now -- maybe.

CHAIRMAN STETKAR: But are you finished?

MEMBER BROWN: I am really finished.

(Laughter.)

CHAIRMAN STETKAR: Any other members have questions for Luminant?

(No response.)

If not, again, this one was really painless.

(Laughter.)

We will have the staff come up and discuss Chapter 16.

And I guess, Girija, we can close the bridge line, if you want. It just keeps the pops and crackles down.

Mr. Hicks, on the other end of the bridge line, we are going to close it from this end. Even though you have been really good about muting your end, we still get a lot of noise. So, if for some reason a question comes up where we need your help, we will reopen it, but it just helps the general noise level down here on this end. Okay?

Thank you.

MR. ROY: Okay. My name is Tarun Roy. I am the NRO Project Manager. I am responsible for coordinating staff review of the Chapter 16 COLA application.

The NRC technical staff involved in the review is from the Balance of Plant and Technical Specifications Branch, Mr. Bob Tjader.

During this meeting, the staff plans to make a presentation on Chapter 16, Safety Evaluation Report with Open Items. We have 20 questions we asked the applicant requesting additional information. Out of 20 questions, there is one open item unidentified in the SER. The staff will discuss the open item in detail.

Now I turn over the presentation to Mr. Bob

Tjader.

MR. TJADER: Thanks, Tarun.

This is just for confusion's sake, this Theodore Tjader.

(Laughter.)

My middle name is Robert. So, I go by Bob.

As Don presented, there is open item and one confirmatory item. We will present the summary of those.

Next slide, please. That's it, yes.

As previously presented, the design certification specs, the US-APWR tech specs, provide the option for adopting risk-management tech specs, otherwise known as risk-informed completion times and, also, adopting Surveillance Frequency Control Program options based on NEI 06-09 and 04-10.

Comanche Peak has opted to adopt these risk initiatives, these I guess state-of-the-art applications of PRA, use of risk information. As previously stated, the risk-management tech spec and Surveillance Frequency Control programs, they require programs in the tech spec admin control section, Section 5 of the specs, which incorporate, in essence, NEI 04-10 and 06-09 into the methodology and the requirements in those documents, incorporate them into the specs. And

Comanche Peak has done that.

Next slide, please.

Since these two applications, these two programs, apply PRA and risk information based on PRA information, the PRAs have to have a capability and a quality, so that they can be applied for these applications. And since the PRA itself will not be ready until the as-built, as-to-be-operated plant is available about a year prior to fuel loading, and it is not available at the time of COL issuance, then a program is required. The tech specs are required to be complete at the time of the issuance of the license, in accordance with ISG-08.

We provide three options to comply with and meet these requirements, and Option 3 methodology is the option that is being applied for ensuring that the PRA is adequate to support these programs.

The staff has reviewed Comanche Peak's tech spec methodologies for completing a PRA. We have, in essence, approved it in the Safety Evaluation for Chapter 9, and we have, through an iterative process with Luminant, have determined that it is adequate for applying to these programs.

The methodology for ensuring the PRA is adequate, not only does it ensure that the PRA is adequate, but, as also previously applied, it also updated NEI 06-09 and 04-10 to a small degree to ensure that they apply to the new plants. And these also are referenced in the admin control section in the same paragraphs of 5.5.18 and 5.5.19.

Next slide.

CHAIRMAN STETKAR: Bob, before you get to this open item --

MR. TJADER: Sure.

CHAIRMAN STETKAR: -- I read all of the words about approving methodologies and approving NEI guidance and all of the things that you just discussed. How does the staff assure themselves, and when is that assurance developed, that, indeed, the PRA that is used to support those risk-managed tech specs is of sufficient quality for those applications?

Because it is clear, reading the SER for Chapter 19 of the design certification, that the current PRA is not adequate. So, things have to be done, things that are perhaps more fundamental than simply saying what is the installed -- you know, do I have a motor-operated valve here, for example.

Do you rely completely on the peer-review process that is done under the NEI guidance to give you that assurance that the PRA is complete and of adequate technical detail?

MR. TJADER: Well, we rely on the peer-review guidance. We rely on Reg. Guide 1.200. We rely on the requirements stipulated, that it has to be, you know, Capability Category 2, PRA, that sort of thing. In addition, the methodology has some -- the licensee has to address certain uncertainty aspects of the PRA.

But, to a large degree, just as Reg. Guide 1.200 is allowed to be applied by individual licensees on operating plants without prior NRC oversight, so, too, are we relying on this peer-review process in Reg. Guide 1.200 to be applied by the licensee. Now that is not to say that separately the PRA does have, I believe, ITAACs associated with it, not associated directly with the tech specs, but they do, to ensure that they are appropriate.

And just because there is not stipulated that inspection or an oversight review by the resident inspectors and things like that -- I am sure that that will occur. And we will ensure that it is adequate.

MR. MONARQUE: Oh, John? John?

CHAIRMAN STETKAR: Yes?

MR. MONARQUE: We do have Lynn Mrowca here to give supplemental information --

CHAIRMAN STETKAR: Good.

MR. MONARQUE: -- to answer your question.

CHAIRMAN STETKAR: Hi there.

MS. MROWCA: Hi. This is Lynn Mrowca.

One more thing to add to what Bob said is that we have precedent for inspecting the implementation of risk-managed tech specs. So, we fully assume that that will be done.

CHAIRMAN STETKAR: Okay. I will bring up more when we get to the Chapter 19. I am troubled about this process, quite honestly, because I read words, and I know the SER says otherwise, that, indeed, the thing that I can look at today, Rev. 3 of the PRA, has been subject to a peer review according to the guidance in Reg. Guide 1.200 and satisfies all of the ASME/ANS standards for quality of the PRA. And it is my opinion that it doesn't.

And I will bring up very specific examples. I know the staff has taken issue with those statements. But my concern is that, if we keep relying as an agency on peer reviews of things that have received tacit approval of the NRC staff -- the NRC staff has tacitly approved the design certification PRA, except for these key issues of uncertainty, or something like that -- we are walking ourselves down a slippery slope where nobody has really taking a holistic view at that PRA to say, is it really what I would call a risk assessment rather than a political document, quite honestly?

And I would hope that the staff and those inspections, if that is the only vehicle that you have for the actual risk-informed technical specifications, performs a rather detailed audit of the PRA and a rather detailed review of that peer-review document. Because peer reviews are peer reviews. They are done by human beings over a limited amount of time, according to guidance that is written on pieces of paper.

MS. MROWCA: We fully agree, and that would be our plan, to do a detailed review at that point. And implementation can occur anytime, you know, post-fuel-load. So, I would expect that we would do something very quickly after that.

CHAIRMAN STETKAR: Okay.

MR. TJADER: It is my understanding, though, that the peer reviews are rather rigorous these days, that the licensees have experience of doing them with respect to PRAs, and they are pretty self-critical.

CHAIRMAN STETKAR: You know, I haven't been involved in any. So, I can't comment on that. My problem in seeing reviews that have been done in the past is that people tend to review what is there and accept previous audits, inspections, whatever, as assurance that what isn't there ought not to be there, if you will. And those omissions are where people get in trouble.

MEMBER SHACK: Of course, that is a larger question than just this.

CHAIRMAN STETKAR: That is a much larger question. It is why I am going to talk about it a little bit more in the context of the design certification PRA.

MR. TJADER: Well, we agree that it is an important question, particularly for applying risk-informed completion times.

CHAIRMAN STETKAR: And in particular, on this one, I mean, I dug into this PRA a little bit more detailed than I would normally do because of its projected use going forward, recognizing that we, as the ACRS, won't have this opportunity again. At the COL issuance, our involvement ends. So, any of our concerns regarding potential pitfalls in using this particular model going forward, we basically have to get out on the table either today or when we revisit these chapters in the final SER.

MS. MROWCA: There is different criteria for a design certification PRA than there would be for one that implements a risk-informed application, and we fully understand that, that there will be quite a few changes between the design certification PRA and the one that is used to implement risk-managed tech specs.

CHAIRMAN STETKAR: As long as everyone understands that, as long as the applicant is fully cognizant of the fact that they can't take this particular risk assessment, add in a plant-specific switchyard arrangement, and plant-specific ultimate heats in cooling towers, and say the NRC staff has said this one is okay. MHI has said that it has been peer-reviewed and meets all of the ASME/ANS standards. That is in writing. And therefore, we can use it.

MS. MROWCA: That is why we have been very careful about documenting assumptions, uncertainties, and trying to make sure that our COL action items or older items include those details of the PRA that we have seen that need to be upgrade/updated prior to use of it for risk-managed tech specs.

CHAIRMAN STETKAR: Okay. Thank you.

MEMBER SHACK: It is a little strange that the one example we have of risk-managed tech specs is South Texas, which is sort of reputed to have a very high-quality PRA, and now we are suddenly going to leap to a plant with no operating experience, you know, and it is just a little different.

(Laughter.)

CHAIRMAN STETKAR: I understand.

MEMBER SCHULTZ: It presents different challenges.

MEMBER SHACK: It presents different challenges.

CHAIRMAN STETKAR: Well, it presents a lot of challenges, in my mind. I understand the design certification process and what is expected of a PRA to satisfy the intent of that process. I understand. I don't have to agree with it, but I understand it.

The challenges are for Luminant going forward and that poor peer-review team who must take something with a history to it now -- it is not a new PRA that is presented to you, and you are assessing the quality of it -- it is something that now has a history, and very, very rigorously critique that risk-assessment model for its quality, detail, and all that kind of stuff to support those applications. That is a real challenge from a real practical review perspective and assurance perspective.

CHAIRMAN STETKAR: Yes, you have listed three very important components of the task, and it hasn't been done before.

CHAIRMAN STETKAR: That's right.

MR. TJADER: With regard to its application to the risk-informed completion times, I personally don't feel that we are going that far out on a limb or taking that much of a risk and applying it to it, for a number of reasons.

No. 1, we have the backstop where you can't extend the completion time beyond that. Generally, for Comanche Peak, in particular, they are applying it to a very limited set of completion times, and you are not allowed to apply it to loss of function. You basically apply it to a loss of a single train for the most part, application.

And in addition to that, because Comanche Peak is a four-train system, and we are applying it to one or two trains out, for the most part I think that, in fact, whatever PRA you come up with, assuming that you come up with a good one, but, I mean, assuming there is a lot of uncertainty in it, and given that initially, I still think that it is not highly inappropriate to apply it because you have a four-train plant. You are limiting its application. And because it is a four-train plant, and you apply the metrics that 06-09 allows you to apply, in many cases, if not most of them, you would probably run into the backstop, the 30 days, because it is relatively risk-insignificant.

So, it is not like we are allowing them to operate in an unsafe manner. We are not. In fact, if anything, I look at these applications as actually enhancing safety. In fact, that is what they should be doing and are doing, is enhancing safety, because you are letting them apply an appropriate completion time for restoring equipment to operable status prior to taking subsequent actions, such as shutting down the plant.

CHAIRMAN STETKAR: One of the things we found on South Texas -- and I happened to have been involved in the first applications of that PRA -- is that they discovered that some of their completion times they needed to rein-in a little bit. They needed, in fact, to tighten them up compared to what they had in the generic tech specs. It was kind of a surprise to them, and they did that.

And --

MR. TJADER: Let me -- go ahead.

CHAIRMAN STETKAR: Let me finish.

Things that bother me are that, for example, the current completion times that are in the existing design certification tech specs aren't modeled in the PRA. The capability to have two pieces of equipment out in the same system simultaneously, as allowed in the current PRA for 72 hours for a large number of systems, is not only not modeled, it is logically excluded. There is logic in the PRA model that does not permit that configuration. It has zero likelihood. The logic explicitly excludes it.

So, the current PRA doesn't even model the current tech specs, period. So, I don't know whether the current PRA -- you know, certainly you can't use the current PRA to justify extending the tech spec times because it doesn't model what is in there now.

Those are some of my concerns. If, indeed, I looked at today's PRA and said, oh, yes, they allowed -- there is some uncertainty; I don't know exactly how long within this indeterminate time that I can have a single train out, how long it might be out. I have experience from European plants that might a week to a couple of weeks per refueling outage because it is planned maintenance now, not emergency maintenance. And I don't have the likelihood that two pieces of equipment will be out at the same time. That tends to be combinations of plant and emergent maintenance.

I don't know. There is some uncertainty about that. But the models don't even include that.

I can't even test that in the current model.

The staff, during their review of the PRA, asked for some sensitivity studies, and it was identified as a key issue of uncertainty to be resolved later, when the plant-specific PRA is developed for these risk-informed applications.

So, the confidence that applying the PRA to most likely support running into backstops, I don't necessarily have that confidence. That might happen; that might not happen.

Those are some of the concerns that I have, you know, kind of going forward from what we can look at today to support the design certification and what is available at the time of COL issuance, making that large leap to a real risk assessment to support these risk-informed applications.

And we will talk a little bit, I think, more about that when we get to the PRA itself. I mean, that sort of ended my rant for now. But those are some of the concerns at least that I have.

MR. TJADER: Well, it could be that the PRA doesn't model one train out, because when you deal with four trains, two are required.

CHAIRMAN STETKAR: I will tell you what it does. It models an average unavailability of each component in the plant based on generic data from NUREG/CR-6928, which is U.S. data with U.S. tech specs and U.S. plant design. That is what it does.

And it models that individually for each component in the plant. It does not take an entire train out, as plants in Europe do. So, you will do a planned maintenance on Train A. Simultaneously, every piece of equipment in Train A will be out some number of days. They do that because they can do that, and it allows them to perform maintenance during operation. I mean, it is why you build a four-train plant from an operations perspective.

So, the PRA does not have that coordinated train-level maintenance. Every piece of equipment is out independently in the plant, and the logic precludes, through the structure of the fault trees, precludes two pieces of equipment in the same system being out simultaneously. The PRA model will not allow two emergency feedwater pumps to be out simultaneously. Now the tech specs for emergency feedwater will not allow that.

For electrical buses, AC and DC, AC buses high-head injection pumps, for cooling-water pumps, for essential service water pumps, all of those things can have two pumps out simultaneously. The PRA model does not allow that. It precludes it logically. You cannot see a cut set with those two out.

So, it does not model the tech specs at all, nor does it model the likely application of the tech specs for this coordinated planned maintenance that a lot of plants do where you have entire train out. You can have Train A HHSI pump out independently or you can have Train A EFW pump out independently or Train A, whatever I said, containment spray pump out, but you can't have them all out at the same time.

Again, the staff's review of Chapter 19 acknowledged this, and some sensitivity studies were done and say, yes, if we did that, the risk would increase, but, well, that is a key uncertainty issue to be resolved later.

My question, when staff comes up for Chapter 19, is, why don't we resolve it now? Why don't we really make the design certification PRA model the design and the design certification tech specs? Start from there.

MR. TJADER: Well, I think we do have some things we can do.

CHAIRMAN STETKAR: Well, yes, we will talk a few more things about it. But this is important, back to the topic at hand, this is important I think for our understanding, at least to know the process that people are going to apply and sort of the timing considerations when that process will be implied.

Now you can go to your open items.

MR. TJADER: Okay. Open item. One of the RAIs was requesting, since Comanche Peak was adopting the Surveillance Frequency Control Program for many of the surveillances that are in the tech specs, they have chosen to say, in accordance with the Surveillance Frequency Control Program, in the frequency column "as is appropriate," but we wanted them to state what are the initial frequencies that you are using. And the response to the RAI was that we are using the initial DCD values, except for ultimate heat sink, which is a site-specific system, and we will give you those numbers, which they have done.

And then, those numbers will be in the program. So, from a tech spec perspective, when you are up and operating, that is perfectly satisfactory. The numbers are in the program. The program is required by specs. And to revise them, you have to do it in accordance with the specs, in accordance with the referenced 04-10.

So, when you are up and running and you have the program in place, you have the frequencies in the program, that is fine. The members of the staff, however, raised the question, "Well, before the program is actually" -- that is, the actual, not the tech spec program which is there, but the program that it references that is going to incorporate or include these surveillance frequencies, that will not be in place until, again, probably -- well, pure load is when all these programs, however they are processed for creating the programs is, will be in place. This is, until that point in time -- you know, once you are up and running, the frequencies are in the program and are hard and fast. They are as if they are in the column, in the frequency column in the spec. But, until that program is approved and ready for use, there is this period of time between the COL and that program where the question is raised, well, what if they come up with a better frequency for one of the numbers and they want to change it? You know, what is to prevent them from doing that or just changing the number?

And so, we requested that they put the initial values of the Surveillance Frequency Control Program in the FSAR, so there is some oversight process to it initially. And they have agreed to do that.

So, it just a matter of us -- and actually, all that they need to do, in essence, is reference in Chapter 16 of the FSAR, reference the DCD values. They don't even have to have the list except for the ultimate heat sink, which they will put in there. They have agreed to do that.

So, the reason it is open is that we just need to see their proposal for where they are putting it, i.e., Chapter 16 of the FSAR, and what they are putting there. And once we see that and approve it, this will be closed. It should be relatively easy to close.

And that is the open item. As far as the confirmatory item, it is basically, once we have the approved version of the tech spec PRA methodology, that that reference will be specifically incorporated in the next revision to the tech specs in there. So, it is a rather simple thing.

For the most part, other than instrumentation and ultimate heat sink, they have been incorporated by reference. So, the tech specs are accepted.

CHAIRMAN STETKAR: Okay. Thank you.

Any questions for the staff, Chapter 16?

(No response.)

No?

Again, this ends another topic. So, I will take the opportunity to ask if we have any comments from members of the public regarding COLA technical specifications.

(No response.)

Hearing none, we will now hear from Luminant on loss of large area events.

MR. MONARQUE: Mr. Stetkar?

CHAIRMAN STETKAR: Yes?

MR. MONARQUE: We need to close the session for members of the public.

CHAIRMAN STETKAR: Okay. We will do that. So, can we make sure that the bridge line is closed completely, Girija?

And I will ask MHI and the staff to make sure that people in the room are appropriately cleared for this session.

For the record, let's recess briefly while we reconvene here. I don't want to give anybody a break. It is too early for a real break. So, just hang around while the staff gets -- just be aware that if there are two of us in our mind or in the room, I am going to whack this gavel.

(Laughter.)

(Whereupon, the above-entitled matter went off the record at 1:30 p.m. and resumed at 2:28 p.m.)

CHAIRMAN STETKAR: We are back in session.

And as I understand it, at least at the beginning, this session is open. Is that correct as far as MHI is concerned?

DR. CURRY: Yes, sir.

CHAIRMAN STETKAR: If we get into detailed questions that delve into areas that you feel it is necessary to close the session, please let us know and we will deal with those appropriately, because I know the PRA report and details in there are proprietary. So, we will rely on you to alert us to topics where we are getting into treading on proprietary information.

And with that, it is yours.

DR. CURRY: Thank you, Mr. Chairman.

My name is Jim Curry. So, we are here to discuss Chapter 19 DCD. And on the panel in front of you is Dr. Tanaka, who you saw this morning; Mr. Nirasawa, and Mr. Ed Wiegart. And we have additional folks here to support us as necessary. Dr. Tanaka and Mr. Nirasawa from MHI and our PRA subject matter experts; Ed Wiegart is MNES, also a subject matter expert in PRA.

We heard your comments this morning, you know, about the transition from a design certification PRA to one that is suitable for plant application purposes. We also heard comments on Expert Panel and peer review. So, we welcome the additional detail that you mentioned, and we brought people up to the table that we thought would be best focused on that issue.

We also have Mr. Goda, Hiroshi Goda, from MHI here, when we get to Level 2 in severe accident analysis, but we figured we would probably be starting on Level 1. Just our intuition.

(Laughter.)

Okay. So, thank you for the comments this morning. Based on the comments this morning, I think we can probably expect some discussion on some of our slides. And we welcome that additional discussion.

So, let's just start as we did with other sections. Chapter 19, for those that aren't intimately familiar, has four major sections. 19.0 is the first major section, and it summarizes PRA objectives, the conclusion that the US-APWR meet safety goals, and is of a quality and detail to support risk insights at the design certification stage, and key references.

19.1 provides Level 1 and Level 2 probabilistic analysis results and uses of the PRA, one of which is to support the RAP, which we discussed this morning.

The DCD evaluates internal events, flood, fire, and seismic. So, our understanding is that the Seismic Margins Analysis, which is in the DCD, is not going to be discussed today. That will be discussed in concert with Chapter 3.

So, we will be focusing on the internal events, at-power PRA, internal floods, and internal fires.

Section 19.2 is the severe accident evaluation.

CHAIRMAN STETKAR: Jim, I'm sorry.

DR. CURRY: Yes, sir?

CHAIRMAN STETKAR: Are you going to talk about, also, the low power and shutdown part of the PRA?

DR. CURRY: Loss of --

CHAIRMAN STETKAR: Low power and shutdown.

DR. CURRY: Oh, yes, absolutely, because you get low power at shutdown --

CHAIRMAN STETKAR: Because all you said was "at power".

DR. CURRY: Yes.

CHAIRMAN STETKAR: Okay.

DR. CURRY: Yes, sir.

CHAIRMAN STETKAR: Thanks.

DR. CURRY: Yes, that is on the agenda. Thank you, sir.

And then, 19.3 summarizes COL items resulting from the PRA and is kind of the transition point to the COL actions to maintain, update, and upgrade the PRA over time.

All right. There are a couple of appendices; for example, the Aircraft Impact Assessment Summary, which is outside of the scope of this discussion as well.

Relevant Technical or Topical Reports, there are three, which we believe the staff has: the PRA itself, which is 07030; a report, 08004, which was performed for SAMDA purposes and addresses, also, consequences, and another MUAP which addresses the treatment of hydrogen in containment.

Are there any other Topical Reports associated with the PRA?

MR. SPRENGEL: Real quick on that, Jim, to interject, just so the members are aware, we are adding this slide at the request of the staff and we will use this consistently going forward. Sorry, the previous slide on the reports, just to make sure that we have a good understanding of where the reports are being applied within the chapter. So, we are developing that going forward.

DR. CURRY: Okay. Level 1 PRA, the PRA demonstrated that the US-APWR evolutionary design meets the probabilistic safety goals. The PRA identified design improvements, which we will summarize for the Committee.

The PRA model was developed consistent with the guidance provided in the Reg. Guides and the ANSI standard, which the Committee referred to this morning.

At the design certification stage, bounding assumptions were used when detail was not available; for example, specific plant procedures.

We would refer you to Table 19.1-119, which is a summary in the DCD of important assumptions and risk insights.

Where appropriate, there are COL action items that are identified. And again, there is a summary in Section 19.3, but the COL action items are also identified in that table.

The PRA was developed with good administrative controls, independent review, a corrective action. There is a qualification program for PRA analysts. The model was peer-reviewed some number of years ago, and the peer review included outside parties, independent outside experts.

CHAIRMAN STETKAR: Is there a peer-review report available?

DR. CURRY: Yes, Dr. Tanaka, I believe we do have one, and I think we have given it to the staff.

CHAIRMAN STETKAR: Have all of the findings from that peer review been addressed and resolved in Revision 3 of the PRA?

DR. TANAKA: Yes. Of course, there are requirements that are not applicable to design plans, like operating experiences.

CHAIRMAN STETKAR: Sure, I understand that. But, in terms of any technical findings from that peer review regarding the models or the data or the event sequence model, the systems model, the data, and so forth, regardless of operating experience, all of those have been resolved in --

DR. CURRY: Rev. 3 of the PRA.

CHAIRMAN STETKAR: -- reflected in DCD Rev. 3?

DR. TANAKA: Yes, it is reflected in 3, yes.

CHAIRMAN STETKAR: Okay. Thank you.

MEMBER REMPE: Okay. So, Level 1 and 2 were reviewed, and that includes the Severe Accident Analysis, too? And what about Level 3, because it was issued after that date? And is there a plan to have it reviewed?

DR. TANAKA: The Severe Accident Analysis was not subjected to peer review; Level 3 was not. Only Level 1 and Level 2, yes.

MEMBER REMPE: Is there a plan to have those other items peer-reviewed?

DR. TANAKA: For the DCD, no.

CHAIRMAN STETKAR: And one other question. When the peer review was done, was the peer review performed with consideration of Capability Category 1, 2, or 3 from the ASME/ANS PRA standard?

DR. TANAKA: It did not have like a target. We knew that for the DCD. And so, it was not -- in this case, it was Category 1.

CHAIRMAN STETKAR: Category 1?

DR. TANAKA: One, yes.

CHAIRMAN STETKAR: Okay.

MEMBER BLEY: But it was done against the standard?

DR. TANAKA: Yes, it was done against the standard.

MEMBER BLEY: But only Category 1?

DR. TANAKA: Only 1.

MEMBER BLEY: Okay.

CHAIRMAN STETKAR: It is a big jump between Category 1 and 2, and that is why I am trying to understand in terms of technical quality.

DR. TANAKA: I will try to answer as correct as possible. So, basically, yes, the Category 1, but if it is better, then, of course --

CHAIRMAN STETKAR: But let me see if I can understand. Was it reviewed specifically against Capability Category 2 requirements? In other words, were the findings organized against Capability Category 2 or were they organized against Capability Category 1? And findings said, for example, it is deficient because it does not meet Capability Category 1 requirements here, but it is better than Capability Category 1 in some other areas? That is different than saying I review it against Capability Category 2.

DR. TANAKA: I will have to check that out --

CHAIRMAN STETKAR: Okay.

DR. TANAKA: -- to be more precise.

CHAIRMAN STETKAR: I would appreciate if we can get some feedback on that because it may affect some of our questions later. Thank you.

DR. CURRY: Okay. We understand that action.

The PRA scope --

MEMBER SCHULTZ: Just one moment, Jim.

DR. CURRY: Yes, sir?

MEMBER SCHULTZ: On that last slide, the qualification program for PRA analysts, could you expand on what that entails and how many analysts have been through the qualifications program?

DR. CURRY: So, Nirasawa-san, number of analysts that have been qualified?

MR. NIRASAWA: Yes. Number of PRA analysts is 15 now.

MEMBER SCHULTZ: And the program, can you describe some elements of the program at a high level? What is defined as a qualification, the major elements of the qualification program?

DR. TANAKA: Well, of course, we consider the experience in the area of PRA which he or she will be working on and the training. Training, but it means it is in MHI, being trained for that area.

MEMBER SCHULTZ: Is it a mentoring process?

DR. TANAKA: It is mostly a mentoring process.

MEMBER SCHULTZ: Okay. And then, a qualification program with a mentor to demonstrate capability for a particular application? You mentioned that an individual might be working on a particular part of the PRA.

DR. TANAKA: Right, yes.

MEMBER SCHULTZ: Okay.

DR. TANAKA: So, he or she has to have

experience in that area. Some do not cover all of the PRA aspects. We define which area a person has experience in, so that we have the right person working on the PRA area.

MEMBER SCHULTZ: Good. Thank you.

DR. CURRY: The scope, as we discussed before, but just to kind of clarify, the DCD PRA will address internal events, both at-power and low-power shutdown conditions as well as internal flooding, internal fire, and seismic. Seismic is not within the scope of today's discussion. Again, it will be part of Chapter 3. Then, other external events are handled in the SAR by the COL applicant.

In some cases, a bounding assumption was used, notably where you see the black triangles. In calculating the LRF values, the containment was assumed to be open to the environment.

The uses of the PRA, as you might expect, were to identify and eliminate weaknesses in the design. The PRA, in the course of the US-APWR development, proposed and implemented design changes to reduce plant risk. So, some examples are the first bullet, alternate charging pump cooling. The charging pump is important to protecting RCP seals. So, an alternate method was identified to provide charging pump cooling.

On the second bullet, I would like to make a correction, if you don't mind. On the second bullet, instead of the locked closed state for the emergency letdown isolation valve, that should read "RHR full-flow test line valve". And that is what is locked closed, particularly relevant to the low-power shutdown condition. And the intent is to avoid diverting our HR flow back to the RWSP. It is relevant in the fire because you could have a hot short. So, that should be "RHR full-flow test line".

The third bullet, another design insight was to prevent a loop with the turbine building, in the event of a turbine building fire. So, electrical rooms were separated with fire barriers and, also, the offsite power ducts had some fire separation implemented.

Another insight from the flooding perspective was the separation of ECCS pumps and component cooling water pumps. The ECCS pumps are separated by train. The CCW pumps are separated by subsystems. Subsystem in the case of CCW is two trains.

Another use, as we heard this morning, was input to the Reliability Assurance Program. So, from a Chapter 19 perspective, we probably aren't going to get into a whole lot more detail unless the Committee wants to comment. We did hear your comments this morning.

So, we would be happy to take any additional comments.

CHAIRMAN STETKAR: I don't know when best to raise this question. Please defer it if you think it is better to discuss it in a different part of the presentation.

Regarding that last bullet -- and you heard earlier comments -- but there are many things in the plant that are either not modeled at all in the PRA or are modeled very simplistically. An example is, in fact, the main feedwater system where recovery of main feedwater has a value of .1. There is no model for the main feedwater system. There is no model for the non-essential power systems.

And there are a lot more specific details, but I want to try to keep this at a fairly high level, at least at this stage of the discussion. How do those modeling decisions affect the relative importance now of equipment that is explicitly modeled in the PRA versus the actual risk importance of equipment that is not modeled at all? And when it is not modeled, in some cases it is assumed to be failed and in some cases it is assumed to be perfectly available. So, not modeled is simply not modeled.

And my concern is, from the purposes of the Reliability Assurance Program, at, again, a high level, if I have modeled something and it has a relatively high importance because I can actually test the PRA and run out all of those importance measures and all of that stuff, I have not modeled something else. So, I don't have any numerical measures for it.

Perhaps if I put it in the PRA, I would find that, indeed, it is somewhat important to risk. In other words, its Risk Achievement Worth or its Fussell-Vesely importance are not zero. And indeed, that equipment might be elevated in importance to risk compared to where it is now; it is completely unimportant. And conversely, some of the importance of the systems and equipment that I have modeled might be reduced. And that rearrangement of relative numerical importance could affect decisions regarding the structure of the Reliability Assurance Program lists. At a high level, that is sort of the issue that I would like to address now in terms of this is completeness of the existing PRA models and how they might affect that last bullet on your slide.

DR. CURRY: Let me make a couple of points, and then turn that question over to Dr. Tanaka.

A couple of points, first, though, from a top-level perspective. You know, what to do simplified modeling on, as you know, versus what to ignore is an important value judgment right off the bat.

CHAIRMAN STETKAR: Yes.

DR. CURRY: And so, that would be probably an acceptable approach, clearly, at the design certification stage.

The second point is recall those risk measures, the Fussell-Vesely and the RAW value, I think the US-APWR uses those measures where other plants might have chosen different threshold values. So, we end up with a list that is pretty broad in the RAP.

CHAIRMAN STETKAR: I am aware of one design certification that used others. I think that everybody else has used the same values you have used.

DR. CURRY: Right, but, you know, there is an argument to be made for --

CHAIRMAN STETKAR: IBF. Yes. Yes, we have plowed that ground.

DR. CURRY: Excellent.

CHAIRMAN STETKAR: You are using the values, the good news is you are using the values that are more universally used --

DR. CURRY: Right.

CHAIRMAN STETKAR: -- and you are using

values that are consistent with the values that are typically applied in the --

MEMBER SHACK: Maintenance Rule.

CHAIRMAN STETKAR: -- thank you -- Maintenance Rule importance determination. So that you don't face this kind of discontinuity that some others have faced.

DR. CURRY: That's right, yes.

CHAIRMAN STETKAR: So, you are at least in line.

DR. CURRY: Right. Thank you, sir.

CHAIRMAN STETKAR: Recognizing that, indeed, arguments can be made otherwise.

DR. CURRY: Exactly. With that kind of backdrop, then, I guess your question is, look, if we assume that a system or a component is completely available or is just ignored, how much have we potentially modified or could modify the resultant importance measures?

CHAIRMAN STETKAR: Right. Right. And the reason I bring it up is, in terms of a very high-level determination of, are there any particular, let's call them, outliers in this design that are very, very important to risk that you would like to address? Or is the overall level of risk within nominal acceptance goals?

One might make decisions in one direction to achieve those goals; whereas, those decisions might mask other things that are more important to having a better balanced set of understanding of relative importance for, in particular, the Reliability Assurance Program.

DR. CURRY: So, maybe the first way to attack that is just kind of speak about the completeness and the thought process of what was in and not considered in the PRA initially.

CHAIRMAN STETKAR: And if you would rather address that as we kind of go through the different elements, that is perfectly fine. I mean however you feel it is better to address that. But that is one of the higher-level concerns that I have.

DR. CURRY: I think it would be appropriate to just hit it now.

DR. TANAKA: I am thinking which to start with. For the components that are not in the PRA, but we know the impact of the failure of that component has impact similar or the same to what is modeled in the PRA. For instance, we have a human action that is important. And all the equipment used relied on for that human action may not be all modeled in the PRA.

It is too detailed probably.

In that case, we look at the importance of human action. We can kind of estimate at least for the Risk Achievement Worth of the equipment that is relied on for the human actions. Because an indicator, for example, if it has failed, that could result in a failure of the human action. That means probably the Risk Achievement Worth will be the similar value.

And if the PRA team with analysts identifies those kinds of components which are not modeled, and which can be estimated from other important value of other components or human actions, we assume that it has the same importance value. And if it is above the criteria, if you enter it in the RAP, it will be.

CHAIRMAN STETKAR: Let me follow that because an example that I can point to there that you might say, although it is not characterized as a human action, is the .1 value that is in there for main feedwater --

DR. TANAKA: Yes, okay.

CHAIRMAN STETKAR: -- restoration of main feedwater. And now, it is not characterized as human action, but let me think of it as a human action right at the moment.

Suppose that if you had actually modeled the main feedwater system and modeled a human action to restore it within a particular period of time, suppose that the reliability of successfully restoring main feedwater to the steam generators was 10 to the minus -- I will pick a crazy number -- 10 to the minus 10. You have absolutely perfect operators and a really good system. Wouldn't that change the overall results of your PRA from many transient events, because you wouldn't challenge bleed-and-feed cooling. The importance of bleed-and-feed cooling, the importance of the SDVs would not be as important to your overall risk results. And you wouldn't challenge containment heat removal, so it challenges the CS RHR, and alternate containment heat removal wouldn't be as important, simply because main feedwater was a lot more reliable than the .1 number that is in there.

DR. TANAKA: Yes, that's --

CHAIRMAN STETKAR: So, here is an example where you threw a number in there that you can call a human reliability number, but it really isn't because you didn't do a human reliability analysis. And it may, for a large number of initiating events, be numerically conservative, quite conservative. It may be optimistic for others because there might be some buried in there for which recovery of feedwater is not possible. And that is an example of my concern.

DR. TANAKA: This may be a different one of that -- in other words, it is kind of a rough estimation. It was based errors that can lead to lost power, failure to recover the main feedwater. It is not a value just without any basis.

So, it shouldn't be like the magnitude is different, you know. Like, or is magnitude different from what it would be if you had been modeling detail? So, that is one.

And also, when --

CHAIRMAN STETKAR: And that analysis is based on -- I couldn't find that analysis anywhere.

DR. TANAKA: It is kind of a simple analysis. It is simple. We just listed out what kind of failures that can lead to failure of the main feedwater recovery, and we gave a bounding value which is not so far, but it is bounding enough so that, if we have missed some closes, it will not bump up that value. That is one.

And the contribution of that event to the total core damage frequency is not much as high -- if that failure contributes, dominates the risk, of course, it can distort the other importance values. But it was not high enough to distort the other risk-important values.

CHAIRMAN STETKAR: But if you made it perfect --

DR. TANAKA: Yes.

CHAIRMAN STETKAR: -- you would never need to go to bleed-and-feed. So, anything to do with the SDVs for bleed-and-feed, anything to do with heat generation into the containment during bleed-and-feed scenarios would disappear from the risk results. You need to think about making the effects of not only how important is it if it fails; you need to think of how important is it if it succeeds, because that can change the overall risk profile.

And I understand what you are saying in terms of, given the .1 value, it is not very important. And even if we made it a lot worse, it wouldn't make things too much different in terms of overall risk profile, if I think of it that way. But if you made it perfect, how would things change?

Now it, obviously, is not perfect.

DR. TANAKA: Yes.

CHAIRMAN STETKAR: But we don't know where it is between .1 and perfection.

DR. TANAKA: Well, that can be estimated by the Fussell-Vesely value of that basic event because that gives the contribution compared to the core damage frequency. So, unless that Fussell-Vesely value of that failure of main recovery is high or close to like 0.-something, 10 percent or more, even if we made it perfect, it should not distort the whole risk profile.

DR. CURRY: It is essentially what the Fussell-Vesely value does, right?

CHAIRMAN STETKAR: Yes.

DR. CURRY: It assumes that the probability of failure is zero.

CHAIRMAN STETKAR: That is one way of thinking about it. That is one way of thinking about it, yes. Okay.

Go on. I kind of interrupted you. So, in one case, you are saying that in some places you have effectively used human actions as a surrogate to things that aren't, for pieces of equipment that aren't modeled?

DR. TANAKA: Exactly, yes.

CHAIRMAN STETKAR: Are there other places where you have not modeled things where you have not used human actions as a surrogate?

DR. TANAKA: Basically, where I did not use it? So, okay. Another example is what we had in the morning session, the accumulator. We don't model the failure of the accumulator to attack itself. So, that does not appear in the cut sets or the importance.

But we know that the function of that accumulator should be important because we model, for example, the check valves after the accumulator, and it has a high importance value. So, we know that the accumulator itself, it should be important. And that is how we identified that particular component, SSC. So, that is another example.

CHAIRMAN STETKAR: What about something like -- and I will bring it up again because I like ventilation -- what about main control room ventilation?

DR. CURRY: Could you just elaborate a little bit?

CHAIRMAN STETKAR: Main control room ventilation is not modeled in the PRA. This morning, during some of the discussions we have had, it was noted that, well, it is not modeled because, even if it gets really hot in the main control room, the operators can go to the remote shutdown console. Okay, maybe that is certainly the case.

I don't know whether there are some contributions from chilled-water failures, for example, that would disable ventilation for both the main control room and the remote shutdown console area, but there may be. There may be some electric power failures that could do that.

None of that is modeled in the PRA. There is not a surrogate basic event that says we fail if ventilation fails and the operators don't do anything. We don't know, if they do relocate, whether they can successfully operate the equipment from that alternate location. It is simply not modeled. It is not an example where, you know, my analogy for main feedwater where you can say, well, that .1 is perhaps a surrogate for operator actions and may be bounding for the equipment. It is not one of those. It is not something where the hardware reliability isn't modeled, but there is something else that is an equivalent, like the accumulator. That is another example of something that is just not there.

And I don't know how important that might be because I have no way of measuring the importance of that, either the operator actions or the equipment, or anything. It is just not there. And any support systems for that, electric power, DC power, AC, you know, chilled water, and so forth. It is just simply not there.

And there are some other examples. As I said, I spent quite a bit of time looking at this. There are some other examples. Ventilation is one of the key areas that I looked at that just mostly isn't modeled.

And in terms of high-level concerns for the DCD, do I believe that ventilation failures will make two orders of magnitude difference in the core damage frequency? Certainly I don't. Do I believe that explicit modeling of ventilation and its dependencies could change the nature of the contributors to the risk profile? I do. But I have no reason to disbelieve that belief. I haven't been presented with any evidence that convinces me otherwise, that I believe that it could.

And part of the PRA ought to, I would think, address those types of concerns. As I said, in terms of balancing safety-related, the PRA, with the exception of the essential chilled-water system, does, as best as I can tell, examine all safety-related things to a greater or less extent. It doesn't do so well in non-safety-related areas.

And in my experience with highly-redundant four-train plants, there have been a lot of surprises that people that have found, that if you model the secondary systems, No. 1, they are good. They reduce the importance of the safety-related systems. No. 2, they are more important to risk than you would expect them to be, if you hadn't modeled them. And so, you risk this balance between safety versus non-safety. Relative risk importance can change an awful lot in ways that, unless you model it, you don't appreciate.

And again, I am not so much concerned on whether it is 1.0 times 10 to the minus 6 or .100 conditional containment value probability. It is more in terms of feeding forward into actual plant operations where they are going to be implementing the Reliability Assurance Programs to make sure that, indeed, that list of equipment that is being fed forward, that Luminant is taking as their initial conditions, has the appropriate mix of things in it.

MR. SPRENGEL: I am going to ask for clarification. That was a long discussion.

CHAIRMAN STETKAR: It is.

MR. SPRENGEL: And I guess there is a general point and a specific --

CHAIRMAN STETKAR: The PRA is not complete. It is not a complete PRA of the plant. It is not a complete PRA of the plant design, if you want it on the record in very specific terms.

It does not model a number of systems that exist in the plant. It does not model the effects of failures of those systems. And it does not model the effects of possible successes of other systems that do exist in the plant that might change the overall risk profile if they were included in the PRA.

Is it okay for the purpose, the narrow purposes of a design certification to say, is the core damage frequency from this plant 10 to the minus 2 or 10 to the minus 100? Yes, it is okay for that. Yes, it is somewhere between those numbers.

But a bit of my concern is if it is being relied on very strongly to populate that Reliability Assurance Program list, it may be overemphasizing the importance of some safety-related systems because non-safety systems are not modeled, and it may not recognize the importance of some systems, safety or non-safety, that are not modeled at all because they are just not modeled.

DR. CURRY: A couple of points. I think we should revisit why it was not modeled, you know, and then, because ultimately we may conclude that there is some engineering judgment that is applied --

CHAIRMAN STETKAR: Right.

DR. CURRY: And if we are never allowed -- not "we," but anybody in general -- if we aren't allowed to provide some engineering judgment, then, literally, you end up with every single thing modeled --

CHAIRMAN STETKAR: Sure.

DR. CURRY: -- which would be complete, as you say.

But, Dr. Tanaka, can you comment why the ventilation system was not elected to be modeled?

DR. TANAKA: Yes. As you already explained, yes, we, the PRA team, we considered that we have a chance, if we evaluate to the remote shutdown console, which provides functions -- you can control almost everything, the same with the main control room -- then that will allow us to safely shut down the plant as we were in the main control room.

And we made a judgment that that action, moving from evacuating from the main control, is highly reliable. And therefore, it is our judgment that, even if we did not model the failure probability, that will not affect the core damage frequency. That was the judgment behind why it was not modeled in the PRA.

MEMBER BLEY: Two things strike me, and I will jump into this just a little. One is the one John mentioned earlier. If, in fact, it is the same chilled-water trains that are cooling the remote shutdown area as the control room, and that is the reason the control room heated up, the assumption that you are dandy going over there might not hold up.

DR. CURRY: Yes, that's true.

MEMBER BLEY: The other is that is one ventilation system. I think you modeled at least the chillers for one of the other systems. But did you do any kind of analysis to be convinced that loss of HVAC in various spaces around the plant won't lead to equipment failures? You know, rooms that house the electrical equipment such that you might have things tripping off or, if it has got solid-state electronics, you might actually enter failure states for those?

DR. TANAKA: Yes. We did a room heat up calculation.

MEMBER BLEY: For every room?

DR. TANAKA: Every is different, yes, but for the electrical room, yes; the I&C room, yes.

CHAIRMAN STETKAR: Did you also account for temperatures inside the cabinets or just bulk air temperature in the room, taking the heat source and configuration of size of the room and heat sinks in the walls?

DR. TANAKA: I can't answer the details of this right now. I don't have the information --

CHAIRMAN STETKAR: Are those room heat up calculations documented anywhere? I couldn't find them.

DR. CURRY: It is the subject of an RAI.

CHAIRMAN STETKAR: It is?

DR. CURRY: Right. And there is a long list, and it is actually an item we are still discussing with Chapter 9.

CHAIRMAN STETKAR: There have been events that have occurred at real plants where, because of elevated temperatures inside cabinets, especially digital I&C cabinets that tend to have their own power supplies inside there, so they are the heat generators, have gotten quite warm, despite the fact that the bulk air temperature in the room met all of the requirements.

DR. CURRY: Right. It is a room-by-room calculation. We have submitted an RAI response, compared the requests to the EQ list. We are still discussing with the staff the technical details of that calculation.

CHAIRMAN STETKAR: Were they run out to equilibrium steady-state temperature? Because I saw some --

DR. CURRY: Twenty-four hours I think.

CHAIRMAN STETKAR: Not 24 hours because I saw those words in many places that said, within the PRA mission time, temperature did not exceed design limits. Well, the equipment doesn't care about the PRA mission time. So, if the temperature was still increasing at 24 hours, those temperature calculations ought to be taken to steady-state equilibrium temperatures. And even if those occur at -- pick a number -- 30 hours, there is a problem.

DR. CURRY: Right.

MEMBER BLEY: Because you might still be operating.

(Laughter.)

CHAIRMAN STETKAR: You might be operating or you still might need to take away decay heat.

MEMBER BLEY: You might need to take away decay heat.

DR. CURRY: We appreciate the point. That is what we did in the RAI response.

CHAIRMAN STETKAR: You did, you took them out to --

DR. CURRY: Right.

MEMBER BLEY: But you don't know if you looked inside the cabinets? Because that is kind of a crucial --

DR. CURRY: I know it was a comparison to the EQ profile.

MEMBER BLEY: And did you require -- because we haven't seen any of this -- did some of your calculations indicate that you would need to take actions, like rig pans or anything, to cool rooms?

DR. CURRY: I believe there is one room that requires an operator action.

MEMBER BLEY: And is that modeled?

DR. CURRY: Well, when you say, "Is it modeled" --

MEMBER BLEY: The operator action.

DR. CURRY: Without any operator action, you know, the heat up calculation indicated that no operator action was required. There was a room, if I recall -- and I would have to pull up the RAI -- that, you know --

MEMBER BLEY: What did you use for the worst ambient temperature condition when you started this? I mean, is this for a plant in the tropic or --

DR. CURRY: I think I would have to pull up the RAI, but I am happy to pull it up.

MEMBER BLEY: Well, if all of that is covered in the RAI, I guess we will see that eventually.

DR. CURRY: We can get our hands on it --

MEMBER BLEY: I don't know how much is there because I haven't looked at that.

DR. CURRY: We can get our hands on it

before we leave tonight. I am sure we have got it somewhere.

CHAIRMAN STETKAR: I think we would like to see that RAI. Has the staff reviewed the RAI yet or is it --

DR. CURRY: The staff has reviewed it. It was the subject of an audit. And the staff is continuing to review it.

CHAIRMAN STETKAR: It is still in review? Okay.

DR. CURRY: Right. We submitted it. The staff had some comments on the methodology.

CHAIRMAN STETKAR: Okay. I just didn't want to insert us into the middle of something until the staff got done reviewing it.

MEMBER BLEY: That's fine. That's fine, yes. I didn't, I mean, if it is in there and it is addressing all these issues, we will see it, yes, eventually.

CHAIRMAN STETKAR: Okay. In the interest of time -- I mean, the good news is we are ahead of schedule; the bad news is this is PRA.

(Laughter.)

So, why don't you continue with your presentation? I think we sort of elaborated, at least

I have on it, on a couple of my general concerns.

DR. CURRY: And that is great, Mr. Chairman, you know, because if we can get through a number, tonight if we have some homework, it will give us an opportunity.

CHAIRMAN STETKAR: Yes, yes.

DR. CURRY: All right. Design features. This slide is kind of a summary of design features to reduce the core damage frequency. Four-train safety injection or high-head injection system with direct vessel injection, direct lines into the vessel. Four-train Class 1E GTGs, gas turbine generators, for AC power.

There is no low-head injection required, low-head injection system required, because of the use of the advanced accumulator. And there is no switchover from an injection to a recirc mode because of the in-containment refueling water storage pit.

Additional design features to reduce the core damage frequency, the alternate AC generators, although they are not Class 1E themselves, they are within a Seismic Class 1 structure, which provides protection from site hazards, such as high winds.

Upgrade the piping for the RHR system and the flow path of the RHR system reduces the potential for interfacing systems LOCA. I started to say event tree, the old WASH-1400 term.

(Laughter.)

Four trains of emergency feedwater, two motor-driven, two turbine-driven. So, the emergency feedwater system is diverse.

And as I mentioned earlier, the charging pump can be cooled using the non-essential chilled-water system or the fire protection system, and that is important for cooling.

MEMBER BLEY: Yes, No. 2 up there, I couldn't -- it depends on where you look, I guess, I have heard. What I read was that the upgraded piping system has a higher design pressure than in most PWRs, which is 600 pounds in most of them. There was a hint somewhere that it is designed to be capable of handling full RCS pressure. What is the truth? I didn't see it laid out.

DR. CURRY: I think there's a couple of answers. The design pressure is 900.

MEMBER BLEY: Nine hundred? Okay. Thank you.

DR. CURRY: Right, but I think we want to talk about -- and Hamamoto-san can help me -- but I believe the rupture pressure of the piping is very high.

That is No. 1.

And No. 2, we wanted to talk about the flow back --

MR. HAMAMOTO: This is Hiroshi Hamamoto.

DR. CURRY: Hamamoto-san, yes.

MR. HAMAMOTO: My understanding is the design piping is 900. We set the actual normal operating pressure to 50.

MEMBER BLEY: I didn't follow that.

MR. HAMAMOTO: Yes. If we design RHR piping, if we decide a 900-pound rating, if we use separating piping, we stand normal pressure, 2,250.

MEMBER SHACK: He is going to allow to deform plastically, but --

MR. KIPPER: My name is Scott Kipper with MNES.

I believe this is coming from a URD requirement, which is discussing the ultimate rupture strength of the material. So, it does allow for plastic deformation. It is the ultimate strength of the material, not your normal service ratings or allowable stresses. But it is an ultimate strength of the piping.

CHAIRMAN STETKAR: That's good for nice things that I consider a pipe. What about things like pumps and valves and connections to heat exchangers, and all of those other things that aren't a pipe? Are they also designed and rated for that pressure?

So, for example, a pipe might not rupture. But if I blow the bonnet off of a valve, it is still not a good day in the electric faculty.

MEMBER BLEY: Or the seals out of a pump.

CHAIRMAN STETKAR: Or the seals out of a pump.

DR. CURRY: Yes, they are all designed to 900. But I think we also want to talk about the flow path and the likelihood that --

MR. KIPPER: Correct. We will need to follow up on components that would be non-uniform geometries or non-simple geometries, basically, your components that will be stress-designed by the vendors. So, we would need to confirm basically how this relates to the piping and the components.

I think what Jim and Tanaka-san were going to discuss next was basically the open path to the RWSP in this case. So, I will let you guys --

DR. CURRY: No, I will let you do it.

MR. KIPPER: Oh, okay.

(Laughter.)

DR. CURRY: Please.

MR. KIPPER: What we do have with the RHR system is, during power operation, it is aligned to perform containment spray. So, basically, the suction of the piping system is open to the RWSP. In this case, during power operation if we did have a failure of the reactor coolant pressure boundary isolation valves on the RHR, we would essentially be just -- we would have an open-flow path to the RWSP to basically collect the intersystem LOCA water. And then, we could use our safety injection pumps or charging pumps to basically recover RCS at the torque.

MEMBER REMPE: On your ability to maintain RCS -- are we done with this question, John, or did you have another follow-on? Okay. I have a different question then.

On the seals on the pumps, they always talk about engineering judgment like on page 46 of your Design Certification Document for Chapter 19 that was used to assume that they could last for one hour. Is there any data? Were sensitivities done or anything? Or you assumed one hour?

DR. CURRY: Chapter 19 took input from another chapter on that. I want to say that one hour doesn't -- 19 uses one hour that identified in another chapter.

MEMBER REMPE: But there is a basis for it somewhere else that you can find, besides engineering judgment?

DR. CURRY: Yes.

DR. TANAKA: Yes, there is a basis. There is a calculation done --

MR. HAMAMOTO: Yes, this is Hiroshi Hamamoto.

That would be based characterization. Reading that one lower, the same temperature, does not exceed the design temperature. The temperature is 130 degrees Fahrenheit, because to first see if the coolant, see the temperature is the room temperature, around 50 or 60 degrees Fahrenheit.

The seal coating, also, it was seawater reactor system high temperature water up to the sealed portion. And the sealed portion temperature is included, but that time is a long time. Before one hour, the seal portion's temperature does not include that second seal reactor coolant pumps to come to seal design temperature.

DR. CURRY: Hamamoto-san, is that testing or calculation?

MR. HAMAMOTO: No, that is a calculation.

DR. TANAKA: Yes, and we provided that calculation as an RAI response. It is a calculation based on how long it will take for the sealed assembly to heat up to the design temperature. And we have the response. The RAI response is a calculation, and we show that for one hour it does not reach the design temperature.

MEMBER REMPE: Okay. So, I would like to see a copy of that, if it is possible, please.

CHAIRMAN STETKAR: Don't look at me. I can tell you, I am not the staff.

(Laughter.)

MEMBER REMPE: But you are the enforcer, John.

(Laughter.)

Okay.

CHAIRMAN STETKAR: We have raised that question in a couple of other Subcommittee meetings also, I know, about the survivability for an hour.

MEMBER REMPE: For this particular design? Because I didn't remember it. Indeed, I wasn't here.

CHAIRMAN STETKAR: For this particular --

MEMBER REMPE: Okay.

CHAIRMAN STETKAR: Yes. And I went back and looked, and the last notes I had was it was still in the process of review. So, it sounds like it may have moved since then.

MEMBER REMPE: Okay.

CHAIRMAN STETKAR: So, we should try to see that, if that is the case.

MEMBER REMPE: So, sensitivities, even if it is an analysis of the effects on what happens, if it is longer or shorter, might be worthwhile. And I didn't see that done.

CHAIRMAN STETKAR: There is a different question that I had related to the seals. And that is, there are statements that seem to be made that said, well, you know, we have much better seals than Westinghouse, and they can, indeed, survive, maybe they can survive without any LOCA, but we are going to assume that they fail because that is conservative.

Of course, that assumption makes things like station blackout look bad, for loss of all component cooling water look bad, those two being the largest single initiating-event contributors to my risk profile.

If, indeed, the design-specific seals can resist loss of all coolant, no seal injection and no thermal barrier cooling, for a long time, hours and hours and hours, without significant increase in seal weep-off flow, if that, indeed, is the claim from the designer's perspective, then why doesn't the risk analysis model that design? And that would substantially change the entire risk profile of this plant.

MR. SPRENGEL: I think, right now we do understand that we have a conservative model being used for RCP seal failure. And we also have additional testing being performed now on the RCP seals themselves. That is one of the reports that was mentioned by Hossein earlier going in the end of February.

CHAIRMAN STETKAR: Okay.

MR. SPRENGEL: So, one of them is the Fukushima Technical Report, and the other one is the RCP seal performance. So, we have that testing ongoing now, and the report will be coming in the end of this month.

Along with those submittals, we will do an evaluation of how different assumptions for RCP seal performance would affect the PRA. We do not intend to change the model because determining what the new model should be would be very challenging. So, we do intend to look at the impacts, like a sensitivity analysis, to determine what impacts there would be on the PRA. But we do not have a plan right now to change the model itself.

CHAIRMAN STETKAR: See, this is what really bothers me a bit. If, indeed, the US-APWR design is extremely resistant to reactor coolant pump seal LOCAs, as the testing program may confirm, that feature is a very important feature of the design and it would substantially affect not only the overall core damage frequency, which I admit from this particular issue is evaluated conservatively -- so, in terms of, is my core damage frequency 10 to the minus 2 or 10 to the minus 10, it conservatively estimates it within that range. But it would also substantially change the risk profile.

The relative importance of component cooling, the relative importance of station blackout, the relative importance of any of those scenarios involved in seal LOCA would change substantially; other things would raise. The overall level would go down. Different rocks would come up and poke their head above the surface. In that sense, getting a Risk Achievement Worth of 2 to a much lower overall core damage frequency from something that is not modeled might appear. It could change your overall conclusions about what is the population of equipment on that D-RAP list that the licensee eventually will need to pay attention to.

MR. SPRENGEL: And that is the reason why we are doing the evaluation. So, we do agree with what you are saying --

CHAIRMAN STETKAR: But you said you are not going to change PRA.

MR. SPRENGEL: That is correct. That is correct. And it goes back to one of your points earlier of what your viewpoint of the current PRA is versus what its application is.

So, when we evaluate the application of the PRA now for the certification, we are looking at the use of it and the detail put into the PRA right now, and what amounts of impact we have. So, we are going to confirm the level of impact. And I do agree, if there was an enormous amount of impact from the model change, it would need to be put in place.

CHAIRMAN STETKAR: Okay.

MR. SPRENGEL: And that will be part of our evaluation --

CHAIRMAN STETKAR: Okay.

MR. SPRENGEL: -- to confirm that the impact is not so large that it basically invalidates the current --

CHAIRMAN STETKAR: I am glad to hear what you just said because the problem is, if it could make a large impact, then it would make the task assigned to that Expert Panel extremely difficult because they would, then, need to think about what would the risk profile be with that improved design, and then, what might be important. And that is really, really difficult to ask a human being to sort of consider. So, I am glad to hear that, if it does make a big difference, you will get the model --

MEMBER REMPE: Maybe I am asking the obvious, but you said for the application design certification you would rather not change the PRA, if you don't have to. But, in light of all the discussion here today, if the purpose of the upgraded PRA is to support technical specifications, there is some sort of intent from MHI to significantly change the PRA and make it more robust, consider different things?

I mean, we have heard this a lot. That was a question I wanted to ask after John had his last discussion about omitting certain components. And is there an acknowledgment on MHI's part that perhaps something that is more complete will be needed if you are going to use this for tech specs?

DR. TANAKA: Yes, for the rights and for applications like tech specs, we have all reviewed, and they will be updated or upgraded, as necessary. But we are talking about DCD PRA?

MEMBER REMPE: Yes.

DR. TANAKA: This, we do not plan to change the model unless it has huge impacts on the risk insights.

MR. SPRENGEL: But, separate from the model, I do want to acknowledge your question. The PRA will be upgraded for plant operation.

MEMBER REMPE: Okay. Because maybe it is an obvious question, but I have heard a lot of discussion here today. And I just had to ask.

CHAIRMAN STETKAR: Yes, but it will be upgraded not -- I won't use company names -- it won't be upgraded to support the design certification or the combined license. It will be upgraded at some later date by --

MEMBER SHACK: Well, it has to be Category 2 for the risk-informed tech specs.

CHAIRMAN STETKAR: That's right. That's right.

MEMBER SHACK: Whenever that --

CHAIRMAN STETKAR: Whenever that -- but we will never see that upgraded PRA. We, the ACRS, will never see the upgraded PRA.

MR. SPRENGEL: Correct. You will see a revised PRA. There is a revision coming.

CHAIRMAN STETKAR: Sure, sure.

MR. SPRENGEL: But you will not see the

upgraded --

CHAIRMAN STETKAR: The upgraded PRA, because that thing will be done post-COL --

MR. SPRENGEL: Yes.

CHAIRMAN STETKAR: -- for whatever application-specific --

MEMBER BLEY: Unless it comes up under an application.

CHAIRMAN STETKAR: Yes, but we typically don't see those. We can ask them.

MR. SPRENGEL: We don't have a plan for you to see them.

(Laughter.)

CHAIRMAN STETKAR: Right. We understand that.

And you said end of February, Ryan, that report is going to be submitted to the staff on the seal testing?

MR. SPRENGEL: Yes.

CHAIRMAN STETKAR: Okay.

DR. CURRY: Okay. I would propose moving to the next slide, which is --

MEMBER BLEY: Well, before you move, just let me ask you a question --

DR. CURRY: Yes, sir.

MEMBER BLEY: -- because I have got to think some more about this. Is everything about the interfacing LOCA given in that page-and-a-half in Chapter 2 or is there more information somewhere else in the PRA? Oh, I am not talking Chapter 9 now. I am talking the PRA.

All I found about interfacing LOCA was a little over a page of kind of back-of-the-envelope calcs to dismiss it. Is that the extent?

DR. CURRY: So, are you talking about the PRA?

MEMBER BLEY: Yes.

DR. CURRY: The PRA itself?

MEMBER BLEY: Rev. 3 of the PRA.

DR. CURRY: I would say Rev. 3 of the PRA is a summary of -- you know, it is the PRA.

MEMBER BLEY: But that's it; it is just that one page? There is nothing hidden off in some other systems analysis or somewhere that tells me more than that?

DR. CURRY: One of the other 14,000 pages?

MEMBER BLEY: Well, under "Initiating Events," it says --

DR. CURRY: Right.

MEMBER BLEY: -- can't happen; here's a

little back-of-the-envelope calculation to convince you.

CHAIRMAN STETKAR: That is the only one I could find, was in that "Initiating Event" section.

MEMBER BLEY: That's it?

DR. TANAKA: DCD, yes, is a short summary.

MEMBER BLEY: I need to look at that some more. Okay. I mean, when I get to the end, it says 10 to the minus 12 per year is a very conservative calculation. I want to think about that some more.

(Laughter.)

DR. CURRY: All right?

MEMBER BLEY: Go ahead.

DR. CURRY: Okay. US-APWR special design features to reduce the large release frequency. We talked a little bit this morning about the igniter system. So, in the course of developments and discussions with the staff, a battery-powered hydrogen ignition system is a design change that has been made.

Reliable reactor cavity flooding features the reactor cavity geometry. And if you have the DCD, some of this may be illustrated more easily in Figure 19.2-1. It is a good summary of these issues.

MEMBER BLEY: Say that again, 19 --

DR. CURRY: Figure, yes, 19.2-1.

MEMBER REMPE: Page 1324.

DR. CURRY: Reactor cavity geometry, so in terms of the depth and the spreadability of a core EM, a diverse RCS-to-pressurization line, in addition to the safety depressurization valves. Geometry to limit direct containment heating and DCH event; basically, a core debris trap. Alternate method of containment cooling using component cooling water in the fans, and the ability to eject core water to the cavity in the spray header. So, all of those features act to limit the containment failure modes and help protect the tank.

MEMBER REMPE: But, before you go on -- in fact, if you could bring up this figure on page 1324, it would be great. But, first of all, regularly, you and the staff refer to the fact that you can assure ex-vessel cooling, but then you say, "We are not taking credit for it because there is so much uncertainty," right?

DR. CURRY: That's right.

MEMBER REMPE: So, even though you have got those words there, you can't count on it.

But the other thing, though, is that I look at this figure, and even at the beginning of the DCD or the PRA, it shows a vessel that just snuggly fits inside some structure there. If you had tried to take credit for internal reactor vessel cooling, there would have been a lot of questions about the insulation around the vessel, the gap between the vessel and the cavity, and the ability to relieve steam that is generated.

So, even though you are not taking credit for it, how do I know -- and again, I apologize; maybe there are some documents where I missed some better pictures of this vessel. It is stuck in the structures.

You are going to have a path for the steam to leave, and you are not going to have any pressurization occurring in that area. Has someone evaluated that somewhere?

DR. CURRY: Goda-san, would you like to respond to this question, please?

MR. GODA: Okay. I am Hiroshi Goda, an accident analyst.

We performed mock evolution in containment performance behavior, and then, we have more developed inside of containment suddenly, including a pathway between the reactor cavity and the compartment that connected that cavity upward. We identified there is not much pressurization inside the reactor cavity after melt-through. So, we believe that there is a sufficient to release now steam from the reactor cavity to other compartment inside containment.

MEMBER REMPE: Is there insulation around your vessel?

MR. GODA: Yes.

MEMBER REMPE: And did you model that structure of --

MR. GODA: Well, in truth, by itself, it is not modeled. It is not modeled, but we identified that gap between the reactor vessel and, also, that cavity wall.

MEMBER REMPE: And how big is the gap?

MR. GODA: It is very narrow, like 200 millimeters, like 8, 10, 8 inches. But not just in the gap, but, also, we have entered the pathway to release generated steam.

MEMBER REMPE: Where is the other pathway? I am looking at the picture, and I thought that -- oh, it is this little kind of curve over on the other side?

MR. GODA: Yes, that's right. That's right.

MEMBER REMPE: Okay. What about the fact that you didn't include the insulation, and other industrial retention evaluations that concerned the insulation could adversely affect what is going on down there when you have got water and chugging from steam being generated, and that it would fall against the vessel? And there was a lot of concern that there might be some adverse consequences from it.

MR. GODA: We do not consider any kind of external vessel cooling for the core. So, related to industrial retention or any kind of cooling, we do not model.

MEMBER REMPE: Right, but you are going to have to relieve steam, and you are going to have a lot of junk down there from insulation that is probably going to fall all off.

MR. GODA: That's right. That is why I say we have the pathway.

MEMBER REMPE: The alternative pathway?

MR. GODA: That's right. That's right.

MEMBER REMPE: Okay. And you did consider that, and it helped you alleviate any sort of pressurization?

MR. GODA: Yes.

MEMBER REMPE: What about this ledge? I guess that when you talk about that you have limited the debris going up into the containment, if I look at this picture again, the one thing, I don't think I have seen another plant designed with this ledge that kind of sticks out on the -- it would be nice if I could look at the picture, but you have, I believe you call it the core debris trap. And I think it is this ledge thing that sticks out.

Is there any experience on what the effect is? I assume you have limited the debris going up in the containment because of just the structures and barriers and the debris, but what is the role of that ledge?

MR. GODA: Well, actually, experiment, any kind of a trend we do not perform. But as long as our research, our literature review performs for the Zion plant for DCH, and the Zion does not have that kind of area to trap the core debris after the entrainment, the entrained debris, and then, comparing to the Zion geometry and, also, the US-APWR geometry, then, qualitatively, we expect that debris dispersion is less than the Zion.

MEMBER REMPE: I just haven't seen it before. It might be a little bit less, but I am surprised.

MEMBER BLEY: Do you mean that little hook where you go around?

MEMBER REMPE: Yes, I have never seen a hook like that before. So, again, if you had a lot of junk coming down, would it catch on that hook and --

MEMBER BLEY: No, there is a big hole right next to the hook.

MEMBER REMPE: Well, not much, but would it cause a lot of stuff to pile up higher than normal, is what I am kind of wondering.

MR. GODA: I'm sorry?

MEMBER REMPE: Well, that hook, could it cause debris to pile up underneath, is what I am wondering, so you would have -- you know, melt spreading is an important thing. Everybody wants it to spread out after it falls out of the vessel. And you have got a hook there that particulates and junk would come out. And would it cause things to pile? I was wondering if you had done some experiments.

I know that for the Zion geometry they did do a lot of experiments trying to look at entrainment.

MR. GODA: Not experiments, nothing, no experiments, no.

MEMBER REMPE: I was just curious.

CHAIRMAN STETKAR: Are you okay, Joy?

MEMBER REMPE: I'm done now. Thank you.

CHAIRMAN STETKAR: Jim, on this slide -- we are slowing down, but we expected to do that -- a couple of questions on this slide. The fourth bullet, the diverse RCS depressurization valves, the DVs, why are those valves not included in the model for bleed-and-feed cooling?

DR. CURRY: These are the severe accident slides.

CHAIRMAN STETKAR: There are valves. Why are those valves not included in the model for feed-and-bleed cooling?

DR. TANAKA: To make clear the question, we take credit for a different valve, safety depressurization valve, but we don't take credit for this one.

CHAIRMAN STETKAR: I know what is in the model. I am asking why those valves are not included in the model for feed-and-bleed cooling. If I am an operator and I try to open valve No. 1, and it doesn't open, and I try to open valve No. 2, and it doesn't open, and I see I have these other valves over here that I can open, I am going to sit there and say, okay, I'll melt the core because the PRA guys only took credit for those as severe accident mitigation valves.

(Laughter.)

The reason that I am being so flip about this is that it is a vent path, a release path for the containment, the same way that the SDVs through the pressurization relief tank are a release path for the containment, dumping heat eventually into the RWSP.

If you took credit for those valves for feed-and-bleed cooling, you would have a lower frequency of core damage scenarios. Those valves would be guaranteed failed once you got out to your Level 2 models. So, Level 2 wouldn't make any difference because you still need failures of all three sets of valves. But you would never have the core damage that got to Level 2.

So, the question is, why don't you include credit for those valves for feed-and-bleed cooling to prevent core damage? Because the same consequential failures after you open those valves in terms of CS RHR, alternate containment heat removal, and whatever, would apply regardless of however I am dumping the energy back in there.

DR. CURRY: Just to rephrase your question, it is just another way of depressurizing the system, which is important to us. So, I don't know whether that was --

CHAIRMAN STETKAR: And, in fact, it is a larger flow path. So, it would be even more efficient than the SDVs.

MEMBER BLEY: It makes me wonder if there was a linkage to the development of emergency procedures. Would opening these be in the procedures or would just the ones you modeled be in the procedures?

CHAIRMAN STETKAR: They don't have the procedures.

MEMBER BLEY: Well, they don't have the US-APWR procedures complete, right? We have heard you have got some, right?

MR. GODA: Excuse me. We have the procedure. However, we have not opened it to the NRC yet. In the procedure, we do have the process to open all the valves.

MEMBER BLEY: All the valves?

MR. GODA: Fifty percent of them involved. If that fails, then depressurization is involved for a severe accident. In the PRA, no, not these are an assumption in the PRA because we say that a severe accident is mitigated. So, that is why we wanted to model. SDV is for design basis. If it is failing the design basis, then we have analog redundant diversity ready for severe accident.

Just we wanted to model it in that way. And also, we wanted to consider a defense-in-depth concept. Because the safety depressurization is involved, that is provided to mitigate the design basis. So, the accident dedicated? It sounds to me it is not dedicated for the accident. So, we model as it is, not these other assumptions. However, for the actual procedure, that is not right.

MEMBER REMPE: Do they have a positive indication that the valves have opened in the control room? You have positive indication in the control room the position of these valves all the time?

MR. GODA: Yes. Yes.

MEMBER REMPE: And there is some way of determining if they are --

CHAIRMAN STETKAR: They are motor-operated --

MR. GODA: Yes.

CHAIRMAN STETKAR: -- safety-related valves.

MR. GODA: That's right.

DR. TANAKA: And also, I would like to add that, for the feed-and-bleed operation or failure of feed-and-bleed is mostly dominated by human operator action error. So, even if this valve is credited, I do not believe it will change the risk profile significantly.

CHAIRMAN STETKAR: I mean, I don't know what else to say. You are not modeling the actual design of the plant, and you are not modeling the design consistent with what we just heard in your operating procedures.

And I don't like excuses that say, well, this thing is more important, has a higher failure rate than this thing, so we don't need to model this. That is just an excuse.

Alternate containment cooling, that function, that is an interesting function. Do you have any slides on it? Were you going to address that? Or is this the place to talk about it?

DR. CURRY: Well, I would say this is the place to talk about it.

CHAIRMAN STETKAR: This is? For a while when I was looking at the model, because it is always characterized as the fan coolers, and I always think of a fan cooler as a fan and a cooler. It is not really the fan cooler. It is only the cooling coils for the fans with convective heat transfer from the RWSP up to those cooling coils, and component cooling water flow through those cooling coils.

I looked at whatever it is, Appendix 5A, or whatever, in the PRA report where there are some math calculations to show that that works. Now I will ask the staff on this. I have never seen anybody take credit for that. I am not a thermal hydraulics person. I don't know, Joy, whether you looked at it.

Every plant I have seen said you need forced airflow across the surfaces of those cooling coils to get effective heat transfer. I don't know what the fan cooler geometry looks like. I have seen several that have shrouds around them, so that you make sure you get active flow across the cooling coils. They are not just open, hanging out in the containment by themselves, which would imply that this natural convective flow needs to come up through the fan itself and get past the fan blades into the cooling coils.

How carefully have you looked at that passive convective heat transfer process within the containment? Because it is in all of the models. It is your ultimate way of saving the core and the containment in all of your event sequence models. So, it could be -- numerically, I didn't pay much attention to how much your Risk Achievement Worth is, but, in principle, it could be very, very important.

MEMBER SCHULTZ: If it is functional.

CHAIRMAN STETKAR: If it is can actually work.

DR. CURRY: Goda-san.

MR. GODA: Okay. We have discussed about the mechanism, how the natural convection works, through the RAI. And the NRC staff requested to explain the mechanism. I do not remember that number, but we have answered about that.

We performed by experiment how the coil cooling works. And then, we plotted, sometimes including efficiency, and then, we modeled that result into a math variation model. And then, we evaluated the coolability.

CHAIRMAN STETKAR: Okay. And you said that analysis and the experiment has been submitted to the staff?

MR. GODA: Yes.

CHAIRMAN STETKAR: Okay. Okay. I will ask the staff about that. Thank you.

Joy, did you look at that at all?

MEMBER REMPE: No, I didn't, but I am not aware of any other analysis that has been done to look at that in other places.

CHAIRMAN STETKAR: Or experiments. I don't know where the fan coolers are physically located, you know, geometrically located.

Okay, yes, that is a cartoon. They are on Bill's screen over here.

(Laughter.)

They tend to be fairly high up in the containment. They tend to be around the edges usually in most plants. But I don't know this plant.

And they said that, basically, putting component cooling water flow through two, and only two, of them provides sufficient heat transfer to remove decay heat, basically.

MEMBER REMPE: Steve, did you say you were aware of other analyses for other plants that have been done?

MEMBER SCHULTZ: No, I was interested in this analysis because I am not aware of other --

CHAIRMAN STETKAR: I have seen a lot of plants who have said they have forced convection flow, you know, that they look at the normal heat removal capacities with forced flow across them. And some of the make it and some of them don't, depending on how big the fan coolers are. But I have never seen one like this. And because I can't boil water, I can't independently sense whether or not this is reasonable. So, we will ask the staff when they come up and see where that stands.

DR. CURRY: All right. Moving on, Mr. Chairman?

CHAIRMAN STETKAR: Yes, sir.

DR. CURRY: I think you discussed this morning standard data sources and you did mention that we used generic data, and that is true in a number of cases. So, you will probably recognize some of these references.

CHAIRMAN STETKAR: Yes. Are you going to talk about initiating-event frequencies or is this the place to ask about those?

DR. CURRY: I think you should ask about them here.

CHAIRMAN STETKAR: Okay. Loss of component cooling water or loss of central service water, you have lumped the two symptoms together. You have two initiating events, one that is total loss of component cooling water, LOCCW, and one that is partial loss of component cooling water, PLOCW.

You developed a fault tree model to quantify the frequency of LOCCW. And in fact, that practice is what is generally recommended for any type of support system failure because, generically, they just pretty much don't apply.

Let me ask first about why did you use generic data from U.S. nuclear power plants to quantify the frequency for partial loss of component cooling water when you felt it necessary to rely on a plant-specific fault tree analysis to quantify the frequency of total loss of component cooling water? I don't understand philosophically why you did that.

So, could you explain that? Because you did use from NUREG/CR-6928 exactly the frequency for -- you added together loss of ESW and loss of CCW for the partial.

DR. CURRY: Please answer.

MR. NIRASAWA: US-APWR has two separate systems, one in B and C and D. And this is the same feature over US-APWR component screening water system. So, credits initiating-event frequency of the total or also with the CCW event. We performed the fault tree analysis.

CHAIRMAN STETKAR: Yes, I know that. I am asking, because you did that -- and I understand why you did that -- why did you use the generic frequency from U.S. nuclear power plant operating experience for partial loss of component cooling water?

DR. CURRY: Just to repeat, the fault tree for the complete loss of component cooling water, but data for the partial loss, is that your question?

CHAIRMAN STETKAR: Uh-hum.

DR. CURRY: Do you recall --

CHAIRMAN STETKAR: If U.S. data for total loss of component cooling water don't apply because of the design-specific configuration, normal lot, number of operating trains, and because you have lumped together essential service water and component cooling water, I understand that. Then, why do generic data from U.S. plants apply for partial?

DR. CURRY: For the partial loss?

CHAIRMAN STETKAR: It just doesn't seem to be logically consistent.

DR. CURRY: Right. Could we take that maybe as a homework assignment?

CHAIRMAN STETKAR: That would be great.

(Laughter.)

I mean, the more of these questions that you can answer that way, the better we will keep things moving along.

DR. CURRY: All right.

CHAIRMAN STETKAR: Let me ask you one thing, because CCF also appears on this slide, and I brought it up. That total loss of component cooling water initiating-event frequency is quantified through a fault tree. And in that fault tree, you use a component cooling water running common-cause failure parameter that is effectively 1E to the minus 4. Now it is calculated by a beta times a gamma. So, it is calculated by a 10 to the minus 3 times a .1. But the way it is implemented is the common-cause failure parameter for failure of all four running component cooling-water pumps or all four running essential service water pumps is 10 to the minus 4. That common-cause failure parameter is not derived from NUREG/CR-5497. In fact, it is derived from one -- and I will not mention his name; he is listed in the references -- one value provided by one consultant.

Now I submit that total loss of component cooling water and the component cooling water system are some of the more risk-important results in your PRA right now. It is difficult for me to understand why, when you use generic data from all of these sources, that when you come to that one particular parameter, you rely on an estimate from one person, especially because in NUREG/CR-5497 the experts who looked at the actual common-cause failure data that were used to support that report in principle -- now I didn't participate, so I don't know what they really did -- but, in principle, they looked at each event and said, would this event apply to a population of two, and only two, components; three, and only three, components; four or more components?

So, they developed what they called the impact vectors to say there is some probability that this particular event would, indeed, apply to four components. That is how they derived for the most part many of their conditional values for delta and gamma in that, because many, many times they only had failures of two.

So, if they went through that process and derived a gamma factor and a delta factor for failures of running component cooling water pumps, why do those values not apply to a plant design that has four pumps? Why do you need to use values that are a factor of, oh, 100 times lower? They are not quite 100. I think it is 60. I exaggerate sometimes.

I have a real question about that. I know the staff raised a question about it also. But when you talk about all of these sources of data, it is not quite as clean as what appears on your slide here.

DR. CURRY: That's right. Basically, just the major sources.

Okay. So, just to repeat your question, the common-cause failure probability of the CCW, 1E to the minus 4, we used a specific reference which, you know, you are really questioning why did we use that reference as opposed to applying a methodology --

CHAIRMAN STETKAR: And as best as I can tell, it wasn't an expert elicitation. It was a value provided by one, and only one, individual. That is the way it is referred to in the report. Because it is in the proprietary report, and I don't necessarily want to point fingers at individuals -- it is in the PRA report in the initiating-event, I believe, analysis section. And that is why I didn't want to mention the individual or the specific reference.

DR. CURRY: Well, we appreciate that. Do you have, just to make it easy for our assignment, do you have that particular page number or something that --

CHAIRMAN STETKAR: Somewhere I do. It is in this pile here somewhere. I will give it to you offline later.

DR. CURRY: Okay. Yes, we appreciate it.

CHAIRMAN STETKAR: You can go on, if you are ready. I am just writing notes here.

DR. CURRY: All right. This slide is just a summary of the PRA methods and codes which you are familiar with, based on the prior discussions. So, that was all that was intended by this slide.

MEMBER REMPE: Before you leave it, though -- and again, this could be me -- but I couldn't find it in the almost 200 pages or files in the PRA. But when I look at File 110, which is Chapter 14 of the PRA, I don't see anywhere that you present a comparison between WCOBRA and MAAP to give me confidence that the MAAP model is consistent with the thermal hydraulics behavior. Is there some other file somewhere that I have missed that I should have looked for?

DR. CURRY: Maybe we should clarify what did we use MAAP for, what did we use the WCOBRA for. And then, your question is, did we --

MEMBER REMPE: Well, usually, you use MAAP for severe accidents and WCOBRAs for the design basis.

DR. CURRY: Right.

MEMBER REMPE: But you typically will do a comparison to say, yes, they are predicting the same pressure when you have a certain size hole. Did you do some sort of comparison showing that? Because that is typically a good idea.

(Laughter.)

It might be good to do such a comparison.

MR. GODA: No.

MEMBER REMPE: Okay.

MEMBER SHACK: And the staff didn't ask you to do that? That has typically been done.

DR. CURRY: Well, just to reaffirm, you know, they were for different purposes.

MEMBER SHACK: Right.

DR. CURRY: But your thought is it would

still be good to maybe benchmark them?

MEMBER SHACK: Yes. I mean, it has been frequently done, to just benchmark the MAAP since --

MEMBER SCHULTZ: That would be for a crossover comparison.

MEMBER SHACK: Yes.

MEMBER REMPE: Right. And it is typically done, and I didn't see it, but there was a lot of stuff to read here. But it sounds like it was not asked if no one has done it from MHI.

MR. KHATIB-RABHAR: Can I make a remark?

CHAIRMAN STETKAR: Uh-hum.

MR. KHATIB-RABHAR: Mohsen Khatib-Rabhar from ERI. We are the contractor to the staff in reviewing things.

The question you are asking relates to thermal hydraulics. MAAP generally for severe accidents is compared to MELCORE.

MEMBER REMPE: I am asking --

MR. KHATIB-RABHAR: And the NRC has done confirmatory calculations to check those. And keep in mind, WCOBRA, it only goes to a certain level. For severe accidents, you go to a core melt situation.

MEMBER REMPE: I truly understand that, but, typically, even --

MR. KHATIB-RABHAR: Heat trapped temperature is not --

MEMBER SHACK: We are in Level 1 yet.

MR. KHATIB-RABHAR: I'm sorry?

MEMBER SHACK: We are in Level 1.

MR. KHATIB-RABHAR: I understand. I understand you are Level 1, but --

MEMBER SHACK: But, then, why are you talking about MELCORE? I mean, all you are going to do is compare success criteria computed with MAAP and with WCOBRA.

MR. KHATIB-RABHAR: But the question was asked regarding severe accidents, I think.

MEMBER REMPE: No, what I am asking is the depressurization. Just as you have got a hole in the vessel --

MR. KHATIB-RABHAR: Sure.

MEMBER REMPE: -- and what predicted by WCOBRA versus what is predicted by MAAP, and are they giving consistent values, just like we might compare RELAP to MELCORE at first?

MR. KHATIB-RABHAR: Yes.

MEMBER REMPE: And I have heard from MHI they did not receive such a request, and they did not do that.

MR. KHATIB-RABHAR: Yes, but for severe, I just want to say for severe accidents, that is not the case. The staff has done confirmatory calculations, and they have actually looked at this issue.

MR. FULLER: Excuse me. Can I make a remark?

CHAIRMAN STETKAR: Come on up, Ed.

MR. FULLER: Thank you.

This is Ed Fuller from the Office of Research. I am a Senior Technical Advisor for severe accident phenomena. And I used to be, before I got that position, the technical reviewer for the Level 2 PRA and severe accident evaluation.

Now what we are seeing here is MAAP's use for the Level 1 for the success criteria. And we were looking at COBRA for the large break LOCA. Well, then, you get into, whoever has tried to use MAAP for large break LOCA analysis for thermal hydraulics knows that the phenomenology are not modeled properly. And for years, EPRI has told people that is the case.

So, I am interpreting this slide to mean that MAAP was used for success criteria for other transients and small break LOCAs, but they didn't use it for the large break LOCA. And perhaps maybe if you wanted to ask the question of MHI, if that is true, it might be a good idea.

(Laughter.)

MEMBER REMPE: Is that true? But, again, I would still like to see some comparison for some place, just to see that the model for the MAAP is appropriate.

MEMBER SHACK: I mean, I think there is still a question that, even when you are using MAAP for all the other success criteria besides the large break LOCA, it is an approximate thermal hydraulic model. And at least verify with some COBRA track calculations it is giving you reasonable results.

MR. GODA: But your question, if we performed the comparison, then my answer is no.

MEMBER REMPE: Right.

CHAIRMAN STETKAR: You are going to have to help me here or just tell me to be quiet because I can't boil water. Some of the scenarios that are modeled in the PRA include credit for opening the main stead depressurization valves to cool down the secondary side and, thereby, reduce pressure far enough, fast enough, so that you can, indeed, align what I will call low-pressure injections, through containment spray RHR, but essentially get flow, pooling flow into the reactor vessel at low-pressure conditions.

Main steam depressurization valves are relatively small on this plant. Each valve has a rated relief capacity of about a half of percent rated core power, if you do the calcs. The main steam relief valves are pretty big. I can get a good cooldown on the mainstream relief valves.

And I was curious how well the thermal hydraulic models do that. The plots, unfortunately, in the PRA model look at 24 hours, and I am kind of interested in, oh, about the first 30 minutes of the event, and everything looks like a vertical line no those plats. So, I couldn't really see rates of cooldown.

But it struck me for a core of this power rating it just didn't seem right that opening -- I can't remember right now whether the success criterion is two or three, but it probably doesn't make too much difference -- MSDVs would get you a rapid-enough cooldown for all of the scenarios that include credit for that.

Now I don't know, does that seem right or not?

MEMBER REMPE: I can't answer that for you.

CHAIRMAN STETKAR: Certainly, in the main steam relief valves, they have about 2.5 percent, I think, of rated core power per valve. So, I can get a healthy cooldown through the relief valves.

MEMBER REMPE: Perhaps did the staff verify it with some of the MELCORE runs?

CHAIRMAN STETKAR: I don't know. I was going to ask the staff about that.

MEMBER REMPE: Yes, because, I mean, that is how I would ask --

CHAIRMAN STETKAR: I thought I would ask the folks who did the initial calculation first.

DR. CURRY: Well, so, again, just to make sure we are on the same page, you are questioning the modeling of the depressurization, the capacity of the depressurization valves, the modeling?

CHAIRMAN STETKAR: Main steam depressurization valves, do they have -- because for anything that is larger than a medium LOCA, that function, if you don't have high-head safety injection, the model includes credit for the operators basically cooling down rapidly on the secondary side, allowing the primary side to depressurize, and I can't remember whether you need active pressure. I think it does open up the SDVs. Get pressure down and, then, inject and go into, you know, essentially, a cooling mode from the RWSP through the heat exchanger, back into the reactor vessel at low-pressure conditions.

And I don't know how rapidly that needs to be initiated. I don't know how quickly the operators need to open those valves, and I don't know whether the thermal hydraulic models treated them -- part of the problem is in some of the documentation I see them incorrectly referred to as main steam relief valves. Although if I look in the fault tree models, they are actually the MSDVs. And I think in the documentation of the thermal hydraulic analyses, they seemed to refer to them mostly as MSDVs, not MSRVs.

And I wouldn't question this at all if I had confidence that everything works okay using the MSDVs. But if, for some reason, the thermal hydraulic models looked at the MSRVs, then I know you can get enough cooldown there, but the PRA models are wrong.

DR. CURRY: Do you have a reference for us to look at? Because unless we --

CHAIRMAN STETKAR: Of the thermal hydraulic analysis? Again, I will give that to you offline.

DR. CURRY: That would be helpful.

CHAIRMAN STETKAR: I will.

DR. CURRY: Unless we are prepared to answer that question now using --

CHAIRMAN STETKAR: I will give it to you

as soon as we go offline.

DR. CURRY: Okay. Okay.

CHAIRMAN STETKAR: Because I have to look it up. I would give it to you now, but I would have to look it up in my files.

DR. CURRY: Ready to go on to the next one?

MEMBER REMPE: Oh, you bet.

(Laughter.)

CHAIRMAN STETKAR: Interpret silence as move as fast as you can.

(Laughter.)

DR. CURRY: I would be happy to.

All right. Here is a summary of the PRA results, which here is a numerical summary. And if we prefer to see it on a pie chart, you will see comparable contributions really for the internal events that power internal fire and the flood, also shown here as low-power shutdown contribution.

I think I would look also at the LERF number, and you see for low-power shutdown, as we mentioned before, LERF -- sorry, not LERF -- LRF equals CDF.

So, the PRA summary that we would say at this point for internal events, the seal LOCA, as we have discussed, is important. We have discussed the one hour and the basis for the one hour.

As you might expect for a four-train system, common-cause failures are important. I sort of jumped to the last bullet.

But I should point out that we have no significant common-cause between the Class 1E diesels and the alternate AC diesels -- gas turbine generators.

Now, in terms of the important risk insights for a four-train system, support systems are important. The component cooling water is important, as we mentioned, due to seal LOCA impact. And the common-cause failure, due to the high redundancy, is relevant.

This is a pie chart which basically shows the major contributors. Loss of offsite power is a significant contributor. Ultimately, the assumption that power is not restored, and we have a seal LOCA leads into a large part for those sequences. Also, a loss of component cooling is also important, again, leading to RCP seal failure.

And in those situations, of course, you lose component cooling. You lose the ability to mitigate with injection systems.

CHAIRMAN STETKAR: Jim, back up. I am trying to kind of selectively insert some observations that I had when I reviewed the PRA. For example -- and

I am not saying that these are going to be important; I don't believe that they are important overall -- but examples: LODC and LOAC are modest contributors right now. The models for those initiating events assume that for the LOAC event it is Train B and for the LODC event it is Train A of DC. That is what is in the PRA model.

There is a discussion about why those are conservative assumptions, B for AC and A for DC. Indeed, they are not conservative. There are more conservative impacts. In fact, the most conservative impacts would be C for AC and D for DC.

So, I am curious, you know, when people make decisions about the word "conservative," what type of analysis was done to reach those conclusions? I have examples to tell you why C is more conservative for AC and D is more conservative for DC.

I think somebody only looked at emergency feedwater and didn't consider the impacts on the whole plant, is my best guess. So, that is just something for you to look into, if you have some explanation.

I read what is there. I understand what I can read.

DR. CURRY: Right.

CHAIRMAN STETKAR: It is just I don't think it is correct.

DR. CURRY: And just to take it a step further, you conclude that D for the loss of DC power, that train would be more conservative because --

CHAIRMAN STETKAR: How much do you want to get into it? It is because it affects several functions in the event tree, as does C for AC. C for AC, for example, takes out a motor-driven emergency feedwater pump, which is correct, which is why it was B, but C also takes out Train C of component cooling water, which affects one-half of your supply for the alternate containment heat removal. B does not affect the alternate containment heat removal because only C and D affect alternate containment heat removal. So, C is worse from that perspective. D, DC power, takes out one charging pump, which is important for seal LOCAs. It takes out D for alternate containment heat removal, and it takes out D, emergency feedwater. It took out A because it takes out A, emergency feedwater. A doesn't affect those other functions.

So, what I am trying to understand is, when people make these so-called conservative decisions, what is the basis for them? Now I am not implying that those little, thin wedges are going to become a huge contributor, but it is kind of symptomatic of decisions that are made that are ostensibly conservative, which in some cases I know are not.

And that is why there is a big stack of paper here. There are a lot of examples like that. It is just easy to identify these simple ones here.

I don't expect a response back. I will just state that as a fact. They are not conservative. This is not open to debate. They are not conservative.

If you had modeled all four of them individually, you would have found that, but you didn't. Now, in the eventual plant-specific PRA, they would need to model all four of them individually because, otherwise, I can't determine the relative importance at that level of detail that I would need for an actual model. But, as long as you are only going to select one, you had better be pretty sure that it, indeed, is the bounding one.

DR. CURRY: Okay. I think we understand that comment.

MEMBER BLEY: I was just thinking, if they gave you a counter-example why you were wrong, they would have scored a "hat trick" today.

(Laughter.)

CHAIRMAN STETKAR: Keeping score. As long as it is more than 51 percent correct, I'm happy.

(Laughter.)

I don't strive for perfection. I strive for winning.

DR. CURRY: Thank you. We have the comment, yes.

And also, this is just another breakdown of the relative sequences important to LERF, a large release frequency.

Release category summary. In most situations, we have an intact containment with a final containment leakage.

The uncertainty results, this just gives you some statistical information. We were talking about mean values earlier. So, this gives you the statistical supporting breakdown.

We have discussed with the NRC in several discussions, and this slide just kind of presents it. And I think as the Committee referred to earlier in the day, the documentation of uncertainties is something that you know that we are working on.

We have also performed several sensitivity results that are summarized in that Table DCD 19.1-140 and added a COL action item to identify and address uncertainties.

Key insights and assumptions.

CHAIRMAN STETKAR: Not too fast. One

quick question about uncertainty quantification. I didn't see it listed anywhere.

I know that in the actual quantification of uncertainty, not the key issues of uncertainty, which is a different subject -- did you, when you quantified uncertainty in risk spectrum, account for the state of knowledge correlation? In other words, you fully correlated all basic events that use the same parameter or did you treat them as independent?

There are two options in risk spectrum. You can either correlate the uncertainties or you can treat them as independent. Which one did you use?

You might want to take that away and look it up tonight.

DR. CURRY: Yes.

CHAIRMAN STETKAR: Because it is a detail. It is just that, as long as you are only quantifying parametric uncertainties, especially for a highly-redundant four train, X-to-the-fourth-type correlated uncertainties can occasionally show up. They are not going to dominant common-cause failures and the other things, but it is just a question about the method that you used to actually generate those uncertainty results, because the option is there in risk spectrum.

DR. CURRY: Yes.

CHAIRMAN STETKAR: It isn't something that you have to play with.

DR. CURRY: So, I think that is all we had intended to say about the at-power PRA, and I have got a summary of the fire PRA, if the Committee would like to proceed.

CHAIRMAN STETKAR: I am going to try to be more self-restraining. So, I think if you can hit some of the highlights of the fire PRA, that would be helpful.

For planning, if we run until 5:30, will that create problems for anyone? Staff? I understand that we are going to lose bodies. Our recorder, are you okay? Okay.

So, let's plan on running until 5:30, and if you can get through the fire and some of the low-power shutdown, that would help.

DR. CURRY: Okay. We have fire, flood, and low-power shutdowns.

CHAIRMAN STETKAR: Good.

DR. CURRY: So, let's go through the fire. Fire, again, the methodology is the methodology outlined in that NUREG. A key point is the four safety trains are separated by a fire barrier. We talked about the turbine building earlier and the electrical rooms being separated by qualified fire barriers as a risk insight to avoid loss of offsite power.

Here is a key assumption: no credit is taken for fire detection and suppression in an area.

The yard fire and the turbine milling fire are the largest contributors to risk due to other features, making fire less important in other areas.

The yard fire causes a loss of offsite power and ultimate damage, if we have a failure of the Class 1Es and ACs.

The turbine building fire, the turbine building is divided into one fire area, several compartments that were treated in the PRA and, then, modeled in a transient tree, as appropriate.

This is the pie chart kind of summarizing key events, key contributors of the fire risk. I guess the blue one, the FA6-101-01, is a turbine building basement fire, this guy, which causes a spurious -- one of the sequences causes spurious turbine bypass valves to open, which is essentially, you know, it initiates a transient and prevents us from using the steam generators. Therefore, we must depressurize.

CHAIRMAN STETKAR: Why do the MSIVs not used? Were the MSIVs modeled for that fire?

DR. CURRY: I don't know. The MSIVs, were they modeled in this?

DR. TANAKA: Yes. Which particular event are you talking about?

CHAIRMAN STETKAR: Well, the fire, the largest contributor from the turbine building is spurious opening of the turbine bypass valves, which to the plant looks like a steamline break downstream of the MSIVs. Now I was a little bit surprised that it was the biggest fire contributor from the turbine building. And I was curious whether the main steam isolation -- did you use the steamline break downstream of the MSIVs event model, event tree, for that fire?

DR. TANAKA: Yes.

CHAIRMAN STETKAR: You did? Okay. Because, if that is the case, if that is the biggest contributor from fires, I am really curious why you didn't model stuck-open turbine bypass valves as a similar type of an event in any of your transient models.

Steam relief is not modeled in your transient models. One possible thing that can happen is the turbine bypass valves can open, and they can stick open. It has happened at plants. That looks an awful lot like this fire-induced event, except it starts out with a plain vanilla transient, and the valves stick open.

If that type of condition is really important from a fire perspective, I don't know why it might not be important from a transient perspective. So, there may be some details of the fire model that make it worse that I don't understand, and that may very well be the case. But it just seemed really curious when I looked at those results. I wouldn't have expected that to be the case.

I will just do that. In the interest of time, we can move on. I will just make that as an observation.

DR. CURRY: Okay. The next is just taking the data and dividing things up by LRF frequency and contribution.

We go to the uncertainty slide. Again, there is your statistical breakdown. We have been using mean numbers when we talk about these numbers.

I think this is kind of similar in terms of discussions with the staff in terms of making our insights and assumptions clear.

The transfer to the main control room, to the remote shutdown, console from the main control room was credited in this evaluation.

CHAIRMAN STETKAR: Jim, I have to admit I didn't read absolutely everything in the entire PRA.

When you say "the transfer of the remote shutdown console is credited," do you mean that it is modeled or you just assumed that it was successful? In other words --

DR. CURRY: The value, yes.

CHAIRMAN STETKAR: Did you evaluate the likelihood that the operators would, indeed, abandon the control room with some probability and the features that they can control with the remote shutdown console? Or did you just assume that a fire in the control wasn't a problem because the operators could do all of that other stuff?

DR. CURRY: I would somewhere in between there. We have a probabilistic number.

DR. TANAKA: Yes.

DR. CURRY: And so, what was the basis of the number?

DR. TANAKA: Yes. The first question, yes, it was modeled as a value and represents the failure probability to move to the remote shutdown console. So, I don't know the details, but those numbers were driven by, came from NUREG/CR-6850. I don't know the details for it.

CHAIRMAN STETKAR: Okay. Okay.

DR. TANAKA: But there was some kind of

value.

CHAIRMAN STETKAR: Okay. You basically used -- there is some estimation in there. So, you used that? Okay. Thanks.

MR. NIRASAWA: The probability, the approximate, 0.2, this is discussed in the previous RHRS pumps.

CHAIRMAN STETKAR: Okay. It is just that, when you said you included credit for it, that raised a flag because I actually didn't look at that part in detail. So, I am not very well-versed on what was done.

By the way, one more point that I wanted to raise, and I should have earlier, you didn't have a slide on Human Reliability Analysis in the discussion of the internal events at power. One thing that I noticed was that a number of human actions, if I go to the Human Reliability Analysis chapter of the PRA -- and I have forgotten which chapter it is -- there are tables for each human action. So, I can go to each human action basic event that is in the PRA, find a table that does a simplified task analysis, develops a value for each task, sums over the tasks, and then says, well, these are characterized as median values and I will take a log-normal distribution with an error factor of five, and here is the mean value of that uncertainty distribution.

I had a really difficult time, No. 1, I had a difficult time because in many cases, if I added up the values, they came out different. If I added the values for each of the individual tasks, they came out different from the bottom-line number. So, I didn't know why that was. That is a curiosity. I didn't look at every table. I can give you spot-numbers, but I can't say how pervasive it is.

What I did look at, and what I did notice, is that there are a number of key human actions in the study for which the 5th percentile value of the uncertainty distribution is the value that is actually used to quantify the human error probability in the PRA model. And there is a justification that says, well, we felt that the operators would be very well-trained and very familiar. So, we will justify using the lower-bound value, which is, indeed, the 5th percentile of the human error probability uncertainty distribution.

That disturbs me mightily. First of all, if you apply a methodology, which you did, that develops a mean value, one ought to use the mean value everywhere because you have developed a methodology.

Second of all, it is really difficult in design certification space for me to understand how the operators at any given plant that has yet to develop their own emergency procedures and training can be 95 percent better than -- not 95 percent better -- but at the 5th percentile of the error rate compared to the whole industry. In my experience, on average, everybody is average.

Now how important is this? It is about a factor of eight difference. If you look at a log-normal uncertainty distribution with an error factor of 5, the difference between the mean value and the 5th percentile is about a factor of 8.

And there are a number of human error probabilities that are used in the model with that low value. And indeed, a number of the most important identified human errors are quantified that way. That is also simply a statement of fact.

I understand what you did. I can read those words. But it is just very, very, let's call it curious.

Telegraph for tomorrow: I would be interested to see what the staff had to say about that when they reviewed the Human Reliability Analysis. So, this is something for the staff for tomorrow, if you are taking notes.

MEMBER BLEY: Yes, but I didn't see that.

CHAIRMAN STETKAR: No, it is hard to find. I was looking for time windows, but there is no discussion of available time and feasibility or anything about timing. But when I went to go look for timing, I, first of all, found out that 1 plus 1 plus 1 plus 1 didn't add up to 4; it added up to some other number. And then, I found that the number that it didn't add up to wasn't used in the fault tree, anyway; it was some other number. And then, I found in the bottom of one of these tables a little note saying: well, for this action, we feel that they are very familiar and very well-trained. So, we will use the lower bound. It is real hard to find.

MEMBER BLEY: I have got to go look at it. That certainly sounds outrageous.

CHAIRMAN STETKAR: It is not done across the board, either. It is only for selected --

MEMBER BLEY: For the ones we want --

CHAIRMAN STETKAR: It is only done for selected human actions. I don't know what criteria were used to select those human actions. I didn't try to divine why they were selected. I can just tell you it is not used across the board, but it was used for a number of the human actions that are identified when you look at the importance rankings, not all of them, though.

For example, it was not done for feed-and-bleed cooling, which was identified as an important action. Indeed, the numbers don't add up there, but at least the mean value from the numbers that don't add up was used.

It is just I will leave it there. I am sorry, I wanted to bring -- I had a laundry list of things here that I wanted to bring up in the context of the Level 1 at-power models, and I missed that one while I was making notes.

And I can confirm that at least -- you know, I can look at cut set lists. I can look at the fault trees. I can confirm that this percentile value was used.

MEMBER SCHULTZ: And that is in the Level 1, you say, John?

CHAIRMAN STETKAR: It is in, yes, I mean, that is right.

MEMBER BLEY: In the human factors.

CHAIRMAN STETKAR: You can find the footnotes in the tables of the Human Reliability Analysis, but it is not clear what it means until you go to the fault tree models and see what actual number was used for that basic event in the fault tree, and generate the log-normal distribution to see that, indeed, it is that number.

MR. SPRENGEL: Tanaka-san, do you have any response now or clarification needed?

DR. TANAKA: No. No. How we calculated the median or provide how we calculated from the table?

CHAIRMAN STETKAR: Yes. Some of those numbers, by the way, you may want to go back and check them because some of the numbers don't sum up to the number on the bottom. And there are some error bars along the side. So, it is clear that some numbers have been changed --

DR. TANAKA: Okay.

CHAIRMAN STETKAR: -- you know, in Rev. 3, for example.

DR. TANAKA: Maybe it is not just simply a sum, but --

CHAIRMAN STETKAR: In some places it is. I couldn't figure out what was done, for example, because in many places it is a simple sum; in other places it is apparently not. And I tried many different theories about what -- I tried mean values of distributions and adding up the mean and regenerating the log normal for the median. That didn't work.

DR. TANAKA: Okay.

CHAIRMAN STETKAR: And in other places it is a simple sum. So, I really don't know.

DR. TANAKA: We will check it.

CHAIRMAN STETKAR: Yes, that bottom, the way the tables are organized, the first number you come to is characterized as a median value with an error factor. And then, typically, there is another line down below which, indeed, is the mean value --

DR. TANAKA: Yes.

CHAIRMAN STETKAR: -- of that distribution. The ones I spot-checked, indeed, the ratio of the median to the mean was correct. So, I knew that you were using value No. 1 as a median. I knew you were using an error factor of 5.

DR. TANAKA: Yes.

CHAIRMAN STETKAR: And indeed, that other value was the mean. And then, in the bottom of the table there is a little explanation that says: well, for this action, we think it is good training and good familiarity. So, we will use the lower bound.

DR. TANAKA: Right. Yes.

CHAIRMAN STETKAR: So, you are familiar with that?

DR. TANAKA: We will check it, yes.

CHAIRMAN STETKAR: Okay.

DR. TANAKA: Yes.

CHAIRMAN STETKAR: I'm sorry to interrupt, but, as I said, I had that laundry list of things, and that was actually the last one that I wanted to get the zinger in on.

(Laughter.)

DR. CURRY: Thank you. We appreciate it.

MEMBER BLEY: I have one more I want to toss out for you to think about for tomorrow. I thought a little more about that interfacing LOCA scenario. And I would like you to go back and take a look at it.

You do two calculations. One is the chance that you broach the RHR system. Look at the little calculation you did. It looks like it is R5 factor of 1,000, just doing the arithmetic.

And then, you calculate, given you applied pressure to the RHR system, what is the chance the pipe breaks? And it is based on a failure rate something like 10 to the minus 7 per hour foot, or something like that. And I wonder where that number came from and what is the basis for it. So, if you could fill us in on those, that thing, I would appreciate it.

DR. CURRY: Do you have a reference for that?

MEMBER BLEY: Well, it is the initiating-event chapter on interfacing system LOCA.

DR. CURRY: Okay.

MEMBER BLEY: There is one page there where it does this calculation and talks about interfacing system LOCA in the initiating-event section, Chapter 2.

DR. CURRY: And it was off by a factor --

MEMBER BLEY: Chapter 2 of the PRA.

DR. CURRY: Right, and what was off? The initiating-event frequency was off by a factor of 1,000, you feel, or --

MEMBER BLEY: Yes, essentially. If you do a little, one-line calculation where you multiply three numbers, at least my arithmetic comes out a factor of 10 to the minus 3 off, 10 to the 3 on it. And the other one, I just don't know the basis for that number used for the pipe failure rate, given it is subjected to RCS pressure.

CHAIRMAN STETKAR: I didn't look at the numbers. I know they assumed 100 pipe feet.

MEMBER BLEY: Yes.

CHAIRMAN STETKAR: So, that is somewhere, but, I mean, I didn't --

MEMBER BLEY: I assumed they got that right, but I could -- you know, that is another question. But I didn't, either, except I saw it was very low to start with, and I didn't go back and check that until later.

That's it for me on that one. I would just like to get really convinced about that analysis.

DR. CURRY: All right. We will look at that.

Moving on to flooding, I am going to skip the usual pie chart because I think you know the routine.

Fundamentally, you see the references that we used. Pipe rupture frequencies were from the EPRI document, divided into the categories as specified in that document.

Internal key features are that the reactor building, essentially, is divided into two divisions, an east and west side, by flood barriers. Water-tight doors for safety-related SSC areas, the main control room and the reactor building exits. And once again, there is a transfer to the remote shutdown console, if necessary, from the main control room to achieve safe shutdown.

As I said, I will just skip the pie charts and the data in the interest of time because you have seen those.

Internal flooding assumptions. There is no credit for action by the operators outside of the main control room.

And if we have a break or a flood in the heat exchanger room, then we assume, due to the essential service water, we assume it is isolated in 15 minutes. And this just simply requires a pump trip.

As we mentioned, the east and west areas are divided of the reactor building. So, the effect of a flood is limited because of that division.

And floods from the emergency feedwater system, they do contribute, but, once again --

MEMBER BLEY: On that first, the isolation in 15 minutes, you didn't do a human reliability analysis or do any chance that they don't do that? You just assumed in 15 minutes it is wrapped up?

DR. CURRY: I think so. It took that amount of water. And again, as we mentioned, it is a simple action to terminate it. Sorry, Dr. --

MEMBER BLEY: Well, yes, but, you know, I don't remember this thing. In the heat exchanger room, which is what you are talking about, all you would have is some trouble alarm probably coming in that you have a full sump? Or how would the operators even know it is going on, such that they would isolate it in 15 minutes? And if you have a good story on that, then why don't we do an HRA? Why do we just assume 100 percent that it is wrapped up before the water goes everywhere?

DR. CURRY: Do we want to comment on that, the diagnostics of the flood now or --

DR. TANAKA: No. I'm sorry, I couldn't catch your question. We couldn't catch the question.

DR. CURRY: Well, basically, I think the Committee is asking how do we know, how would an operator know that we have flooding in that area. We have assumed 15 minutes. And we have explained that it is a fairly straightforward action to terminate the event. But I think the Committee member's question is, well, how do we know it happens? And what are the diagnostics?

DR. TANAKA: Okay.

MEMBER BLEY: How do you know it happens, know exactly where the water is coming from? And then, once you have got that, why don't you use an NHRA kind of model rather than just assume it is turned off in 15 minutes?

DR. CURRY: Scott, do you want to add something?

MR. KIPPER: Scott Kipper from MNES.

Just one thing. The rooms do have leak detection.

MEMBER BLEY: What kind?

MR. KIPPER: Just level sensors in the

floor drains, yes.

MEMBER BLEY: In the sump?

Yes, I mean, to me, it is a big jump to say, "I have got a sump alarm in some room and I am going to shut off the pump that is in that room in 15 minutes."

CHAIRMAN STETKAR: Well, it is an essential service water pump. It is not just any pump, either.

DR. CURRY: Right.

CHAIRMAN STETKAR: It is the kind of pump that takes the heat from half of your plant.

(Laughter.)

MEMBER BLEY: Yes, you don't want to turn that off in the first place.

CHAIRMAN STETKAR: I wouldn't.

MEMBER BLEY: But, in the second place, I mean, you get sump alarms. Water comes from different places. I have seen incident reports where people, when they get one of those, say, "Oh, yeah, wasn't somebody doing some work down there? Yeah, that's what that is. I'm busy with something else now."

And this is, bam, I've got it. I know it is there, and I am going to turn off the one pump that is in that room.

Is there other water piping going through that room? You know, how do we know for sure where the flooding is coming from? It just seems a leap to me. So, I want to hear the story.

CHAIRMAN STETKAR: A plant that will remain unnamed, for obvious reasons in about two minutes, filled up the entire space in the annular region between their containment shell and their external annulus to a depth of about 30 meters with service water because it was leaking. A sump was full of water, and the one sump-level switch didn't work. Nobody knew about it.

MEMBER BLEY: That is a lot of water coming in.

CHAIRMAN STETKAR: That was a lot of water.

MEMBER BLEY: I don't know for sure how big this room is.

CHAIRMAN STETKAR: That is an actual event that happened in a real plant.

DR. CURRY: Unless we want to go further today, we can consult with the flood panelists.

DR. TANAKA: Yes, we will check with the flood people.

MEMBER BLEY: Yes, and I don't know what kind of connections you have. If there is a flexible coupling on this, like there is on a lot of service water systems, you can get a really big hole suddenly, and you might be seconds to fill up the whole room rather than --

MEMBER SCHULTZ: It was also just interesting that this was what was selected to apply this approach, the particular approach. Everything else was presumed no credit.

MEMBER BLEY: That's right.

CHAIRMAN STETKAR: On the CCW, I haven't looked at the plant layout, and be careful here because we are treading on possible proprietary information. I don't know whether certainly in this forum whether the CCW heat exchanger rooms are entirely sealed or are they open to other areas? And you don't have to answer if you think it is too close to proprietary information, but that also hinges on some of Dennis' questions about --

MEMBER SCHULTZ: From a flood protection perspective, though, is that?

CHAIRMAN STETKAR: Yes.

MEMBER BLEY: Right. And back on that same thing, you know, I don't know if you have anything else, but you surely have component cooling water in there, too.

CHAIRMAN STETKAR: So, from what Steve said, it is curious that this approach was applied to this particular scenario, which means it almost has to be affecting something more than that train of ESW and that train CCW. Single-train failures aren't going to get you much of anything. So, you could essentially afford to assume that they didn't isolate that break, stop that break.

DR. TANAKA: The consequence of this kind of flood will cause an effect on two trains.

CHAIRMAN STETKAR: Okay. Yes.

DR. CURRY: Moving on, I think the key point of this next slide is the bottom line in terms of identifying the source of the flooding information. And there was a sensitivity study performed indicating that more recent flood data would reduce the flooding risk.

That is all we had planned to present on internal flood.

So, if the Committee is ready, we will go to low-power shutdown. The first bullet on this slide is meant to indicate that fundamentally the internal vents at power, PRA models were used to develop the low-power shutdown PRA. RHR was obviously added to those models for that purpose.

There are a number of plant operating states for low-power shutdown, 13 in particular. The mid-LOOP operation states are 4 and 8. So, detailed, because of the risk profile, a detailed sequence quantification was performed for those reduced-inventory states.

CHAIRMAN STETKAR: Jim, again, this is an area I didn't look at excruciating details of the low-power shutdown models, but 13 POSes, many features from things that I looked at looked very familiar to me.

One question I had is that many currently-operating plants that I have at least worked with for low-power and shutdown models have changed their outage management philosophy. So, for example, when I was operating at Zion, we, indeed, did drain to mid-LOOP in what you are calling POS 4.

Many plants now offload the entire core during refueling outage, put the fuel over in the spent-fuel pool, and any maintenance that requires them to drain down to mid-LOOP is typically performed while the core is in the spent-fuel pool. And they do that for a variety of reasons, but risk is one; the other is kind of the efficiency of the fuel shuffle.

So, my question is, do APWRs in Japan drain down to mid-LOOP in these pre-flooding the cavity and post-draining the cavity? Your plant operating states 5, 6, and 7 are a cavity flooded up and you say, well, the risk is insignificant in those.

The question is, is the drain to mid-LOOP in 4 and 8 consistent with operating practice in Japan for APWRs? As I said, I know from Zion back 30 years ago it is what we did, but the industry has learned some lessons from that. And I don't know what all plants in the U.S. do now. I am not familiar. I know that a few not in the U.S., but European plants that I have looked at, and in other countries, do not drain to mid-LOOP until all the fuel is out of the core.

And if that is the case here, now we have skewed the low-power-in-shutdown risk considerably because those are the only two plant operating states that contribute, based on something that might not necessarily be consistent with actual operating practices that we would expect. So, I don't know what your experience is, if you have any from the Japanese plants.

DR. TANAKA: Okay. First, we don't have any APWRs in Japan. So, I will talk about the PWRs, operating PWRs.

CHAIRMAN STETKAR: I said APWR.

DR. TANAKA: APWRs, there is no APWR yet.

CHAIRMAN STETKAR: Oh, that's right. No, I'm sorry.

DR. TANAKA: Okay.

CHAIRMAN STETKAR: There is the "hat trick," Dennis.

(Laughter.)

MEMBER BLEY: Congratulations.

CHAIRMAN STETKAR: Do you have any operating experience for not-so-advanced Pressurized Water Reactors in Japan, how they conduct their refueling outages?

(Laughter.)

DR. TANAKA: Yes. They move to mid-LOOP.

CHAIRMAN STETKAR: They do go to mid-LOOP?

DR. TANAKA: Yes.

CHAIRMAN STETKAR: Okay. Okay. All right. I am not going to ask -- what Luminant does at Comanche Peak Units 1 and 2 is kind of irrelevant because this is for the design certification. So, at least this characterization of the outage profile is, indeed, consistent with current operating practices in Japan. Okay.

Thanks. That helps.

DR. CURRY: Now design features to reduce shutdown risk. And we talked about mid-LOOP a moment ago, but the first bullet is there are no penetrations below the top of the core. So, a draindown event from the vessel, the probability of that is minimized.

There is an interlock for the automatic isolation of the low-pressure letdown line when inventory is reduced, and the location of the steam generator nozzle dams of the steam generators allows the nozzle dams to be installed on the water level is above the top of the main coolant piping.

Generic Letter 88-17 of the US-APWR is consistent with Generic Letter 88-17, which requires that the hatch be closed prior to reaching harsh conditions in containment, which is defined as 200 degrees F in containment. So, the US-APWR is committed to that requirement. And there is a main stand inventory to the RCS, as required by 88-17.

There is the pie chart just kind of showing risk from all contributors at the design certification stage, at-power events, fire, and flood.

This, again, is talking about mid-LOOP condition and the potential for air ingestion, vortexing of the CS RHR pumps.

The automatic isolation of low-power letdown line actuates at a set point above which the pumps would be damaged by air ingestion. That is set point is above that main coolant piping level.

And the PRA makes much more conservative assumptions in terms of inventory that exists with respect to actual planned practice.

CHAIRMAN STETKAR: Jim, can you go back to that pie chart? I guess I didn't appreciate something.

I read somewhere that the mid-LOOP conditions were essentially the whole story for low-power in shutdown. If I look at this pie chart, I see a big fraction of the total coming from POS 8-3, which is the mid-LOOP after refueling, and a relatively small fraction -- when I say "relative," relatively, it is small; it is still a large fraction -- coming from POS 4, which is mid-LOOP pre-refueling.

And I was curious why is POS 8 so much more important than POS 4, especially, if nothing else, the decay heat is a lot higher in POS 4. So, boiloff times would be quicker in POS 4 than POS 8, if the analysis was taken to that level of detail. And it may not be for this purpose.

But it is just still curious that POS 8, in particular, since it is also modeled as mid-LOOP, as I understand, is so much more important than 4. Do you have any insights about why that is?

And I happened to appreciate it because I was looking at a kind of bigger picture why is mid-LOOP so important.

DR. CURRY: So, you are comparing POS 4-3

LOOP with POS 8-3 LOOP?

CHAIRMAN STETKAR: Well, yes, or is there something else about POS 8? Is POS 4-3 and 8-3 the particular mid-LOOP configurations? What is the difference between 8-1 and 8-3, for example?

DR. CURRY: 8-1 is RHR cooling. So, that is mid-LOOP operation to draindown.

CHAIRMAN STETKAR: To draindown? Okay.

DR. CURRY: Right.

CHAIRMAN STETKAR: Okay.

DR. CURRY: 8-2 is mid-LOOP operation to nozzle dam removal and manway installation.

CHAIRMAN STETKAR: Okay.

DR. CURRY: And 3 is mid-LOOP operation to refilling the RCS.

CHAIRMAN STETKAR: Refilling?

DR. CURRY: Yes.

CHAIRMAN STETKAR: Okay. I will have to think about this a little bit more. I was just curious that I see an awful lot of 8's there and not many 4's.

DR. CURRY: Yes.

CHAIRMAN STETKAR: There must be something specific about the configurations that I am not appreciating. So, I will look at that tonight.

DR. CURRY: Okay. Well, we talked about

the set point above the point associated with potential air injection and the fact that the PRA was even more conservative in terms of assumed water levels.

So, our conclusions are that the US-APWR does have advanced features and meets the Commission's safety goals. And contributors to this are the four trains of safety-related systems, the in-containment refueling water storage pit, and we talked about that we believe the full digital instrumentation and controls enhances the human/system interface. The advanced accumulators, doing away with the need for low-pressure injection system. Safety trains are physically separated from a fire perspective and from a flood perspective. So, we provide separation in terms of divisions or subsystems.

The final few slides are a summary of the open items in the SER that I expect the staff will go over in more detail.

CHAIRMAN STETKAR: Yes.

DR. CURRY: We owe the staff several thermal hydraulic analyses which are associated with RAI 750. I think most of the other items we have provided responses to the staff.

Major topics, if you were to kind of take a cut through these and take a look at them, have to do with documenting COL items, which are done in 19.3, and the staff helped us quite a bit in beefing-up that section to assure an effective transfer to COL applicants.

Documenting risk insights. If you look at Table 19.1-119, documenting uncertainties. Our method of conformance with 88-17 is one of the items here.

So, I think that probably summarizes the key points of where we are. And the vortexing issue is being addressed in Chapter 5. That is row 13 on the list.

So, with that, I would conclude our discussion of Section 19.1.

Yes, please, Nirasawa-san?

MR. NIRASAWA: Please change the page.

DR. CURRY: Change the page? Oh, so sorry. Okay. Thank you, Nirasawa-san.

Okay. So, I think that kind of concludes our summary of what we had planned to say about Section 19.1 And this might be a good place -- we can pick up with 19.2 tomorrow, if the Committee likes.

CHAIRMAN STETKAR: It is up to you, because it has been a long day. I don't want to risk running long tomorrow, for a variety of reasons. We can either run to 5:30 -- let me ask our severe accident expert, who is sitting in the corner, do you think we can get through the five or six slides on this in 20 minutes or not?

MEMBER REMPE: Well, there's not many slides. But I have another question that is down deep in the details of the MAAP analysis and the assumptions that I would like to ask. They don't really show up here on the slides.

DR. CURRY: We have our team here. I think we would be happy to go through it.

CHAIRMAN STETKAR: Will it take --

MEMBER REMPE: It is not that long. It is just that is more of interest than the material on the slides to me because --

CHAIRMAN STETKAR: I'll tell you what. Let's see if we can through these slides. If we don't get to Joy's question, we can at least get the question quickly out on the table. If it is something that MHI can do some homework at night --

MEMBER REMPE: Yes, that would be good.

CHAIRMAN STETKAR: -- let's do that.

MEMBER REMPE: I don't know; maybe they will have a good answer real quick for me.

CHAIRMAN STETKAR: Joy, why don't you get your question out on the table quickly, so we make sure we have that? And then, we will see if we can get through the slides also.

MEMBER REMPE: Sure. Okay.

So, again, it comes from a proprietary document, but you specify it in your PRA, in Chapter 14, which is in File 110 of the PRA document, that your fuel melting assumption was a certain value. Can I say temperatures? Is it allowed here? Is it proprietary?

CHAIRMAN STETKAR: You have at least pointed them to what it is.

MEMBER REMPE: Okay. And that is not the melting temperature for UO2. That is not the liquidus temperature ZrO2. And so, what is the basis? It is quite low again. And I just was wondering what that basis was for the melting temperature you assumed in that.

MR. GODA: Basis.

MEMBER REMPE: Basis?

MR. GODA: Basis.

MEMBER REMPE: It is much lower.

MR. GODA: I'm sorry, I cannot answer right now.

MEMBER SCHULTZ: Can you show or point --

MEMBER REMPE: I can show you.

MEMBER SCHULTZ: No, not me.

MEMBER REMPE: Okay. I can show you the value and I can show you the page.

The reason I am asking that is because years ago -- and again, I have not kept up with more recent versions of MAAP -- but a long time ago, MAAP stopped hydrogen generation when the fuel reached a melting temperature. So, if you have a very low melting temperature assumed in your MAAP analysis, you might have less hydrogen generation, unless the PIRT has been changed.

MEMBER BLEY: Than real.

MEMBER REMPE: I'm sorry, you know this is true still?

MEMBER BLEY: No, no, I said less hydrogen than the real case.

MEMBER REMPE: Than real, yes. So, have you underestimated hydrogen generation because you have fortuitously picked a low melting temperature of fuel is what I am asking. So, it would be good to try to understand that assumption.

(At this point, the Applicant has asked that the exchange between Member Rempe and Mr. Goda be stricken from the record because it contains proprietary information.)

MR. GODA: I am sorry, if it is quite

different from mine, that is in the MAAP variation. Mine is in the MAAP code. Oh, that is Kelvin. Oh, I see. I see. I see.

(At this point, the Applicant has asked that the exchange between Member Rempe and Mr. Goda be stricken from the record because it contains proprietary information.)

MEMBER REMPE: Why was that number assumed?

MR. GODA: Well, I cannot answer correctly, but it is set in a conservative way.

MEMBER REMPE: Okay. So, it might be conservative --

MR. GODA: Yes.

MEMBER REMPE: -- because you get the fuel to locate to the lower head.

MR. GODA: That's right.

MEMBER REMPE: But --

MR. GODA: And also, another one, regarding the hydrogen generation -- (At this point, the Applicant has asked that the exchange between Member Rempe and Mr. Goda be stricken from the record because it contains proprietary information.)

DR. CURRY: You are correct that MAAP won't generate 100 percent metal-to-water reaction.

MEMBER REMPE: Right.

DR. CURRY: So, it is common practice to kind of mechanically add --

MEMBER REMPE: Bump it up.

DR. CURRY: That is right. So, you are correct with that. But, as Goda-san said, then it was kind of input into the code anyway, rather than just relying on the MAAP number.

MEMBER REMPE: Okay. That helps me. So, I am glad I got to ask that tonight and think about it and what was done, then, subsequently.

CHAIRMAN STETKAR: Great.

Let's see if we can get through these slides.

DR. CURRY: Okay. In terms of severe accident evaluation, the design features from an average standpoint, four-train safety-grade reactor protection system and a DAS diverse actuation system. There was no credit for tripping, for operator action to trip.

Mid-LOOP operations, we talked about that. The four-train RHR design and the draindown path interlock with water level. Station blackout, we have talked about that. Four Class 1E GTGs and two alternate AC sources.

Fires, we have talked about the separation of safety systems into the trains.

And we also talked about the RHR designed not to fail by overpressure, and we discussed that. There may have been an action item on that. I will look through our notes.

The evaluation of severe accident phenomena, the thermally-induced steam generator tube rupture, I think at this point it is a confirmatory item, but it was evaluated based on current understanding about temperature-induced steam generator tube rupture.

Ex-vessel steam explosion, that has also been addressed, considering a range of uncertainties for the evaluation of steam explosion.

Hydrogen burning, that I think, Goda-san, because of the Gothic prediction of potential hydrogen concentration in the RWSP, we made a design change to deal with that.

MR. GODA: Yes.

DR. CURRY: That is battery-powered igniters, dedicated igniter system. And that is documented in an RAI response as well.

So, on the next slide, we are talking about the control of hydrogen.

Core debris coolability, we have the ability to flood the reactor cavity with multiple systems, and then, the geometry, both floor area and depth are relevant to core coolability.

MEMBER REMPE: You did some standalone calculations for the flooding height. I didn't see anything, again, in this section, in the MAAP analysis that you assumed that a certain amount of water comes out, and you actually have done some calculations with MAAP showing that water level increasing to where it did? Or how did you come up with the flooding height in cavity?

MR. GODA: Flooding height? You mean --

MEMBER REMPE: The water height in the cavity.

MR. GODA: The cavity? Yes, we have the calculation, but that is an internal memo of MHI.

MEMBER REMPE: Okay. We will see if the staff did some audit calculations tomorrow to see if there is anything. But, okay.

DR. CURRY: And high-pressure melt ejection, we mentioned earlier the separate line. This was the Chairman asked whether that was considered in the Level 1 PRA, but there is a dedicated line, severe accident, a depressurization valve line.

You also talked about the debris trap earlier.

CHAIRMAN STETKAR: In the structure of your models -- and I meant to check this last night and I forgot -- you have your containment systems event tree, CSET, and your containment phenomenological event tree. What we are talking about here, the phenomena are out in CPET.

I thought that I read that the CSETs are linked directly to the core damage event sequences. Is that correct? In other words, it is quantified as one integrated model? Is that the way the model was assembled?

And in particular, I want to make sure that, indeed, if electric power was not available, for example, in the Level 1 full-power PRA model to the safety depressurization valves, for example, and perhaps also to the depressurization valves, that that condition, indeed, was transferred through the CSET to the appropriate plant damage state, so that that frequency was correctly accounted for. Was it?

And were the fire protection pumps explicitly modeled in the CSET, so that if they were not available for alternate, at least alternate cooling of the charging pumps, where I know there is credit for them, they were also not available for flooding the reactor cavity?

DR. CURRY: So, you are really asking about dependencies as we --

CHAIRMAN STETKAR: Yes, in other words, it models it completely. If I have confidence of that, I have confidence in risk spectrum to solve cut sets. I just didn't look at enough detail. I read some words that it was linked, and therefore, those intermediate ACLs, or whatever you call them, really don't mean anything.

DR. TANAKA: Yes, it is linked.

CHAIRMAN STETKAR: It is linked?

DR. TANAKA: It is linked and it is propagated.

CHAIRMAN STETKAR: Oh, good. Good. Thanks.

DR. CURRY: Okay. So, this is a little bit repetitive. The steam explosion, low probability of steam explosion, and the containment is designed to withstand that.

The temperature-induced steam generator tube rupture, we mentioned the dedicated depressurization line.

CHAIRMAN STETKAR: Jim, the challenges to that depend on what is going on on the secondary side of the steam generators in the Level 1 PRA model. It comes back to the question I asked earlier. The Level

1 PRA model does not model steam really. It assumes that you have enough available. But, in particular, it doesn't model stuck-open valves.

So, for example, if you go to what is characterized now as a high-pressure melt, with a stuck-open valve on one steam generator, if it is a relief valve or a safety valve, or common stuck-open valves, like the turbine bypass valves that are not isolated, you will have low-pressure, dry conditions on the secondary sides of one or more steam generators.

That condition, you don't know the frequency of that condition from the Level 1 models right now. So, I am curious how you quantified the frequency of scenarios that, indeed, essentially, excite the need to depressurize the primary system, so you don't get a temperature-induced tube rupture.

Now I understand how you might know that from like a steamline break that goes to core damage, you know, some small subset of events. But I don't know how you account for the other frequency. I don't know how important it is because --

DR. CURRY: Right.

CHAIRMAN STETKAR: -- I just don't.

DR. CURRY: So, basically, the contribution of the secondary side being at low pressure due to a stuck-open valve?

CHAIRMAN STETKAR: Yes. Yes. Again, these tend --

MR. GODA: I can answer.

CHAIRMAN STETKAR: -- to be high-pressure scenarios. So, because of that, you probably don't have feedwater flow. So, one or more steam generators are going to blow down. So, you get the dry low on the secondary side.

MR. GODA: We have communicated with the NRC staff as well about that here. And then, evaluated the frequency of a stuck-open valve, stuck-open main steamline valves as well in our EPET, Extended Progress Event Tree Model. And that also we unstuck. We communicated through the RAI.

CHAIRMAN STETKAR: Okay. Thanks. I will have to look at that. Thanks. Thanks a lot. That helps. Thank you.

DR. CURRY: So, in summary, basically, the design options and changes that we talked about represent those that were found to be cost-beneficial in terms of severe accident mitigation, and there were no additional design alternatives found to be cost-beneficial.

We have one open item in this area. It has to do with the survivability of components in a severe accident environment.

MEMBER SCHULTZ: Jim, I just have to ask here, what process was used to determine the quantification of cost-beneficial? What does that mean? In other words, what analysis or approach was used to do the cost/benefit analysis?

DR. CURRY: Goda-san, do you want to comment?

MR. GODA: Okay. We performed SAMDA evaluation in accordance with instructions provided in a NUREG report, NUREG -- I don't remember the number, but there are two reports about the SAMDA. So, we just looked at, referenced those ones, those instructions.

MEMBER SCHULTZ: That gives me a benchmark as to where you were. Thank you.

MEMBER REMPE: Vessel failure would be impacted by the temperature of the material relocating to the lower head and the heat transfer on the outside of the vessel, which it seemed to me there would be some uncertainty. Did you consider uncertainty in vessel failure timing and some of the parameters that are predicted?

MR. GODA: You mean in SAMDA?

MEMBER REMPE: No. No, no. Just with

your MAAP analysis and how you quantified the releases as a function of time during various severe accident scenarios.

MR. GODA: Well, we do not do some particular sensitivity studies using a MAAP code about that timing for --

MEMBER REMPE: You did do some?

MR. GODA: No. No, we did not. In specific, you mean absolute, right?

MEMBER REMPE: Right. Because it would be affected by some of the user-defined input parameters for MAAP as well as the heat transfer from the lower head to whatever.

MR. GODA: No, no, we didn't. No, we did not do that, that sensitivity. The ex-vessel, we did perform it, but in the in-vessel we did not.

MEMBER REMPE: Okay.

CHAIRMAN STETKAR: Any members have any other questions for MHI?

(No response.)

If not, again, in the interest of our purpose here, are there any members of the public who have any comments regarding the design certification, Chapter 19?

(No response.)

If not, thank you very much.

Do you have a question?

(Laughter.)

DR. CURRY: No questions on the record, but I just would remind the Chairman there were a couple of action items that we want to go over with him.

CHAIRMAN STETKAR: I have them, and I will do that offline, so I get the right references.

Thank you very much.

We finished one minute ahead of where I thought we might finish. So, that was excellent.

And you have stamina.

(Laughter.)

Thank you very much.

We will recess until tomorrow morning.

(Whereupon, the above-entitled matter went off the record at 5:29 p.m.)

Presentation to ACRS Subcommittee

Chapter 17:
Quality Assurance
and Reliability Assurance

February 21, 2013

Mitsubishi Heavy Industries, Ltd.

MHI Presenters

Lead Presenter:

Kevin Lynn

MHI Technical Experts:

Takashi Kurisaki

Takayuki Nirasawa

Dr. Futoshi Tanaka

Osami Watanabe

MNES Support:

Dr. James Curry, P.E.

Kurt Walter

Edmond Wiegert, P.E.

Acronyms

ACRS	:Advisory Committee on Reactor Safeguards
APWR	:Advanced Pressurized Water Reactor
CCF	:Common Cause Failure
CFR	:Code of Federal Regulations
COL	:Combined License
DCD	:Design Control Document
D-RAP	:Design Reliability Assurance Program
EP	:Expert Panel
FV	:Fussell-Vesely Importance
ITAAC	:Inspection, Test, Analysis, and Acceptance Criteria
MHI	:Mitsubishi Heavy Industries, Ltd.
MNES	:Mitsubishi Nuclear Energy Systems, Inc.
NEI	:Nuclear Energy Institute
NRC	:Nuclear Regulatory Commission
OE	:Operating Experience
PRA	:Probabilistic Risk Assessment
QA	:Quality Assurance
QAP	:Quality Assurance Program
QAPD	:Quality Assurance Program Description
RAI	:Request for Additional Information
RAP	:Reliability Assurance Program
RAW	:Risk Achievement Worth
SE	:Safety Evaluation
SSC	:Systems, Structures, and Components

Contents of DCD Chapter 17

Section No.	Description
17.0	Quality Assurance and Reliability Assurance
17.1	Quality Assurance During the Design Phase
17.2	Quality Assurance During the Construction and Operation Phases
17.3	Quality Assurance Program
17.4	Reliability Assurance Program
17.5	Quality Assurance Program Description
17.6	Description of the Applicant's Program for Implementation of 10 CFR 50.65, the Maintenance Rule

Relationship between DCD and Topical/Technical Reports

DCD Section	Topical / Technical Reports
17.1 QA During the Design Phase	PQD-HD-19005
17.2 QA During the Construction and Operation Phases	NA
17.3 QA Program	PQD-HD-19005
17.4 Reliability Assurance Program	MUAP-07030
17.5 QA Program Description	PQD-HD-19005
17.6 Implementation of Maintenance Rule	NA

Topical Reports	PQD-HD-19005 (R4)	Quality Assurance Program Description For Design Certification of the US-APWR	April 2011
Technical Reports	MUAP-07030 (R3)	US-APWR Probabilistic Risk Assessment	June 2011

17.1 - Quality Assurance During the Design Phase

- **Quality Assurance (QA) for the US-APWR design certification is described in Section 17.5 for the standard plant design**
- **Combined License (COL) Applicants are responsible for QA applicable to site-specific design activities in the design phase**

17.2 - Quality Assurance During the Construction and Operation Phases

- COL Applicants are responsible for QA applicable to construction and operation phases

17.3 - Quality Assurance Program

- Quality Assurance Program (QAP) for the US-APWR design certification is described in Section 17.5
- COL Applicants are responsible for QAP applicable to site-specific design activities in the design phase and for the construction and operation phases

17.4 - Reliability Assurance Program Introduction

- **Purpose of the US-APWR Reliability Assurance Program (RAP) activities is to provide reasonable assurance that:**
  - ✓ the US-APWR is designed, constructed, and operated in a manner that is consistent with the assumptions and risk insights for risk-significant SSCs,
  - ✓ risk-significant SSCs do not degrade to an unacceptable level during plant operations,
  - ✓ the frequency of transients that challenge risk-significant SSCs is minimized, and
  - ✓ risk-significant SSCs function reliably when challenged.

17.4 - Reliability Assurance Program Introduction (cont.)

- **US-APWR Design Reliability Assurance Program (D-RAP) activities are implemented in accordance with:**
  - ✓ Section 17.4, "Reliability Assurance Program (RAP)" of NUREG-0800, "Standard Review Plan"
  - ✓ Interim Staff Guidance on Standard Review Plan, Section 17.4, "Reliability Assurance Program" DC/COL-ISG-018

- **Phases of the US-APWR D-RAP activities:**
  - ✓ **<u>Design Certification Phase (Phase I)</u>**
  - ✓ Site-specific Phase (Phase II)
  - ✓ Procurement, Fabrication, Construction, and Preoperational Testing Phase (Phase III)

17.4 - Reliability Assurance Program
D-RAP Implementation

- **The process for identification of SSCs within the scope of the RAP (RAP SSCs) uses a combination of the following sources:**
  - ✓ Probabilistic Risk Assessment (PRA)
  - ✓ Severe Accident Evaluation
  - ✓ Industry Operating Experience
  - ✓ Expert Panel (EP)

17.4 - Reliability Assurance Program
D-RAP Implementation (cont.)

- **PRA Scope used to identify risk-significant SSCs:**
  - ✓ Level 1 and Level 2 Internal Events for Operations at Power
  - ✓ Level 1 and Level 2 External Events (Internal Fires and Internal Flooding) for Operations at Power
  - ✓ Low-Power and Shutdown Operations
  - ✓ Seismic (PRA-based Seismic Margin Analysis)

17.4 - Reliability Assurance Program D-RAP Implementation (cont.)

✓ SSCs that meet the importance criteria are identified as Risk-significant SSCs.



✓ SSCs evaluated in the PRA-based Seismic Margin Analysis are all identified as Risk-significant SSCs.

✓ PRA key insights and insights from severe accident evaluation are also taken into consideration.

17.4 - Reliability Assurance Program D-RAP Implementation (cont.)

➢ Expert Panel

- ✓ EP reviews and finalizes the RAP SSC list using the following information:
  - PRA results (including SSCs deemed to not be risk-significant in the PRA)
  - Nuclear industry operating experience
- ✓ EP members must meet qualification for education and experience
- ✓ EP is comprised of members who have sufficient knowledge of:
  - PRA,
  - Plant Operations,
  - Plant Maintenance,
  - Design Engineering, and
  - Quality Assurance.

17.4 - Reliability Assurance Program
D-RAP Implementation (cont.)

- **RAP SSCs are identified in DCD Table 17.4-1**
  - ✓ DCD Table 17.4-1 includes information regarding RAP SSCs, rationale for inclusion, risk-significant failure mode, and risk insights and key assumptions.

Table 17.4-1 Risk-significant SSCs (Sheet 1 of 51)

#	Systems, Structures and Components (SSCs)	Rationale(1)	Failure Mode(2)	Insights and Assumptions
1	**Accumulator injection system**			
1	Discharge line secondary isolation check valves [SIS-VLV-102A (B, C, D)]	RAW(L1, L1-CC, L2-CC)	OD, EL, PR	The accumulator provides safety injection function for refill and re-flooding of the reactor vessel following a loss of coolant accident (LOCA). Also provides negative reactivity to shutdown the reactor. Single failure of any SSCs listed here has potential to cause failure of its dedicated train to inject coolant to RCS.
2	Boundary check valves (Discharge line) [SIS-VLV-103A (B, C, D)]	RAW(L1, L1-CC, L2-CC)	OD, EL, PR	
3	Discharge line isolation motor operated valves [SIS-MOV-101A (B, C, D)]	RAW(L1)	EL, PR	
4	Discharge line orifices train A through D [SIS-SRO-006A (B, C, D)]	RAW(L1)	PR	
5	Piping train A through D (Accumulator injection line)	RAW(L1) SM	EL, SS	
6	Accumulators [SIS-MTK-001A (B, C, D)]	EJ SM	SR, SS	

EJ = Engineering Judge
SM = SEISMIC Event

EL = External Leak [Valve, Pipe, Tube, Pump, Tank, Heat Exchanger(Shell/Tube)]
OD = Fail to Open [Valve]
PR = Plug [Valve, Orifice, Strainer, Heat Exchanger, Nozzle, Sump]
SR = Fail to Run [Pump, Gas Turbine Generator, Fan]
SS = Structural Failure by Seismic Hazard

17.5 - Quality Assurance Program Description

- Basis of the US-APWR Quality Assurance Program Description (QAPD) is described in "*Quality Assurance Program (QAP) Description For Design Certification of the US-APWR*", PQD-HD-19005
- MHI QAPD is based on the requirements of 10 CFR 50 Appendix B, 10 CFR 52, and NQA-1-1994 and was developed using the NEI template (NEI 06-14A)
- Topical report for the MHI QAPD Revision 4 (PQD-HD-19005 Rev. 4) was submitted April 8, 2011
- MHI QAPD Rev. 4 was approved by the NRC on November 9, 2011 as documented in the NRC's Chapter 17 Safety Evaluation (SE) dated January 17, 2013

17.6 – Description of Applicant's Program for Implementation of 10 CFR 50.65, the Maintenance Rule

- **COL Applicants are responsible for development of the program for implementation of 10 CFR 50.65, the Maintenance Rule**

Open Items from Chapter 17 SE

Open Item	Description	Resolution
17.05-01	An open item was created to track the NRC's inspection of MHI's implementation of the QAP.	The NRC performed an inspection in December 2010. Three violations were identified. MHI responded to the violations and also proposed changes to the QAP. The NRC accepted MHI's response. **This Open Item is resolved as described in the SE.**

Confirmatory Items from Chapter 17 SE

Confirmatory Item	Description	Resolution
17.04-52 (RAI 606-4827 Question 17.04-52)	It was not clear that industry OE is incorporated into expert panel D-RAP dominant failure mode selection.	MHI clarified DCD Tier 2 Section 17.4.7.1 to state that industry OE is used in D-RAP dominant failure mode selection. The proposed DCD changes from the RAI response will be incorporated into the next revision of the DCD.
17.04-63 (RAI 891-6268 Question 17.04-63)	The corrective action program described in the DCD only applied to design documents that address SSC reliability assumptions.	MHI clarified the extent of the corrective action program in relation to the D-RAP in DCD Tier 2 Section 17.4.4. The proposed DCD changes from the RAI response will be incorporated into the next revision of the DCD.
17.04-66 (RAI 891-6268 Question 17.04-66)	Additional failure modes for some D-RAP SSCs listed in DCD Table 17.4-1 were identified.	MHI updated DCD Tier 2 Table 17.4-1. The proposed DCD changes will be incorporated into the next revision of the DCD.
17.04-67 (RAI 891-6268 Question 17.04-67)	Several potential additional D-RAP SSCs were identified.	MHI updated DCD Tier 2 Table 17.4-1 to include the additional D-RAP SSCs. The proposed DCD changes from the RAI response will be incorporated into the next revision of the DCD.
17.04-68 (RAI 891-6268 Question 17.04-68)	Potential inconsistencies between Tier 1 and Tier 2 D-RAP – ITAAC were identified.	MHI clarified the discussion in DCD Tier 2 Section 17.4.8. The proposed DCD changes will be incorporated into the next revision of the DCD.

U.S.NRC

United States Nuclear Regulatory Commission

Protecting People and the Environment

Presentation to the ACRS Subcommittee

US-APWR Design Certification Application Review

Safety Evaluation with Open Items for

CHAPTER 17: Quality Assurance and Reliability Assurance

February 21, 2013

Staff's Presentation Order

U.S.NRC
United States Nuclear Regulatory Commission
Protecting People and the Environment

- **Jeffrey Ciocco-** US-APWR, Lead Project Manager
- **Tarun Roy -** Project Manager
- **Greg Galletti** - Construction Electrical Vendor Branch
- **Todd Hilsmeier** – PRA and Severe Accidents Branch

Conclusion:

There are no open items associated with this CHAPTER 17 ‘Quality Assurance and Reliability Assurance’

LUMINANT GENERATION COMPANY

Comanche Peak Nuclear Power Plant, Units 3 and 4

ACRS US-APWR Subcommittee

FSAR Chapter 17 – Quality Assurance and Reliability Assurance

February 21, 2013

Luminant

US-APWR

MNES
MITSUBISHI NUCLEAR ENERGY SYSTEMS, INC.

Agenda

- Introduction
- NRC Proposed License Condition
- Site-specific Aspects

Introduction

- FSAR uses IBR methodology
- No departures from US-APWR DCD
- All COL Items addressed in FSAR
- No Chapter 17 SER Open Item
- No SER Confirmatory Items
- One NRC proposed License Condition
- No contentions pending before ASLB

NRC Proposed License Condition 17-1

No later than 12 months after issuance of the COL, the licensee shall submit to the Director of NRO, a schedule that supports planning for and conduct of NRC inspection of the Maintenance Rule program. The schedule shall be updated every 6 months until 12 months before scheduled fuel loading, and every month thereafter until the Maintenance Rule program has been fully implemented.

Luminant

US-APWR

MNES
MITSUBISHI NUCLEAR ENERGY SYSTEMS, INC.

R-COLA Proposed License Condition

The Licensee shall submit to the Director of NRO, a schedule, no later than 12 months after issuance of the COL or at the start of construction as defined in 10 CFR 50.10(a), whichever is later, that supports planning for and conduct of NRC inspections of operational programs listed in FSAR Table13.4-201 with the exception of the Fitness for Duty program. The schedule shall be updated every 6 months until 12 months before scheduled fuel loading, and every month thereafter for each applicable operational program until either the operational program has been fully implemented or the plant has been placed in commercial service, whichever comes first.

Site-Specific Aspects

17.1 Quality Assurance During the Design Phase

17.2 Quality Assurance During the Construction and Operation Phases

Quality Assurance for site-specific design, construction, and operation is described in Sections 17.3 and 17.5.

17.3 Quality Assurance Program

- Luminant responsible for establishing and implementing QAP for design, construction and operation
- Luminant has delegated work, but retains responsibility for QAP
- QA for preparation and review of COLA governed by NuBuild QAPP invoking elements of Units 1&2 QAP; both based on ANSI N45.2-1971 and meets 10CFR50 Appendix B
- Luminant required Primary Contractor to have QAP based on NQA-1-1994 and meet 10CFR50 Appendix B

17.4 Reliability Assurance Program

- US-APWR D-RAP implemented in phases
  - Phase I – Design certification phase
  - Phase II – Site-specific phase
  - Phase III – Procurement, fabrication, construction, and preoperational testing phase
- Phase II and III programs continue structure and quality controls of Phase I and occur before fuel load
- Luminant responsible for D-RAP Phases II, III, and O-RAP
- The only site-specific Phase II risk-significant SSCs are UHS cooling tower fans (Table 17.4-201)

17.4 Reliability Assurance Program (cont'd)

- O-RAP will be under Systems Engineering and Maintenance Engineering

- O-RAP integrated into Maintenance Rule Program and other operational programs (ISI, IST, RVMSP, etc.)

17.5 Quality Assurance Program Description

- Implementation of QAP will transition, upon issuance of COL and as project progresses, from QAPP to QAPD
- Full transition to QAPD complete no later than 30 days prior to fuel load
- Nuclear operations governed by fully-implemented QA program based on NEI 06-14A

17.6 Maintenance Rule Program

NEI 07-02A IBR

Acronyms

ACRS	Advisory Committee on Reactor Safeguards
APWR	Advanced Pressurized Water Reactor
ASLB	Atomic Safety and Licensing Board
COL	Combined License
COLA	Combined License Application
DC	Design Certification
DCD	Design Control Document
D-RAP	Design Reliability Assurance Program
FSAR	Final Safety Analysis Report
IBR	Incorporated by reference
ISI	In-service Inspection
IST	In-service Testing
NEI	Nuclear Energy Institute
NRO	Nuclear Reactor Operations
O-RAP	Operations Reliability Assurance Program
QA	Quality Assurance
QAP	Quality Assurance Program
QAPD	Quality Assurance Program Description
QAPP	Quality Assurance Project Plan
RAP	Reliability Assurance Program
RVMSP	Reactor Vessel Material Surveillance Program
SER	Safety Evaluation Report
SSC	Structures, Systems, and Components
UHS	Ultimate Heat Sink

U.S.NRC
United States Nuclear Regulatory Commission
Protecting People and the Environment

Presentation to the ACRS Subcommittee

Comanche Peak Nuclear Power Plant, Units 3 and 4
COL Application Review

Safety Evaluation Report with Open Items for

CHAPTER 17: Quality Assurance and Reliability Assurance

February 21, 2013

Staff's Presentation Order

U.S.NRC
United States Nuclear Regulatory Commission
Protecting People and the Environment

- **Stephen Monarque** - Comanche Peak COLA Lead Project Manager
- **Tarun Roy -** Project Manager
- **Greg Galletti** - Construction Electrical Vendor Branch
- **Todd Hilsmeier** – PRA and Severe Accidents Branch

Conclusion:

There are no open items associated with this CHAPTER 17 ‘Quality Assurance and Reliability Assurance’

LUMINANT GENERATION COMPANY

Comanche Peak Nuclear Power Plant, Units 3 and 4

ACRS US-APWR Subcommittee

FSAR Chapter 16 –
Technical Specifications

February 21, 2013

Agenda

- Introduction
- SER Open Item
- SER Confirmatory Item
- Site-Specific Aspects

Introduction

- FSAR uses IBR methodology
- No departures from US-APWR DCD
- All COL Items addressed in FSAR
- One SER Open Item
- One SER Confirmatory Item
- License Conditions not applicable to TS
- No contentions pending before ASLB

SER Open Item

16-1 RAI 90 (3113) Question 16-10

Provide full list of site specific SRs affected by the SFCP and deterministic values for the frequency assignments

Proposed resolution – will remain open until Luminant confirms that SFCP numerical values will be placed in FSAR

SER Confirmatory Item

16.4-1 RAI 26 (3287) Question 19-3

Incorporate methodology and adequacy requirements for PRA to support RITS in PTS

Proposed resolution – reference to methodology and technical adequacy are included in PTS. The final approved revision level of the methodology to be added to PTS.

Site-Specific Aspects

16.1 Technical Specifications

- US-APWR TS and Bases are adopted by the COLA in Part 4 and site specific information provided in bracketed areas
- CPNPP Units 3 and 4 adopt RMTS and SFCP developed under RITS Initiatives 4b and 5b
- Luminant will establish a CRMP and SFCP to be completed, reviewed, and approved by NRC prior to fuel load
- Luminant following DCD TS changes still under discussion with NRC

COLA Part 4

- Section A explains and justifies the 25 locations where COL Items are addressed with plant-specific information
  - Plant-specific information replaces bracketed information in DCD as appropriate
  - Brackets removed where PTS same as DCD
- Section B provides complete PTS

Acronyms

ASLB	Atomic Safety and Licensing Board
COL	Combined License
COLA	Combined License Application
CPNPP	Comanche Peak Nuclear Power Plant
CRMP	Configuration Risk Management Program
DCD	Design Control Document
FSAR	Final Safety Analysis Report
IBR	Incorporated by Reference
PTS	Plant-Specific Technical Specifications
PRA	Probabilistic Risk Assessment
RAI	Request for Additional Information
RITS	Risk-Informed Technical Specifications
RMTS	Risk-Managed Technical Specifications
SER	Safety Evaluation Report
SFCP	Surveillance Frequency Control Program
TS	Technical Specifications
US-APWR	United States Advanced Pressurized Water Reactor

Presentation to the ACRS Subcommittee

Comanche Peak Units 3 & 4 Combined License Application Review

SER/OI Chapter 16

Technical Specifications

February 21-22, 2013

Staff Review Team

- **Technical Staff**
  - Tech Reviewer
    CTSB Branch: Theodore Tjader
- **Project Managers**
  - Lead PM: Stephen Monarque
  - Chapter PM: Tarun Roy

Technical Topic of Interest: Risk-Managed Technical Specifications

U.S.NRC
United States Nuclear Regulatory Commission
Protecting People and the Environment

- Comanche Peak Units 3 & 4 are adopting Risk-Managed Technical Specifications (RMTS, NEI-06-09)(aka Risk-informed Completion Times) and Surveillance Frequency Control Program (SFCP, NEI 04-10)(for licensee control of surveillance frequency adjustments) using risk information with specific PRA requirements.

- RMTS & SFCP require programs in TS Admin Controls section, referencing approved NEI 04-10 and NEI 06-09 methodology documents.

Technical Topic of Interest: Risk-Managed Technical Specifications

U.S.NRC
United States Nuclear Regulatory Commission
Protecting People and the Environment

- Since the CP PRA reflecting the as-built/as-to-be-operated plant is not available at time of COL issuance, when TS must be complete, a TS methodology is needed per Option 3 of ISG-08 for completing a PRA that is adequate for the RMTS & SFCP applications.
- The staff has reviewed the CP TS methodology (with no open items) for completing a PRA adequate for the RMTS & SFCP applications.
- The methodology is referenced in the CPNPP 3&4 TS Admin Controls Sections 5.5.18 and 5.5.19, along with the referenced NEI 06-09 (RMTS) and NEI 04-10 (SFCP) documents.

Description of Open Items

U.S.NRC
United States Nuclear Regulatory Commission
Protecting People and the Environment

- Open Item 16-1: The initial surveillance frequency values that are to be included in the Surveillance Frequency Control Program (SFCP) are the values listed in the DCD TS, except for the Ultimate Heat Sink (UHS) which is a site-specific system with its site specific values. The FSAR shall state that SFCP initial values will be the DCD surveillance frequencies and the specific UHS initial surveillance frequency values will also be specifically stated in the FSAR.

- Questions?

Presentation to ACRS Subcommittee

Chapter 19: Probabilistic Risk Assessment and Severe Accident Evaluation

February 21-22, 2013

Mitsubishi Heavy Industries, Ltd.

MHI Presenters

Lead Presenter:

Dr. James Curry, P.E.

MHI Technical Experts:

Hiroshi Goda

Takayuki Nirasawa

Dr. Futoshi Tanaka

MNES Support:

Hiroshi Hamamoto

Scott Kiffer, P.E.

Shinji Kiuchi

Kevin Lynn

Yuichi Tanaka

Kurt Walter

Edmond Wiegert, P.E.

Acronyms

AAC	:Alternate Alternating Current
AC	:Alternating Current
ACRS	:Advisory Committee on Reactor Safeguards
ANS	:American Nuclear Society
APWR	:Advanced Pressurized Water Reactor
ASEP	:Accident Sequence Evaluation Program
ASME	:American Society of Mechanical Engineers
ATWS	:Anticipated Transient Without Scram
CCDP	:Conditional Core Damage Probability
CCF	:Common Cause Failure
CCW/CCWS	:Component Cooling Water System
CDF	:Core Damage Frequency
COL	:Combined License
CS/CSS	:Containment Spray System
DC	:Direct Current
DCD	:Design Control Document
DCH	:Direct Containment Heating
DDT	:Deflagration to Detonation Transition
DEP	:Operator action to depressurize following SGTR
DVI	:Direct Vessel Injection
ECCS	:Emergency Core Cooling System
EFW/EFWS	:Emergency Feedwater System
EPRI	:Electric Power Research Institute
ESW/ESWS	:Essential Service Water System
FLML	:Failure to maintain water level
FSS	:Fire Protection Water Supply System
FWLB	:Feedwater Line Break
FV	:Fussell-Vesely Importance
GL	:NRC Generic Letter
GTG	:Gas Turbine Generator
HVAC	:Heating Ventilation and Air Conditioning

Acronyms (cont'd)

H/L	:Hot Leg
I&C	:Instrument and Controls
IEEE	:Institute of Electrical and Electronic Engineers
ISLOCA	:Intersystem LOCA
LHSI	:Low Head Safety Injection
LLOCA	:Large Break Loss of Coolant Accident
LOAC	:Loss of Vital AC Bus
LOCA	:Loss of Coolant Accident
LOCCW	:Loss of Component Cooling Water
LOCS	:Loss of CCW/ESW
LODC	:Loss of Vital DC Bus
LOFF	:Loss of Feedwater Flow
LOOP	:Loss of Offsite Power
LORH	:Loss of RHR
LPSD	:Low Power and Shutdown
LRF	:Large Release Frequency
LTOP	:Low Temperature Overpressure
MAAP	:Modular Accident Analysis Program
MCCI	:Molten Core-Concrete Interaction
MCP	:Main Coolant Piping
MCR	:Main Control Room
MGL	:Multiple-Greek-Letter
MHI	:Mitsubishi Heavy Industries, Ltd.
MLOCA	:Medium Pipe Break LOCA
MNES	:Mitsubishi Nuclear Energy Systems, Inc.
MSIV	:Main Steam Isolation Valve
NRC	:Nuclear Regulatory Commission
NUREG/CR	:Nuclear Regulatory Commission Documents prepared by Contractors
OI	:Open Item
OVDR	:Over Drain Down
PLOCW	:Partial Loss of Component Cooling Water

Acronyms (cont'd)

POS	:Plant Operational State
PRA	:Probabilistic Risk Assessment
RAI	:Request for Additional Information
RCP	:Reactor Coolant Pump
RCS	:Reactor Coolant System
RG	:Regulatory Guide
RHR/RHRS	:Residual Heat Removal System
RSC	:Remote Shutdown Console
RWSP	:Refueling Water Storage Pit
RVR	:Reactor Vessel Rupture
R/B	:Reactor Building
SBO	:Station Black Out
SER	:Safety Evaluation
SFP	:Spent Fuel Pit
SG	:Steam Generator
SGTR	:Steam Generator Tube Rupture
SI	:Safety Injection
SLB	:Steam Line Break
SLBI	:Steam Line Break Upstream of MSIV
SLBO	:Steam Line Break Downstream of MSIV
SLOCA	:Small Break Loss of Coolant Accident
SMA	:Seismic Margin Analysis
SPAR-H	:Standardized Plant Analysis Risk – Human Reliability Analysis
SSC	:Structure, System or Component
THERP	:Technique for Human Error Rate Prediction
TISGTR	:Temperature Induced SGTR
TS LCO	:Technical Specification Limiting Condition for Operation
T/B	:Turbine Building
T-D EFW	:Turbine Driven Emergency Feedwater
T-H	:Thermal-Hydraulic
TRANS	:Transient
VSLOCA	:Very Small LOCA

Contents of DCD Chapter 19

Section No.	Description
19.0	Probabilistic Risk Assessment and Severe Accident Evaluation
19.1	Probabilistic Risk Assessment
19.2	Severe Accident Evaluation
19.3	Open, Confirmatory, and COL Action Items Identified as Unresolved

Relationship between DCD and Topical/Technical Reports

DCD Section	Topical / Technical Reports
19.1 PRA	MUAP-07030
19.2 Severe Accident Evaluation	MUAP-07030, MUAP-08004, MUAP-10004
19.3 Open, Confirmatory, and COL Items	None

Topical Reports	None	--	--
Technical Reports	MUAP-07030 (R3)	US-APWR Probabilistic Risk Assessment	June 2011
	MUAP-08004 (R1)	US-APWR Probabilistic Risk Assessment (Level 3)	Sep. 2008
	MUAP-10004 (R0)	Additional Sensitivity Analyses for the DDT potential and the Mixing in the Containment	Mar. 2010

19.1 PRA

Introduction

- ➢ The US-APWR evolutionary design improvements will be presented and demonstrate that probabilistic safety goals are met

- ➢ Specifics of the US-APWR PRA:
  - ✓ PRA model was developed considering RG 1.200 and ASME/ANS PRA Standard RA-S-2008, RA-Sa-2009
  - ✓ Bounding assumptions were used when detailed information was not available
  - ✓ Important assumptions and risk insights are summarized in Table 19.1-119. There are COL Action items to ensure that the assumptions and risk insights are valid during as-built and construction phases.

PRA Technical Adequacy

- Documentation developed and revisions are procedurally controlled including independent review and control of documentation
- Corrective action program is in place for changes in information and errors
- Model was peer reviewed in July – September 2007
  - ✓ Internal events, flood and fire at power
  - ✓ Low Power and Shutdown
  - ✓ Level 2, LRF for internal events at power
  - ✓ PRA-based Seismic Margin Analysis
- MHI has a qualification program for PRA analysts

PRA Scope

Initiator	POS	Level 1	Level 2
Internal Event	Full Power	PRA	PRA
	LPSD	PRA	▲
Internal Flooding	Full Power	PRA	PRA
	LPSD	PRA	▲
Internal Fire	Full Power	PRA	PRA
	LPSD	PRA	▲
Seismic	Full Power	PRA-based SMA	
	LPSD		
Other External Events	Full Power	Screening approach based on ASME/ANS PRA standard criteria (Scope of COL phase)	
	LPSD		

▲ Conservative or bounding estimate of frequency

PRA Uses in Design Process

- Identify and eliminate weaknesses and vulnerabilities
- Proposed design changes to reduce plant risk
  - ✓ Alternate charging pump cooling to prevent RCP seal LOCA
  - ✓ Locked closed state for emergency letdown isolation valve (for internal fire PRA)
  - ✓ Prevention of LOOP event caused by turbine building fire (for internal fire PRA)
  - ✓ Physical barriers in ECCS pump and CCW pump room (for internal flooding PRA)
- Provide input to Reliability Assurance Program

US-APWR Special Design Features
(to reduce CDF)

- Four train safety related high head injection system with Direct Vessel Injection (DVI)
- Four train safety related electrical system with four Gas Turbine Generators (GTG) for AC power
- Elimination of the need for Low Head Safety Injection (LHSI) by use of an advanced accumulator injection system
- Elimination of recirculation switch-over by use of an in-containment Refueling Water Storage Pit (RWSP)

US-APWR Special Design Features
(to reduce CDF)

- Two alternate AC (AAC) GTGs within Seismic Category I structure
- Upgraded piping design pressure for Residual Heat Removal System (RHRS) reducing potential for Intersystem LOCA (ISLOCA)
- Four trains of Emergency Feedwater (2 motor driven, 2 steam driven)
- Alternate charging pump cooling using non-essential chilled water system or fire protection water supply system to maintain RCP seal cooling

US-APWR Special Design Features

(to reduce LRF)

- Battery powered hydrogen ignition system
- Reliable reactor cavity flooding features (ECCS, CSS, FSS)
- Reactor cavity geometry to ensure ex-vessel cooling of the core debris
- Diverse RCS depressurization valves
- Reactor cavity geometry to limit direct containment heating (DCH) following a high pressure melt ejection
- Alternate containment cooling
- Fire water injection to reactor cavity and spray header

PRA Data Sources

U.S. data sources are applied to US-APWR PRA.

- Initiating event frequency (Major data sources)
  - NUREG/CR-6928
  - NUREG/CR-5750
  - NUREG/CR-6890 (for LOOP event)
- Failure probability and rate (Major data sources)
  - NUREG/CR-6928
  - Institute of Electrical and Electronic Engineers (IEEE) Std. 500
- CCF data
  - NUREG/CR-5497

PRA Methods and Codes

- CCF Model
  - MGL Model: NUREG/CR-5485
- Human Reliability Analysis
  - ASEP: NUREG/CR-4772 (Pre- and post-initiating event)
  - THERP: NUREG/CR-1278 (Initiating event related)
  - SPAR-H: NUREG/CR-6883 (Human error dependency)
- Thermal Hydraulic Analysis Code
  - MAAP 4.0.6 for accident sequence and success criteria
  - WCOBRA/TRAC(M1.0) for verification of large break LOCA
- PRA Quantification
  - RiskSpectrum® PSA professional
  - Truncation value of 1E-15

Summary of PRA Results

Initiator Group	CDF [1/year]	LRF [1/year]
Internal Events	1.0E-6	1.1E-7
Internal Fire	8.6E-7	1.9E-7
Internal Flood	8.9E-7	1.6E-7
Low Power and Shutdown	3.0E-7	3.0E-7
Total	3.1E-6	7.6E-7

LPSD is sum of the CDFs of internal and external (internal fire and flood)
The LRF of LPSD is conservatively assumed to be the same as the CDF.

At-Power Initiating Event Contribution

Initiator Contribution to At-Power CDF



At-Power CDF – 2.8E-6 / yr

Internal Events PRA Summary

At-Power Internal Events

- **Key internal event assumptions**
  - ✓ 480 gpm RCP Seal LOCA per pump assumed 1 hour after seal cooling and seal injection are lost
  - ✓ Common Cause between the Emergency AC power system and the Alternate AC power is assumed minimal

- **Internal event risk insights**
  - ✓ Support systems for LOOP are important
  - ✓ Component Cooling Water is important (due to seal LOCA impacts)
  - ✓ CCF is important due to high redundancy (4 train)

At-Power Internal Events CDF Results



At-Power Internal Events CDF – 1.0E-6 / yr

At-Power Internal Events LRF Results



At-Power Internal Events LRF – 1.1E-7 / yr

At-Power Internal Events LRF Release Category Results



At-Power Internal Event Uncertainty Results

Parameter	CDF [/year]	LRF [/year]
95th Percentile	2.9E-06	3.5E-07
Mean	1.0E-06	1.1E-07
Median	7.8E-07	8.2E-08
5th Percentile	3.1E-07	2.6E-08

Key Sources of Uncertainty

◆RAI Topic / NRC Concern

Identify "Key sources of uncertainty" from all PRA areas to ensure that the uncertainties are addressed in the future PRA applications

◆ MHI Response

- ✓ Identified the key sources of uncertainty and provided in DCD Table 19.1-38 (CDF) and 19.1-53 (LRF)
- ✓ Performed sensitivity analyses to study their impact on the PRA and summarized the results in DCD Table 19.1-140
- ✓ Added COL Action item to evaluate and address the key sources of uncertainty and key assumptions in DCD Table 19.1-38

Key Insights and Assumptions

◆RAI Topic / NRC Concern

Identify “Key insights and assumptions” regarding design operational features and document in the DCD with proper dispositions

◆ MHI Response

- ✓ Identified the key insights and assumptions (e.g. design feature, operator actions) and their disposition, and documented in DCD Table 19.1-119
- ✓ Added COL Action item to ensure the key insights and assumptions are valid in as-built design and construction phase

Internal Fire PRA Summary

At-Power Internal Fire

- **Internal fire PRA methodology**
  - ✓ Fire PRA methodology and fire data are based on NUREG/CR-6850
- **Key internal fire design features**
  - ✓ Each of the four safety trains is segregated by a fire barrier in the reactor building (R/B)
  - ✓ Turbine building electrical rooms are separated into two groups by qualified fire barriers

At-Power Internal Fire (cont'd)

- **Key internal fire PRA assumptions**
  - ✓ No credit is taken for fire detection and suppression activities

- **Internal fire risk insights**
  - ✓ Yard fire and turbine building fire are largest contributors to fire risk due to enhanced fire protection design features in the R/B
  - ✓ Yard fire causes loss of offsite power and it results in core damage in the case of failures of four Class 1E GTGs and two AACs
  - ✓ Turbine building fire causes a general transient

At-Power Internal Fire CDF Results



At-Power Fire CDF – 8.6E-7 / yr

At-Power Internal Fire LRF Results



At-Power Fire LRF – 1.9E-7 / yr

At-Power Internal Fire LRF Release Category Results



At-Power Internal Fire Uncertainty Results

Parameter	CDF [/year]	LRF [/year]
95th Percentile	2.7E-06	5.1E-07
Mean	8.6E-07	1.9E-07
Median	6.3E-07	1.5E-07
5th Percentile	2.1E-07	5.2E-08

Key Fire Insights and Assumptions

◆RAI Topic / NRC Concern

✓ Identify and document "Key insights and assumptions" regarding internal fire in the DCD

◆ MHI Response

✓ Identified and summarized the internal fire key design features, insights and assumptions in DCD Table 19.1-119

➢ **Main Control Room (MCR) fire**

✓ Transfer to Remote Shutdown Console (RSC) from MCR to achieve safe shutdown

Internal Flooding PRA Summary

At-Power Internal Flooding

- **Internal flooding PRA methodology**
  - ✓ Flooding analysis followed ASME/ANS PRA standard and NUREG/CR-2300 guidance
  - ✓ Pipe rupture frequencies based on EPRI-TR-1013141 guidance
    - Flood sources: “Spray”, “Flood”, “Major Flood”

- **Key Internal flooding design features**
  - ✓ All floors of reactor building (R/B) are divided into two separate flood divisions (East side and West side) by concrete walls and/or water tight doors
  - ✓ Water tight doors for safety-related SSC areas, main control room, and Reactor Building exits
  - ✓ Transfer to Remote Shutdown Console (RSC) from MCR to achieve safe shutdown

At-Power Internal Flooding CDF Results



At-Power Flooding CDF – 8.9E-7 / yr

At-Power Internal Flooding LRF Results



At-Power Flood LRF – 1.6E-7 / yr

At-Power Internal Flooding LRF Release Category Results



At-Power Internal Flooding Uncertainty Results

Parameter	CDF [/year]	LRF [/year]
95^{th} Percentile	2.4E-06	3.8E-07
Mean	8.4E-07	1.5E-07
Median	5.0E-07	9.7E-08
5^{th} Percentile	1.4E-07	3.3E-08

Flooding Insights and Assumptions

- **Key internal flooding assumptions**
  - ✓ The isolation of flood sources by operators outside MCR is not credited
  - ✓ Flood water from ESW in CCW heat exchanger room is isolated within 15 minutes (ESW pump trip)

- **Internal flooding risk insights**
  - ✓ Floods in either area (east or west) of the R/B contribute to internal flood risk but impact is limited because of no flood propagation to the other area
  - ✓ Floods from EFW system on the second floor of either side of R/B contribute to internal flood risk but impact is limited because of no flood propagation to the other area

Flooding Insights and Assumptions (cont'd)

- **Key internal flooding insights and assumptions**
  - RAI Topic / NRC Concern
    - ✓ Identify and document "Key insights and assumptions" regarding internal flooding in the DCD
  - MHI Response
    - ✓ Identified and summarized the internal flooding key design features, insights and assumptions in DCD Table 19.1-119
- **Pipe rupture frequencies of EPRI-1013141 used for US-APWR internal flooding PRA are updated in EPRI-1021086 in October 2010**
  - ✓ A sensitivity study indicated that the updated flood data will reduce internal flooding risk

Low Power / Shutdown PRA Summary

Low Power Shutdown

➢ LPSD PRA Approach

- ✓ Scope of the LPSD PRA added RHR operation to the at-power internal events PRA model to develop model for Modes 4, 5, and 6.

- ✓ Plant condition during shutdown operation is categorized into 13 POSs, and each of the POSs of mid-loop operation (POS 4 and 8) is categorized into 3 sub-POSs

- ✓ Detailed accident sequence quantification performed for POS 4-3 and POS 8-1. For other POSs, the risk is evaluated by initiating event frequency and the conditional core damage probability (CCDP) of either POS 4-3 or 8-1.

Low Power Shutdown (cont'd)

- **Design Features to Reduce Shutdown Risk**
  - ✓ No penetrations are located below the top of the reactor core to minimize potential for a loss of coolant (by drain-down) from the reactor vessel
  - ✓ There is an interlock for automatic isolation of the low-pressure letdown line when the RCS inventory is reduced
  - ✓ Elevation of SG nozzle dams is designed to be higher than the top of main coolant piping. Due to the design, the water level during nozzle dam installation is higher than that of conventional US plants.

Low Power Shutdown (cont'd)

- **Conformance with Recommendations of GL 88-17**
  - ✓ Plant personnel calculate plant-specific time to reach 200F in the RCS and time to close the containment hatch in order to determine if the hatch is "capable of being closed" prior to reaching harsh environment in containment in the loss of RHR event. If the time to hatch closure is shorter than that to reach harsh environment, then containment is allowed to be opened
  - ✓ Provide the means to add inventory in the RCS by SI pump, charging pump and gravity injection from SFP when the decay heat removal using RHR system is unavailable

LPSD Initiating Event Contribution

Initiator Contribution to LPSD CDF (IE, Fire & Flood)



Low Power Shutdown (LPSD) CDF – 3.0E-7 / yr

Low Pressure Letdown Line Vortexing

➢ **CS/RHR Pump Operation in Reduced Inventory Condition**

◆RAI Topic / NRC Concern

✓ Provide (1) the H/L level/set point at which automatic isolation of low-pressure letdown line actuates and (2) the highest H/L level at which CS/RHR pump is damaged by air ingestion.

◆MHI Response

✓ Set point for the isolation is set above the MCP.

✓ PRA assumption

- RHR operation can be maintained while the RCS level is above the set point.
- When the level is below the set point, CS/RHR pump is damaged by air ingestion.

PRA Conclusions

- US-APWR advanced design features reduce the plant risk and meet the Commission's safety goals against internal and external hazards

  - ✓ Four trains of safety related systems
  - ✓ In-containment refueling water storage pit
  - ✓ Full digital instrumentation and controls
  - ✓ Advanced accumulators
  - ✓ Each safety train is physically separated with fire protection features
  - ✓ Reactor building and power source building are separated by two divisions (east and west sides) with flood protection features

SER Open Items for PRA

Item	RAI No.	RAI Topic / NRC Concern	RAI Response / DCD Impact
1 (OI 19.1-LEVEL1-574)	750-5675 Q19-507, 750-5675 Q19-509, 834-6035 Q19-559, 898-6275 Q19-564, 967-6790 Q19-574	The list of COL action items in the DCD appears to be incomplete.	MHI committed to revise COL Action items 19.3(1) and 19.3(6) and added new COL Action item 19.3(10).
2 (OI 19.1-LEVEL1-512)	750-5675 Q19-512	The "key insights and assumptions" should include items for design and operational features in the DCD.	MHI will document the key insights and assumptions in DCD Table 19.1-119.
3 (OI 19.1-LEVEL1-513)	40-610 Q19-97&98, 423-2710 Q19-364, 750-5675 Q19-513	A systematic review to demonstrate the robustness of the assumed PRA success criteria should be performed.	MHI will perform T-H analyses to provide the basis for success criteria and summarize the results in DCD Subsection 19.1.4.1.
4 (OI 19.1-LEVEL1-514)	750-5675 Q19-514	The failure probability of the operator action to equalize primary and secondary pressures (event DEP) must be estimated and documented.	MHI will provide the T-H analysis results to demonstrate that the operator action has redundancy and sufficient allowable time and will document the results in DCD Table 19.1-119.
5 (OI 19.1-LEVEL1-515)	750-5675 Q19-515	The precise definition of I&C hardware and software CCFs modeled in the PRA should be provided.	MHI will provide additional information regarding how to model digital I&C in the PRA.

SER Open Items for PRA (cont'd)

Item	RAI No.	RAI Topic / NRC Concern	RAI Response / DCD Impact
6 (OI 19.1-LEVEL1-516)	750-5675 Q19-516	Provide the basis of the assumption made in the PRA that the time the T-D EFW pumps are capable of operating without HVAC.	MHI will provide the room temperature analysis results to show that the components can operate within mission time, regardless of room cooling.
7 (OI 19.1-LEVEL1-575)	967-6790 Q19-575	Statements in the DCD should be clarified.	MHI committed to clarify the statements in DCD Section 19.1.2.3.
8 (OI 19.1-FIRE-573)	967-6790 Q19-573	The transfer of the control of the plant from MCR to RSC should be included in DCD Table 19.1-119.	MHI committed to include the key assumption in DCD Table 19.1-119.
9 (OI 19.1-LEVEL2-560)	871-6121 Q19-560	Concerns regarding the Level 2 PRA modeling of the hydrogen control top event need to be addressed.	MHI will revise the Level 2 PRA addressing the NRC's concern. The LRF safety goal is still satisfied with this modification.
10 (OI 19.1-LPSD-546)	783-5855 Q19-546, 924-6352 Q19-570, 983-6953 Q19-579	The impact on LPSD risk should a COL applicant decide to drain the RCS in POS 4-1 with the RCS open should be determined.	MHI committed to provide the sensitivity analysis assuming no SG cooling is available during drain down (POS 4-1) and document it in DCD Subsection 19.1.6.2.

SER Open Items for PRA (cont'd)

Item	RAI No.	RAI Topic / NRC Concern	RAI Response / DCD Impact
11 (OI 19.1-LPSD-565)	899-6281 Q19-565	The omission of LOCAs during POSs 5, 6, and 7 from the LPSD PRA should be addressed.	MHI committed to document the reasons why risk during the POSs is considered insignificant in DCD Subsection 19.1.6.1.
12 (OI 19.1-LPSD-506)	749-5651 Q19-506, 983-6953 Q19-578	The failure of the SG nozzle dams due to a postulated RCS re-pressurization and RCS venting during nozzle dam installation should be addressed.	MHI committed to document the need for operational procedure during mid-loop in DCD Chapter 5 and Table 19.1-119.
13 (OI 19.1-LPSD-495)	681-5257 Q19-495	The auto-isolation function of RCS letdown on low hot-leg level and prevention of vortexes in the hot-leg should be justified.	This open item is now being discussed as part of related Chapter 5 RAIs.
14 (OI 19.1-LPSD-568)	899-6281 Q19-568	Concerns with instrumentation for auto and manual isolation of letdown which impacts over-drain (OVDR) and failure to maintain level (FLML) frequency should be addressed.	MHI committed to provide the interlock information and the related design description in the DCD.
15 (OI 19.1-LPSD-494)	669-5219 Q19-494	The need for Technical Specifications rather than voluntary initiatives should be addressed.	MHI will evaluate TS LCO modifications to address the concern.

SER Open Items for PRA (cont'd)

Item	RAI No.	RAI Topic / NRC Concern	RAI Response / DCD Impact
16 (OI 19.1-LPSD-567)	899-6281 Q19-567	The lack of automation for standby RCS injection should be addressed.	MHI provided justification for not having automated standby RCS injection.
17 (OI 19.1-LPSD-570)	924-6352 Q19-570	Key sources of uncertainty and key assumptions should be documented.	MHI committed to document key sources of uncertainty and key assumptions in the DCD, with qualitative and quantitative assessment results.
18 (OI 19.1-LPSD-566)	899-6281 Q19-566	The information requested on containment closure and consistency with GL 88-17 should be provided.	COL applicant will be required to evaluate and demonstrate the capability to close containment prior to RCS boiling after a loss of RHR, which was documented in DCD Table 19.1-119.
19 (OI 19.1-LPSD-66)	39-548 Q19-66, 983-6953 Q19-577	Risk insights regarding the design description of the reactor vessel (there is no penetration path at the bottom of the vessel) should be added to the LPSD PRA.	MHI committed to update Table 19.1-119 of the DCD.

19.2 Severe Accident Evaluation

Severe Accident Evaluation (Prevention)

- **ATWS**
  - ✓ Four train safety grade reactor protection system
  - ✓ Diverse actuation system
- **Mid-Loop operations**
  - ✓ Four train RHR design
  - ✓ Drain down path interlocked with water level
- **SBO**
  - ✓ Four train Class 1E power sources, and
  - ✓ Two alternate AC sources
- **Fire**
  - ✓ Four trains of safety systems are physically separated
- **ISLOCA**
  - ✓ RHR designed not to fail by over-pressure

Severe Accident Phenomena and LRF

- **Evaluation of Severe Accident Phenomena Effect on the LRF**
  - ✓ Temperature Induced SGTR (TISGTR)
    - Evaluated based on the latest understanding about the occurrence of TISGTR
    - Revised probability of TISGTR for LRF
  - ✓ Ex-Vessel Steam Explosion
    - Considered large range of uncertainties for evaluation of Ex-Vessel Steam Explosion
    - Assessed the sensitivity of Ex-Vessel Steam Explosion for LRF
  - ✓ Hydrogen burning
    - Evaluated the hydrogen burning in the RWSP in SBO with loss of AAC which may cause the increase in LRF
    - Adopted battery powered hydrogen ignition system

Severe Accident Evaluation (Mitigation)

- **Hydrogen Generation and Control**
  - ✓ Battery powered hydrogen igniters
  - ✓ Large volume containment

- **Core Debris Coolability (MCCI)**
  - ✓ Diverse reactor cavity flooding systems
  - ✓ Reactor cavity geometry and floor area

- **High Pressure Melt Ejection**
  - ✓ Safety depressurization valves
  - ✓ Severe accident dedicated depressurization valves
  - ✓ Reactor cavity debris trap (DCH)

Severe Accident Evaluation (Mitigation)

➢ Steam Explosion

- ✓ In-vessel steam explosion (negligible – NUREG-1524)
- ✓ Ex-vessel steam explosion (containment structural capacity sufficient to withstand)

➢ Temperature-Induced SGTR

- ✓ Safety depressurization valves

➢ Long Term Containment Overpressure

- ✓ Diverse injection sources to spray header
- ✓ Alternate containment cooling

Potential Design Improvements

- No additional design alternatives were shown to be cost beneficial in severe accident mitigation design

SER Open Items for Severe Accident Evaluation

Item	RAI No.	RAI Topic / NRC Concern	RAI Response / DCD Impact
1 (OI 19.2-SER-569)	924-6352 Q19-569 983-6953 Q19-580	The severe accident design features and their survivability for a severe accident during shutdown conditions need to be clarified.	MHI will provide reasonable assurance for the severe accident design features during shutdown conditions, including the survivability evaluation.