

# **Industry Comments on Draft Regulatory Basis for Proposed Onsite Emergency Response Capabilities Rule Change**

**NEI**


NRC Public Meeting – March 28, 2013

# **Presentation Topics**

- Overview
- Discussion of generic level SAMGs by BWR and PWR owners group representatives
- Industry proposal for integrated approach
- Discussion of NEI comment letter on draft regulatory basis for Recommendation 8

# Overview – Current State

Recommendation 4      Recommendation 8      Recommendation 9  
Loss of AC Power      Response Procedures      Emergency Plan




Rule/Guidance      Rule/Guidance      Rule/Guidance

*Potential for overlap, and inadvertent introduction of unnecessary redundancy, inconsistency and unintended consequences*

# Generic Level SAMGs

- Discussion of generic level SAMGs by BWR and PWR owners group representatives

# Overview – Integrated Approach



## Background - NEI Comment Letter Summary

- Summary of comments from NEI Letter,  
*Docket ID NRC-2012-031; 10 CFR Part 50 and  
52, Onsite Emergency Response Capabilities;  
Draft Regulatory Basis (78 Fed. Reg. 1154),*  
Pietrangelo to Vietti-Cook, dated March 19,  
2013

# Scope of NRC's Preferred Option 1

- “High-level” rule language with accompanying guidance is appropriate
- Change would be subject to backfit rule
  - In our view, aspects of the proposed scope of Option 1 will add significant regulatory burden without providing measurable safety benefit
    - Will review these aspects in presentation
- NEI comment letter Attachment 1 provides updated cost information; however, these are preliminary estimates and will need to be refined once a more detailed proposed rule is developed

# Integration of Procedures and Guidelines

- US plants have a comprehensive set of mitigation strategies for accident responses
  - AOPs
  - EOPs (including alternate/contingency actions and functional restoration procedures)
  - FLEX Support Guidelines (under development)
  - SAMGs (core damage events)
  - EDMGs (threat-based events)

# Integration of Procedures and Guidelines

- Rule should address “beyond-design-basis event response,” not just “severe accident mitigation”
  - A severe accident is a subset of a BDSEE<sup>1</sup> accident (i.e., one that involves core damage)
- Need to recognize distinction between “procedures” and “guidelines”
  - Responses to a BDSEE cannot be mechanistically prescribed in detailed procedures
  - Maintain flexibility to deal with uncertainties in accident progression

# Command and Control

- Licensees have emergency response command and control structures in place
  - Reflects existing EP planning standards, requirements and related guidance (plus years of OE)
  - Includes implementing capabilities for SAMGs per applicable Owners Group guidance
  - Potential changes should consider existing capabilities
- Command and control structures should remain consistent so as not to complicate response efforts or confuse responders

# Command and Control

- Licensees have a command and control structure for implementation of EDMGs
  - Developed in accordance with NEI 06-12
  - Interfaces with the site ERO are considered
- A command and control structure for implementation of FLEX strategies being developed per requirements of NRC Order EA-12-049 and related guidance documents

# Training and Qualification Requirements

- Changes to SAMG training requirements should be based on a gap analysis of existing training programs
  - For both Control Room and TSC personnel
- Maintain balance of operator training program content
  - A core damaging event is highly unlikely
  - Do not dilute training focus from more likely plant transients and accidents (within scope of AOPs and EOPs)
  - Training provides operators with fundamental knowledge
  - Specific SAMG and EDMG job tasks are identified and trained using the SAT process

# Training and Qualification Requirements

- Recognize significant response capabilities being added to address Mitigating Strategies Order (FLEX)
  - Core damage event will be even more unlikely
  - Training on FLEX strategies addressed in NEI 12-06
- Use of plant simulators to model BDBEE/SAMG scenarios is not warranted
  - Not required by 10 CFR 55.46 or ANSI-3.5-2009
  - Estimates range from \$1M to \$1.5M per simulator
  - Use of other simulation tools and drill venues

# Drills and Exercises

- Industry supporting staff's proposed approach to address the related Tier 2 EP enhancement (from Rec 9.3) through integration with actions for NRC Order EA-12-049
  - A rule for BD-BEE drills and exercises should reflect this approach, and the OE/lessons learned (similar to experience with HAB Exercises)
  - Premature to begin work on drill/exercise-related rule language, relative to Recommendation 8, at this time

# Drills and Exercises

- Rulemaking for a new BDDBEE drill or exercise requirement should consider existing wording in 10 CFR 50, Appendix E, IV.F.2.j concerning 10 CFR 50.54(hh)(2)
  - Would be redundant and should be deleted
- New BDDBEE drill and exercise requirements should not be located in 10 CFR 50, Appendix E
- Provided updated cost information for staff analyses (Attachment 1)

# EDMGs

- EDMGs address large-area explosions and fires, caused by certain beyond-design-basis attack threats, resulting in a loss of the Control Room and remote safe shutdown locations
  - See NEI 06-12 and related ISG
- Implementation of EDMGs would not be required in response to a BDBEE/ELAP unless caused by this type of event
  - Could be implemented on an ad hoc basis

# EDMGs

- Equipment for implementing BDBEE response strategies (e.g., a portable pump) may be referenced in one or more of the governing guideline sets - FLEX Support Guidelines, SAMGs or EDMGs
- Response to a BDBEE like Fukushima would be performed in accordance with EOPs, FLEX Support Guidelines and SAMGs
  - The focus of EDMGs should remain on the governing of a responses to a threat-related event

# Guidance Development

- Drill/exercise guidance should consider:
  - Enhanced safety capabilities and margins of advanced and passive reactor designs (e.g., EPR, AP1000, etc.)
  - Maintaining realistic/credible scenarios for use in drills and exercises consistent with the expected use of mitigation strategies and equipment
  - Potential dilution of organizational focus on practicing responses to more likely events such as those within the plant design and EOP bases

# Guidance Development

- Drill/exercise guidance should consider:
  - Recognition of additional demands on licensee (e.g., Work Hour/Fatigue Rule limitations), NRC staff and Offsite Response Organizations resources
  - Using different venues, such as tabletop drills and out-of-sequence field demonstrations, to practice and evaluate some aspects of responses to beyond design-basis external events
  - Allowances for using non-simulator sources of data in beyond design-basis event response drills

# Conclusion

- In summary, industry supports the rulemaking, but requests consideration of a temporary deferral to allow additional time to integrate this regulatory activity with other ongoing efforts, and to concentrate our resources on timely implementation of higher-priority safety improvements at the plants