

Testing of automatic control functions actuated by activity monitors, i.e., radiation or radioactivity monitors, can be performed at any value within the range of the activity monitors using an established trip setpoint.