

ArevaEPRDCPEm Resource

From: Miernicki, Michael
Sent: Wednesday, April 17, 2013 8:27 AM
To: WILLIFORD Dennis (AREVA)
Cc: Snyder, Amy; 'RYAN Tom (AREVA)'
Subject: FW: Advanced Response to RAI 547, Question 03.07.02-78

Importance: High

See additional comments on subject advanced response below.

Mike

Michael J. Miernicki
Sr. Project Manager
NRC/NRO/DNRL/LB1
301-415-2304

From: Xu, Jim
Sent: Tuesday, April 16, 2013 9:00 PM
To: Miernicki, Michael
Cc: Xu, Jim
Subject: FW: Advanced Response to RAI 547, Question 03.07.02-78
Importance: High

Additional inconsistencies identified in David's email below. Please forward it to AREVA.

Thanks,
Jim

From: David Foster [<mailto:dfoster@numarkassoc.com>]
Sent: Tuesday, April 16, 2013 6:13 PM
To: Xu, Jim
Cc: carl costantino; Thomas Houston
Subject: Advanced Response to RAI 547, Question 03.07.02-78
Importance: High

While answering some questions for Manuel, I went back and looked at the response to RAI 371, Question 03.072.02-66. In that response, AREVA provided a table of maximum tendon gallery wall pressures (Tables 3.7.2-66-1 and 3.7.2-66-2). The values reported are not the same as those reported in the response to RAI 547, Question 3.7.2-78, Tables 3.7.2-78-9 and 3.7.2-78-10. There is no explanation as to why these values changed. AREVA should include this explanation in its final response to RAI 547, Question 3.7.2-78.

David C. Foster
-480-488-2551
-80-292-3904

Hearing Identifier: AREVA_EPR_DC_RAIs
Email Number: 4330

Mail Envelope Properties (9C2386A0C0BC584684916F7A0482B6CADCC3E9F801)

Subject: FW: Advanced Response to RAI 547, Question 03.07.02-78
Sent Date: 4/17/2013 8:27:29 AM
Received Date: 4/17/2013 8:27:32 AM
From: Miernicki, Michael

Created By: Michael.Miernicki@nrc.gov

Recipients:

"Snyder, Amy" <Amy.Snyder@nrc.gov>
Tracking Status: None
"RYAN Tom (AREVA)" <Tom.Ryan@areva.com>
Tracking Status: None
"WILLIFORD Dennis (AREVA)" <Dennis.Williford@areva.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	1273	4/17/2013 8:27:32 AM

Options

Priority: High
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: