

DISCUSSION

The current treatment of postulated fires in the MCB is described in NUREG/CR-6850, Appendix L. Although the guidance in this Appendix is applicable only to the MCB, it provides key insights as to the treatment of fire detection and suppression. A key insight from this guidance is that the conditional probability that a fire at any location within the MCB results in damage beyond the ignition source is less than approximately $8E-3$. This value is taken from Figure L-1 using $d = 0$ m. As described in Appendix L, this value would be multiplied by the MCB fire frequency to obtain the frequency of the specific event. The discussion in Appendix L and the development of the analysis used to generate the results shown in Figure L-1 shows that credit for manual suppression using the λ term of 0.33 from Appendix P is included.

In Section P.1.3, the following two items are noted:

If in-cabinet smoke detection devices are installed in the electrical cabinet postulated as the ignition source, the analyst should assume that the fire will be detected in its incipient stage. This incipient stage is assumed to have a duration of 5 minutes.

~~Prompt detection should be only credited when ... a high-sensitivity smoke detection system is installed....~~

The following treatments can therefore be considered to be within the existing methodology of NUREG/CR-6850.

- If an in-cabinet smoke detector is available in the MCB, then the Appendix L treatment can be modified to provide an additional 5 minutes for fire suppression.
- If an in-cabinet smoke detector is available in an electrical cabinet (panel), then successful suppression at 5 minutes would prevent the occurrence of a fire, be equivalent to no damage beyond the individual incipient source within the cabinet (panel), and would not require any additional procedural guidance or features such as those described in FAQ 08-0046 for the δ parameter, "Technician Successful in Preventing Fire in Incipient Stage."-

The treatment framework already described in NUREG/CR-6850 will be used to establish an 'anchor' point as part of the process of developing recommendations for the crediting of an ASD installed as a VEWFD as defined by NFPA 76 for applications beyond those addressed by FAQ 08-0046.

In-Cabinet Smoke Detectors – The credit available for the presence of in-cabinet smoke detectors is described in NUREG/CR-6850. Three cases are considered:

1. MCB panel in the MCR
2. Non-MCB panel in the Main Control Room
3. Electrical cabinet in a non-continuously occupied location
 1. MCB Panel in the MCR – The current guidance in NUREG/CR-6850 recommends that a FPRA treat the presence of an in-cabinet smoke detector in the MCB by considering the availability of an alarm before it would have otherwise been detected by the control room operators. The guidance states that this advance warning would occur during an assumed 5 minute incipient period. This credit in the treatment can be directly calculated using the information in Appendix L.

FAQ Title **Clarifications on Treatment of VEFWDS to Support NFPA 805 Risk Analysis**

From Appendix L :

$$[SF \bullet P_{ns}](d) = \frac{1}{H \bullet W} \int_0^H \int_0^W SF(d, w, h) \bullet P_{ns}(d, w, h) dw dh$$

$$P_{ns}(d, w, h) = e^{-\lambda \bullet t}$$

With a traditional non-aspirating (e.g., ionization) smoke detector installed inside the MCB, the suppression term $e^{-\lambda t}$ would become $e^{-\lambda(t+5)}$. The ratio of these two factors can then be applied to the original equation from Appendix L. The net result is that a constant factor is added as shown below.

$$[SF \bullet P_{ns}](d) = \frac{1}{H \bullet W} \int_0^H \int_0^W SF(d, w, h) \bullet P_{ns}(d, w, h) dw dh \bullet \frac{e^{-\lambda \bullet (t+5)}}{e^{-\lambda \bullet t}}$$

$$[SF \bullet P_{ns}](d) = e^{-\lambda \bullet 5} \bullet \frac{1}{H \bullet W} \int_0^H \int_0^W SF(d, w, h) \bullet P_{ns}(d, w, h) dw dh$$

$$\lambda = 0.33, \text{ and therefore, } e^{-\lambda \bullet 5} = 0.19$$

This development shows that if a traditional non-aspirating smoke detector were to be installed in a MCB, application of the existing guidance in NUREG/CR-6850 would result in the factors taken from Appendix L, Figure L-1, being reduced by a factor of 0.19 (plus the random hardware failure probability for the detector).

–The only readily available guidance for the hardware failure probability for a traditional non-aspirating smoke detector is NUREG/CR-6850, Appendix P. This appendix provides a simplified bounding value of 5E-02 which is known to significantly over-estimate the failure probability. This over-estimation is evidenced by considering the failure probability of 4E-02 for a CO₂ recommended in NUREG/CR-6850 for a CO₂ suppression system. Since many CO₂ flooding systems are actuated by cross-zoned smoke detectors, the failure of either zone of detectors would prevent system actuation. If it is assumed that the non-detector portion of the CO₂ system has the same failure probability as the detectors, then:

$$P_a + P_b + P_{CO2} = 4E-02, \text{ where } P_a \text{ and } P_b \text{ represent the two zones of smoke detectors and } P_{CO2} \text{ represents the remainder of the CO}_2 \text{ system}$$

- Formatted: Subscript
- Formatted: Indent: Left: 1"
- Formatted: Subscript
- Formatted: Subscript
- Formatted: Subscript
- Formatted: Subscript

FAQ Title Clarifications on Treatment of VEWFDS to Support NFPA 805 Risk Analysis

Since $P_e = P_d$, and it is assumed that $P_{CO2} = P_e + P_d$, then $P_e = 1E-02$

Therefore, the random failure probability that should be used for a traditional non-aspiring smoke detector is 1E-02. This value is conservative on the basis that a relatively simple traditional non-aspiring smoke detector would reasonably be expected to have a random failure probability lower than the more complex active ASD detector which has a recommended failure probability of 1E-02 as noted in FAQ 08-0046. This value should be added to the 0.19 factor calculated earlier yielding a total value of 0.20.

~~Including hardware failure would result in this value being increased to 0.24 (0.19 + .05).~~

If instead, an ASD installed as a VEWFD were to be used instead, the associated reduction factor should be lower than 0.204. The lower value would be based on the additional time associated with the advance warning that would be appropriate given the presence of an ASD system. Although FAQ 08-0046 assumes that, an hour of warning would be available, that timing is based on the onset of open flaming. It is evident that prior to open flaming, enough smoke would be generated that it would be recognized by the MCR staff. In order to eliminate concerns related to dependencies between the detection mechanisms while still providing for a reasonable credit for the ASD system, a value less than 60 minutes should be used. As an example, the advance warning time could be increased from 5 minutes to 10 minutes (ASD system provides an additional 5 minutes of advance warning). In addition, the screening hardware failure probability of 0.01 from FAQ 08-0046 should also be included.

$$e^{-\lambda(10)} + 0.01 = e^{-0.33(10)} + 0.01 \sim 0.05$$

It is recognized that the result of this treatment is sensitive to the time duration assumed. The results of a sensitivity study as the value of this additional delay varies.

Continuously Occupied Location	
ASD Detection Credit (min.) ¹	Appendix L Adjustment Factor
0	0.20
5	0.05
10	0.02
15	0.01
20	0.01
25	0.01
30	0.01

Note 1: The time duration refers to the additional time warning provided by the ASD system as compared to a traditional non-aspiring smoke detector

- Formatted: Subscript
- Formatted: Subscript
- Formatted: Subscript
- Formatted: Subscript
- Formatted: Indent: Left: 1"
- Formatted: Subscript
- Formatted: Subscript

**FAQ Title Clarifications on Treatment of VEWFDs to Support
NFPA 805 Risk Analysis**

The performance of an ASD system as compared to a non-aspirating smoke detector is undergoing testing by the NRC. Preliminary test results do not provide sufficient evidence to support assigning specific guidance. In order to provide interim guidance and to ensure the treatment is bounding, a value of 0.20 is recommended until such time additional test results are available. As noted above, this value should be applied together with the parameters from Figure L-1 of NUREG/CR-6850 and represents the fraction of fire events the results in damage beyond the individual component within the MCB.

The extent of internal fire damage within the MCB should be treated using the existing guidance in Appendix L of NUREG/CR-6850.

2. Non-MCB Panel in the Main Control Room – The current guidance in NUREG/CR-6850 recommends that a FPRA treat the presence of an in-cabinet smoke detector by considering the availability of an alarm before it would have otherwise been detected by other means. The guidance states that this advance warning would occur during an assumed 5 minute incipient period. As discussed in the previous section, if an ASD installed as VEWFD were to be used instead, no additional advance warning should be credited until such time more complete test results are available.

If the panel is located in the MCR and in the same general proximity to the MCR staff as the MCB, then a non-suppression factor of 0.20 should be used -and represents the fraction of fire events the results in damage beyond the individual component within the electrical cabinet (panel).

The extent of internal fire damage within a panel requires further guidance. If suppression is successful, then the fire would still be in its incipient phase and no damage beyond the individual ignition source within the enclosure should be considered. If the fire is not suppressed, then the postulated fire should be assumed to grow and be treated using the existing guidance in NUREG/CR-6850.

3. Electrical Cabinet in a Non-Continuously Occupied Location – The current guidance in NUREG/CR-6850 recommends that a FPRA treat the presence an in-cabinet smoke detector by considering the availability of an alarm before it would have otherwise been detected by other means. The guidance states that this 'advance' warning would occur during an assumed 5 minute incipient period. If the panel is in a location that is not continuously occupied, then the manual suppression characteristics documented in FAQ 08-0050 (Supplement 1) and the values in Table 14-1 should be used. As noted in the prior discussions, pending further testing results, only five minutes of advance warning should be credited if in-cabinet detection is provided (regardless of whether it is ASD or non-aspirating). The five minutes of available incipient time for electrical fires (cabinets and panels) translates to a probability of 0.60. Adding the screening hardware failure probability of 0.01 from ~~FAQ 08-0046~~ yields a non-suppression probability of 0.61, and represents the fraction of fire events the results in damage beyond the individual component within the electrical cabinet (panel). It is noted that scenario-specific adjustments to this value can be made as appropriate using the guidance in FAQ 08-0050 (Supplement 1).

The extent of internal fire damage within a panel requires further guidance. If suppression is successful, then the fire would still be in its incipient phase and no

Formatted: Font: (Default) Arial

