



Make-up from ESW when needed.

Spent Fuel Pool Make Up from the RWST using installed Fuel Pool Cooling pumps.
Fuel Pool Cooling pumps are powered from the FLEX Generator from 1&4A33-SA and 1A3-SA or 1&4B33-SB and 1B3-SB.
This method does not require access to the Fuel Handling Building operating deck to make up to the pool. This method also allows make up from the ESW system when it becomes available.

NOTES:
FOR ADDITIONAL NOTES AND REFERENCE DRAWINGS SEE DRAWING CAR-2165-G-061.

11	10/17/00	INCORPORATED ESR 08-00425 AND CONSIDERED REVISION CONSTRUCTION HOLD	ARM	WPL	AMA	JDS
10	7/17/00	INCORPORATED ESR-060056 REV. 4 (EXCLUDED BY LINE)	LLS	HPP	EWJ	MP
REV	DATE	DESCRIPTION	DES	CHK	APP	APPL
THIS DRAWING HAS BEEN PRODUCED AND IS CONTROLLED BY THE HNP CAD/CAM SYSTEM. ANY REVISIONS TO THIS DRAWING SHOULD BE MADE USING THE CAD/CAM SYSTEM TO ASSURE PROPER CONTROL OF THE ELECTRONIC DRAWING DATABASE.						
NUCLEAR SAFETY RELATED (O-LIST)? YES <input type="checkbox"/> NO <input type="checkbox"/> PARTIAL <input type="checkbox"/> F.P.-O <input type="checkbox"/> R.W.-O <input type="checkbox"/>						
CAROLINA POWER & LIGHT COMPANY NUCLEAR ENGINEERING DEPARTMENT - RALEIGH, N.C.			CP&L SCALES: NONE			
TITLE: FLOW DIAGRAM FUEL POOLS COOLING SYSTEM UNIT 2			DRAWING NO.: CAR-2165 G-0307			

RECEIVED
HNP DOCUMENT CONTROL