

## ArevaEPRDCPEm Resource

---

**From:** Buckberg, Perry  
**Sent:** Wednesday, April 24, 2013 7:41 AM  
**To:** WILLIFORD Dennis (AREVA)  
**Cc:** LENTZ Tony (EXTERNAL AREVA); Snyder, Amy; GUCWA Len (EXTERNAL AREVA); Miernicki, Michael  
**Subject:** April 4-5 public meeting on ITAAC - Follow up comments

Dennis,

Two more ITAAC comments.

- Tier 1 Section 2.8.1, ITAAC 2.4: The AC column should read:
  - “A report exists and concludes that the as-built turbine rotor meets the requirements of the manufacturer’s turbine missile probability analysis:
    - (1) Turbine material property data, rotor and blade design analyses (including loading combinations, assumptions and warm-up time) demonstrating safety margin to withstand loadings from overspeed events, and
    - (2) The results of pre-service inspection and testing, and the requirements for inservice inspection and testing.”
- Tier 1 Section 2.2.1, ITAAC 3.30:  
Add Class “CS” to Commitment and AC columns to read “ASME Code Class 1, 2, 3 and CS components.....” This is needed to include the CS components that are currently listed in table 2.2.1-1 to verify that they are fabricated, installed, and inspected in accordance with ASME Code Section III requirements.

**Note** - The staff is still working on additional follow-up comments related to ASME Code ITAAC.

**Note** - Specific ITAAC updates may be still required as technical issues are resolved and FSAR Tier II changes continue to be made.

Thanks,

**PERRY BUCKBERG**

**Senior Project Manager**  
Nuclear Regulatory Commission  
Office of New Reactors  
phone: (301)415-1383  
fax: (301)415-6406  
[perry.buckberg@nrc.gov](mailto:perry.buckberg@nrc.gov)

---

**From:** GUCWA Len (EXTERNAL AREVA) [<mailto:Len.Gucwa.ext@areva.com>]  
**Sent:** Friday, April 05, 2013 12:02 PM  
**To:** Snyder, Amy; Buckberg, Perry  
**Cc:** WILLIFORD Dennis (AREVA); LENTZ Tony (EXTERNAL AREVA)  
**Subject:** April 4-5 public meeting on ITAAC

Amy and Perry:

As requested, attached are documents discussed during the subject public meeting with changes incorporated.

Thanks,

Len Gucwa, P.E.  
404-673-2739 cell

**Hearing Identifier:** AREVA\_EPR\_DC\_RAIs  
**Email Number:** 4394

**Mail Envelope Properties** (44CD2E65B0FF0E499CB32BC30CF781F0D5D7ACB54D)

**Subject:** April 4-5 public meeting on ITAAC - Follow up comments  
**Sent Date:** 4/24/2013 7:40:32 AM  
**Received Date:** 4/24/2013 7:40:32 AM  
**From:** Buckberg, Perry

**Created By:** Perry.Buckberg@nrc.gov

**Recipients:**

"LENTZ Tony (EXTERNAL AREVA)" <Tony.Lentz.ext@areva.com>

Tracking Status: None

"Snyder, Amy" <Amy.Snyder@nrc.gov>

Tracking Status: None

"GUCWA Len (EXTERNAL AREVA)" <Len.Gucwa.ext@areva.com>

Tracking Status: None

"Miernicki, Michael" <Michael.Miernicki@nrc.gov>

Tracking Status: None

"WILLIFORD Dennis (AREVA)" <Dennis.Williford@areva.com>

Tracking Status: None

**Post Office:** HQCLSTR01.nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	1946	4/24/2013 7:40:32 AM

**Options**

**Priority:** Standard

**Return Notification:** No

**Reply Requested:** No

**Sensitivity:** Normal

**Expiration Date:**

**Recipients Received:**