Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 2 of 7

Status: Y N U

Equipment ID No.:003-1601-0024-V05	
Equipment Class:(7) Fluid-Operated Valves	
Equipment Description: PRESSURE SUPPRESSION/ Drywell and Torus Vent Valve	
 Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Overhead light fixtures judged to be acceptable. Adjacent masonry walls are safety-related. 	Yes
9. Do attached lines have adequate flexibility to avoid damage?	Yes
10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects?	Yes
Other Adverse Conditions	
11. Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment?	Yes
<u>Comments</u> Seismic Walkdown Team: J. Griffith & M. Wodarcyk - 8/2/2012	
Evaluated by: James Griffith Date: 9/30/20	112
Michael Wodarcyk 9/30/20)12

Seismic Walkdown Checklist (SWC)

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 3 of 7

Status: Y N U


Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-1601-0024-V05

Equipment Class: (7) Fluid-Operated Valves

Equipment Description: PRESSURE SUPPRESSION/ Drywell and Torus Vent Valve

Photos



20120802-Dresden-3 096







20120802-Dresden-3 099

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 4 of 7

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-1601-0024-V05

Equipment Class: (7) Fluid-Operated Valves

Equipment Description: PRESSURE SUPPRESSION/ Drywell and Torus Vent Valve



20120802-Dresden-3 100





20120802-Dresden-3 101



20120802-Dresden-3 103

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 5 of 7

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment	ID	No.:	D03-1601-0024-V05	

Equipment Class: (7) Fluid-Operated Valves

Equipment Description: PRESSURE SUPPRESSION/ Drywell and Torus Vent Valve



20120802-Dresden-3 104




20120802-Dresden-3 106





20120802-Dresden-3 107

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 6 of 7



20120802-Dresden-3 110

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 7 of 7

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-1601-0024-V05

Equipment Class: (7) Fluid-Operated Valves

Equipment Description: PRESSURE SUPPRESSION/ Drywell and Torus Vent Valve



20120802-Dresden-3 112



20120802-Dresden-3 114



20120802-Dresden-3 113



Status: Y N U

No

Seismic Walkdown Checklist (SWC)

Equipment ID No.: ______003-1601-0057-V20

Equipment Class: (8) Motor-Operated and Solenoid-Operated Valves

Equipment Description: PRESSURE SUPPRESSION/ Drywell/Torus Nitr. Makeup Valve

Project: Dresden 3 SWEL

Location (Bldg, Elev, Room/Area): Reactor, 476.50 ft, ALL

Manufacturer/Model:

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

- Is anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)?
- 2. Is the anchorage free of bent, broken, missing or loose hardware? Not Applicable
- 3. Is the anchorage free of corrosion that is more than mild surface oxidation? Not Applicable
- 4. Is the anchorage free of visible cracks in the concrete near the anchors? Not Applicable
- Is the anchorage configuration consistent with plant documentation? (Note: Not Applicable This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
- 6. Based on the above anchorage evaluations, is the anchorage free of Yes potentially adverse seismic conditions?

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 2 of 8

Status: Y N U

Equipment ID No.:003-1601-0057-V20	
Equipment Class: _(8) Motor-Operated and Solenoid-Operated Valves	
Equipment Description: PRESSURE SUPPRESSION/ Drywell/Torus Nitr. Makeup Valve	
Interaction Effects	
7. Are soft targets free from impact by nearby equipment or structures?	Yes
Distance between valve handwheel and adjacent pipe judged to be acceptable.	
8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment?	Yes
9. Do attached lines have adequate flexibility to avoid damage?	Yes
10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects?	Yes
Other Adverse Conditions 11. Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment?	Yes
<u>Comments</u> Seismic Walkdown Team: J. Griffith & M. Wodarcyk - 8/3/2012	
Evaluated by: James Griffith Date: 9/30/2012	

Seismic Walkdown Checklist (SWC)

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 3 of 8

Status: Y N U


Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-1601-0057-V20

Equipment Class: (8) Motor-Operated and Solenoid-Operated Valves

Equipment Description: PRESSURE SUPPRESSION/ Drywell/Torus Nitr. Makeup Valve





20120803-Dresden-3 101

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 4 of 8

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-1601-0057-V20

Equipment Class: (8) Motor-Operated and Solenoid-Operated Valves

Equipment Description: PRESSURE SUPPRESSION/ Drywell/Torus Nitr. Makeup Valve



20120803-Dresden-3 103



20120803-Dresden-3 105



20120803-Dresden-3 104



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 5 of 8


Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-1601-0057-V20

Equipment Class: (8) Motor-Operated and Solenoid-Operated Valves

Equipment Description: PRESSURE SUPPRESSION/ Drywell/Torus Nitr. Makeup Valve



20120803-Dresden-3 107



20120803-Dresden-3 109



20120803-Dresden-3 108



20120803-Dresden-3 110

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 6 of 8

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-1601-0057-V20

Equipment Class: (8) Motor-Operated and Solenoid-Operated Valves

Equipment Description: PRESSURE SUPPRESSION/ Drywell/Torus Nitr. Makeup Valve



20120803-Dresden-3 111



20120803-Dresden-3 113



20120803-Dresden-3 112



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 7 of 8

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-1601-0057-V20

Equipment Class: (8) Motor-Operated and Solenoid-Operated Valves

Equipment Description: PRESSURE SUPPRESSION/ Drywell/Torus Nitr. Makeup Valve



20120803-Dresden-3 115



20120803-Dresden-3 117





20120803-Dresden-3 118

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 8 of 8

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-1601-0057-V20

Equipment Class: (8) Motor-Operated and Solenoid-Operated Valves

Equipment Description: PRESSURE SUPPRESSION/ Drywell/Torus Nitr. Makeup Valve



Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No	D03-1601-0062-V05	
Equipment Clas	s: _(7) Fluid-Operated Valves	
Equipment Descriptio	n: PRESSURE SUPPRESSION/ Drywell Ventilation Line Val	ve
Pi	roject: Dresden 3 SWEL	
Location (Bldg, Elev, Room//	Area):Reactor, 570.00 ft, ALL	
Manufacturer/N	Aodel:	
Instructions for Completing	g Checklist	
SWEL. The space below ea	to document the results of the Seismic Walkdown of an item of ach of the following questions may be used to record the results a provided at the end of this checklist for documenting other cor	s of judgments and
Anchorage	· · · · · · · · · · · · · · · · · · ·	
	uration verification required (i.e., is the item one of the 50% iring such verification)?	No
2. Is the anchorage fre	e of bent, broken, missing or loose hardware?	Not Applicable
3. Is the anchorage fre	e of corrosion that is more than mild surface oxidation?	Not Applicable
4. Is the anchorage fre	e of visible cracks in the concrete near the anchors?	Not Applicable
	nfiguration consistent with plant documentation? (Note: pplies if the item is one of the 50% for which an anchorage ation is required.)	Not Applicable
 Based on the above potentially adverse s 	anchorage evaluations, is the anchorage free of seismic conditions?	Yes

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 2 of 2

Seismic Walkdown Checklist (SWC)	Status: Y N U
Equipment ID No.: D03-1601-0062-V05	
Equipment Class: (7) Fluid-Operated Valves	
Equipment Description: PRESSURE SUPPRESSION/ Drywell Ventilation Line Valv	e
Interaction Effects	
7. Are soft targets free from impact by nearby equipment or structures?	Yes
8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment?	Yes
9. Do attached lines have adequate flexibility to avoid damage?	Yes
10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects?	Yes
Other Adverse Conditions 11. Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment?	Yes
<u>Comments</u> Seismic Walkdown Team: J. Griffith & M. Wodarcyk - 8/2/2012 For photographs, see SWC for D03-1601-0023-V05.	
	_
Evaluated by: James Griffith Date: 10)/24/2012
Evaluated by: <u>Other Water</u> James Griffith Date: <u>10</u>	
Michael Wodarcyk 10)/24/2012
Photos	

Status:	Υ	N	U
---------	---	---	---

Seismic Walkdown Checklist (SWC)

Equipment ID No.:003-1601-0063-V05	
Equipment Class: _(7) Fluid-Operated Valves	
Equipment Description: PRESSURE SUPPRESSION/ Containment to SBGT Line \	Valve
Project: Dresden 3 SWEL	
Location (Bldg, Elev, Room/Area):Reactor, 570.00 ft, ALL	
Manufacturer/Model:	
Instructions for Completing Checklist	
This checklist may be used to document the results of the Seismic Walkdown of an item of e SWEL. The space below each of the following questions may be used to record the results findings. Additional space is provided at the end of this checklist for documenting other com	of judgments and
Anchorage	
 Is anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? 	No
2. Is the anchorage free of bent, broken, missing or loose hardware?	Not Applicable
3. Is the anchorage free of corrosion that is more than mild surface oxidation?	Not Applicable
4. Is the anchorage free of visible cracks in the concrete near the anchors?	Not Applicable
 Is the anchorage configuration consistent with plant documentation? (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) 	Not Applicable
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions?	Yes

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 2 of 8

Seismic Walkdown Checklist (SWC)	Status: Y N U
Equipment ID No.: D03-1601-0063-V05	
Equipment Class: (7) Fluid-Operated Valves	
Equipment Description: PRESSURE SUPPRESSION/ Containment to SBGT Line	Valve
Interaction Effects	
 Are soft targets free from impact by nearby equipment or structures? 	Yes
8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment?	Yes
9. Do attached lines have adequate flexibility to avoid damage?	Yes
10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects?	Yes
Other Adverse Conditions 11. Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment?	Yes
<u>Comments</u> Seismic Walkdown Team: J. Griffith & M. Wodarcyk - 8/2/2012	
Michael J. Westwyte	/30/2012 //30/2012

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 3 of 8

Status: Y N U


Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-1601-0063-V05


Equipment Class: (7) Fluid-Operated Valves

Equipment Description: PRESSURE SUPPRESSION/ Containment to SBGT Line Valve

Photos



20120802-Dresden-3 217





20120802-Dresden-3 218



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 4 of 8

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: ______003-1601-0063-V05

Equipment Class: _(7) Fluid-Operated Valves


Equipment Description: PRESSURE SUPPRESSION/ Containment to SBGT Line Valve



20120802-Dresden-3 221



20120802-Dresden-3 223





20120802-Dresden-3 224

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 5 of 8

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-1601-0063-V05

Equipment Class: (7) Fluid-Operated Valves

Equipment Description: PRESSURE SUPPRESSION/ Containment to SBGT Line Valve



20120802-Dresden-3 225





20120802-Dresden-3 226



20120802-Dresden-3 228

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 6 of 8

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-1601-0063-V05

Equipment Class: (7) Fluid-Operated Valves

Equipment Description: PRESSURE SUPPRESSION/ Containment to SBGT Line Valve



20120802-Dresden-3 229





20120802-Dresden-3 230



20120802-Dresden-3 232

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 7 of 8

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-1601-0063-V05

Equipment Class: (7) Fluid-Operated Valves

Equipment Description: PRESSURE SUPPRESSION/ Containment to SBGT Line Valve



20120802-Dresden-3 233



20120802-Dresden-3 234

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 8 of 8

Status: Y N U

Seismic Walkdown Checklist (SWC)


Equipment ID No.: D03-1601-0063-V05

Equipment Class: (7) Fluid-Operated Valves

Equipment Description: PRESSURE SUPPRESSION/ Containment to SBGT Line Valve



20120802-Dresden-3 235







Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.:003-2203-0006	
Equipment Class: (18) Instruments on Racks	
Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2203-6	
Project: Dresden 3 SWEL	
Location (Bldg, Elev, Room/Area):	
Manufacturer/Model:	
Instructions for Completing Checklist	
This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.	
Anchorage	
 Is anchorage configuration verification required (i.e., is the item one of the 50% Yes of SWEL items requiring such verification)? 	S
2. Is the anchorage free of bent, broken, missing or loose hardware? Ye	S
3. Is the anchorage free of corrosion that is more than mild surface oxidation? Ye	s
4. Is the anchorage free of visible cracks in the concrete near the anchors? Ye	S
 Is the anchorage configuration consistent with plant documentation? (Note: Ye This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) 	S
6. Based on the above anchorage evaluations, is the anchorage free of Ye potentially adverse seismic conditions?	S

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 2 of 8

Seismic Walkdown Checklist	(SWC)	Status: Y N U
Equipment ID No.:	D03-2203-0006	
	(18) Instruments on Racks	
	INSTRUMENT RACKS/ Instrument Rack 2203-6	
Interaction Effects		
7. Are soft targets free fro	m impact by nearby equipment or structures?	Yes
masonry block walls no	nt, distribution systems, ceiling tiles and lighting, and t likely to collapse onto the equipment? o be acceptable. Adjacent masonry wall is safety- g B-1709, Rev. A).	Yes
9. Do attached lines have	adequate flexibility to avoid damage?	Yes
	ismic interaction evaluations, is equipment free of smic interaction effects?	Yes
	d found no adverse seismic conditions that could ety functions of the equipment?	Yes
<u>Comments</u> SEWS Anchorage Notes: Anchored by 10 - 3/8" concrete braces and to floor by 4 knee-b ***** Seismic Walkdown Team: J. Gr		crete wall by 3 large
Evaluated by: <u>} bars</u> J	ames Griffith Date J. Washing K.	e: 9/30/2012
1	Michael Wodarcyk	9/30/2012

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 3 of 8

Seismic Walkdown Checklist	(SWC)	Status: Y N U
Equipment ID No.:	D03-2203-0006	
Equipment Class:	(18) Instruments on Racks	and the second
Equipment Description:	INSTRUMENT RACKS/ Instrument Rack 2203-6	


Photos	
Senset Road	
The design of th	
20120802-Dresden-3 181	20120802-Dresden-3 182
EDIZ/DEA/E 11:28	EDIZIDADE 11-20
20120802-Dresden-3 183	20120802-Dresden-3 184

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 4 of 8

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No .:	D03-2203-0006	
Equipment Class:		



20120802-Dresden-3 185



20120802-Dresden-3 187



20120802-Dresden-3 186



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 5 of 8

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2203-0006

Equipment Class: (18) Instruments on Racks

Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2203-6



20120802-Dresden-3 189





20120802-Dresden-3 190



20120802-Dresden-3 192

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 6 of 8

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2203-0006

Equipment Class: (18) Instruments on Racks

Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2203-6



20120802-Dresden-3 193



20120802-Dresden-3 195



20120802-Dresden-3 194



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 7 of 8

Status:	Y	N	U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2203-0006

Equipment Class: (18) Instruments on Racks

Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2203-6



20120802-Dresden-3 197



20120802-Dresden-3 199



20120802-Dresden-3 198



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 8 of 8


Status: Y N U

Seismic Walkdown Checklist (SWC)

	Equipment	ID No .:	D03-2203-0006
--	-----------	----------	---------------

Equipment Class: (18) Instruments on Racks

Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2203-6



20120802-Dresden-3 201

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.:003-2203-0008	
Equipment Class: (18) Instruments on Racks	
Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2203-8	
Project: Dresden 3 SWEL	
Location (Bldg, Elev, Room/Area):Reactor, 517.50 ft, ALL	
Manufacturer/Model:	
Instructions for Completing Checklist	
This checklist may be used to document the results of the Seismic Walkdown of an item of equipment o SWEL. The space below each of the following questions may be used to record the results of judgment findings. Additional space is provided at the end of this checklist for documenting other comments.	
Anchorage	
 Is anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? 	Yes
2. Is the anchorage free of bent, broken, missing or loose hardware?	Yes
3. Is the anchorage free of corrosion that is more than mild surface oxidation?	Yes
	163
4. Is the anchorage free of visible cracks in the concrete near the anchors?	Yes
Minor shrinkage cracks in wall judged to be acceptable.	
 Is the anchorage configuration consistent with plant documentation? (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) 	Yes
configuration verhication is required.)	
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions?	Yes

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 2 of 7

Seismic Walkdown Checklist (SWC)	Status: Y N U
Equipment ID No.:003-2203-0008	
Equipment Class: _(18) Instruments on Racks	
Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2203-8	
Interaction Effects	
7. Are soft targets free from impact by nearby equipment or structures?	Yes
8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Overhead light fixtures judged to be acceptable. Adjacent masonry wall is safety-related.	Yes
9. Do attached lines have adequate flexibility to avoid damage?	Yes
10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects?	Yes
Other Adverse Conditions 11. Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment? Tubes near overhead supports are flexible and judged to be acceptable.	Yes
Comments SEWS Anchorage Notes: Anchored by 10 - 3/8" concrete expansion anchors and braced back to reinforced concre ****** Seismic Walkdown Team: J. Griffith & M. Wodarcyk - 8/1/2012 See U3 West HCU Bank area walk-by for further notes. Evaluated by:	te wall by 4 braces.

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 3 of 7



20120801-Dresden-3 196

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 4 of 7

Status: Y N U

2012/08/01 10:17

Seismic Walkdown Checklist (SWC)

Equipment ID No.:	D03-2203-0008
Equipment Class:	(18) Instruments on Racks
Equipment Description:	INSTRUMENT RACKS/ Instrument Rack 2203-8



20120801-Dresden-3 198



20120801-Dresden-3 200



20120801-Dresden-3 202



20120801-Dresden-3 201



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 5 of 7

Status: Y N U


Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2203-0008

Equipment Class: (18) Instruments on Racks



20120801-Dresden-3 204



20120801-Dresden-3 206



20120801-Dresden-3 208



20120801-Dresden-3 205



20120801-Dresden-3 207



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 6 of 7

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2203-0008


Equipment Class: (18) Instruments on Racks

Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2203-8




20120801-Dresden-3 210









20120801-Dresden-3 211



20120801-Dresden-3 213



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 7 of 7

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2203-0008

Equipment Class: (18) Instruments on Racks

Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2203-8





20120801-Dresden-3 217

20120801-Dresden-3 216



Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.:003-2203-0070A	
Equipment Class: (18) Instruments on Racks	
Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2203-70A	
Project: Dresden 3 SWEL	
Location (Bldg, Elev, Room/Area):Turbine, 517.50 ft, ALL	
Manufacturer/Model:	
Instructions for Completing Checklist	
This checklist may be used to document the results of the Seismic Walkdown of an item of equipment of SWEL. The space below each of the following questions may be used to record the results of judgment findings. Additional space is provided at the end of this checklist for documenting other comments.	
Anchorage	
 Is anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? 	Yes
2. Is the anchorage free of bent, broken, missing or loose hardware?	Yes
3. Is the anchorage free of corrosion that is more than mild surface oxidation?	Yes
4. Is the anchorage free of visible cracks in the concrete near the anchors?	Yes
Minor shrinkage cracks in floor judged to be acceptable.	
 Is the anchorage configuration consistent with plant documentation? (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) 	Yes
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions?	Yes

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 2 of 7

Seismic Walkdown Checklist (SWC)	Status: Y N U
Equipment ID No.: D03-2203-0070A	
Equipment Class: (18) Instruments on Racks	
Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2203-70A	-
Interaction Effects	
Are soft targets free from impact by nearby equipment or structures?	Yes
Panels adjacent to 2203-70A restrained at top and judged to be acceptable.	
8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Temporary light fixture tethered with cord and with redundant supports to permanent light fixtures and judged to be acceptable.	Yes
Adjacent masonry wall is safety-related.9. Do attached lines have adequate flexibility to avoid damage?	Yes
10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects?	Yes
Other Adverse Conditions	
 Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment? All cabinet doors opened to view internal base anchorage. No other adverse seismic conditions. 	Yes
Comments SEWS Anchorage Notes:	
Anchored by nine 1/2" Wedge-type and shell concrete expansion anchors.	
***** Seismic Walkdown Team: J. Griffith & M. Wodarcyk - 7/30/2012	
Seismic Walkdowit Team. 3. Ghintit & W. Wodarcyk - 1730/2012	
Evaluated by: <u>An Date:</u> Date: <u>Method ()</u> Working K	9/30/2012
Michael Wodarcyk	9/30/2012

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 3 of 7

Status:	V	N	U
Status.		IN	U

Seismic Walkdown Checklist (SWC)

Equipment ID No.:	D03-2203-0070A
Equipment Class:	(18) Instruments on Racks
Equipment Description:	INSTRUMENT RACKS/ Instrument Rack 2203-70A

Photos



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 4 of 7



Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2203-0070A

Equipment Class: (18) Instruments on Racks

Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2203-70A




20120730-Dresden-3 106




20120730-Dresden-3 108



20120730-Dresden-3 107



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 5 of 7



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 6 of 7

Status: Y N U

Seismic Walkdown Checklist (SWC)


Equipment ID No.: D03-2203-0070A

Equipment Class: (18) Instruments on Racks

Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2203-70A



20120730-Dresden-3 114



20120730-Dresden-3 116



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 7 of 7

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2203-0070A

Equipment Class: (18) Instruments on Racks

Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2203-70A





20120730-Dresden-3 119

20120730-Dresden-3 118

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2203-0073A	
Equipment Class: (18) Instruments on Racks	
Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2203-73A	
Project: Dresden 3 SWEL	
Location (Bldg, Elev, Room/Area):Turbine, 538.00 ft, ALL	
Manufacturer/Model:	
Instructions for Completing Checklist	
This checklist may be used to document the results of the Seismic Walkdown of an item SWEL. The space below each of the following questions may be used to record the result findings. Additional space is provided at the end of this checklist for documenting other of the space space.	ults of judgments and
Anchorage	
 Is anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? 	Yes
2. Is the anchorage free of bent, broken, missing or loose hardware?	Yes
	100
View of east-side middle anchor is obstructed.	
3. Is the anchorage free of corrosion that is more than mild surface oxidation?	Yes
4. Is the anchorage free of visible cracks in the concrete near the anchors?	Yes
 Is the anchorage configuration consistent with plant documentation? (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) 	Yes
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Viewed 5 of 6 anchors. Remaining anchor could not be viewed due to obstruction from equipment. Anchors viewed matched documentation, therefore it is reasonable to conclude that the anchors match plant documentation without further verification.	Yes

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 2 of 4

	• • • • • • • • • • • • • • • • • • • •	t (SWC)	Status: Y N U
	Equipment ID No.:	D03-2203-0073A	
		(18) Instruments on Racks	
		INSTRUMENT RACKS/ Instrument Rack 2203-73A	
Intera	ction Effects		
7.	Are soft targets free fro	om impact by nearby equipment or structures?	Yes
8.	masonry block walls no	ent, distribution systems, ceiling tiles and lighting, and ot likely to collapse onto the equipment? <i>It is judged to be acceptable.</i>	Yes
9.	Do attached lines have	e adequate flexibility to avoid damage?	Yes
10.		eismic interaction evaluations, is equipment free of smic interaction effects?	Yes
Other	Adverse Conditions		
11.	adversely affect the sa	nd found no adverse seismic conditions that could fety functions of the equipment? g has gap at base of equipment; judged to be	Yes
	Adjacent fixed grating acceptable.		
	acceptable.		
SEWS Panel	acceptable.	o steel base, 4Wx 36L 1/2" Plate. Steel base in turn an ors, 3 on each side.	chored to R/C floor by six
Panel 1/2" cc	acceptable. nents Anchorage Notes: 36Dx30Wx98H welded to bncrete expansion ancho	ors, 3 on each side.	chored to R/C floor by six
SEWS Panel 1/2" co ***** Seism	acceptable. <u>nents</u> Anchorage Notes: 36Dx30Wx98H welded to borcrete expansion ancho ic Walkdown Team: J. G	ors, 3 on each side. Friffith & M. Wodarcyk - 7/31/2012	ichored to R/C floor by six
SEWS Panel 1/2" co ***** Seism	acceptable. <u>nents</u> Anchorage Notes: 36Dx30Wx98H welded to borcrete expansion ancho ic Walkdown Team: J. G	ors, 3 on each side.	chored to R/C floor by six
SEWS Panel 1/2" cc ***** Seism <u>See P</u>	acceptable. <u>nents</u> Anchorage Notes: 36Dx30Wx98H welded to borcrete expansion ancho ic Walkdown Team: J. G	ors, 3 on each side. Friffith & M. Wodarcyk - 7/31/2012	
SEWS Panel 1/2" cc ***** Seism <u>See P</u>	acceptable. <u>nents</u> Anchorage Notes: 36Dx30Wx98H welded to borcrete expansion ancho ic Walkdown Team: J. G anel 2202-73A area walk	ors, 3 on each side. Friffith & M. Wodarcyk - 7/31/2012 <-by for further information.	-

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 3 of 4

Seismic Walkdown Checklist	(SWC) Status: Y N U
Equipment ID No.:	D03-2203-0073A
Equipment Class:	(18) Instruments on Racks
Equipment Description:	INSTRUMENT RACKS/ Instrument Rack 2203-73A
Photos	
And	
20120731-Dresden-3 338	20120731-Dresden-3 339

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 4 of 4

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2203-0073A

Equipment Class: (18) Instruments on Racks

Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2203-73A



20120731-Dresden-3 342

Status: Y N U

Seismic Walkdown Checklist (SWC)

......

	Equipment ID No.:003-2253-0010	
	Equipment Class: (20) Instrumentation and Control Panels and Cabinets	
1	Equipment Description: CONTROL PANEL/ DG Metering and Relay Cabinet	
	Project: Dresden 3 SWEL	
Locatio	n (Bldg, Elev, Room/Area):Turbine, 517.50 ft, ALL	
	Manufacturer/Model:	
Instruc	tions for Completing Checklist	
SWEL.	ecklist may be used to document the results of the Seismic Walkdown of an item of equipment on the The space below each of the following questions may be used to record the results of judgments ar Additional space is provided at the end of this checklist for documenting other comments.	
Ancho	rage	
1.	Is anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)?	Yes
2.	Is the anchorage free of bent, broken, missing or loose hardware?	Yes
3.	Is the anchorage free of corrosion that is more than mild surface oxidation?	Yes
4.	Is the anchorage free of visible cracks in the concrete near the anchors? Minor shrinkage cracks in floor judged to be acceptable.	Yes
5.	Is the anchorage configuration consistent with plant documentation? (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)	Yes
6.	Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions?	Yes

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 2 of 6

Seismic Walkdown Checklist (SWC)	Status: Y N U
Equipment ID No.: D03-2253-0010	
Equipment Class: (20) Instrumentation and Control Panels and Cabinets	
Equipment Description: CONTROL PANEL/ DG Metering and Relay Cabinet	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
Interaction Effects	
7. Are soft targets free from impact by nearby equipment or structures?	Yes
8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment?	Yes
9. Do attached lines have adequate flexibility to avoid damage?	Yes
10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects?	Yes
Other Adverse Conditions 11. Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment?	Yes
<u>Comments</u> SEWS Anchorage Notes:	
The base channel is welded in all four corners with 1" long 3/16" fillet welds.	

Seismic Walkdown Team: J. Griffith & M. Wodarcyk - 7/31/2012	
Evaluated by: 3 - 14# James Griffith Date: 9	9/30/2012
Michael Wodarcyk 9	9/30/2012

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 3 of 6

Status: Y N U


Seismic Walkdown Checklist (SWC)

 Equipment ID No.:
 D03-2253-0010

 Equipment Class:
 (20) Instrumentation and Control Panels and Cabinets

 Equipment Description:
 CONTROL PANEL/ DG Metering and Relay Cabinet

Photos




20120731-Dresden-3 171

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 4 of 6

Status: Y N U

Seismic Walkdown Checklist (SWC)



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 5 of 6

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2253-0010

Equipment Class: (20) Instrumentation and Control Panels and Cabinets

Equipment Description: CONTROL PANEL/ DG Metering and Relay Cabinet



20120731-Dresden-3 177



20120731-Dresden-3 179



20120731-Dresden-3 178



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 6 of 6

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2253-0010

Equipment Class: (20) Instrumentation and Control Panels and Cabinets

Equipment Description: CONTROL PANEL/ DG Metering and Relay Cabinet



20120731-Dresden-3 181



20120731-Dresden-3 183



20120731-Dresden-3 182



Status: Y N U

Seismic Walkdown Checklist (SWC)

2

/

Equipment ID No.:003-2253-0021	
Equipment Class: (20) Instrumentation and Control Panels and Cabinets	
Equipment Description: CONTROL PANEL/ DG Excitation Cabinet	
Project: Dresden 3 SWEL	
Location (Bldg, Elev, Room/Area):Turbine, 517.50 ft, ALL	
Manufacturer/Model:	
Instructions for Completing Checklist	
This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.	
Anchorage	
 Is anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? 	(es
2. Is the anchorage free of bent, broken, missing or loose hardware?	(es
3. Is the anchorage free of corrosion that is more than mild surface oxidation?	(es
4. Is the anchorage free of visible cracks in the concrete near the anchors?	res
Minor shrinkage cracks in floor judged to be acceptable.	
 Is the anchorage configuration consistent with plant documentation? (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) 	Yes
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions?	Yes

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 2 of 5

Equipment ID No.: D03-2253-0021 Equipment Class: (20) Instrumentation and Control Panels and Cabinets Equipment Description: CONTROL PANEL/ DG Excitation Cabinet Interaction Effects 7. Are soft targets free from impact by nearby equipment or structures? 8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? 9. Do attached lines have adequate flexibility to avoid damage? 10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Other Adverse Conditions 11. Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment? Comments Comments	Yes
Equipment Class: (20) Instrumentation and Control Panels and Cabinets Equipment Description: CONTROL PANEL/ DG Excitation Cabinet Interaction Effects 7. Are soft targets free from impact by nearby equipment or structures? 8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? 9. Do attached lines have adequate flexibility to avoid damage? 10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Other Adverse Conditions 11. Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment? Comments	Yes
Equipment Description: CONTROL PANEL/ DG Excitation Cabinet Interaction Effects 7. Are soft targets free from impact by nearby equipment or structures? 8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? 9. Do attached lines have adequate flexibility to avoid damage? 10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Other Adverse Conditions 11. Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment? Comments	Yes
Interaction Effects 7. Are soft targets free from impact by nearby equipment or structures? 8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? 9. Do attached lines have adequate flexibility to avoid damage? 10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Other Adverse Conditions 11. Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment? Comments	Yes
 8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? 9. Do attached lines have adequate flexibility to avoid damage? 10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Other Adverse Conditions 11. Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment? 	Yes
 9. Do attached lines have adequate flexibility to avoid damage? 10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Other Adverse Conditions Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment? 	
 10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? <u>Other Adverse Conditions</u> Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment? <u>Comments</u> 	Yes
Other Adverse Conditions 11. Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment? Comments	Yes
11. Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment?	Yes
11. Have you looked for and found no adverse seismic conditions that could adversely affect the safety functions of the equipment?	
	Yes
SEWS Anchorage Notes: Welding is very marginal front of panel has about 2" long by 1/8" fillets, one side has 2 1" and 1-3/4" long fillets and the other side has about 1" long 1/8" fillet toward the back. Rear of panel has no anchorage.	1/8"
Seismic Walkdown Team: J. Griffith & M. Wodarcyk - 7/31/2012	
Evaluated by: James Griffith Date: 9/30/2012	

•

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 3 of 5

Status: Y N U


Seismic Walkdown Checklist (SWC)

 Equipment ID No.:
 D03-2253-0021

 Equipment Class:
 (20) Instrumentation and Control Panels and Cabinets

Equipment Description: CONTROL PANEL/ DG Excitation Cabinet

Photos



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 4 of 5

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2253-0021

Equipment Class: (20) Instrumentation and Control Panels and Cabinets

Equipment Description: CONTROL PANEL/ DG Excitation Cabinet



20120731-Dresden-3 189



20120731-Dresden-3 191



20120731-Dresden-3 190



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 5 of 5

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2253-0021

Equipment Class: (20) Instrumentation and Control Panels and Cabinets

Equipment Description: CONTROL PANEL/ DG Excitation Cabinet





20120731-Dresden-3 193



Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2253-0084	
Equipment Class: (18) Instruments on Racks	
Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2253-84	
Project: Dresden 3 SWEL	<u>. </u>
Location (Bldg, Elev, Room/Area):	
Manufacturer/Model:	
Instructions for Completing Checklist	
This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on t SWEL. The space below each of the following questions may be used to record the results of judgments a findings. Additional space is provided at the end of this checklist for documenting other comments.	
Anchorage	
 Is anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? 	Yes
2. Is the anchorage free of bent, broken, missing or loose hardware?	Yes
3. Is the anchorage free of corrosion that is more than mild surface oxidation?	Yes
4. Is the anchorage free of visible cracks in the concrete near the anchors?	Yes
5. Is the anchorage configuration consistent with plant documentation? (Note: This question only applies if the item is one of the 50% for which an anchorage	Yes
configuration verification is required.)	
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions?	Yes

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 2 of 7

Seismic Walkdown Checklist (SWC)	Status: Y N U
Equipment ID No.: D03-2253-0084	
Equipment Class: (18) Instruments on Racks	
Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2253-84	
Interaction Effects	
7. Are soft targets free from impact by nearby equipment or structures?	Yes
8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment?	Yes
 9. Do attached lines have adequate flexibility to avoid damage? 	Yes
10. Based on the above seismic interaction evaluations, is equipment free of	Yes
potentially adverse seismic interaction effects?	
Other Adverse Conditions 11. Have you looked for and found no adverse seismic conditions that could	Yes
adversely affect the safety functions of the equipment?	165
<u>Comments</u> SEWS Anchorage Notes:	
Distribution Panel cantilevered from floor on two legs each. Each leg is welded to a base pl to the floor with four 1/2" diameter expansion bolts.	ate that is anchored

Seismic Walkdown Team: J. Griffith & M. Wodarcyk - 8/2/2012	
	/30/2012
Michael Wodarcyk 9	/30/2012

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 3 of 7

Seismic Walkdown Checklist	(SWC)	Status: Y N U
Equipment ID No.:	D03-2253-0084	
Equipment Class:	(18) Instruments on Racks	ers man e uniter sur sur sur sur sur man and sur sur and sur
Equipment Description:	INSTRUMENT RACKS/ Instrument Rack 2253-84	
Photoes Same sector concerts regarding the sector concerts re		-84 2012/DB/D2 10 41
20120802-Dresden-3 117	20120802-Dresden-3 118	

20120802-Dresden-3 119

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 4 of 7

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No .:	D03-2253-0084

Equipment Class: (18) Instruments on Racks

Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2253-84




20120802-Dresden-3 121





20120802-Dresden-3 122



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 5 of 7

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2253-0084

Equipment Class: (18) Instruments on Racks

Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2253-84



20120802-Dresden-3 125



20120802-Dresden-3 127





20120802-Dresden-3 128

Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 6 of 7

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No.: D03-2	253-0084
-------------------------	----------

Equipment Class: (18) Instruments on Racks

Equipment Description: INSTRUMENT RACKS/ Instrument Rack 2253-84



20120802-Dresden-3 129



20120802-Dresden-3 131



20120802-Dresden-3 130



Dresden Generating Station Unit 3 12Q0108.30-R-002, Rev. 2 Correspondence No.: RS-12-167 Sheet 7 of 7

Status: Y N U

Seismic Walkdown Checklist (SWC)

Equipment ID No .:	D03-2253-0084	
Equipment Class:	(18) Instruments on Racks	
Equipment Description:	INSTRUMENT RACKS/ Instrument Rack 2253-84	
Cardina and a second		

