

**SAFETY INSPECTION REPORT AND COMPLIANCE INSPECTION**

1. LICENSEE/LOCATION INSPECTED:

Decorative Panels International, Inc.  
416 Ford Ave.  
Alpena, MI 49707

REPORT NUMBER(S) 2013001

2. NRC/REGIONAL OFFICE

Region III  
U. S. Nuclear Regulatory Commission  
2443 Warrenville Road, Suite 210  
Lisle, IL 60532-4352

3. DOCKET NUMBER(S)

030-04843

4. LICENSE NUMBER(S)

21-05856-01

5. DATE(S) OF INSPECTION

4/30/2013

**LICENSEE:**

The inspection was an examination of the activities conducted under your license as they relate to radiation safety and to compliance with the Nuclear Regulatory Commission (NRC) rules and regulations and the conditions of your license. The inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector. The inspection findings are as follows:



- 1. Based on the inspection findings, no violations were identified.
- 2. Previous violation(s) closed.
- 3. The violation(s), specifically described to you by the inspector as non-cited violations, are not being cited because they were self-identified, non-repetitive, and corrective action was or is being taken, and the remaining criteria in the NRC Enforcement Policy, to exercise discretion, were satisfied.

Non-cited violation(s) were discussed involving the following requirement(s):

- 4. During this inspection, certain of your activities, as described below and/or attached, were in violation of NRC requirements and are being cited in accordance with NRC Enforcement Policy. This form is a NOTICE OF VIOLATION, which may be subject to posting in accordance with 10 CFR 19.11.  
(Violations and Corrective Actions)

**Statement of Corrective Actions**

I hereby state that, within 30 days, the actions described by me to the Inspector will be taken to correct the violations identified. This statement of corrective actions is made in accordance with the requirements of 10 CFR 2.201 (corrective steps already taken, corrective steps which will be taken, date when full compliance will be achieved). I understand that no further written response to NRC will be required, unless specifically requested.

TITLE	PRINTED NAME	SIGNATURE	DATE
LICENSEE'S REPRESENTATIVE			
NRC INSPECTOR	E.L. Kulzer		5/1/13
BRANCH CHIEF	T.E. Bloomer		

**Docket File Information**  
**SAFETY INSPECTION REPORT AND COMPLIANCE INSPECTION**

1. LICENSEE/LOCATION INSPECTED:  Decorative Panels International, Inc. 416 Ford Ave. Alpena, MI 49707  REPORT NUMBER(S) 2013001	2. NRC/REGIONAL OFFICE  Region III U. S. Nuclear Regulatory Commission 2443 Warrenville Road, Suite 210 Lisle, IL 60532-4352
---	---

3. DOCKET NUMBER(S)  030-04843	4. LICENSE NUMBER(S)  21-05856-01	5. DATE(S) OF INSPECTION  4/30/2013
--------------------------------------	---	---

6. INSPECTION PROCEDURES USED  IP 87124	7. INSPECTION FOCUS AREAS  03.01 through 03.07
---	--

**SUPPLEMENTAL INSPECTION INFORMATION**

1. PROGRAM CODE(S)  03120	2. PRIORITY  5	3. LICENSEE CONTACT  Dan VanMassenhove	4. TELEPHONE NUMBER  (989) 356-8528
---------------------------------	----------------------	--	---

Main Office Inspection      Next Inspection Date: 4/30/2018

Field Office Inspection \_\_\_\_\_

Temporary Job Site Inspection \_\_\_\_\_

**PROGRAM SCOPE**

The licensee manufactures wood paneling and employs 180 individuals. The licensee possesses six specifically licensed fixed gauges used in the production of panel products. Currently, one individual is involved with use and oversight of the devices who is the RSO. Gauges are leak tested at six-month frequencies in accordance with manufacturers specifications. Inventories and shutter checks are performed at required frequencies.

The licensee is not authorized to remove and/or relocate gauges. The licensee has the manufacturer relocate, remove, etc. the gauges. The licensee does not perform any service or maintenance activities on its gauges; these services are performed by the manufacturer.

**Performance Observations**

The plant facility was toured and all of the gauges were observed in conjunction with the licensee's current inventory. The RSO demonstrated survey techniques used if/when a gauge is relocated. Proper lock-out and leak test procedures were also adequately described. Interviews conducted with plant workers revealed that under no circumstances would a vessel be entered without RSO supervision of lock-out/tag-out procedures. The licensee's posting were at the point of becoming illegible. The RSO stated that he would have these posting replaced.