



MAY 14 2013

Serial: BSEP 13-0054

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Subject: Brunswick Steam Electric Plant, Unit Nos. 1 and 2
Docket Nos. 50-325 and 50-324
Supplement to Request for License Amendments - Diesel Generator (DG)
Completion Time (CT) Extension for Technical Specification (TS) 3.8.1, "AC
Sources - Operating" (TAC No. ME8893 and ME8894)

Reference: Letter from M. Annacone to the U.S. Nuclear Regulatory Commission, Request for
License Amendments - Diesel Generator (DG) Completion Time (CT) Extension for
Technical Specification (TS) 3.8.1, "AC Sources - Operating,"
dated June 19, 2012, ADAMS Accession Number ML12173A112

Ladies and Gentlemen:

On June 19, 2012, Duke Energy Progress, Inc., formerly known as Carolina Power & Light Company (CP&L), requested a revision to the Technical Specifications (TS) for the Brunswick Steam Electric Plant (BSEP), Unit Nos. 1 and 2. The proposed revision extends the Completion Time (CT) of TS 3.8.1, Required Action D.4 for an inoperable diesel generator (DG) from 7 days to 14 days. A commensurate change was also proposed to extend the maximum Completion Time of TS 3.8.1, Required Actions C.3 and D.4.

In support of the proposed amendments, Duke Energy is installing a supplemental diesel generator (SUPP-DG). Currently, the SUPP-DG is scheduled to be available (i.e., installed and ready for use by Operations) in January 2014. As such, Duke Energy requests that the approval date for the proposed amendments be revised from June 28, 2013, to October 28, 2013.


Duke Energy originally requested that implementation of the amendments be completed within 90 days of approval. Rather than implementation being based on issuance of the amendments, Duke Energy requests that implementation of the amendments be contingent upon availability of the supplemental diesel generator.

Based on the above, Duke Energy requests approval of the proposed amendments by October 28, 2013, with implementation within 90 days of the supplemental diesel generator being available.

A001
NRR

No regulatory commitments are contained in this submittal. Please refer any questions regarding this submittal to Mr. Lee Grzeck, Manager - Regulatory Affairs, at (910) 457-2487.

Sincerely,



Annette H. Pope
Manager – Organizational Effectiveness
Brunswick Steam Electric Plant

MAT/mat

cc:

U. S. Nuclear Regulatory Commission, Region II
ATTN: Mr. Victor M. McCree, Regional Administrator
245 Peachtree Center Ave, NE, Suite 1200
Atlanta, GA 30303-1257

U. S. Nuclear Regulatory Commission
ATTN: Mr. Christopher Gratton (Mail Stop OWFN 8G9A)
11555 Rockville Pike
Rockville, MD 20852-2738

U. S. Nuclear Regulatory Commission
ATTN: Ms. Michelle P. Catts, NRC Senior Resident Inspector
8470 River Road
Southport, NC 28461-8869

Chair - North Carolina Utilities Commission
P.O. Box 29510
Raleigh, NC 27626-0510

Mr. W. Lee Cox, III, Section Chief **(Electronic Copy Only)**
Radiation Protection Section
North Carolina Department of Health and Human Services
1645 Mail Service Center
Raleigh, NC 27699-1645
lee.cox@dhhs.nc.gov