



STEVEN D. CAPPS
Vice President
McGuire Nuclear Station

Duke Energy
MGO1VP / 12700 Hagers Ferry Rd.
Huntersville, NC 28078

980-875-4805
980-875-4809 fax
Steven.Capps@duke-energy.com

March 25, 2013

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555-0001

Subject: Duke Energy Carolinas, LLC
McGuire Nuclear Station, Units 1 and 2
Docket Nos. 50-369, 50-370
Annual Commitment Change Report

Attached is a summary report of commitment changes for McGuire Nuclear Station completed during the 2012 calendar year. These changes were made per the guidance defined in NEI 99-04, "Guidelines for Managing NRC Commitments" and have no adverse effect on compliance with NRC rules or regulations.

Questions regarding this submittal should be directed to Kay Crane, McGuire Regulatory Affairs at (980) 875-4306.

Steven D. Capps

Attachment

A001
NRC

U. S. Nuclear Regulatory Commission
March 25, 2013
Page 2

xc:

Mr. Victor McCree
U. S. Nuclear Regulatory Commission, Region II
Marquis One Tower
245 Peachtree Center Ave., NE, Suite 1200
Atlanta, GA 30303

Mr. Jon Thompson
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, DC 20555-0001

Mr. John Zieler
NRC Senior Resident Inspector
McGuire Nuclear Station

McGuire Nuclear Station
Commitment Change Summary Report
Docket Nos. 369 and 370

NUMBER	SOURCE DOCUMENT	ORIGINAL COMMITMENT	MODIFIED COMMITMENT
2012-M-001	Licensee Event Report 370/97-02 dated November 3, 1997.	Upon completion of the NC pump motor stator replacements, a long-term motor maintenance and monitoring program, consisting of on-line partial discharge testing and off-line electrical testing will be implemented.	Upon completion of the NC pump motor stator replacements, a long term maintenance and monitoring program, consisting of off-line electrical testing will be implemented.