


At-Rest Earth Pressure on 1-ft Wide Vertical Strip



- A = $K_0 (q)$ = Effect of uniform full coverage surface surcharge
- B = $K_0 \gamma_s (z)$ = Earth pressure at-rest above water table
- C = $K_0 \gamma' (h)$ = Earth pressure at-rest increment below water table
- $P_w = 62.4 (h)$ = Hydrostatic pressure increment
- H = A + B = Static lateral earth pressure above water table ($z < dw$)
- H = A + $K_0 \gamma_s (dw)$ + $K_0 \gamma' (z - dw)$ = Static lateral earth pressure below water table ($z > dw$) (P_w not included)

Conditions on information:

- Units of pressure, psf
- Backfill of granular material compacted to 96% maximum dry density by ASTM D1557
- γ_s = saturated unit weight of granular backfill above water table, pcf
- γ' = submerged unit weight of granular backfill, pcf
- $\phi = 35$ degrees = angle of internal friction of soil
- $K_0 = 1 - \sin(\phi)$ = at-rest earth pressure coefficient of soil
- Plane strain conditions (corner adjustment factors not included)
- Dynamic soil pressure not included
- Compaction-induced residual pressure not included

USCS Type	γ_s	γ'	K_0
GW	150	87.6	0.426
GP	142	79.6	0.426
SW	136	73.6	0.426

WLS COL 2.5-13

**WILLIAM STATES LEE III
NUCLEAR STATION UNITS 1 & 2**

Static Lateral At-Rest
Pressures on Nuclear Island

FIGURE 2.5.4-255b Rev 7