

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 US-APWR Subcommittee: Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Thursday, April 25, 2013

Work Order No.: NRC-4166

Pages 1-334

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

US-APWR SUBCOMMITTEE

+ + + + +

THURSDAY

APRIL 25, 2013

+ + + + +

OPEN SESSION

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B1, 11545 Rockville Pike, at 8:30 a.m., John Stetkar,
Chairman, presiding.

COMMITTEE MEMBERS:

JOHN W. STETKAR, Chairman

DENNIS C. BLEY, Member

CHARLES H. BROWN, JR. Member

JOY REMPE, Member

WILLIAM J. SHACK, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

NRC STAFF PRESENT:

GIRIJA S. SHUKLA, Designated Federal Official

JOE ASHCRAFT

TOM BERGMAN

JEFF CIOCCO

IAN JUNG

ERICK MARTINEZ

LYNN MROWCA

KHOI NGUYEN

DINESH TANEJA

ALSO PRESENT:

HIROSHI HAMAMOTO

KEVIN LYNN

RICHARD SAMPLES

KEN SCAROLA

RYAN SPRENGEL

MAKOTO TAKASHIMA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

T-A-B-L-E O-F C-O-N-T-E-N-T-S

PAGE

Opening remarks and objectives

 John Stetkar.....5

Staff Introduction

 Jeff Ciocco.....7

 Ryan Sprengel.....8

 Makoto Takashima.....8

Discussion of the US-APWR DCD Chapter 7

 Richard Samples.....9

Discussion of the staff SE for the
US-APWR DCD Chapter 7

 By Tom Bergman.....259

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1

2

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

P-R-O-C-E-E-D-I-N-G-S

(8:34 a.m.)

CHAIR STETKAR: The meeting will now come to order. This is a meeting of the United States Advanced Pressurized Water Reactor Subcommittee. I'm John Stetkar, Chairman of the Subcommittee meeting.

ACRS members in attendance are, Dennis Bley, Bill Shack, Charles Brown and Joy Rempe. Mr. Girija Shukla of the ACRS Staff is the designated federal official.

Subcommittee will discuss the US-APWR Design Certification Document and Comanche Peak Combined License Application Chapter 7, Instrumentation Controls and Sections 2.0 through 2.3 of the Combined License Application Chapter 2, Site Characteristics.

We will hear presentations from Mitsubishi Heavy Industries, Luminant Generation Company and the NRC Staff. Mr. Royce Beacom of the NRC staff has requested to make a brief presentation on the US-APWR Chapter 7. His presentation is scheduled today at 1:00 p.m. and it will be closed for external participants.

The Subcommittee will gather information, analyze relevant issues and facts and formulate proposed positions and actions as appropriate for deliberation by the full Committee.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Rules for participation in today's meeting
2 have been announced as part of this notice of this
3 meeting previously published in the Federal Register.

4 Parts of this meeting may need to be closed to the public
5 to protect information proprietary to MHI or other
6 parties.

7 I'm asking the NRC Staff and the Applicant
8 to identify the need for closing the meeting before we
9 enter into such discussions and to verify that only
10 people with the required clearance and need to know are
11 present.

12 A transcript of this meeting is being kept
13 and will be made available as stated in the Federal
14 Register notice. Therefore, we request that
15 participants in this meeting use the microphones located
16 throughout the meeting room when addressing the
17 Subcommittee.

18 The participants should first identify
19 themselves and speak with sufficient clarity and volume
20 so they may be readily heard.

21 The telephone bridge line has also been
22 established for this meeting. To preclude interruption
23 of the meeting the phone will be placed in a
24 listen-in-mode during the presentations and Committee
25 discussions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Please silence your cell phones, anything
2 else you have during the meeting. And we will now
3 proceed and call upon Jeff Ciocco.

4 MR. CIOCCO: Yes, good morning everybody.
5 My name is Jeff Ciocco, I'm the lead project manager
6 for the US-APWR Design Certification.

7 We'd like to thank the ACRS Subcommittee
8 for having us here today to present Chapter 7 on
9 Instrumentation and Controls, as we progressed through
10 the remaining chapters of the US-APWR Design
11 Certification in our Phase 3 licensing review.

12 We do have technical staff here this
13 morning, of the NRC Staff, available for any questions.

14 And we'll do our introductions this afternoon before
15 we begin the NRC presentation.

16 And we find it particular helpfully, John,
17 as you have always done, is to recapitulate at the end
18 of the session any specific action items or questions
19 that you have so we can write them down and we certainly
20 peruse the transcripts whenever they become available.

21 So thank you very much.

22 CHAIR STETKAR: Great, thanks a lot, Jeff.
23 And with that, well turn it over to MHI.

24 MR. SPRENGEL: I'm still over here.

25 CHAIR STETKAR: Ryan.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SPRENGEL: This is Ryan Sprengel with
2 MNES. Good morning again and I guess it's been about
3 two weeks since we've seen each other, so glad to see
4 you again.

5 We will be picking back up with our
6 Subcommittee meetings on Chapter 7, as you're all aware.

7 And one thing I'd like to point out, we have received
8 previous questions and discussion topics throughout our
9 Subcommittee meetings that we try to integrate those
10 into our presentation. And so we do plan to cover those
11 and then have any need of discussion on those specific
12 topics.

13 CHAIR STETKAR: Great.

14 MR. SPRENGEL: So they'll be throughout the
15 presentation. So now I'll go ahead and turn it over
16 to Makoto Takashima.

17 MR. TAKASHIMA: My name is Makoto Takashima
18 from MHI. I have a responsibility for the US-APWR I&C
19 Design.

20 First I would direct a thank you very much
21 to the vast opportunity to present our key design
22 features of the US-APWR I&C Design. And the main
23 presentation will be provided by Mr. Richard Samples.

24 MR. SAMPLES: Good morning.

25 CHAIR STETKAR: Before we start, let me

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 just alert you. Essentially all of the technical
2 reports are proprietary information. So if the
3 questioning gets into enough details where you feel that
4 we are treading on proprietary information, just alert
5 us.

6 I don't know how that will transpire. If
7 we're kind of going in and out of public information
8 quite bit, what I'd like to do is kind of hold all the
9 proprietary discussion to a block of time. So I'll let
10 you alert us to situations where we're getting to deep
11 into the details, if you will, and we'll organize kind
12 of closing the meeting for a block of time to discuss
13 those.

14 MR. SAMPLES: Okay.

15 CHAIR STETKAR: Just wanted to alert you
16 to that.

17 MR. SAMPLES: That's good. Well then good
18 morning, my name Richard Samples. I'm a
19 Instrumentation and Control Engineer with Mitsubishi.
20 I'll be the main presenter today with Mr. Makoto
21 Takashima, Mr. Ken Scarola and several Mitsubishi
22 engineers supporting me.

23 This is the US-APWR Chapter 7 presentation
24 for the advisory Committee for Reactor safeguards. Due
25 to limited time I can't cover every detail that's in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the draft safety evaluation so I'll cover the main
2 points.

3 The safety evaluation does run over 300
4 pages. I'll cover the safety related, non-safety and
5 diverse instrumentation and control systems of the
6 US-APWR as well as their conforments to sense of safety
7 criteria and covering opening items and will summary
8 at the end.

9 Mitsubishi does have experts present today
10 if you have questions. These are the topics I'll cover
11 in the introduction.

12 In this figure you see how the various
13 topical and technical reports are associated with the
14 different chapters, different sections of DCD Chapter
15 7. These topical and technical reports refine key
16 details that support the information in DCD Chapter 7.

17 CHAIR STETKAR: Richard, before you click
18 off that slide, you'll find you haven't been here before
19 so you don't get a chance to string together more then
20 about 30 seconds of continuous thought without us
21 interrupting you. Topical reports, it's only one
22 topical report on this list, 7006, correct?

23 MR. SAMPLES: Yes.

24 CHAIR STETKAR: Are you going to reissue
25 that topical report? You've changed the design of DAS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and that topical report has outdated, incorrect design
2 information.

3 MR. SAMPLES: I'll let Mr. Takashima answer
4 that.

5 MEMBER BROWN: Can I, you say pink means
6 it's outdated?

7 CHAIR STETKAR: No, pink is the only,
8 that's the only topical report.

9 MEMBER BROWN: Oh --

10 CHAIR STETKAR: The other technical,
11 technical --

12 MEMBER BROWN: I got it.

13 (Crosstalk)

14 CHAIR STETKAR: Technical reports I don't
15 care about, topical reports I do. There's an SER and
16 more importantly, the ACRS has written a letter
17 endorsing that topical report.

18 MEMBER BROWN: I'm aware of that, okay.
19 I just didn't --

20 CHAIR STETKAR: But it's my understanding
21 that you've changed the DAS design from, to digital
22 actuation to control cabinets, whatever you call DACs.

23 MEMBER BROWN: I guess.

24 CHAIR STETKAR: To four and change the
25 coincidence logic. And that topical report report

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 actually describes the old, it has information with the
2 old design. Two cabinets and super coincidence logic.

3 So that is now outdated.

4 MR. SCAROLA: We understand. This Ken
5 Scarola. And I'm going to give you some background and
6 then we'll basically explain where we're going.

7 When we had originally submitted all of
8 these topical reports, they were all topical reports,
9 okay. And they were intended to be applicable to both
10 operating clients as well as the US-APWR.

11 But overtime it was recognized that that
12 was going to be a difficult review process. So the
13 subsequent topical report, the first one that got
14 approved as topical report was 07006. The others we
15 were able to changed the technical reports before hand.

16 So although 07006 is a topical report,
17 whatever needed to be superceded in 07006 has been
18 superceded by DCD information. So within Chapter 7.8
19 it supercedes, it references 07006, but it identifies
20 where there are changes.

21 So at this point in time there is probably
22 no need to --

23 CHAIR STETKAR: Okay.

24 MR. SCAROLA: -- update 07006 for the
25 US-APWR, however, as Mitsubishi thinks about their

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 strategy for operating plants, it may be appropriate
2 to update it. But that decision has not been made.

3 CHAIR STETKAR: Okay, thanks.

4 MEMBER BROWN: Can I ask one question
5 relative to that because in the existing, because I had
6 to read a good bit of 06, the output of the DAS actually
7 feeds over in the output section of the SLS into the
8 I/O, the PIF, whatever you want to call it.

9 Is that combination of things different
10 than what it was before? Although it only indicates
11 only two channels --

12 CHAIR STETKAR: I'm sure we'll talk about
13 DAS, more of the details.

14 MEMBER BROWN: No, I just wanted to --

15 CHAIR STETKAR: This is kind of
16 administrative --

17 MEMBER BROWN: No, I understand that.

18 CHAIR STETKAR: -- legal thing that I
19 wanted to get on the record.

20 MEMBER BROWN: I just wanted to know how
21 much that fed over into the output of the SLS as it goes
22 and feeds down to the ESFAS function?

23 MR. SCAROLA: The simple answer is it's all
24 the same. We have slides, we'll show them later.

25 MEMBER BROWN: Okay, that's fine. Thank

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you. Well let me ask one other question. I keep
2 forgetting the nuance between topical and technicals.

3 You referenced technical reports in the DCD
4 as well as the one topical. To me that meant those also
5 get brought under as part of the licensing basis when
6 it gets approved.

7 So even though there's a nuance as to
8 whether you get and SER on them or not or whether you
9 do or don't, it's irrelevant relative to its
10 applicability in terms of other design detail. Okay.

11 CHAIR STETKAR: Just for the record,
12 everything that's referenced in the DCD is part of the
13 basis. The only difference between topical and
14 technical reports is, a topical report receives its own
15 separate review by the staff and they write a Safety
16 Evaluation so that in principle the information in a
17 topical report can be used for other applications.

18 MEMBER BROWN: Without review.

19 CHAIR STETKAR: Without review, unless the
20 staff, SER, restricts it to a particular application.

21 Technical reports are strictly for this application
22 and only this application. So it's a nuance but it's
23 sort of the way the world works.

24 MEMBER BROWN: And how come the MELTAC
25 technical report is not a topical report since it has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 multiple applications?

2 CHAIR STETKAR: Because there's a long
3 history to this and MHI may want to speak to it. But
4 it's my understanding, they decided it was more
5 expedient for this particular licensing activity to not
6 try to have that reviewed as a topical report. It
7 originally was a topical report --

8 MR. SPRENGEL: Right.

9 CHAIR STETKAR: -- back --

10 MR. SPRENGEL: This is Ryan Sprengel, just
11 a, it's not the potential use of it but it's the intended
12 use. So right now we've accepted that the intended use
13 is specifically for US-APWR and that's the kind of the
14 genesis of the switch from topical to technical.

15 So we do agree that in general it could be
16 applied broader, but for right now we're focusing that
17 submittal and review for the reason stated. And that's
18 why we switched it to a technical report.

19 MEMBER BROWN: Did that have some bearing
20 on whether it was, what do you call it, a
21 commercial-grade --

22 MR. SPRENGEL: Dedication.

23 MEMBER BROWN: --dedication process vice
24 a formal acceptance of the qualification -

25 MR. SPRENGEL: No.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Did that play into this at
2 all or?

3 MR. SPRENGEL: No.

4 MEMBER BROWN: I expected that answer.

5 MR. SPRENGEL: And if the staff want to
6 contribute anything?

7 MEMBER BROWN: All right, I just was
8 curious.

9 MR. SPRENGEL: Okay.

10 MEMBER BROWN: Thank you.

11 CHAIR STETKAR: You're starting, Richard,
12 you're starting to get a flavor of this now.

13 MR. SAMPLES: Yes, I have to.

14 CHAIR STETKAR: Oh, the other thing is, if
15 you haven't been here before, interpret silence as
16 expediently go to the next slide.

17 MEMBER BROWN: If we want you to come back
18 we'll tell you. Excuse me, unless you're a gluten.

19 MR. SAMPLES: Okay, the instrumentation
20 and control systems of the US-APWR, they're the
21 Protection and Safety and Monitoring System or PSMS,
22 the Plant Control and Monitoring System or PCMS, the
23 Diverse Actuation System or DAS, the main control board
24 or as we'll refer to it at the later slides, the
25 Human-System Interface or HSI and the data communication

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 systems.

2 In this picture you see a picture of the
3 main control room of the US-APWR. This picture actually
4 comes from the US basic HSI simulator in Pittsburgh,
5 Pennsylvania.

6 Now the point of view you have is the view
7 of someone standing in the very back of the simulator.

8 MEMBER BLEY: We were up there several
9 years ago.

10 MEMBER BROWN: It was 2009 or something
11 like that.

12 MEMBER BLEY: Have there been any
13 substantial changes in the way the displays are setup
14 and the way it's organized?

15 MR. SCAROLA: No, there are not.

16 MR. SAMPLES: It's essentially the same now
17 for all of this. But what you see in the front of the
18 room is a large display panel. It shows different plant
19 parameters and indications on a ref or representation
20 of plant systems for easy comprehension of data.

21 Directly in front is the operator console
22 where the Reactor Operator will sit. On the left side
23 over here you have conventional switches. These are
24 part, the large display panel is part of the PCMS, by
25 the way.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The conventional switches here for system
2 level actuation of safety systems are part of the PSMS.

3 Over here on the right you have four VDUs, visual
4 display units. VDUs are touch computer screens. There
5 are four of these, one for each safety train.

6 In the middle you have different non-safety
7 VDUs. Alarm VDUs, operational VDUs, procedural VDUs.

8 MEMBER SHACK: Are those four the only
9 safety VDUs?

10 MR. SAMPLES: Yes. In the current design
11 these four you see here, we have four, but there are
12 also two other ones for, these basically do control.

13 We'll take about this later in the slide, but there's
14 four that do control and two you can monitor everything.

15 But we'll go into that more later.

16 MEMBER REMPE: So commands are entered, as
17 I think you said, with touch screens?

18 MR. SAMPLES: Yes.

19 MEMBER REMPE: I wasn't at your tour that
20 you had previously, but is that how you can enter
21 commands?

22 MR. SAMPLES: Yes, that's the normal way
23 from the operational VDU here in the middle. It's a
24 normal way the operator will control all the plant
25 systems.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER REMPE: And are there a feedback
2 that it says, is this what you really mean or how does
3 it work?

4 MR. SAMPLES: Well you have to select the
5 component. Say a valve you want to open or shut then
6 you have a signal and then, I'm kind of getting past
7 my information here --

8 MR. SCAROLA: There's a later slide where
9 we actually show the pop-ups. I think it would be better
10 --

11 MR. SAMPLES: Yes, we could probably
12 explain it better --

13 MEMBER REMPE: Again, if I had been on the
14 tour, this is for my time --

15 MEMBER BROWN: Yes, but my memory is --

16 MR. SCAROLA: But you're invited come
17 anytime in the future if you'd like. We'd love to have
18 --

19 MEMBER REMPE: Oh, I'd love another trip
20 right now. I'll keep that in mind.

21 MEMBER BROWN: The main operator position
22 is in the center?

23 MR. SAMPLES: Yes, it is. Right in the
24 center.

25 MEMBER BROWN: And so he doesn't really

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have to slide to the other side in order to perform any
2 of his operational control functions?

3 MR. SAMPLES: For normal operations he can
4 sit at one VDU and control everything in the plant.

5 MEMBER BROWN: Okay. When does he slide
6 over to the other ones? Is that going to be answered
7 at some point or does he have to or --

8 CHAIR STETKAR: This will come up.

9 MEMBER BROWN: All right. So you're
10 prepared to attack on --

11 CHAIR STETKAR: This will --

12 MEMBER BROWN: Okay. All right, I'll --

13 CHAIR STETKAR: We'll either hear about
14 this from MHI or the staff later.

15 MEMBER BROWN: Okay, all right.

16 MR. SAMPLES: We'll go into more depth
17 about how each of these work later --

18 MEMBER BROWN: Okay, I was just trying to
19 help Joy out here a little bit.

20 MR. SAMPLES: I think we've made it to the
21 back of the room here. On the left side the shift
22 technical advisors console, some more VDUs and the main
23 control room supervisor on the right. These again are
24 part of the PCMS.

25 Now over in the right, it's a little hard

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to see, that's the diverse HSI panel. That's were you
2 would do manual initiation of the diverse actuation
3 system components.

4 CHAIR STETKAR: Where's that, Richard,
5 because I don't think they had that in the mockup when
6 we were there?

7 MEMBER BLEY: Are you sure, I thought it
8 was there.

9 MR. SCAROLA: Hey, John, when you were
10 there we had a blank cabinet --

11 CHAIR STETKAR: That's right, you had a
12 blank cabinet.

13 (Crosstalk)

14 CHAIR STETKAR: Okay.

15 MR. SAMPLES: Take a look at the --

16 MR. SCAROLA: We actual have a cabinet that
17 had indicators and switches on it now.

18 MR. SAMPLES: It's kind of hidden in the
19 right, it's kind of like --

20 MR. SCAROLA: We have to update our
21 picture.

22 MR. SAMPLES: Behind the safety VDUs. So
23 if you're not used to seeing it, it maybe kind of hard
24 to see.

25 MEMBER BROWN: Now there's also a remote

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 shutdown room in addition to this, correct?

2 MR. SAMPLES: Yes.

3 MEMBER BROWN: Or is that's two different
4 things? The DAS is in the main control room if I
5 remember, with the other things you have to abandon ship
6 --

7 MR. SAMPLES: The diverse HSI panel, yes,
8 is in the main control room right over here. Here's
9 overall architecture of the I&C systems. The general
10 logic here is, on the top you have the HSI while
11 controller is on the bottom.

12 Okay, starting with the protection and
13 safety monitoring system on the left, this is a
14 four-train redundant fully digital system that, for all
15 safety related I&C. You can see we just talked about
16 the previous slide, the conventional push-buttons.

17 Conventional switches, excuse me, the
18 safety VDUs. Now you can also see the four trains, the
19 Reactor Protection System.

20 Down here it's showing the engineered
21 safety featured system, a safety logic system and behind
22 me there are four other trains. You see one train of
23 those down there.

24 Over on the right you have the plant control
25 and monitoring system. It's a redundant fully digital

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 system for all non-safety I&C.

2 The DAS is over here on the left. It's an
3 analog system. It's hardwired for diverse and
4 independent control.

5 You see the HSI system up here and the
6 largest wave panel, the operator console, supervisor
7 console, the Shift Technical Officer console.

8 Also shown on this picture are the data
9 communications systems. First of all the multi-drop
10 networks or the unit bus that connects all I&C.

11 Then you're showing one of four safety
12 buses. Also a multi-drop network.

13 Throughout here, a little bit hard to see
14 on this diagram, are point-to-point data links. And
15 also if you look, these black dotted lines show hardwired
16 connections directly, for instance, from direct
17 protection straight to the reactor trip breakers.

18 MEMBER BROWN: One question that I couldn't
19 get out of the DCD. The safety bus that's specified,
20 that is contained totally within that division?

21 MR. SAMPLES: Yes, sir.

22 MEMBER BROWN: That doesn't have access,
23 it only takes the internal for that division from its
24 RPSA and feeds off to ESFAS functions and all, okay.
25 So that's replicated --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SAMPLES: One for each --

2 MEMBER BROWN: -- from one and so it's
3 isolated, it has no other connections to the outside?
4 There's no inter-divisional communications or anything
5 like that on that safety bus?

6 MR. SAMPLES: Yes, sir.

7 MEMBER BROWN: Okay.

8 MR. SAMPLES: That is correct. Now the
9 protection safety monitoring system is implemented
10 using the Mitsubishi electric total vas control or
11 MELTAC.

12 MELTAC is a fully digital distributed
13 control system platform produced by Mitsubishi Electric
14 Company.

15 Now we use MELTAC to implement, not only
16 the controllers for the protection safety monitoring
17 system, but also the HSI for the protection safety
18 monitoring system, the controllers for the protection
19 plant controller monitoring system.

20 We use Mitsubishi real-time computers for
21 the various VDU computers. Such as alarm operational
22 and operating procedure of the large display computer,
23 alarm logic computer, the different ones you see here.

24 Also over here, just a little harder to see,
25 for the technical support center we also have operation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 VDUs and a large display and the computers that run them.

2 So those are actually apart of the PCMS. And all of
3 this here is also part of the PCMS or the HSI.

4 For the unit bus and the safety buses we
5 have multi-divisional, multi-bidirectional
6 communication. However, we do transmit one-way-only
7 information from the unit bus through the unit
8 management computer out to the station bus.

9 And I'll talk about that for a moment here.

10 For data flow, again, it's one direction data flow to
11 external networks.

12 So we give data to the station bus, the
13 station provides information to plant corporate
14 personnel to the emergency operating facility to the
15 emergency response data system. Receives its
16 information from the data communication systems via the
17 unit management computer.

18 The unit management computer provides a
19 firewall interface, allows only outbound communication.

20 There's no other connections from those data
21 communications systems of the control systems to any
22 outside network.

23 MEMBER BROWN: Are you going to talk about
24 that firewall now or later.

25 MR. SAMPLES: We have kind of a surprise

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for you in the next slide.

2 MEMBER BROWN: Okay.

3 MR. SAMPLES: I think you'll like.

4 CHAIR STETKAR: Charlie likes surprises.

5 MR. SAMPLES: Let's take a picture of this
6 and, well you're not going to see this in DCD Rev 3,
7 we have done it yet, but we're going to add a hardware
8 based unidirectional device to this system.

9 If you see the data communication system,
10 unit management computer station bus, right there
11 between the unit management computer and the station
12 bus we're going to add this hardware device.

13 MEMBER BROWN: It's going to be on the
14 output of the unit management computer as opposed to,
15 I'm not arguing whether ones better than the other, I'm
16 just saying it's on the output not the input from the
17 unit --

18 MR. SAMPLES: Again, you see it right here,
19 this big green box, the big red arrow, here's the current
20 unit management computer, here's the station bus, we're
21 putting it right in between. Now this device is not
22 going to rely on any kind of software to ensure
23 unidirectional data flow.

24 You have design concept, you know, kind of
25 optical fiber with a transmitter on one side and a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 receiver on the other. And you can only transmit data
2 one way through that optical fiber. So that's what
3 we've used to ensure one-way data flow.

4 MEMBER BLEY: And that will make the next
5 revision within DCD?

6 MR. SAMPLES: We're planing for DCD Rev 4.

7 MEMBER BLEY: Okay.

8 MR. SAMPLES: So again, this is not in yet
9 we're adding this and we should have this to you by DCD
10 Rev 4.

11 CHAIR STETKAR: Just out of curiosity,
12 what's the schedule on Rev 4?

13 MR. SPRENGEL: It will be August.

14 CHAIR STETKAR: August, thanks. I forgot.

15 MEMBER BROWN: When you issue that, will
16 there be some identification to the changes? I mean
17 I know I'm going to want to look at it, but I don't want
18 to try to have to read the whole thing, divine what has,
19 word by word what's been changed.

20 I've seen a revision blocks in some of them,
21 but they weren't real crisp in terms of what was changed.

22 I'm not talking about the nits and lice, I'm only
23 talking about the fundamental design features that
24 change. For instance, this.

25 MR. SPRENGEL: The changes are identified.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And I guess to go, to give a little extra detail, in
2 the actual DC revision that's submitted, it will just
3 be a rev bar identification.

4 But separately with changes that are not
5 submitted in kind of complete markups with RAI
6 responses, we also submit tracking reports. And that
7 includes a, like a red-line strike-out version. It
8 gives a little more detail in terms of specifically what
9 words are being removed and what are being added.

10 MEMBER BROWN: Yes, sometimes words make
11 a difference.

12 MR. SPRENGEL: Agreed.

13 MEMBER BROWN: Even with the pictures.

14 MR. SPRENGEL: Usually they do. So
15 there's a tracking report that will contain this and
16 then there will also be the DC revision. But that will
17 just have the rev bars indicating what portions are,
18 what areas are changing but not the specific details.

19 MEMBER BROWN: And they're rev bars from
20 Rev 2 to Rev 3 will have been canned by then, right?

21 MR. SPRENGEL: That's correct.

22 MEMBER BROWN: They will not be there,
23 okay.

24 MR. SPRENGEL: That's correct.

25 MEMBER BLEY: So before you leave that, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 see another one of those boxes with the big red arrow,
2 is that another one-way hardware device?

3 MR. SPRENGEL: Yes.

4 MR. SAMPLES: Yes.

5 MEMBER BLEY: Okay. Good, thank you.

6 MEMBER BROWN: Yes, so let me make sure I,
7 you bet me to the punch, Dennis thank you. So you're
8 really kind of, the way I look at this is kind of a
9 double-ended set of backstops.

10 The station bus is a plant station, I
11 presume that's a generating station?

12 MR. SAMPLES: It is a plant IT network.

13 MEMBER BROWN: Okay. And the stuff that
14 runs off the folks who are uncontrolled from an
15 information technology standpoint, the corporate LAN,
16 et cetera, will be further isolated, but yet the EOF
17 and other stuff will have, just be fed right off the
18 station bus?

19 MEMBER BLEY: Maybe uncontrolled is not the
20 right word.

21 MEMBER BROWN: Not controlled --

22 MEMBER BLEY: Well in any case, all that
23 stuff is isolated.

24 MEMBER BROWN: Yes, well my point being is
25 it's the second red box. Downstream of that is where

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the internet gets connected in someplace.

2 MEMBER BLEY: Well no, even further then
3 that.

4 MEMBER BROWN: I understand that you go to
5 the corporate --

6 MEMBER BLEY: I just didn't want our record
7 to say that's an open access box hooked to the internet.

8 MEMBER BROWN: You didn't like my
9 phraseology, but that's okay.

10 MEMBER BLEY: I didn't like the concept.
11 But go ahead, Charlie.

12 MEMBER BROWN: It's just that EOF and ER,
13 what's the ERDS anyway? Emergency Response --

14 MR. SAMPLES: Emergency Response Data
15 System.

16 MEMBER BROWN: -- Data System, okay.

17 MR. SAMPLES: Yes, sir.

18 MEMBER BROWN: Is that transferred to the
19 NRC via the internet?

20 MR. SCAROLA: No.

21 MEMBER BROWN: Or is that via a dedicated
22 --

23 MR. SCAROLA: It is typically a dedicated
24 interface.

25 MEMBER BROWN: Dedicated, okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCAROLA: I misspoke.

2 MEMBER BROWN: Okay, I had know idea what
3 those look like, but okay.

4 CHAIR STETKAR: Richard, the --

5 MR. SAMPLES: Yes, sir.

6 CHAIR STETKAR: The station bus, you
7 characterized it as a plant system. And I know the EOF
8 is shared among all four units, if I am correct? I'm
9 looking over to Luminant, but I believe I read that the
10 EOF was going to be shared among all four units.

11 Which means there will be communications,
12 at least in the simple cartoon, on the station bus coming
13 over from Units 1 and 2. Which in principle have the
14 same practice, communicate with the outside world.

15 Are there protections, similar protections
16 installed over on the Unit 1 and 2 side?

17 I know that the Unit 3 and 4 folks can't
18 really control that in terms of the design and licensing
19 of Units 3 and 4, but it's another potential
20 communications pathway. Unless there's an actual break
21 and you have a Unit 3, 4 station bus and a Unit 1, 2
22 station bus.

23 So do you have that level of information
24 or is that something we should ask --

25 MR. SAMPLES: I don't think we have --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SPRENGEL: I guess I would request that
2 we delay that discussion.

3 CHAIR STETKAR: Okay.

4 MR. SPRENGEL: Until the COLA portion.

5 CHAIR STETKAR: Okay.

6 MR. SCAROLA: It's important to understand
7 that the scope of the US-APWR DCD ends at that picture
8 that you see right there.

9 CHAIR STETKAR: Understand.

10 MR. SCAROLA: So the responsibility is, we
11 define the information that goes to the station bus.

12 CHAIR STETKAR: Understand.

13 MR. SCAROLA: The design of the EOF is a
14 COLA item.

15 CHAIR STETKAR: Is a COLA, okay, thanks.
16 We'll hold it till then. Don, be ready.

17 MR. SAMPLES: Okay, now we'll start
18 discussing the safety related I&C systems, the
19 protection and safety monitoring system. And these are
20 the topics we will cover.

21 Now the PSMS consist of five digital
22 subsystems. These are the reactor protection system
23 or RPS, the engineered safety featured actuation system
24 or ESFAs, the safety logic system or SLS, and the
25 communication subsystem of the PSMS and also the safety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 related portion of the human-system interface system.

2 Now all safety, I&C safety functions of the
3 US-APWR are implementing using either one or more of
4 these subsystems. Here you see a figure that shows
5 configuration of the reactor protection system.

6 You see first of all we have four different
7 trains of reactor protection system. Within each train
8 we have two different groups.

9 And we'll explain why we have those two
10 different groups later. But first we'll just walk
11 through and show you how signals are generated for
12 protection actions in the RPS.

13 Starting with the sensor on the left, we
14 sense a condition to the pressurizer pressure, high or
15 low. Goes in through one of the groups, there's analog
16 signals converted to digital, they send signal process.

17 Here in the middle we have a bistable that
18 senses that we're exceeding a set point. If we do we
19 get a signal. This signal is combined with signals from
20 the other three trains over here, two-of-four logic.

21 This is one parameter of being monitoring,
22 there's several others being monitored. So here and
23 over here several others are being also combined
24 together.

25 Then through digital output through the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 hardwire connections straight down to the reactor trip
2 breakers for a trip. That's the automatic path. Now
3 --

4 MEMBER BROWN: Before you leave that
5 definition I wanted to make sure I understood.

6 MR. SAMPLES: Yes.

7 MEMBER BROWN: Right in that CPU Group 1
8 Box.

9 MR. SAMPLES: This one?

10 MEMBER BROWN: There's two-out-of-four
11 showing the stuff coming from the other trains and
12 there's a little dotted line to the two-out-of-four,
13 and the way I interpreted that there's, this is a
14 redundant parallel, redundant controllers in the CPU,
15 Group 1 and Group 2.

16 I mean you got the Group 1 and Group 2 stuff.
17 Two different controllers, right?

18 MR. SCAROLA: But they're not redundant.

19 MEMBER BROWN: I understand they've got
20 different parameters that they monitor.

21 MR. SCAROLA: They have different
22 parameters.

23 MEMBER BROWN: Functionally they are
24 redundant, I understand. You all refer, if you look
25 at the MELTAC report it says, redundant parallel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 controllers configuration.

2 My understanding of that is the Group 1 one
3 has, and you listed them in one of your tables, a series
4 of protection or plant parameters that you monitor.
5 All of those, that one sensor that you show coming in
6 is represented by, there will be nine, for Group 1 there
7 will be eight or nine other ones or whatever the right
8 number is.

9 MR. SCAROLA: Yes, there's a couple of
10 groups.

11 MEMBER BROWN: For Group 2 there will be
12 another seven or eight, whatever that is, to repopulate
13 the remaining of the parameters.

14 MR. SCAROLA: Different parameters.

15 MEMBER BROWN: Different parameters. And
16 then that's replicate, that functionality is replicated
17 in each other train?

18 MR. SCAROLA: Yes.

19 MR. SAMPLES: Correct.

20 MEMBER BROWN: Okay. So there's multiple,
21 within each group there's multiple two-out-of-four of
22 like functions in each of those. And that's to separate
23 on a functional basis, the protection parameters. It
24 gives you some functional diversity.

25 MR. SAMPLES: That's correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Are you planning to discuss
2 that in --

3 MR. SCAROLA: We have a later slide about
4 --

5 CHAIR STETKAR: You do, okay, thanks.

6 MEMBER BROWN: And the thing to note is that
7 out of either Group 1 or Group 2, you come down to that
8 little circle with a flat bar on it, that's a Or gate.
9 And so either one of those producing a trip, sends a
10 trip down to the reactor trip breaker functionalities?

11 MR. SAMPLES: That is correct.

12 MEMBER BROWN: Okay. And that's
13 replicated also? Okay, thank you.

14 MR. SAMPLES: They're also --

15 MEMBER BROWN: Just want to make sure I
16 understood.

17 MR. SAMPLES: Yes, that's correct. I
18 think you understand it. There's also a shunt here on
19 the bottom, the system level conventional switch is on
20 the far left side of the reactor operator console in
21 the main control room where you can manually initiate
22 with those conventional switches, trip the reactor
23 breaker that way.

24 MEMBER BROWN: The detail of that was not
25 shown. If I actually have it, do they actually, presume

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 these breakers have undervoltage or shunt trip coils
2 or both? I guess they have both?

3 MR. SAMPLES: Both.

4 MEMBER BROWN: Do they --

5 MR. SCAROLA: The detail --

6 MEMBER BROWN: -- note switches, pardon?

7 MR. SCAROLA: I'm sorry, the detail is
8 actually in one of the technical reports. 07004,
9 there's a figure that shows the detail of the interface
10 to the shunt trip and the undercurrent.

11 MEMBER BROWN: Oh, I missed that. Okay,
12 I apologize for that. Seven-hundred pages later I was
13 starting to phase out.

14 MEMBER BLEY: Is that all you read?

15 MR. SCAROLA: Are you --

16 MEMBER BLEY: I had my eyes open that long.

17 MR. SCAROLA: And it's hardwired, it's
18 completely hardwired.

19 MEMBER BROWN: Yes, that was my next
20 question, my memory was that you all said it was and
21 that's why I wanted to see if that functionality was
22 stated. And it is in 04 so that's fine.

23 MR. SCAROLA: There's a figure that shows
24 the details of that and how it's tested.

25 MEMBER BROWN: Okay, thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Are you, I haven't had a
2 chance to study all of your slides because I was reading
3 702 pages.

4 MEMBER BROWN: He beats me every time.

5 CHAIR STETKAR: Are you going to talk, in
6 any of your slides anymore about the so called
7 conventional switches and the hardwired connections?
8 Or is this an appropriate place to ask you about things?

9 MR. SCAROLA: Well this is the appropriate
10 place to ask about the switches for reactor trip. Later
11 we will talk about the switches for the engineered safety
12 features actuation.

13 CHAIR STETKAR: I'll wait for that, thank
14 you.

15 MR. SAMPLES: Yes, this showed you one way
16 to manually trip the reactor breakers. The other way
17 is through the safety VDUs on the right side of the
18 operator console.

19 So there's actually soft switches on the
20 safety VDUs. Push those, a signal will be transmitted
21 through a safety VDU processor down on a safety bus.

22 For instance, say Safety Bus A since we're talking about
23 Train A, into the two different groups inside Train A.

24 Then you get reactor trip signal that way.

25 Also, output down in through straight to the hardware

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 connection, to the reactor trip breakers.

2 But the reactor trip breakers themselves,
3 these range from four different divisions such that you
4 trip any two breakers you'll get a reactor trip. So
5 basically, two of these different divisions give you
6 a trip.

7 Okay, hold on. For some monitor variables
8 --

9 MEMBER BROWN: Oh, one other question
10 before you run off. I apologize.

11 MR. SAMPLES: Okay.

12 MEMBER BROWN: In your legend you talk
13 about E/O, which are electrical to optical convertors.

14 MR. SAMPLES: Yes.

15 MEMBER BROWN: In your diagrams you
16 frequently have the words, D/O, and that's not defined
17 anywhere. And so I took it upon myself, someplace you
18 didn't, a D/O was a digital output and I didn't know
19 whether D/O was equal or was that with digital to optical
20 or --

21 MR. SCAROLA: Digital output.

22 MEMBER BROWN: It's the same, okay. Have
23 to just, small --

24 MR. SCAROLA: We'll fix that in Rev 4.

25 MEMBER BROWN: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SAMPLES: Now for some parameters we
2 measure if we exceed the set point. We don't just want
3 a reactor trip, we may want it, we need to generate a
4 signal to initiate the emergency safety features.

5 So the signal path through the sensor,
6 through the analog to digital, through the bistable,
7 through the combining of logic. We went right for the
8 reactor trip, now we go left through the electrical
9 optical output down through the engineering safety
10 feature system. Now --

11 MEMBER BROWN: Before you shift, go back
12 again. From your first picture of the overall, you show
13 the diverse actuation system output for reactor trip
14 functions going and tripping the M/G set.

15 But yet there is no connection via the
16 diverse system, the automatic part of the diverse
17 system, to tripping the reactor trip breakers. At least
18 the way the dotted lines show that. Is that correct?

19 MR. SAMPLES: Correct.

20 MEMBER BROWN: So you use a different
21 functionality for, and instead of doing both you just
22 do one?

23 MR. SCAROLA: Correct.

24 MEMBER BROWN: Is there some thought
25 process of why you do just one of them vice sending the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 signals off to the screen breakers as well?

2 MR. SCAROLA: 10 CFR 50.62 says, the
3 reactor trip must be completely diverse. Including the
4 hardware, not just the software.

5 MEMBER BROWN: Well there's no software in
6 the DAS.

7 MR. SCAROLA: Right. But the hardware
8 can't be the same, so we can't use the reactor trip
9 breakers. We have to have a diverse mechanism for
10 tripping. Completely diverse. So that's why we use
11 the M/G sets.

12 MR. SAMPLES: So we trip, the motor
13 generate sets that feed director trip breakers.

14 MEMBER BROWN: Well the director trip
15 breakers are not exactly software. No, but, so.

16 MR. SCAROLA: So that's my point. Is that
17 in the old rule for ATWS, there was no distinction
18 between hardware and software. It just requires
19 complete diversity. Including all the hardware.

20 There are some exceptions. That the ATWS
21 rule allows us to use the same sensors, the same power
22 supplies. But all the active devices must be completely
23 diverse.

24 So we don't use the breakers for the backup
25 for the DAS. We use the M/G set tripping. It's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 completely diverse.

2 MEMBER BROWN: Does that meet your analysis
3 requirement, only M/G sets require that they take, the
4 electromagnetic fields require sometimes to collapse
5 and all that type of stuff.

6 MR. SCAROLA: We trip the outputs, not the
7 motor side.

8 MEMBER BROWN: Not the motor side, okay.

9 MR. SCAROLA: We trip the generator side.

10 MEMBER BROWN: All right, I just wanted to
11 understand your thought process.

12 MR. SAMPLES: So we have the signal for the
13 engineered safety features leaving the reactor
14 protection system, going into ESFAS and the SLS. So
15 basically we saw, down here we see four trains to the
16 RPS.

17 And it's also, we're showing only one train,
18 ESFAS and SLS here. There are four of them, there's
19 four different ones.

20 So the automatic signal, again, it comes
21 from the reactor protection system, goes into ESF
22 Actuation System. Inside the ESF there's two different
23 subsystems. The ESF Subsystem 1 and 2.

24 These are identical modules all work the
25 same way, work in parallel. If either one detects a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 condition where you need to actuate engineered safety
2 features, it will transmit it to safety logic system
3 which is on component level actuation of pumps, valves,
4 different components of the plant.

5 Again, there is two different subsystems
6 inside SLS. Now what happens is, inside ESFAS,
7 Subsystem 1 will send itself a signal to Subsystem 1
8 inside the SLS. Subsystem 2 to Subsystem 2. They
9 operate in parallel.

10 Then the signals are combined at the bottom
11 and then sent to the component that needs to be actuated.

12 MEMBER BROWN: But only then require a
13 coincidence of the two subsystems in the SLS. All your
14 coincidence is done up in the CPU subsystems of the
15 ESFAS, ESF functionality, similar functionality that
16 you have in the reactor protection system?

17 MR. SAMPLES: It's just voting logic inside
18 the systems and then down here it's combined --

19 MEMBER BROWN: Yes, the SLS is a hard
20 combination of logic. Is it FPGAs or is it, it's not
21 microprocessor based?

22 MR. SCAROLA: No, it is microprocessor
23 based.

24 MEMBER BROWN: Oh it is? The SLS part is?

25 MR. SCAROLA: It's the same MELTAC --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Oh, yes, I'm sorry. I see
2 that, too late.

3 MR. SCAROLA: The part that is hardwired,
4 and we'll talk about later, is the final output in the
5 PIF module. We'll talk about that later.

6 MEMBER BROWN: All right, thank you.

7 MR. SCAROLA: There very bottom here,
8 that's hardwired.

9 MR. SAMPLES: Okay, that's the automatic
10 signal for ESFAS.

11 MEMBER BROWN: Before you leave, what's a
12 Group 2, 3, out to N? You show these multiple groups
13 but they're all still on the same safety bus.

14 MR. SAMPLES: Different groups and safety
15 logic system grouped together to control different
16 components. Also discuss that a little bit later.

17 MEMBER BROWN: Okay.

18 MR. SCAROLA: There might be up to 200
19 components in a safety train.

20 MEMBER BROWN: I understand that.

21 MR. SCAROLA: Maybe even 300. I don't even
22 know what the exact number is, so we --

23 MEMBER BROWN: Okay so what that is, is --

24 MR. SCAROLA: -- distribute them.

25 MEMBER BROWN: Okay. So you don't use the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 output of priority of logic to do that, you've got to
2 distribute it amongst the other functions to ensure that
3 you have, I don't know, to ensure I guess, just to pick
4 up the power.

5 MR. SCAROLA: Well there are two
6 constraints. There is a response-time constraint, so
7 we want to make sure that one controller group pair is
8 not overloaded and running in excessive response-time
9 because we have to trip these things in 300 milliseconds,
10 or get them actuated in 300 milliseconds.

11 And then you have the issue of functional
12 distribution to make sure that if one group were to
13 spuriously actuate, we wouldn't get an unusual event
14 in the plant that's not bounded by the safety analysis.

15 MEMBER BROWN: All right.

16 MR. SCAROLA: So we distribute for two
17 reasons. The performance reason and safety reason.

18 MEMBER BROWN: Okay, thank you.

19 CHAIR STETKAR: You said you're going to
20 talk a little bit more about that distribution later
21 or?

22 MR. SCAROLA: Not that, we don't have any
23 more slides on that distribution. What I pointed out
24 before was the RPFs distribution.

25 CHAIR STETKAR: Okay, let me ask you then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a question I had about the distribution. I don't want
2 to go into individual components, but there is a section
3 of the DCD, I don't remember whether it's a DCD or
4 technical report, it doesn't make any difference, that
5 talks about, a bit about the distribution in particular
6 to prevent spurious actuation.

7 And I'll use one particular function as an
8 example. There's a list of, I don't know, seven or eight
9 different functions that are addressed. One function,
10 for example, main steam insulation.

11 As I understand it, and I might be wrong,
12 the main steam isolation valves receive signals to close
13 from SLS Trains A and D.

14 MR. SAMPLES: Correct.

15 CHAIR STETKAR: And the description in the
16 DCD, there's a little cartoon, if you will, shows that
17 external to what we can see here, you require a signal
18 from both SLS A and SLS D to close the MSIVs?

19 MR. SAMPLES: No.

20 MR. SCAROLA: No, either one.

21 CHAIR STETKAR: Okay.

22 MR. SCAROLA: Either A or D.

23 CHAIR STETKAR: That's what I was curious
24 about. Because I looked at, there's a little logic
25 drawing in the DCD, it might be in the technical report

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of the DCD that shows A and D out to the MSIVs.

2 MR. SCAROLA: Right.

3 CHAIR STETKAR: And I was given the
4 impression that that and logic was somehow out, was out
5 in the plant.

6 MR. SCAROLA: The A and D trains are
7 completely independent --

8 CHAIR STETKAR: Yes.

9 MR. SCAROLA: -- from both an I&C signal
10 path right to the different solenoids. There are two
11 sets of solenoids on those valves.

12 CHAIR STETKAR: Yes.

13 MR. SCAROLA: A solenoids and D solenoids.

14 So everything is completely independent and the
15 actuation of either the A solenoids or the Ds will result
16 in MSIV closure.

17 CHAIR STETKAR: That's what I wanted to
18 hear.

19 MR. SCAROLA: Correct.

20 CHAIR STETKAR: Okay.

21 MR. SCAROLA: Now --

22 CHAIR STETKAR: Now how, if that's the
23 case, what is all this stuff about preventing spurious
24 actuation from a signal from A or D?

25 MR. SCAROLA: You can't prevent spurious

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 actuation.

2 CHAIR STETKAR: Okay.

3 MR. SCAROLA: What you can do is
4 accommodate spurious actuation. So one of our design
5 basis is we don't want any signal failure to trip the
6 plant.

7 CHAIR STETKAR: Right.

8 MR. SCAROLA: Now since A or D can shut
9 those valves, you could say, well then if you have an
10 A spurious failure, you can get a plant trip. So what
11 we do to prevent that, the MSIVs are actually controlled
12 from two groups in this picture that you see here. And
13 the coincidence of both groups has to happen before the
14 A train to close those valves.

15 CHAIR STETKAR: Okay.

16 MR. SCAROLA: And then A signal has a two
17 out of two coincidence from both groups.

18 CHAIR STETKAR: Oh, okay. Okay, I got it.
19 Thank you.

20 MR. SCAROLA: That's how we deal with
21 preventing spurious plant trip. It's not a safety
22 issue, has nothing to do with safety --

23 CHAIR STETKAR: No, no, your right. I was
24 just trying to get straight in my mind about this
25 prevention of single failures and how it was actually

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 implemented out to the valve.

2 MR. SCAROLA: There's a whole technical
3 report entitled SLS Functional Assignments that gets
4 into all the philosophy behind the distribution of the
5 groups. And the few components, like MSIVs, that we
6 actually control from two groups.

7 CHAIR STETKAR: I didn't read the whole --

8 MR. SCAROLA: If there's a bunch of,
9 there's a handful of components that we do to double
10 control.

11 CHAIR STETKAR: We have it, it's
12 MUAP-09020.

13 MR. SCAROLA: Correct.

14 CHAIR STETKAR: I read part of it, I didn't
15 read every word. Thank you.

16 MEMBER BLEY: Ah, yes, okay.

17 MR. SAMPLES: Well we just talked about how
18 we generate automatic signals for engineered safety
19 features actuation. Several different ways to manually
20 initiate ESFAS.

21 First of all, from the system of a
22 conventional switches on the operator console from the
23 main control room. The ones on the left side, there's
24 a switch hardwired directly to the DSF systems. Push
25 the switch you initiate and then the signal through there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 is the same as fully automatic.

2 MEMBER BROWN: Does the switch go to both
3 subsystems within that train?

4 MR. SCAROLA: Yes.

5 MR. SAMPLES: Yes.

6 MEMBER BROWN: Logically it should, I just
7 was making you read up to that push. One switch, okay.

8 MR. SAMPLES: One switch.

9 MR. SCAROLA: There are two contacts on one
10 switch.

11 MEMBER BROWN: Okay.

12 MR. SAMPLES: Now the second way is from
13 down the safety VDUs in the main control room. And say
14 we push a soft switch on the safety VDUs, it will go
15 through a safe VDU processors down to the safety bus
16 and to the ESFS subsystems and then actuate a signal
17 that way.

18 Okay. Now the third way is from the
19 operation VDUs in the middle of director console. Go
20 through, push a soft switch again, go through VDU
21 computer on to the unit bus and then down through the
22 communication subsystem of the PSMS, onto the safety
23 bus and then from there it's the same as it was from
24 the safety VDU to the ESFS subsystems down to the SLS
25 to the components.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 You could also initiate ESFS from the remote
2 shutdown console. Again, through safety VDUs,
3 processor down through safety bus onto ESFS subsystems.

4 MR. SCAROLA: I want to point out, before
5 you asked about sliding, you know the operator sliding
6 his chair left and right, this is the first place where
7 we show that the non-safety operational VDUs have the
8 ability to control all the safety components in the
9 plant. So there is no requirement for any kind of
10 chair-sliding at all.

11 And well hit this again in several places
12 in the presentation. This is the first one where we
13 show it.

14 MEMBER BROWN: You also show the remote
15 shutdown console, a line going over. Which way does
16 that line go from the operational VDUs?

17 MR. SAMPLES: Well the signal starts from
18 the remote shutdown --

19 MEMBER BROWN: So there's two paths. If
20 you operate something from the remote shutdown, it will
21 try two things. One going back to the operational VDU,
22 that's what the impression is, as well as going to the
23 safety VDU processors.

24 MR. SCAROLA: The figure is not perfectly
25 clear. Those words remote shutdown console, are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 intended to simply represent the same thing that's in
2 the main control room.

3 So at the remote shutdown room, we have
4 safety VDUs and we have non-safety operational VDUs.

5 So it's the same signal paths from separate VDUS.

6 So that picture is trying to depict that
7 there are safety VDUs in the main control room and also
8 at the remote shutdown room. We have operational VDUs
9 in the main control room and also in the remote shutdown
10 room. I know the picture is not perfect.

11 MEMBER BROWN: You ought to delete the
12 line. They mean different things. I was totally
13 confused on that. Go ahead.

14 MR. SAMPLES: Essentially, just to
15 reiterate what Ken just said, the remote shutdown room,
16 safety VDU, you can go through the same path we did from
17 the safety VDU in the main control room. And also
18 there's operational VDUs to go through the same path
19 you did through operational VDUs in the main control
20 room to initiate engineering safety features.

21 CHAIR STETKAR: I was writing and I can't
22 write and listen at the same time. Did you talk about
23 the conventual switches?

24 MR. SAMPLES: Yes, I did.

25 CHAIR STETKAR: You did, okay. Like I just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 said, I can't listen and write at the same time. I had
2 a question, why in the reactor trip logic you pay a lot
3 of attention to making sure that those conventional
4 switches go directly to the reactor trip breakers that
5 they're hardwired to the endstate.

6 In ESFAS, they only bypass the reactor trip
7 logic. Those signals are still processed through a heck
8 of a lot of software before they finally get to starting
9 an EFW pump, for example. Why is that? I mean there
10 must be a reason.

11 MR. SCAROLA: Right. They are several
12 reasons. The simplest one to understand is reactor
13 trip.

14 The switch has to go to two breakers.
15 Engineered safety feature, the signal for the A train
16 has to go maybe 50 components for safety injection.
17 Another 30 components for containment isolation. So
18 there is a much broader distribution of those signals.

19 The second reason is, all of those
20 components have interlocks in the SLS for things like
21 equipment protection. So all those interlocks still
22 remain active. You don't want to bypass all those
23 component-level interlocking.

24 MEMBER BROWN: Also meaning that it's a
25 sequence here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SCAROLA: In sequence. The last
2 reason is, when you initiate safety injection, since
3 there are some many components, including HVAC things
4 that have to align, chillers, ventilating, there's a
5 lot of stuff, things have to be sequenced. They can't
6 just go.

7 And all the sequencing logic is in the ESFAS
8 boxes that you see there. So there's a lot of different
9 reasons why we can't just go right to the final
10 components.

11 CHAIR STETKAR: Good answer.

12 MEMBER BROWN: But, okay, I understand your
13 point, but except if I look at the diverse actuation
14 system it shows going right into the priority logic in
15 the I/O as opposed to up into all the sequencing logic.

16 So at some point people are just actuating
17 stuff based on their knowledge of when things ought to
18 be sequenced. Is that, that's the presumption I would,
19 or the assumption that I would make.

20 And I'm not disagreeing with, I'm just
21 saying that's there's a nuance on your comment relative
22 to why the other things are done, that at some point
23 you've got to have human intervention, via the DAS, and
24 there you're using the priority logic directly and
25 therefore the mind, people have to determine what goes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 on and when.

2 MR. SCAROLA: But the DAS actuates a
3 fraction of the components.

4 MEMBER BROWN: I understand that, but it's
5 just a difference. I'm not disagreeing with it.

6 MR. SCAROLA: It's kind of a significant
7 difference because then it doesn't require sequencing
8 and we just don't have some much signal distribution.

9 MEMBER BROWN: Okay, I got it. It's just
10 a difference relative to the discussion.

11 MR. SCAROLA: It's clearly a difference.
12 Realize the purpose of manual actuation. This thing
13 that bypasses the RPS. It's really not intended to be
14 a backup function. Because we have four trains.

15 The purpose of manual actuation is to give
16 the operators the ability to take preemptive action so
17 that they can initiate the same functions that would
18 have been initiated by the reactor protection system.

19 We really do not take credit for it as any kind of a
20 backup.

21 DAS is backup. DAS is clearly a backup.

22 This is really, and it's not intended by IEEE-603 to
23 be a backup either. It's a preemptive initiation.

24 MEMBER SHACK: Just on this operational
25 VDU, I thought there was a one way communication from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the safety systems to the non-safety systems? But
2 somehow now I've got a two-way communication going on.

3 MR. SCAROLA: Well spend a lot of time
4 talking about that. There is definitely two-way
5 communication, we'll explain how we maintain
6 communication independence and the benefits of that
7 two-way communication.

8 MEMBER BROWN: It's also why that data
9 diode is important from the external sources.

10 CHAIR STETKAR: Ken, you're a great
11 straight man. In passing, when I'm listening I actually
12 pick up on words. You mentioned that one of the reasons
13 that you need to inject the manual signals where you
14 do is that the SLS contains all the equipment protective
15 signals.

16 MR. SCAROLA: Not all, some. Some, not
17 all.

18 CHAIR STETKAR: Okay. I'll use the word
19 some then, you didn't use the word all you said,
20 whatever. The question I had, and I don't know how these
21 things work, is suppose that I have a motor overload
22 or a torque switch or thermal overload device or
23 something like that.

24 Do those protective signals block
25 everything coming out of the SLS? In other words, do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the equipment protection signals override the output
2 of the PIF?

3 MR. SCAROLA: In general, yes.

4 CHAIR STETKAR: Okay.

5 MR. SCAROLA: For example, on a
6 motor-operated valve, torque switches stop the valve
7 regardless of any demand from the SLS. Those are
8 outside the SLS. It varies depending upon the
9 protective interlock as to how significant that
10 interlock is.

11 For example, we bypass thermal overloads
12 on motors by the engineered, when you have an accident
13 signal, the thermal overloads are bypassed.

14 CHAIR STETKAR: So there's a smart logic
15 in the SLS that looks at particulate protective --

16 MR. SCAROLA: Well some functions are in
17 the SLS and some functions are actually in the motor
18 control centers.

19 CHAIR STETKAR: Yes.

20 MR. SCAROLA: For example, torque switches
21 on motor-operated valves are in the motor control, not
22 in the SLS.

23 CHAIR STETKAR: Well often thermal
24 overloads are also. That's why I was asking.

25 MR. SCAROLA: Indeed they are. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 because they need to be bypassed, you feed them back
2 up after they get feed back.

3 CHAIR STETKAR: Okay.

4 MR. SCAROLA: It depends on the protective
5 type.

6 CHAIR STETKAR: Okay.

7 MR. SCAROLA: For example, in switchgear,
8 there's a lot of fault protection in the switchgear.
9 Phase imbalances, overload faults, those are all still
10 in the switchgear.

11 CHAIR STETKAR: Yes.

12 MR. SCAROLA: Because --

13 CHAIR STETKAR: But for example, on a pump,
14 I don't know how the pumps are protected, but some
15 sophisticated pumps have high winding temperature or
16 high lube oil temperature or bearing vibration or you
17 name it.

18 MR. SCAROLA: Those things are typically
19 brought back into the SLS. Because we say, well even
20 though we have a high winding, we're going to run that
21 pump.

22 CHAIR STETKAR: Yes, okay.

23 MR. SCAROLA: A high winding temperature
24 or a high thermal overload. Things that you know that
25 the equipment can't run if that happens.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR STETKAR: I didn't look, is there
2 something anywhere that describes which of things are
3 bypassed and which are, remain enabled? I didn't
4 particularly go look for it, so.

5 MR. SCAROLA: There is an MHI
6 documentation. There's something we call a Component
7 Control Design Guide that identifies.

8 MR. TAKASHIMA: There's a discussion in
9 Chapter 8.

10 MR. SCAROLA: In Chapter 8?

11 MR. TAKASHIMA: In Chapter 8.

12 MR. SCAROLA: Okay. I'm not sure.

13 CHAIR STETKAR: I read Chapter 8.

14 MR. SCAROLA: I think the detail you're
15 looking for may not be in Chapter 8.

16 CHAIR STETKAR: No, it's not.

17 MR. SCAROLA: But no, it is --

18 CHAIR STETKAR: Chapter 8 does give you the
19 protection signals, for example, for circuit breakers
20 and things. But it doesn't give this level of detail
21 in terms of which ones are bypassed on, which actuation
22 signals.

23 MR. SCAROLA: Correct.

24 CHAIR STETKAR: I mean it will tell you
25 phase differential over current, you know, all of that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 kind of stuff for the electrical protection, but not
2 what I'm asking about. Okay, thanks.

3 MR. SAMPLES: Now the PSMS interfaces with
4 safety sensors and safety actuators, such as valves and
5 pumps, PSMS interfaces with non-safety I&C systems.
6 First of all, the non-safety portion of the human system
7 interface system, reactor control system, turbine
8 protection system, the balance of plant control system
9 and the diverse actuation system.

10 These interfaces from the PSMS to the
11 non-safety systems, they don't negatively impact the
12 safety functions of the PSMS do to the PSMS independence.

13 And as we progress through this presentation, we'll
14 talk about how these interfaces enhance the safety
15 function.

16 MEMBER BLEY: This isn't really a safety
17 issue, but the discussion you and John just had leaves
18 me wondering what are the folks in the plant going to
19 have? Will they have logic diagrams in detail on all
20 of this stuff so that they can troubleshoot and figure
21 out where the heck these signals are tied up?

22 MR. SCAROLA: They'll have both logic
23 diagrams as well as electrical wiring diagrams. As I
24 said, some functions are in logic, some functions are
25 in motor control centers so they will actually have both.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BLEY: Okay. And those will be of
2 the kind we've seen before?

3 MR. SCAROLA: The electrical part.

4 MEMBER BLEY: Yes.

5 MR. SCAROLA: Oh, yes, even the logic part.

6 Yes.

7 MEMBER BLEY: Okay.

8 MR. SCAROLA: Because you've seen logical

9 --

10 MEMBER BLEY: Two of their logic diagrams,
11 but, yes.

12 MR. SCAROLA: In fact later we will show
13 you a picture of software base logic that they can
14 actually see on the screen.

15 MEMBER BLEY: Okay.

16 MR. SCAROLA: That's coming up later.

17 MR. SAMPLES: There are only two types of
18 inter-divisional. Inter-divisional, between
19 division, data communication, interface methods apply
20 to the PSMS. There's point to point datalink and a
21 multi-drop network.

22 With point to point datalink, the interface
23 between the, communicate information between the
24 different RPS trains for partial trip, between the RPS
25 and the ESFAS for partial ESF actuation and between the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 multi-divisional safety VDU trains. We'll discuss
2 those in a moment for monitoring information.

3 The multi-drop networks communicate
4 between the PSMS and non-safety systems, via the unit
5 bus, for both monitoring control information to
6 non-safety and for manual control commands from the
7 operational VDUs.

8 The PSMS safety function is assured by
9 functional and communication indecense such that the
10 failure of one PSMS division doesn't negatively impact
11 other functions of the other PSMS divisions. And the
12 failure of a non-safety system does not negatively
13 impact the functions of any PSMS division.

14 Now normal shutdown can be achieved and
15 maintained using the operation controls from either the
16 main control room or the remote shutdown room. Safe
17 shutdown, both hot and cold, can be achieved and
18 maintained using only the PSMS from either the main
19 control room or the remote shutdown room.

20 Safety VDUs or operational VDUs can be used
21 with the PSMS to achieve safe shutdown from either main
22 control room or remote shutdown room. There are master
23 transfer switches for transferring control from the main
24 control room to the remote shutdown.

25 One for each PSMS train and one for the PCMS.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 They're in two different locations. One location is
2 just, it's on the pathway between the main control room
3 and the remote shutdown room. And the other one is
4 inside the remote shutdown room.

5 You need two-of-two actuations to transfer
6 control. If you want to transfer to control, for
7 instance, from PSMS Train A from the main control room
8 to the remote shutdown room, you have to push that
9 corresponding switch both, at both locations before you
10 transfer.

11 Pushing only one will not do it. So you
12 have to push all ten of those switches to transfer
13 control.

14 And we'll talk about the safety visual
15 display unit, the VDU. Again, this is a computer touch
16 screen. It is an alphanumeric display because it has
17 the graphical display.

18 It's kept very simple to meet Class 1E
19 quality assurance requirements. Especially the software
20 quality assurance requirements for --

21 CHAIR STETKAR: I'll ask now, you
22 hesitated. Don't ever make eye contact.

23 MEMBER BLEY: First mistake.

24 CHAIR STETKAR: You mentioned a couple of
25 times using a touch screen controls.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SAMPLES: Yes, sir.

2 CHAIR STETKAR: Are they only touch screen
3 controls or you have mice? The reason I'm going to ask
4 about this rather than, because of time, just recently
5 somewhere I read about a problem that had occurred
6 because someone was using touch screen controls and
7 indeed the controls for adjacent components were really
8 close on the touch screen.

9 And I have fat fingers, and basically
10 somebody operated the wrong equipment and it was traced
11 back to the fact because of the proximity on the touch
12 screen of those components were so close, that it was
13 really, really difficult to distinguish between them.

14 And they're solution was, well oh gee, that's right,
15 we'll install mice because they give you a much more
16 precise click and select.

17 MR. SAMPLES: We don't have, we don't use
18 a mouse, it's just touch screen.

19 CHAIR STETKAR: It's only touch screen.

20 MR. SAMPLES: I think Mr. Scarola can
21 explain better.

22 MR. SCAROLA: Someday we'll have an
23 opportunity to come in here and talk to you about Chapter
24 18, where we will address all the human factors designs
25 of touch screen.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR STETKAR: I knew you were going to
2 say that. I just wanted to ask.

3 MR. SCAROLA: And I'm saying someday. I
4 mean I hope I'm still here. But 0700, no, there is a
5 NUREG-0700 that has very strong requirements for things
6 like touch screen separation and, so we'll talk about
7 that in Chapter 18. I was being facetious, that's mean,
8 but.

9 CHAIR STETKAR: Okay.

10 MEMBER BLEY: Well this is a diversion, but
11 all the touch screens I've played with, depending on
12 moisture and that sort of thing, sometimes they work
13 great, sometimes they don't recognize you're touching.

14 Is there something in these designs that gets around
15 that problem?

16 MR. SCAROLA: Well there are many different
17 types of touch screen technology. We use what's called
18 surface acoustic wave technology. And its been
19 extremely reliable.

20 MEMBER BLEY: Okay.

21 MR. SCAROLA: We haven't had any issues.

22 MEMBER BLEY: I mean we were only up there
23 one day, it looked that way, but.

24 MR. SCAROLA: Yes.

25 MEMBER BLEY: I wondered if on a dry day

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 or something like that you run into trouble?

2 MR. SCAROLA: Very honestly I was, when I
3 first got involved with this program I was skeptical
4 about the touch screens. But we've had 13 operating
5 crews, senior reactor operators and the reactor
6 operators through our US basic HSI test facility, the
7 one that you saw, and they loved the touch screens.

8 MEMBER BLEY: Okay.

9 MR. SCAROLA: So that made me a believer.

10 MEMBER BROWN: That's because they're
11 paying with their smart phones all the time.

12 MR. SCAROLA: Well this was actually a few
13 years ago before smart phones were --

14 MEMBER BROWN: No, I'm just going to make
15 one observation. The program I was in before, we looked
16 extensively at touch screens and we avoided them like
17 the plague because they had so many problems.

18 And we ended up with stationary screens and
19 put a whole level of little pushbuttons down below where
20 you had touch, you had tactical feel for the buttons
21 as well. Even if you had soft keys where you could use
22 them multiple times.

23 MEMBER BLEY: What year was that?

24 MEMBER BROWN: It was a couple years ago.
25 I mean you seen how much, it was like ten years.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: But very frankly, ten years
2 ago --

3 (Crosstalk)

4 MR. SCAROLA: One of the problems with
5 screens years ago is screens had curvatures to them.
6 So it was very difficult to make touch screens function
7 because the actual glass of the screen curved. But now
8 with flat screens, it's just much more reliable.

9 MEMBER REMPE: We can come back and confirm
10 and so you have to double indicate, is what you told
11 me earlier, is it really faster if you're in the middle
12 of something? I mean you said you'll take about
13 human-factors later, but is it just expedient as
14 switches?

15 MR. SCAROLA: Yes, it's very expedient.
16 It's what we call soft covers on switches. Where it's
17 kind of like lifting up a hinge cover on a button, we
18 have soft covers on our switches. So you hit something,
19 it removes the soft cover and then you take the action
20 necessary.

21 CHAIR STETKAR: There are a lot of designs
22 in Europe, even hardware based, where you have a confirm
23 switch. And once the operators get use to using it,
24 it's no more then, you need two hands instead of one.

25 MR. SCAROLA: Well this is not two-hand

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 operation. But, no, we'll show you a picture later.
2 I think it will help.

3 MEMBER REMPE: Okay.

4 MR. SAMPLES: Now these safety VDUs consist
5 of both the safety VDU processor and a safe VDU panel.
6 There's two different kinds of safety VDUs.

7 Single additional safety VDUs that we saw
8 in the main control room, the four-train redundant.
9 Each one of these controls and monitors all the safety
10 related functions of a safety train.

11 Or safety Train A, the lead safety train.
12 VDU for safety Train A controls all the equipment in
13 Train A. The VDU for Train B, all the safety functions
14 in Train B and so forth.

15 We also have multi-divisional safety VDUs,
16 which we didn't show in that picture. These are
17 two-train redundant, two different ones.

18 These do not have any control capability,
19 but each one can monitor all of the information, all
20 the parameter from all four of the safety trains at one
21 time. So each can monitor all for the multi-divisional
22 safety VDUs.

23 The type two VDUs consist, are implemented
24 by the same digital platform as the PSMS. That's the
25 MELTAC platform. And they set aside all safety criteria

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and the requirements.

2 Interlocks important to safety. The
3 interlocks are implemented in the PSMS. These are the
4 ones credited for DCD Chapter 15 to prevent accidents
5 and help to ensure the availability of the safety
6 systems. You see a list here of all the various
7 interlocks important to safety for the US-APWR.

8 CHAIR STETKAR: Now that third one from the
9 bottom doesn't exist anymore, is that correct?

10 MR. SAMPLES: Component --

11 CHAIR STETKAR: CCW supply line isolation.
12 Interim Revision DCD Rev 4, at least in Chapter 9
13 eliminated that.

14 MR. SAMPLES: Mr. Hamamoto?

15 MR. HAMAMOTO: This is Hiroshi Hamamoto.
16 I believe this interlock is Rev 4. We don't change
17 that part, somebody else return line. I believe this
18 exists in --

19 CHAIR STETKAR: Okay, that's a disconnect
20 between the information we got when we review Chapter
21 9. So this is in particular, the interlocks on MOV-020
22 A, B, C, D and 007 A, B, C, D.

23 And we were told that that interlock was
24 going to be removed because we had questions about how
25 it was working. It's important because it supplies

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 cooling water to the reactor cooling pumps.

2 So if the Chapter 7 folks think the
3 interlock is still there and the Chapter 9 folks think
4 it's not there, somebody has to get the story straight.

5 I'm just going to make that observation,
6 because we have it on the record that it was changed,
7 that it was removed in, at least interim Revision 4 of
8 the DCD. Now if it's back in place --

9 MR. LYNN: This is Kevin Lynn. I recall
10 the thing that you're asking about, but the isolation
11 interlock that you are talking about is actually a
12 different one that was removed. This is one that was
13 not changed.

14 If you look at DCD Chapter 7, you can see
15 the section that talked about the interlock. Removing
16 the interlock that you're thinking of that was removed,
17 that's shown in redline strikeout, but then that same
18 section is then where this other interlock was discussed
19 and you can see the valve numbers that you're talking
20 about were taken out.

21 But this is referring to different valve
22 numbers. I don't have them in front of me right now,
23 but you can see it in Chapter 7.

24 MEMBER BLEY: Different valves in the same
25 system?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. LYNN: Yes.

2 CHAIR STETKAR: Well take a look at that
3 because when I read Chapter 7 they were the same valve
4 numbers. I referred back to Chapter 9, so.

5 MR. SCAROLA: Okay, we'll look at that.

6 CHAIR STETKAR: I'm not sure which
7 interlocks we're talking about now, but they seem to
8 talk about the same valve numbers. Anyway, go on.

9 MR. SCAROLA: Okay, I don't know if this
10 helps, but this section --

11 MR. HAMAMOTO: We will check it after the
12 break.

13 CHAIR STETKAR: Check it after the break,
14 we'll never finish.

15 MR. LYNN: This is Kevin Lynn again, I just
16 want to clarify. So you're asking about the interlock
17 that was for Valve 7 and 20?

18 CHAIR STETKAR: That's correct.

19 MR. LYNN: That has been deleted.

20 CHAIR STETKAR: And that's --

21 MR. LYNN: The interlock that is showing
22 on that screen is for Valves 57 and 58.

23 CHAIR STETKAR: Somebody ought to change
24 --

25 MR. LYNN: They're different valves.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: I found Valve Number 7 and
2 20 in the DCD.

3 MR. SCAROLA: According to Chapter 7, we
4 use to have interlocks on both the supply line and the
5 return line. Now we only have interlocks on the supply
6 line. The return line interlocks have been deleted from
7 Chapter 7.

8 CHAIR STETKAR: Let's leave this for the
9 break, I'll look up the section that I referred to and
10 see what numbers are listed there and so we can keep
11 going here.

12 MEMBER BROWN: Ken, before you go on, I
13 meant to ask a question back about five slides ago, but
14 this is an easy answer. All the intra-divisional
15 communication for train-to-train voting, those are
16 dedicated communications, know of those go up to the
17 unit bus or require --

18 MR. SCAROLA: Yes, point to point data link
19 --

20 MEMBER BROWN: I saw the point to point,
21 I just wanted to make sure it covered that plethora of
22 items for both the ESFAS as well as RTS. Thank you.

23 MR. SAMPLES: Now for the information --

24 CHAIR STETKAR: I'll refer you to DCD
25 Section 7.6.1.5 where they explicitly list Valve 7 and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 20. I'm done.

2 MR. LYNN: This is Kevin Lynn again.
3 You're looking at DCD Revision 3, right?

4 MR. SCAROLA: That's correct.

5 CHAIR STETKAR: It's the only I have.

6 MR. LYNN: In the change from the Chapter
7 9 RAI it included a markup to that section which
8 eliminated the Valve 7 and 20.

9 CHAIR STETKAR: Okay.

10 MR. LYNN: So in the DCD Revision 4 it will
11 look different then what you're looking at.

12 CHAIR STETKAR: Thank you. I'm sorry I
13 just get, when things are changing, one of the things
14 that we do by the way, one of the functions the ACRS
15 has is to try to make sure that bits and pieces tie
16 together because we only see individual chapters at a
17 time.

18 But we're also responsible for overall
19 safety review for the entire integrated design. So
20 that's one of the reasons why we try to pick up on these
21 things, if they are discrepancies.

22 MR. SAMPLES: Okay.

23 CHAIR STETKAR: That sort of explains a
24 little bit about why I brought that up. Thank you.

25 MR. SAMPLES: Makes perfect sense. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I'll move on to discussing the information systems
2 importance to safety. Specifically the post-accident
3 monitoring system.

4 Post-accident monitoring system monitors
5 all five types of PAM variables from Type A through Type
6 E. With the Type A parameters, excuse me, the Type A
7 and B parameters, these have spatially dedicated and
8 continuously visible displays above safety VDUs and the
9 large display panel.

10 Types A, B and C parameters have Class 1E
11 power. They're processed by the PSMS and they are
12 displayed on the safety VDUS.

13 The performance of the PAM variables such
14 as range, accuracy, response time, required duration,
15 reliability, these have been selected in accordance with
16 IEEE-497.

17 You see there is an open time related to
18 this. Related to the selection basis for PAM variables
19 to demonstrate complete accident coverage. We're
20 preparing a response to that.

21 CHAIR STETKAR: Curiosity been submitted.

22 Are you going to talk anymore about PAM variables or
23 is this the time to ask about PAM?

24 MR. SCAROLA: This is the time.

25 CHAIR STETKAR: Okay. This is more of a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 curiosity but sort of a, may I ask about a few things?

2 Were never going to finish on time so I'm giving up
3 on that.

4 Reactor vessel water level, I found a couple
5 of different reference points for that. One place it
6 said it's from the bottom of the hot leg to the top of
7 vessel. The other place it said it's from the top of
8 the fuel alignment plate, which I'm assuming is the top
9 of the upper core plate.

10 There's a substantial difference between
11 those two elevations. It would seem to make sense that
12 it's the top of the core plate.

13 MR. SCAROLA: Where are you seeing this
14 information? I don't think --

15 CHAIR STETKAR: DCD 7.5.1.1.3.2 says it's
16 from the top of the fuel alignment plate. Table 7.5-3
17 says it's from the bottom of the hot leg. So I'm just
18 curious where it came from. You may want to check that?

19 MR. SCAROLA: Okay. It sounds like we need
20 to take the action. We'll move on.

21 CHAIR STETKAR: Here's a, I understand the,
22 I know about the open item, about selection of the
23 variables. One of the things in the DCD is it discusses
24 that the PAM variables are displayed on both the safety
25 VDUs and the operational VDUs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The operational VDUs, the way it's cast is,
2 it says that recoding and trending are available on PCMS.

3 And only the actual value displays are available on
4 the safety VDUs.

5 Why didn't you provide the trending
6 capability over on the safety VDU side? The reason I'm
7 interested is the PCMS is non-safety related.

8 In a complete Station Blackout, after an
9 hour it's gone. So if I'm now an operator in the control
10 room, it's gone.

11 Station Blackout, in my words, means no ac
12 power. Not a legal Station Blackout, a real Station
13 Blackout.

14 MR. SCAROLA: So you're essentially
15 discrediting the alternate ac sources that --

16 CHAIR STETKAR: That's my definition of
17 Station Blackout, is no ac power.

18 MR. SCAROLA: Okay.

19 CHAIR STETKAR: The non-safety batteries
20 have a rated life of an hour. The trending information
21 is often very important to operators because it tells
22 me how things are changing, the direction they're
23 changing and how fast they're changing, rather than just
24 looking at an individual value.

25 And to understand the trajectory of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plant, that trending information can be really
2 important. And we have a lot of experience with
3 operators, not operators, people in general not doing
4 well about looking at individual point values and
5 remembering which way they're going and how fast they're
6 going.

7 So that's the reason I bring up the question
8 about why the trending information isn't available over
9 on the safety side of the plant.

10 MR. SCAROLA: Well if it were determined
11 to be needed, it would be on the safety side.

12 CHAIR STETKAR: You're going to kick me
13 back to Chapter 18.

14 MR. SCAROLA: Well no, because IEEE-497,
15 which we follow, says that if the emergency procedures
16 require trending, then that is a Type A or Type B
17 variable.

18 CHAIR STETKAR: Okay.

19 MR. SCAROLA: But right now, that has not
20 been the case. And we have been through, not all
21 accidents, but many accidents with operators in our
22 facility and they have not requested any kind of trending
23 on the safety VDU.

24 CHAIR STETKAR: Okay.

25 MR. SCAROLA: So my point is, it is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Chapter 18 issue, but it's also a Chapter 7 issue. But
2 if they are required we will add trends, but right now
3 we have not seen any need for it.

4 CHAIR STETKAR: They're not required and
5 you haven't had any feedback from the operators that
6 they feel that they're missing.

7 MR. SCAROLA: Okay, thanks.

8 MEMBER SHACK: Even if you blacked out the
9 operational VDUs after an hour?

10 CHAIR STETKAR: That's a good question.

11 MR. SCAROLA: Well I'm not an operator, but
12 I, clearly an operator can look at a value on the safety
13 VDU and he can see if something is increasing or
14 decreasing. And he can see the rate of increase and
15 decrease for short term decisions.

16 Now if there was something that the EOP said
17 go back and look at an hour ago, then of course we would
18 have to put some type of historical data. But we have
19 not seen that.

20 MEMBER BLEY: I'm just curious. We'll get
21 to this at Chapter 18, but did you specifically ask the
22 operators about this or they just never talked about
23 it?

24 And the reason I ask is there's only one
25 plant that I know of that's operating today, had one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of those unfortunate things. They had their operating
2 crew on hand for several years before they got to start
3 up. It was while everything was delayed back in the
4 late '70's.

5 And they completely redesigned their
6 control panels the way they wanted them. And they
7 actually, one of the key things they used, they preset
8 in a number of trends that depending on what's going
9 on, they can pop up this set of four or a different set
10 of four and they love them.

11 And they actually designed that into their
12 system. It wasn't there when it started, so.

13 MR. SCAROLA: Well we have that same
14 functionality in the PCMS.

15 MEMBER BLEY: Yes.

16 MR. SCAROLA: There are many preconfigured
17 trends, but the operators also have the ability to --

18 MEMBER BLEY: Setup their own.

19 MR. SCAROLA: -- configure their own trends
20 on the fly during any shift and they can save them so
21 they're available on the next shift. But here we're
22 talking specifically about the safety VDUs --

23 MEMBER BLEY: Right, and it's not there.

24 MR. SCAROLA: -- and those, the way we test,
25 we blackout or freeze, depending upon the scenario, some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 are blackout some are freezes, all the non-safety VDUs

2 --

3 CHAIR STETKAR: So they essentially
4 simulate --

5 MR. SCAROLA: -- and we force the operators
6 to manage accidents and achieve safe shutdown with just
7 the safety VDU. Now we haven't done every accident and
8 we will never do ever accident in the V&V part.

9 We do a broad sampling of that cross
10 section, but the operators are not shy about given us
11 feedback on what they want. And this has never come
12 up.

13 MEMBER BLEY: That's interesting. It
14 surprises me.

15 CHAIR STETKAR: Continue, we'll try to get
16 through the safety related stuff before we take a break
17 here.

18 MR. SAMPLES: Okay, there was a question
19 at a previous meeting about the reactor trip on turbine
20 trip function. Specifically to it's reliability.

21 First of all, unless we have a diagram of
22 how the signal for reactor trip on turbine trip is
23 generated. If you're above ten percent power the P7
24 interlock is satisfied. Then if you have either one
25 of two different conditions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 One, all four of your main turbine stop
2 valves are closed. Because if you had any one of them
3 your turbine could still be operating.

4 Or, you have two of four the turbine
5 emergency trip oil pressure switches indicated low.
6 So either one of those conditions and you're above ten
7 percent power, you'll get your reactor trip on turbine
8 trip.

9 Now this trip is, it's an anticipatory trip
10 function. It's not credited in the Chapter 15 analysis.

11 Now while it can't be Class 1E due to the
12 turbine being non-safety and the turbine building is
13 in a non-seismic location, is a non-seismic location,
14 but it is designed to be highly reliable by seismically
15 and environmental qualified sensors, uses Class 1E power
16 sources, diverse redundant sensors, separation of
17 sensors and cables and the function is maintained by
18 the tactical specifications including periodic
19 surveillance tests.

20 There's also question about the turbine
21 trip on reactor trip function. Now the way we trip the
22 turbine is the main turbine stop valves are held open
23 by high pressure hydraulic oil. So you trip them, you
24 vent that off.

25 These turbine trip solenoid valves in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 bottom, once you operate these, that allows the venting
2 of the high pressure hydraulic oil go off and you get
3 a trip.

4 So what this is showing you is the PSMS on
5 the left and the PCMS on the right with the turbine
6 protection system and the separate turbine control
7 system.

8 Now just from, we have a reactor trip we
9 detect, the reactor trip breakers opening, the CPU would
10 generate a signal through the power interface module
11 down to actuate these turbine trip solenoid valves, vent
12 the pressure trip to the turbines.

13 The turbine protection system, see it's a
14 dedicated system, it has four redundant digital
15 subsystems. Two for A, two for D. And it too generates
16 a signal.

17 Whereas the PSMS, when it's given a turbine
18 trip on a reactor trip, is given this trip to protect
19 the plant from unsafe condition. The turbine
20 protection system, when it gives a trip, it's doing that
21 trip to protect the turbine itself. So these two will
22 all come together and protect power interface module.

23 The turbine control system you see is
24 totally separate system. It's also dedicated as
25 duplex-independent digital subsystems.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Our independent sensors, including speed
2 sensors for these two different turbine protection
3 system, turbine control system and also whereas the main
4 control, excuse me, the turbine control system controls
5 the main turbine control valves, throttle valves, it
6 actuates those to control the Turbine E. The turbine
7 protection system in PSMS control the main turbine stop
8 valves.

9 Okay, now we'll move onto the non-safety
10 systems. The plant controls --

11 CHAIR STETKAR: Let's, I'll stop you here.
12 Let's take a break, it's a convenient time, and
13 reconvene at 10:20.

14 (Whereupon, the foregoing matter went off
15 the record at 10:04 a.m. and went back on the record
16 at 10:20 a.m.)

17 CHAIR STETKAR: We are back in session.
18 Let the fun continue.

19 MR. SAMPLES: Okay, we'll move on now to
20 the non-safety I&C systems. The plant control and
21 monitoring systems and we'll discuss the topics you see
22 here.

23 Starting with the plant control systems.
24 The non-safety systems are controlled by the PCMS.
25 The control and functions are distributed to multiply

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 PCMS controller groups to ensure that transients due
2 to experience signals from one control group are bounded
3 by the DCD Chapter 15, AOO analysis.

4 The controller redundancy and the
5 distribution of functions to multiple controller groups
6 minimizes the potential for single or complete
7 controller function failure. The input and output
8 redundancy apply to the components, for example,
9 feedwater regulation valves that could cause plant trip.

10 There is an open item associated with this.

11 The spurious actuations caused by PCMS failures,
12 including software design defects, they're being
13 examined or plant effects as part of this open item.

14 The PCMS shares sensors with the reactor
15 protection systems for many control functions. The
16 reason being that sensor-sharing reduces pressure
17 boundary penetrations and local maintenance work in
18 accordance with ALARA principles.

19 The PCMS avoids adverse control and/or
20 protection interaction by using multiple redundant
21 sensors and the signal selection algorithm.
22 Essentially the signal selection algorithm works by
23 selecting the highest of four sensors, if there's
24 available.

25 Once sensors failed it selects the highest

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of the three. If another sensor fails and you only have
2 two, we transition into a failure state because with
3 two you don't really know which one is going to be correct
4 in that case.

5 MEMBER BROWN: I guess I missed that, the
6 selection of the second highest, where does this come
7 into, I'm trying to think in the PCMS where this even
8 comes into play sense the sensors that actuate things
9 of interest are all feed up through the RPS and then
10 over to the ESFAS. And what shared, I have no problem
11 with shared sensors so I'm not asking a question relative
12 to that, what part of PCMS actually makes this decision
13 process as opposed to what sensor it uses?

14 MR. SAMPLES: You mean where is the
15 function implemented in the PCMS?

16 MEMBER BROWN: Yes, what function? I mean
17 I looked back at the PCMS I've got rod control, I get
18 a switch actuation, you know if somebody wants to move
19 the rods from the main control room.

20 CHAIR STETKAR: Charlie, think about
21 pressurizer level control pressurizes, pressure
22 control, main feedwater control.

23 MR. SCAROLA: Even rod control, T-average.

24 CHAIR STETKAR: T-ave for rod control.

25 MEMBER BROWN: But how many channels, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 agree, I don't understand all of that. I don't have
2 the knowledge that you all have of the balance of plant
3 or the other systems. You know, the plant systems, from
4 that standpoint.

5 MR. SCAROLA: Well every reactor control
6 system --

7 MEMBER BROWN: Pressurizer level moves up
8 and down, pressurizer pressure is controlled by heaters
9 or I presume it is.

10 MR. SCAROLA: Right.

11 MEMBER BROWN: This is a PWR.

12 MR. SCAROLA: So those are the same sensors
13 that we use in the RPS.

14 MEMBER BROWN: Right.

15 MR. SCAROLA: The sensors are used in the
16 RPS and in their digitized form, the sensor values are
17 sent to the PCMS from each of the four RPS divisions.
18 They're sent separately.

19 And then inside the PCMS in the specific
20 group controller where that function is needed, we have
21 an SSA algorithm block. The signal selection algorithm
22 block.

23 So we take all four signal sensors, put it
24 into the SSA block and the SSA spits out the output,
25 which is the second highest. And the reason we do that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 is so we don't have any spurious control system actions
2 based on a single sensor failure.

3 So you got one sensor deviating, yes, that
4 might make the D division of the RPS out of service
5 because it's deviating non-conservatively, but it won't
6 result in a spurious control system action. Because
7 of this SSA algorithm. Signal Selection Algorithm.

8 So this applies to rod control, because we
9 move rods automatically based on T-average. So we look
10 at hot leg and cold leg temperatures, turbine bypass
11 control. Every control, just about every NSSS control
12 system.

13 MEMBER BROWN: Okay, go ahead.

14 MR. SAMPLES: Now the sensor failure does
15 not cause an adverse control systems action while the
16 PSMS is in degraded state from that very same sensor
17 failure for IEEE-603. And the signal selection
18 algorithm as augmented quality.

19 CHAIR STETKAR: God, I hate to keep doing
20 this, but it's okay. I read someplace where SSA kind
21 of marches down the daisychain if I have four, three,
22 two, one. And it knows if the monitored parameters are
23 out of range.

24 So for example, if one monitored parameter
25 is out of range it takes the second highest of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 remaining three, if two are out of range it takes the
2 second highest of the remaining two, if three are out
3 of range it takes the second highest of the remaining
4 one. That's at least the way I read, I can look up the
5 reference.

6 MR. SCAROLA: You're making it more
7 complicated. It always takes the second highest.

8 CHAIR STETKAR: Okay.

9 MR. SCAROLA: It doesn't matter whether
10 they're drifting or not, it just always, it's very
11 simple. It just always uses the second highest.

12 CHAIR STETKAR: Second highest, okay. So
13 if three of them are all failed high and it's right,
14 it's going to control on the wrong one?

15 MR. SCAROLA: Right. Yes, if three of them
16 are all failed high, one of those three is the second
17 highest.

18 CHAIR STETKAR: Is one of those three the
19 second highest --

20 MR. SCAROLA: Well sure.

21 MEMBER BROWN: They're all the second
22 highest.

23 MR. SCAROLA: Oh, you mean they all fail
24 like right out of range?

25 CHAIR STETKAR: They're all pegged?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCAROLA: It's different. Then
2 they're taken out of the equation completely. If they
3 --

4 CHAIR STETKAR: That's what I was saying.

5 MEMBER BROWN: That's where --

6 CHAIR STETKAR: But that's what I was
7 saying. If they're out of range, there was a discussion
8 in there --

9 MR. SCAROLA: Yes, I'm sorry, your right.

10 CHAIR STETKAR: -- it's the second highest
11 as long as they're in range.

12 MR. SCAROLA: Correct.

13 CHAIR STETKAR: Now if three of the four
14 are out of range, it's going to control on the one-of-one
15 that is in range.

16 MR. SCAROLA: Right.

17 CHAIR STETKAR: Even though it might be
18 wrong?

19 MR. SCAROLA: That's all tech-spec
20 controlled. As soon as you get down to two, you're in
21 a LCO condition.

22 CHAIR STETKAR: I understand. I
23 understand that from the lawyers. I'm trying to
24 understand, if things happen in the plant that the ranges
25 that were set in the SSA didn't anticipate all of my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 potential transient conditions, such that the one that
2 I'm controlling on indeed --

3 MR. SCAROLA: Is the failed one.

4 CHAIR STETKAR: -- is the wrong one.
5 Because it didn't respond correctly.

6 MR. SCAROLA: About this, if the sensors
7 have failed out of range, let's take pressurizer
8 pressure, at that point you have a plant trip because
9 you've got two out of four sensors that have failed --

10 CHAIR STETKAR: That's a good point.

11 MR. SCAROLA: -- out of range and you have
12 a trip.

13 CHAIR STETKAR: Thanks, that's a good
14 point.

15 MR. SCAROLA: And the same thing would
16 apply for most low range sensors.

17 CHAIR STETKAR: Yes.

18 MR. SCAROLA: Pressurizer level,
19 pressurizer level has a high trip and a low trip.
20 Pressurizer pressure got's a high trip and a low trip.

21 So in most cases you can never --

22 (Crosstalk)

23 CHAIR STETKAR: You're right, Ken. You're
24 right, Ken. I didn't think over on the protection side
25 of the equation what would be happening over there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I was just focusing on the description of the SSA.
2 Thanks.

3 MR. SCAROLA: You're right.

4 MR. SAMPLES: Okay, now we're ready to
5 discuss the second information system of the I&C system.

6 These are the alarms for credited manual actions.

7 Now in accordance with the SECY letter,
8 SECY-93-087, the reliability of alarms to prompt manual
9 actions credited to the safety valves is assured by these
10 design features. First, redundancy is provided for all
11 HSI alarm components, the separation between redundant
12 segments, their testability is provided from self
13 diagnostics of the, PSMS, PCMS and the HSI computers.

14 These alarm functions have augmented
15 quality. In addition to these alarms, there's abnormal
16 indications for these same credited manual operator
17 actions, are provided on the safety VDUS.

18 Here we see a simplified block diagram with
19 the PSMS and PCMS. It shows how these alarms
20 indications and abnormal indications are going to be
21 generated.

22 Sensors. Both the safety sensor and the
23 non-safety on the left and the location where the alarm
24 indication is given to you.

25 So first of all, on the top for the PSMS,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 signals received from a safety sensor, that safety
2 sensor goes, is processed with a safety VDU processor
3 that's shown, that's abnormal indication on the safety
4 VDU. The same signal, raw sensor data, also transferred
5 through the unit bus to the PCMS.

6 The non-safety sensor here receive input
7 into the alarm logic computer which will then generate
8 an alarm. It will generate the audible alarm, the alarm
9 indications of the alarm VDU and the alarm indication
10 on the large display panel.

11 And again, the signal is also shared with
12 the PSMS. So for shared signals, a safety signal will
13 come down, also into the PCMS and to the same alarm logic
14 computer, which will then generate alarms on the large
15 display panel alarm VDU and the audible alarms.

16 Whereas an input from the safety sensor will
17 be transmitted to the PSMS and then the safety VDU would
18 also generate the abnormal indication on the safety VDU.

19 MEMBER BROWN: One question, just to make
20 sure I, the little thing that says ISO, you mentioned
21 this earlier. Is that a one way isolation, I mean it's
22 a optical coupling into the unit bus or is it a
23 bidirectional, but electrically isolated? I mean I'm
24 just trying to differentiate it.

25 MR. SCAROLA: The circle that says ISO is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 representing fiberoptic cable of which it is
2 bidirectional.

3 MEMBER BROWN: It's electrical isolation
4 --

5 MR. SCAROLA: Well no, it's a fiberoptic
6 cable.

7 MEMBER BROWN: So by that's it's
8 electrically isolated also?

9 MR. SCAROLA: Oh, yes, it's electrically
10 isolated. But it is bidirectional. Any interface that
11 you see here with the unit bus is a bidirectional
12 interface.

13 The data is one direction. The interface
14 is a bidirectional. So for example in the case, we're
15 showing that safety sensor data is going from the reactor
16 protection system to the unit bus.

17 Non-safety sensors are coming from the
18 reactor control system via the unit bus back to the
19 safety system for display on the safety VDUs. So the
20 data is going one way or the other, depending upon where
21 the data is actually originating. But the unit bus
22 itself is a bidirectional media.

23 MEMBER BROWN: I understand that.

24 MR. SCAROLA: Yes.

25 MEMBER BROWN: I understand the unit bus

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is a bidirectional. It's just my question was relative
2 to the information that gets onto it is unidirectional
3 from the PCMS to all these other displays.

4 Obviously you got to be able to monitor
5 everything, but yet you can't put information into the
6 reactor protection system A from the unit bus?

7 MR. SCAROLA: Not directly.

8 MEMBER BROWN: Not directly.

9 MR. SCAROLA: If you recall the earlier
10 slide --

11 MEMBER BROWN: Yes, I'm old, I forget a lot
12 of stuff.

13 MR. SCAROLA: -- we talked about safety,
14 the operational VDUs, these non-safety VDUs. They can
15 do things like initiate reactor trip. So that's done
16 via the unit bus but through what we call a COM interface,
17 communication module interface. And we'll be talking
18 about that more.

19 MEMBER BROWN: It doesn't go through the
20 functional calculation part and the tripping and voting
21 units. There's a separate set of communications, I
22 remember seeing that in the diagram.

23 MR. SCAROLA: Correct.

24 MEMBER BROWN: So you're going to talk
25 about that later, okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SAMPLES: Now for the non-safety data
2 communication system. The data communication system
3 is non-safety and consists of the unit bus and the
4 station bus.

5 The unit bus interfaces with all I&C
6 systems, including information controls for the main
7 control room and remote shutdown room and technical
8 support center. The unit bus interfaces with the
9 station bus and the station bus is a plant information
10 technology network.

11 It provides information to the NRC via the
12 emergency response data system to the emergency
13 operating facility and to plant personnel. And it
14 contains systems that you see here, such as work order
15 management, for example.

16 Okay, we talked about D, PAM and the alarms
17 previously. Now the two remaining information systems
18 are, the safety parameter display systems and the bypass
19 and inoperable status indication.

20 The safety parameter display system
21 displays keep parameters for critical safety functions
22 and also dynamic safety functions trees used by the
23 operators for procedures. Including emergency
24 operating procedures.

25 It displays key parameters for performance

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of normal and emergency systems used to maintain or
2 restore critical safety functions. The bypass an
3 inoperable status indication gives you availability
4 status of emergency systems for all the critical safety
5 functions.

6 Both of these parameters are displayed in
7 the main control room, remote shutdown room, technical
8 support center and emergency operating facility.

9 CHAIR STETKAR: Richard --

10 MEMBER BROWN: Can you, I'm sorry, go
11 ahead.

12 CHAIR STETKAR: Why is the bypass
13 inoperable status indication not available on the safety
14 VDUs?

15 MR. SCAROLA: It is but not at the system
16 level. For example, if you think about a conventional
17 plant, you can see that a pump is not available because
18 the lights go out on the hand switch. The lights are
19 powered by the same power supply that powers the pump.

20 So at the component level, you can see on
21 the safety VDU if any particular pump or valve is not
22 available. What BISI is, is a system-level algorithm
23 that looks at the entire system.

24 For example, safety injection system looks
25 at the required pumps, require valves and it says, in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 aggregate, are all the components lined up correctly
2 and it gives a system level indication.

3 CHAIR STETKAR: But if I bypassed Train A
4 for example, all of Train A, I'll get a Train A bypass
5 indication on BISI, right?

6 MR. SCAROLA: Up on the LDP.

7 CHAIR STETKAR: Right.

8 MR. SCAROLA: Right.

9 CHAIR STETKAR: I'll get a yellow light?

10 MR. SCAROLA: You'll get a component level
11 on the O-VDU and the safety VDU. Just component level.

12 CHAIR STETKAR: But it will show component
13 level?

14 MR. SCAROLA: Yes.

15 CHAIR STETKAR: Okay.

16 MR. SCAROLA: It's really --

17 CHAIR STETKAR: Yes, it's --

18 MR. SCAROLA: It's a matter --

19 CHAIR STETKAR: Okay.

20 MR. SCAROLA: It's kind of a philosophy
21 that safety HSI is kept as simple as possible so we can
22 achieve all the Class 1E software requirements. All
23 the complexity in the HSI is put in the non-safety systems
24 where we can have nice user friendly graphic displays.

25 CHAIR STETKAR: Okay, I'm just --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCAROLA: BISI is just an example.

2 CHAIR STETKAR: -- thinking the operators
3 are operators, lawyers or lawyers. And the operators
4 who need to understand what they have and what they don't
5 have in extremis --

6 MR. SCAROLA: Same philosophy --

7 CHAIR STETKAR: -- as long as they do have
8 that indication available somehow so they're not
9 struggling to operate a pump that's bypassed and they
10 don't recognize the fact that that whole train is
11 bypassed.

12 MR. SCAROLA: This whole philosophy is
13 really consistent with the philosophy of post accident
14 monitoring variables. On the safety VDUs we show all
15 the type B's and the C variables and the A's, but on
16 an indication by indication basis, single parameters.

17 But here on the safety parameter display
18 system, we so the integration of variables in a format
19 that mimics the safety function status tree. So it's
20 easier for operators to see it.

21 CHAIR STETKAR: I didn't ask about SBDS
22 because somebody lost the battle about making SBDS
23 safety-related a long time ago.

24 MR. SCAROLA: A long time ago.

25 CHAIR STETKAR: But at least I could ask

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 about BISI here.

2 MR. SCAROLA: But even though the battle
3 was lost on SBDS, you still have the PAM variables for
4 as the backup for SBDS. That's my whole point. It's
5 the same correlation.

6 CHAIR STETKAR: Okay.

7 MR. SCAROLA: Component level, component
8 level.

9 CHAIR STETKAR: Thank you.

10 MEMBER BROWN: Can you go back a slide?

11 MR. SAMPLES: Sure can.

12 MEMBER BROWN: I didn't know whether this
13 was the right place to ask a question. The unit buses
14 is an important bus because it kind of puts everything
15 from PCMS, PSMS up into the main control room and all
16 control functions, etcetera, go back down through it.
17 Normal control functions, okay.

18 But yet there's no real discussion, or at
19 least I didn't see any, talking about the details of
20 how that bus operates or is managed. And my vague memory
21 is that I read a statement that said it is not evaluated
22 from a safety basis, it's a non-safety bus or non-safety
23 component or subsystem or whatever.

24 What does that look like? I mean, what
25 manages that bus, how does it operate, how does it obtain

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 real-time transmission of data?

2 Because if it's a LAN it sounds like it's
3 operated by a server, which has an executive which
4 decides what information is going where and when. So
5 who do you ensure real-time data presentation to the
6 operators in both the NCR and any of the other places?

7 MR. SCAROLA: You're familiar with the
8 technology that's used for the safety bus, correct?

9 MEMBER BROWN: No.

10 MR. SCAROLA: Okay.

11 MEMBER BROWN: A bus is a bus is a bus.

12 MR. SCAROLA: Well okay.

13 MEMBER BROWN: I mean there's no real
14 discussion of the safety bus, because it's within a
15 division, I wasn't worried as much about a single failure
16 of a safety bus from train to train to train. My biggest
17 concern was the unit bus is the bus.

18 MR. SCAROLA: Right.

19 MEMBER BROWN: There's only one, its got
20 to be managed. And it looked to me like it was a local
21 area network type bus which has to have servers and other
22 things managing it.

23 MR. SCAROLA: In the DCD we refer to the
24 MELTAC technical report. The MELTAC technical report
25 describes what's called control network.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 That network technology, and it is
2 described in exhausted detail --

3 MEMBER BROWN: I remember there were pages
4 on that.

5 MR. SCAROLA: That network technology is
6 used for the safety bus and the unit bus. There's only
7 one technology used in both places. It's this dual ring
8 that we'll talk about later, this resilient packet ring
9 --

10 MEMBER BROWN: We are going to talk about
11 it then?

12 MR. SCAROLA: We will talk about it.

13 CHAIR STETKAR: It's the section later.

14 MR. SCAROLA: The unit, to make you feel
15 a little bit better, is exactly the same technology as
16 the safety bus. Same design, it is same modules,
17 everything's the same. So we'll talk about that.

18 And I agree with you, it's an extremely
19 important bus. And that's why its been, that's why we
20 adopted the safety technology for the unit bus.

21 MEMBER BROWN: Okay, you will be explaining
22 why failures of, the certain failures of that bus are
23 components or parts of that bus design will still allow
24 complete, as well as why you have real-time
25 communications? Because I'll have to admit to you that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I didn't try to read all of that.

2 MR. SCAROLA: We'll get there.

3 MEMBER BROWN: I would have never been able
4 to do it within a 24 hour, three day period.

5 MR. SCAROLA: Control network technology
6 is completely redundant and self healing and very high
7 speed. Gigabit speed.

8 So we'll talk about that a little bit later.

9 It's actually, I like to call it very elegant
10 technology, but it's --

11 MEMBER BROWN: Well my computer is gigabit
12 speed also, but every now and then I'm sitting there
13 watching the little hourglass and it just never changes.

14 It just happened to me and I just went and say, sorry,
15 this whole program is now not responding.

16 MR. SCAROLA: We'll get there.

17 MEMBER BROWN: Thank you.

18 MR. SCAROLA: I ask for your patient.

19 MEMBER BROWN: I'll take a deep breath.

20 MR. SAMPLES: Now we'll discuss the
21 operational VDUs. Non-safety components and safety
22 components in all divisions can be operated from the
23 non-safety operational VDUs.

24 The PSMS protects itself from any adverse
25 interaction from these O-VDUs based on compliance with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 IEEE-603 independence criteria. Including physical and
2 electrical independence, communication independence and
3 functional independence. It also says that priority
4 for all safety functions, including the safety VDUs.

5 The operational VDUs enhanced plant safety
6 by, one, reducing operator task burden. This results
7 in reduced time for operator actions and improved margin
8 to safety. And two, there's more mental resources
9 available to the operator for plant wide situational
10 awareness. And it reduces a potential for
11 human-performance errors.

12 Now these safety enhancements have been
13 validated through full scope simulator testing using
14 13 crews of US senior reactor operators and reactor
15 operators. Now --

16 CHAIR STETKAR: Before --

17 MR. SAMPLES: Uh-oh.

18 CHAIR STETKAR: You notice we do interrupt
19 quickly. The only reason I want to interrupt here is
20 there's a drawing in the DCD, it's Figure 7.1-7, that
21 shows electrical power supplies for PCMS.

22 And it shows that there are two, there's
23 two non-Class 1E UPSs feed PCMS. And there are several
24 functions, there's one controller, it's listed as
25 Control A comes from UPS 1 and Controller B, which is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 backup, comes from the backup.

2 The input/output modules have a diode --

3 MR. SCAROLA: Auctioneering.

4 CHAIR STETKAR: -- auctioneering. The
5 VDUs are shown as only from one of the two. Why?

6 MR. SCAROLA: Well --

7 CHAIR STETKAR: Since they're really
8 importantly for the operators.

9 MR. SCAROLA: But there are multiply VDUs.
10 So half the VDUs are on one and half the VDUs are on
11 the other.

12 CHAIR STETKAR: Thank you.

13 MR. SCAROLA: Good question.

14 MR. SAMPLES: Now --

15 CHAIR STETKAR: It's a good story anyway.

16 MR. SAMPLES: One of the core features of
17 the Operational-VDUs is the hyperlinks. These
18 hyperlinks among those non-safety human system
19 interfaces reduce operator task burden, potential for
20 human errors, the time required for safety action
21 responses.

22 And how this works is, you see the picture
23 of the alarm VDU, operational-VDU and a procedure VDU,
24 and the blue lines are like indicating these hyperlinks.

25 The way this works is, for instance, you get an alarm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on the alarm VDU, or some parameter, operator selects
2 that.

3 And when he does, on the operational-VDU
4 the page that shows that valve component or other part
5 of the system of interest pulls up. Also on the
6 procedure VDU you'll pull up a procedure, an emergency
7 procedure, a normal procedure, abnormal procedure
8 associated with that.

9 So instead of having to go get the alarm,
10 see what it is and then go dig for it on the O-VDU, then
11 also dig for the procedure, basically push one button
12 and it pulls up what you need to see. Also when you
13 have the procedure VDU and you're working through a
14 procedure to operate, a plant evolution, for instance,
15 as you get to the point in the procedure it will pull
16 up on the O-VDU, the system and the valve components
17 you would need to operate.

18 Now each of these just pulls up the screen
19 that you'd be interested on the operational-VDU. All
20 operations still has to be done from the operational-VDU
21 itself. Hyperlinks don't cause any kind of operation
22 from these other VDUs.

23 See an example screen of an
24 operational-VDU. You see that it has a graphical user
25 interface. You can see the different system, some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 valves, different things shown here. You see that if
2 the operator wants to operate you touch on a component
3 and a screen pops up, if you have such as a shut and
4 close for a certain valve.

5 This graphical user interface reduces the
6 mental processing time for both monitoring and control
7 actions. It reduces the potential for operator
8 selecting the wrong components. It's a lot easier to
9 see what you're looking for here than just try to pick
10 from conventional operating switches.

11 And by using the same screen, a single
12 operator, one operator can control safety and non-safety
13 success paths more than having two separate operators
14 with two separate consoles, with one having to talk to
15 the other to make sure they're doing things in sequence
16 and the right way.

17 So one can actually control everything,
18 such that safety is enhanced when operator time for
19 operator action is reduced, potential for errors is
20 reduced, and the task is simplified. There is an open
21 item associated with this, and MHI is in the process
22 of quantitatively evaluating the safety advantages of
23 operational-VDU in response to this open item.

24 CHAIR STETKAR: This is not for the U.S.
25 Safety WR, is it?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SCAROLA: You mean this pressurizer,
2 that pressure picture?

3 CHAIR STETKAR: Because I'm looking at
4 three relief valves in the parallel, and you guys only
5 have two -- okay, thanks.

6 MR. SAMPLES: I do believe this just must
7 be an example.

8 MR. SCAROLA: This is just an example.

9 CHAIR STETKAR: Thanks.

10 MR. SAMPLES: Okay. With the turbine
11 bypass valves interlock, erroneous turbine bypass
12 control signals are prevented by the PSMS. The PSMS
13 controls redundant non-Class 1E permissive solenoids
14 from the SLS trains both A and D. These are the valves
15 over here. The turbine bypass control function output
16 signals are provided by the reactor control system in
17 the PCMS through current to pressure converters and the
18 trip open solenoids over here.

19 What you see here is the logic for
20 generating the block turbine bypass valve signal. This
21 is the signal that blocks the opening of these turbine
22 bypass valves. The block turbine bypass valve signal
23 is generated under these conditions.

24 First of all, you have two of the four
25 average coolant temperature low-low or two of the four

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 reactor coolant loops. You see this on the other side
2 over here. Or the turbine inlet pressure is low,
3 actually it does not indicate a rate of decrease in the
4 turbine load, or you don't have your condenser available.

5 And your hot full power conditions you have would be
6 established.

7 The turbine inlet pressure is not
8 indicating a rate of decrease in the load. When you
9 have this, you have the block turbine bypass valve signal
10 and you're generating both your trains A and D.

11 CHAIR STETKAR: I'm trying to look forward
12 and I'm not seeing it, but you guys know the slides better
13 than I do. You ever talk about the load rejection at
14 any time?

15 MR. SCAROLA: Only here.

16 CHAIR STETKAR: Only here, okay, let me ask
17 about that. And this is a curiosity, it's not
18 necessarily a safety question, I don't think. If I read
19 the discussion of the load rejection, and I understand
20 you're capable of withstanding a 100 percent load
21 rejection without lifting any secondary relief valves,
22 without lifting any primary relief valves. Everything
23 works, works fine.

24 There is a statement in there that says,
25 "In this scenario, the main turbine control valve is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 immediately fully closed and four banks of turbine bypass
2 valves are tripped open to fully dump excess steam to
3 the condenser." I understand that.

4 My question is, if the load rejection signal
5 closes all of the turbine -- and then it goes on to discuss
6 a lot of things. For in the interest of time, it says
7 eventually, you know, the rods go in, turbine bypass
8 starts to modulate closed so you eventually get a stable
9 state where reactor power matches turbine power.

10 Is the plant designed to go into what I call
11 "island mode operation," where if you have a load
12 rejection the reactor remains at power, the turbine
13 remains at power, and you're supplying in-house loads
14 from the main generator?

15 And if that's the question, what does the
16 load rejection thing do to turbine control? Because
17 if the load rejection signal slams the turbine control
18 valves all the way closed, what reopens them? It's got
19 to do something to turbine load control.

20 MR. SCAROLA: The position of the turbine
21 modulating valves is controlled by the turbine control
22 system based on the load demand or the significant step
23 change in the load demand.

24 CHAIR STETKAR: But this says they go all
25 the way closed. It doesn't say it modulates according

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to turbine load, it says they go all the way closed.
2 So what reopens them and when?

3 MR. TAKASHIMA: Maybe the module open?

4 CHAIR STETKAR: The thing I'm interested
5 in, if at some point I start to get, for example,
6 frequency deviations and voltage and reverse power on
7 my generator and, for example, the thing doesn't recover,
8 if indeed the turbine control valves are all the way
9 fully closed, as this says.

10 I've seen these systems in the past. I'm
11 not familiar with this design. And that caught my eye
12 because other systems run back the turbine, they don't
13 close the valves completely.

14 MR. SCAROLA: In my mind, I'm questioning
15 whether that wording's correct.

16 CHAIR STETKAR: You may want to look it up.
17 It's in section, and just in the interest of time, it's
18 in section -- oh crap, it's on the record too, huh --
19 DCD section 7.7.1.1.11.3. You just may want to look
20 that up. Because I didn't understand, I couldn't see
21 the signal that came in.

22 The reason I asked about this is I look at
23 the schematics and I don't see a load rejection signal
24 specifically that opens all of the turbine bypass valves,
25 all four banks. And the only way I could see that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 happening is a huge difference between Tref and Tave,
2 where Tref falls to zero because you've got no steam
3 pressure in the steam chest.

4 MR. SCAROLA: You will see that signal in
5 section 7.2 in the logic diagrams. There's a set of
6 logic diagrams in 7.2, and I realize 7.2 is RPFs. But
7 those logic diagrams also show the interface between
8 the safety instruments and the control systems. And
9 in one of those figures you'll see the load rejection
10 signal.

11 CHAIR STETKAR: But it still comes from a
12 Tave/Tref deviation. It's not a load rejection at least
13 in what I was looking at. I looked at that drawing.
14 It didn't show a load rejection signal that says open
15 all four banks, boom. It showed a load rejection
16 controller that's got a ramp with Tave and Tref, I
17 believe, into it.

18 It's a lot of detail, and I thought I could
19 make it work if I got all four of the turbine control
20 valves all the way closed, because my Tref would then
21 go to zero because I have no steam pressure and --

22 MR. SCAROLA: On the break we'll look at
23 that diagram. My recollection is that it relates to
24 the turbine inlet pressure signal that you're seeing
25 on this drawing. This turbine inlet pressure signal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 not only removes the block, but it also initiates this
2 trip open of those valves.

3 CHAIR STETKAR: Let's look at it on the
4 break, because that's a lot of detail. But I'm still
5 curious about that statement about the turbine control
6 valves going fully closed, because I'm not sure how you
7 recover from that in enough time to save the electrical
8 side of the plan.

9 MR. SPRENGEL: So real quick, can you
10 summarize the question?

11 CHAIR STETKAR: There's a couple of
12 questions. One question is, if the plant is designed
13 to withstand the full load rejection with the main
14 generator supplying in-house loads, which I'll call
15 island operation, if that's the design philosophy, and
16 if the load rejection signal causes all four of the
17 turbine control valves to close fully, meaning no steam
18 going into the turbine, it's difficult for that system
19 to recover, for the main generator to keep supplying
20 in-house loads in a stable condition. Because power
21 is going to start to decrease immediately, and you're
22 going to get into, you know, voltage or frequency or
23 reverse power or some sort of protective trips on the
24 electrical side that you won't survive.

25 So I'm questioning, first of all, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 statement in the DCD about the full closure on the turbine
2 control valves in terms of the overall design philosophy.

3 The second thing that Ken and I were going back and
4 forth is, maybe we'll work that out during the break
5 so we'll just take a look at that later.

6 MR. SAMPLES: Okay, now for the diverse I&C
7 systems, the diverse actuation system. We'll discuss
8 these topics starting with the basic architecture of
9 the DAS. You see here the starting of the sensor, its
10 distribution.

11 The same sensor signal goes to the RPS and
12 also into the DAS, diverse automatic actuation cabinets
13 through an isolation device. There's four diverse
14 automatic actuation cabinets, within each bistable,
15 logic and output.

16 And the DAS is implemented with
17 conventional discrete logic, relays, latches and other
18 conventional analog electronic devices. Nothing
19 requiring software. So you see the bistable, logic and
20 output, and then the output of each cabinet is combined
21 within the safety logic system and then is sent to a
22 component for actuation.

23 MEMBER BROWN: This is where I asked the
24 question before about how does, you're using a common
25 part. There's this diverse actuation system and yet

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 we're using a common part of the, the PIF is located
2 within the overall SLS envelope.

3 And I guess my normal thought process on
4 a diverse system would have bypassed anything associated
5 with the normal path. I mean what is the argument for
6 saying, well, I can depend on these last little parts
7 of the output logic not being, that it's the same
8 technology for either the automatic or the diverse trip
9 and they're not even separate units, they're the same
10 units?

11 MR. SAMPLES: Well, the same unit, it's the
12 same for ESF --

13 MEMBER BROWN: That question's the same.

14 MR. SAMPLES: For reactor trip we do use
15 two different actuations.

16 MEMBER BROWN: The reactor trip part I
17 don't disagree with, but it's for the ESF DAS --

18 (Crosstalk)

19 MR. SAMPLES: -- interface module for DAS.

20 Mr. Scarola, do you --

21 MR. SCAROLA: I'll be happy to answer. The
22 PIF module is conventional binary digital devices, CMOS
23 logic, no software.

24 MEMBER BROWN: I understand that.

25 MR. SCAROLA: So simply based on BTP 7-19

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 which says you have to take a common cause failure in
2 digital devices, this is not a digital device. But then
3 beyond that this device --

4 MEMBER BROWN: Well, it is a digital, I mean
5 it's a combinational logic is what you're doing to
6 trigger these things. It's manual. It's like we had
7 the old-time computers where they were all transistor,
8 or transistor logic or whatever you want to call it,
9 or CMOS logic all on a single chip. It's still a digital
10 device.

11 MR. SCAROLA: Well, let me continue. This
12 is so simple for this device. It has no timers, no
13 latches. It has very few inputs because it's only
14 control of one component. So it's so simple that we
15 can actually test every combination of inputs and outputs
16 and ensure it's 100 percent tested during the design
17 phase. So therefore we can say there is no potential
18 for common cause failure of that device that would impact
19 both PSMS and DAS.

20 MR. TAKASHIMA: That is the common
21 motivating factor of these kind of devices also evaluated
22 in a PRA.

23 MR. SCAROLA: Yes, there is a deterministic
24 side and a PRA side. On the deterministic side --

25 CHAIR STETKAR: Okay, and before you do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that I'm going to rant later on this afternoon about
2 the PRA. The fact of the matter is, it is not evaluated
3 in the PRA, because the PRA does not consistently and
4 completely include the SLS modules. That is
5 a statement of fact. That is not a question. You can
6 go look it up. Go look at the emergency feedwater
7 system, the SLS is not in there. The only place that
8 I could find it is in high-head injection in the PRA
9 models. A fact, not open to discussion. It's on the
10 record. If you want to dispute me, that's fine, but
11 I can show you the --

12 MR. SCAROLA: What the PRA says is that the
13 high-head injection model is representative of all the
14 other ESFAS signal caps.

15 CHAIR STETKAR: I don't care what the words
16 say. I can tell you what the fault trees are, and the
17 high-head injection model does indeed have the SLS
18 modules in it. I couldn't find them anywhere else.

19 MR. SCAROLA: Okay. All right, I
20 understand.

21 CHAIR STETKAR: Now you can continue on
22 deterministic stuff.

23 MEMBER BLEY: But were you linking this to
24 the PRA or you were talking about probabilistic --

25 MR. SCAROLA: No, what I was trying to say

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 is there are two parts to this. There is the
2 deterministic compliance, the BTP 7-19. And 7-19 says
3 if it's 100 percent testable then we do not have to
4 consider it as a common cause failure point. So that's
5 what we have done.

6 But then what you're saying is in some
7 method, and I'm not going to argue with you, I thought
8 we covered this in the PRA on the probabilistic side.

9 CHAIR STETKAR: I think you should put your
10 eggs in your deterministic basket for the moment.

11 MEMBER BROWN: Okay, you used the words 100
12 percent tested in the design phase. Now I mean, is there
13 a process where this is, you've got all this auto-testing
14 and diagnostic stuff going on.

15 This is a single point where all this stuff
16 comes in. It's one set of little voting logic. There's
17 not multiple, multiple units. Okay, it's for one
18 particular, it comes down right to these combinational
19 logic, CMOS, whatever it is, integrated circuits, which
20 I like, okay.

21 But is there a part of you that the
22 end-process test routine that where this gets tested
23 either manually or automatically on a periodic, manually
24 if it's a periodic basis, or is it part of the auto
25 testing? I was unable to find a discussion, and it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 easy not to find this stuff.

2 MR. SCAROLA: There are two parts to the
3 tech specs. There is the part of the tech specs that
4 covers the DAS, and in those tech specs we have
5 surveillance requirements that ensure the DAS signals
6 propagate all the way to the PIF and are received by
7 the PIF. There's actually feedback from the PIF.

8 MEMBER BROWN: What about the output of the
9 PIF?

10 MR. SCAROLA: Then we have, whenever you
11 control the pump or valve, the safety related pump or
12 valve which is part of like a 90-day test for every ESF
13 component, you send the signal through the PIF module
14 in an overlap with the signal from the DAS. So there's
15 an overlap point where both signals come together. So
16 the PIF is fully tested.

17 For the DAS interface every 24 months, but
18 for the normal pump and valve interface control every
19 90 days for in-service testing of the pumps and valves.

20 Because that PIF is the only way that you can reposition
21 a pump or valve is through that PIF module. There is
22 no way around it.

23 When you control a pump or a valve from the
24 main control room, the signal goes from the O-VDU or
25 the S-VDU all the way through all these networks, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 finally generates an output from that PIF. So the PIF
2 is the common point, but it's frequently tested.

3 MEMBER BROWN: Somebody could have
4 designed in an alternate way of initiating the action
5 on those. It's just you didn't, therefore it is a common
6 point. It's not that it couldn't have been done, it's
7 just that it was not done. You're using a common point.

8 I just was looking for an answer as what you all
9 considered satisfactory --

10 MR. SCAROLA: Okay, so let me explain why
11 we have to have a common point. If you've got two systems
12 that are trying to control the same valve --

13 MEMBER BROWN: I understand that point.

14 MR. SCAROLA: -- you've got to have a common
15 point somewhere.

16 MEMBER BROWN: Well, the valve is the
17 common point.

18 MR. SCAROLA: Well, no, because you can
19 have one system saying open the valve and the other system
20 saying shut the valve. So someplace you need to combine
21 those logic signals and establish which one is going
22 to have priority. So you can't just send both signals
23 to the valve because the valve's a mechanical device.

24 MEMBER BROWN: This is part of the DAS.
25 There could have been a way to block, if the DAS is calling

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 for it that takes precedence. I mean there are ways
2 to do that, just you chose this way. And I just wanted
3 a discussion of why and you've given it to me. I'm not
4 telling you whether I agree or disagree, I'm just saying
5 you've given it to me. Thank you.

6 MR. SCAROLA: I'm never satisfied until you
7 agree.

8 MR. SAMPLES: Now you can actuate. You
9 just saw this signal path for automatic actuation of
10 DAS, but you can also manually initiate it from the
11 diverse HSI panel. This bypasses the DAAC panels and
12 go to the safety logic system.

13 And just to state again that the reactor
14 trip for DAS trips the motor generator set while the
15 PSMS trips the reactor trip breaker so there's a
16 diversity of actuation for those components. This is
17 how the DAS functions. The DAS does it immediately --

18 (Crosstalk)

19 MR. SAMPLES: -- acuate components. So it
20 actuates if it detects an accident and the safety
21 components are not actuated successfully. So you see
22 logic here. Down here you see DAS monitoring several
23 parameters. We'll discuss those in a minute.

24 You see signal trip statuses from the PSMS.
25 DAS says it looks like there's an accident. It looks

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 like PSMS should do something, and it monitors whether
2 it does it or not. And it waits for a short amount of
3 time, and after that time if it doesn't see that its,
4 for instance, reactor trip breakers have been tripped,
5 then it takes action to trip those breakers. In this
6 case, for the diverse reactor trip.

7 MEMBER BROWN: Before you change that, the
8 key words in here are "and safety components are not
9 actuated successfully."

10 MR. SAMPLES: Yes.

11 MEMBER BROWN: And this is discussed in a
12 couple places, the prevention of diverse reactor trip,
13 turbine trip --

14 (Crosstalk)

15 MEMBER BROWN: I mean you're using the
16 actual auxiliary contacts on the reactor trip breakers
17 to do this, so that's good.

18 But fires and other stuff could contaminate
19 switch contacts such that they did not provide the
20 closure such that you get an indication of it, or they
21 might show give you closure when you really haven't
22 activated it due to contamination. And now because of
23 that I have blocked myself from using the DAS system
24 to actually complete the actuation.

25 So I don't know that I'm out to lunch or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not. I just didn't like the idea of having something
2 tell the DAS not, that it's annulled and cannot control
3 that safety function. And that just kind of went against
4 the grain.

5 And I understand the thought process a
6 little bit, but to me the diverse actuation system should
7 always be there and not be prevented. Are we smart
8 enough to always consider all the circumstances under
9 which that prevention signal would not prevent it when
10 we don't want it to prevent it.

11 (Crosstalk)

12 MR. SCAROLA: Well, a couple of issues.
13 First of all, the operator can manually actuate all these
14 components completely around the automation of DAS, so
15 there is a diverse manual method of actuating everything
16 in the diverse actuation system.

17 It's shown in the previous figures if you
18 want to go back to that. So if, in fact, the automated
19 part of DAS does not work, there is a backup manual part
20 that has its own signal path. That's the first point.

21 Second --

22 MEMBER BROWN: Okay. Well, let me then --

23 MR. SCAROLA: Look at it here.

24 MEMBER BROWN: I'm trying to relate where
25 this reactor trip breaker functionality that you show

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on the next page is reflected in the previous page.

2 MR. SCAROLA: Okay. So all this logic that
3 you see in this page, if we now go back to the previous
4 page, is what you see in bistable and logic blocks and
5 the output block on the first page. That's the automated
6 function.

7 MEMBER BROWN: Okay, so the other switch
8 you show, permissive switch that actuates a relay, which
9 closes a contact which, so that's your fallback from
10 that.

11 MR. SCAROLA: That's your final fallback.
12 The other point I wanted to make is that all these
13 interfaces are under tech spec control, so they are all
14 periodically tested. All these manual inputs into DAS,
15 everything is tested as part of the DAS tech specs,
16 periodic tech specs.

17 So you're right. I mean over time you can
18 get random failures in auxiliary breaker contacts, but
19 they would be picked up during the periodic surveillance
20 tests.

21 MEMBER BROWN: I'm more comfortable with,
22 I recognize this. I mean I saw this and I looked at
23 that, I just didn't connect the dots between my
24 discussions. So sorry about that. I appreciate your
25 patience with me.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SCAROLA: No problem.

2 MR. SAMPLES: This table shows you the
3 different components that are actuated by the DAS. You
4 can see on the right side that all of them can be manually
5 actuated from the main control room, and several have
6 automatic actuations.

7 These are the variables monitored by DAS.
8 If you take a look at the pressurizer pressure and steam
9 generator water level, the asterisks are telling you
10 that these are the two different variables monitored
11 to initiate automatic actuation.

12 Now DAS has three automatic diverse reactor
13 trip and ESF actuation signals. These are the high
14 pressurizer pressure, low pressurizer pressure, and low
15 steam generator water level. These signals were
16 selected to be the minimum set required to mitigate
17 occurrence of a Chapter 15 AOO or postulated accident
18 concurrent with a common cause failure.

19 The adequacy of these three reactor trip
20 and ESF actuation signals for the DAS is demonstrated
21 by the defense-in-depth and diversity, D3, coping
22 analysis. Now the D3 coping analysis demonstrates
23 pressure boundary integrity, core coolability and
24 offsite dose limits are maintained for Chapter 15 events
25 with concurrent common cause failures.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The analysis considers both partial
2 actuation and failure to actuate with false indications.

3 With partial actuations, the AOOs and postulate
4 accidents are analyzed with the failure of both the PSMS
5 and the PCMS and a failure of only the PSMS.

6 What we're concerned with is failures that
7 partially, partial failures that block the DAS which
8 could occur if you have conflicting commands, erroneous
9 blocking signals, or erroneous actuation of components
10 not monitored by the DAS.

11 The failure to actuate with false
12 indications that the actuation has actually occurred,
13 the analysis demonstrates this would actually require
14 a common cause failure of multiple software blocks which
15 is beyond the scope of Branch Technical Position 7-19.

16 There's an open item associated with this, and MHI is
17 justifying the inputs and assumptions of the D3 coping
18 analysis in response to this open item.

19 The DAS has augmented quality. It's an
20 augmented quality, non-safety system as defined by
21 Generic Letter 85-06. The attributes of the augmented
22 quality program for the DAS are, it's designed using
23 a nuclear quality program that meets the US-APWR quality
24 assurance program descriptions and the guidance of the
25 Generic Letter 85-06; uses components with a history

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of successful operation; uses components commonly used
2 in conventional non-digital safety systems; the design
3 process includes an independent review; and the seismic
4 testing method is equivalent to that for seismic category
5 1.

6 Now we're going to move into how the I&C
7 systems conform to the essential safety criteria. These
8 different safety criteria have been aggregated from
9 multiple sources such as regulatory guides and IEEE
10 standards.

11 Now the DCD and the related I&C reports
12 demonstrate the PSMS design conformance to the essential
13 safety criteria. The overall conformance to the
14 essential safety criteria is described in DCD Chapter
15 7. That's in Section 7.1.4. And the detailed
16 conformance is described in the technical report, "Safety
17 I&C System Description and Design Process," and Section
18 3 in the appendices listed here.

19 PSMS or redundancy of the PSMS, PSMS
20 consists of four redundant and independent trains, A
21 through D. The RPS performs its function with any two
22 out of four trains tripped. The ESFAS, SLS, the
23 communication subsystem of the PSMS, and the human system
24 interface perform their function by any two out of four
25 trains to actuate safety systems, or one out of two trains

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 depending on how the mechanical system is designed.
2 Essentially we'll use two out of four if we need to
3 actuate an active component. For isolation we use one
4 out of two.

5 Now for independence. The independence of
6 the redundant PSMS divisions is achieved through four
7 different methods. Physical independence, electrical
8 independence, communication independence and functional
9 independence. The methods for ensuring physical,
10 electrical and communication independence are common
11 throughout the entire PSMS. The functional
12 independence on the other hand is application dependent.
13 It's done different ways for each application.

14 Now for physical independence, this
15 provides protection, for instance, against things,
16 flood, fire. Also provides, just meets some operational
17 environment requirements. You see that the four PMS
18 trains, these are A, B, C, and D, are separated into
19 four separate I&C rooms around the main control room.

20 Four reactor trip breaker trains are separated into
21 two separate trip breaker rooms, 1 and 2.

22 MEMBER BROWN: Are they adjacent to each
23 other, physically, in the plant design?

24 MR. TAKASHIMA: Yes.

25 MEMBER BROWN: Okay. The way you laid out

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the other I presumed that that meant the same thing.
2 When you saw a wall between the two they weren't
3 separated, so I presumed they were in the same, just
4 adjacent to each other.

5 MR. SCAROLA: But with a firewall between
6 --

7 MEMBER BROWN: Yes, I understand that.
8 I'm just saying they're adjacent to each other, with
9 a firewall or whatever.

10 MR. SAMPLES: The motor generator sets are
11 in the rooms, motor generator set rooms, separate from
12 both reactor trip breaker rooms. And finally, the
13 non-safety, the PCMS is located in the non-safety I&C
14 room.

15 For electrical independence, each PSMS
16 train is electrically independent from each other and
17 from the non-safety system. I see three different types
18 of electrical isolators here in the red, the green, and
19 the blue.

20 Starting with the red, these electrical
21 independence between the PSMS trains, between the PSMS
22 and the PCMS, and between main control room, remote
23 shutdown room, and I&C equipment rooms, is maintained
24 through the qualified fiber optic data cables. These
25 are again the red lines you see in different places,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 here.

2 For the green lines, for instance, here and
3 here, electrical independence between the PSMS and the
4 DAS is maintained through qualified conventional
5 electrical signal isolation devices.

6 Following the blue lines, there's one up
7 here. The electrical independence between the PSMS
8 power sources is maintained through conventional
9 electrical power isolation devices.

10 Here you see a figure of optical fiber
11 isolation. The optical fiber is used for the digital
12 interfaces in the PSMS. This is for the, sustains just
13 the data links and the control networks. You see, you
14 have an optic cable in the middle. You have a
15 transmitter on one side and receiver on the other.

16 You go from electrical to optical through the
17 cable then back from optical to electrical with physical
18 separation. Now these fiber optic cables are
19 constructed using only non-conducting materials, and
20 that provides inherent blocking of any electrical
21 faults.

22 Conventional isolation modules used for
23 hardwired interfaces for the DAS and to and from the
24 PSMS, these isolation modules are qualified for
25 non-safety side faults for both the AC and DC, the value

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you see, and for both transverse and for most common
2 modes by the isolation tests.

3 On the left you'll see an analog isolation
4 module. This is used for safety side and non-safety
5 side, the isolation amplifier and current limiter.

6 MEMBER BROWN: That would be the green?

7 MR. SCAROLA: On the previous slide.

8 MR. SAMPLES: Now on the other side we have
9 a digital isolation module essentially going the other
10 way from the non-safety side back to the safety side,
11 photo coupler and an over voltage protection design.

12 Now for communication independence, the
13 data is communicated between PSMS divisions, and between
14 the PSMS and the PCMS. Communication independence
15 allows two different digital systems to exchange data
16 while ensuring that there's no potential for one of these
17 digital systems to alter the execution of the other one
18 in any way.

19 The PSMS meets all the communication
20 independence guidance of ISG-04. Now there's only two
21 types of on-line inter-division communication interface
22 methods used in the PSMS. There's the point-to-point
23 data link. It's for communication between the RPS
24 trains, between the RPS, the ESFAS, and multi-drop
25 networks used by the unit bus interface to the PSMS.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Both types of communication assure independence using
2 two-port memory, separate communication processors
3 separate from the functional processors, and unalterable
4 memory.

5 What you're seeing in this figure on the
6 top here is a picture of one computer sending data to
7 another one. The one on the left goes through an optical
8 fiber into a data communication interface module, and
9 then there's a CPU module on the right.

10 Now all communications --

11 MEMBER BROWN: May I ask one, I just want
12 to clarify something to make sure I understand it. Go
13 back to your previous slide.

14 MR. SAMPLES: This one.

15 MEMBER BROWN: Point-to-point data link
16 between RPS trains.

17 MR. SAMPLES: Yes.

18 MEMBER BROWN: Okay, I got that. That's
19 where you're sending trip data from one to the other,
20 and between RPS and ESFAS. Now that's within a train.

21 On your diagrams, I did not see with external, from
22 train to train communications from an ESFAS CPU unit
23 to another train anywhere.

24 MR. SCAROLA: Go to Slide 12.

25 MEMBER BROWN: That's what I was looking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 at. I don't see anything going from the safety buses
2 within Train A, the ESF is, there's no, it's not like
3 if I go back and look at the RPS block where there's
4 communication between Train A and Train B from the ESF
5 subsystems A1 and A2.

6 MR. SCAROLA: Okay. If you look at this
7 figure you see four divisions of the RPS, right?

8 MEMBER BROWN: Yes.

9 MR. SCAROLA: Each one of those divisions
10 is sending data links out to the A-train of the ESF.

11 MEMBER BROWN: I got that.

12 MR. SCAROLA: And to the B-train and to the
13 C-train and to the D-train.

14 MEMBER BROWN: I understand that. That's
15 coming from the RPS to Train A, B, C, and D, of the ESFAS.

16 MR. SCAROLA: I think part of the
17 inter-division that we're talking about --

18 CHAIR STETKAR: I think part of the
19 confusion is, RPS here is not reactor trip. One function
20 of RPS is reactor trip.

21 MEMBER BROWN: No, I understand that. I
22 got that John, okay. I'm looking at this from a, where
23 do I have to look for data communications? They go
24 through all this laundry list, and I'm not going to talk
25 about it because they cover it on Slide 67.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: But my understanding, let
2 me make sure I understand it, because my understanding
3 is the only inter-train communication A, B, C, D, is
4 at the RPS level.

5 MEMBER BROWN: That's what I was saying.

6 CHAIR STETKAR: Is that correct?

7 MR. SCAROLA: That's not correct.

8 CHAIR STETKAR: That's not correct?

9 MR. SCAROLA: In this picture, that's what
10 I'm trying to point out. What you said is right for
11 the parameter voting. If I want to vote on pressurizer
12 pressure I do that in the RPS.

13 But once an RPS decides it needs to actuate
14 an engineered safety feature, that RPS signal now goes
15 down to the ESFAS which you see in this drawing. And
16 the ESFAS does a second layer of voting, two out of four
17 voting, from all four RPS trains.

18 CHAIR STETKAR: So each RPS train goes to
19 all four.

20 MR. SCAROLA: These are all data links but
21 from RPS to ESF.

22 CHAIR STETKAR: Okay, thanks. I'm sorry.
23 Yes, now I get it. I'm sorry, Charlie.

24 MEMBER BROWN: I understand this. This is
25 still RPS trains feeding the ESFs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 MR. SCAROLA: Correct.

2 MEMBER BROWN: There's no links, ESF
3 subsystem to ESF subsystem, they come from the RPS.
4 I understand. That's the point I was trying to make
5 sure I understood.

6 MR. SCAROLA: Correct.

7 MEMBER BLEY: But there's no
8 intercommunication at the ESF --

9 MEMBER BROWN: There's no
10 intercommunications at the ESF submodule level. It all
11 comes from RPS. That's all I was trying to make sure
12 I understood. I understand the voting point. It's a
13 matter of where I'm going to pay attention to later which
14 you cover on Slide 67. So I'll wait until I get there
15 instead of interrupting this conversation. You've been
16 very patient. Okay, where are we?

17 CHAIR STETKAR: We're at 49 or 50.

18 MEMBER BROWN: We're not at 67.

19 CHAIR STETKAR: We're not on 67.

20 MR. SAMPLES: I think we just moved past
21 49 into 50. I was explaining that this figure is, again,
22 it's one computer talking to another and the data was
23 going across the fiber optic cable. Data communication
24 interface module here is separate from the CPU module.

25 Now all communication uses a two-port

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 memory. The two-port memory, you can see it here.
2 There's a separate communication controller. It has
3 its own processors here in this module. There's a
4 separate CPU function process, it's over here in the
5 CPU module.

6 Now the functional processor and the
7 communication processor accesses its two-port memory
8 asynchronously. What's going to happen is, this data
9 is going to be coming into the communication module.
10 It's in the buffer. The communication controller is
11 going to write it to the two-port memory.

12 Now going on asynchronously, whenever the
13 CPU module needs information it will go over here and
14 read the information out and pull it into the CPU module
15 and use it as it is necessary. Now these signals are
16 transmitted. They have a predefined format, length,
17 and message content. And anytime a signal doesn't meet
18 those requirements it's just ignored.

19 If you want to know more about the control
20 network, these control networks are the multi-drive
21 networks, the ones for the unit box and the four different
22 safety buses.

23 MEMBER BROWN: Let me ask, let me go back
24 a slide again. And I think I got this out of the reading
25 of it, I just want to confirm my understanding.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The F-ROM is where you actually operate and
2 control the, you don't download your basic, your
3 operational application code into a faster, more speedy
4 RAM or anything like that. I thought I saw the words
5 "operate out of ROM." So my thinking is correct?

6 MR. SCAROLA: Correct.

7 MR. SAMPLES: Yes. Yes. So the control
8 network, this is the multi-drop networks, the ones we
9 use for running across the safety bus. They use the
10 IEEE standard 802.17 Resilient Packet Ring protocol.

11 So what you're going to see here on the left
12 side is the network operating normal conditions. There
13 are several nodes. For each node you have
14 communication, control network interface module here
15 with communications going on. You have a controller.

16 You notice there's a two-port network in
17 the interface module. They're showing six different
18 of these nodes. Each of these nodes through
19 communication control are going through an optical
20 switch. We have the equivalent of point-to-point data
21 links so, for instance, this node here on the bottom,
22 a point-to-point link to the one up here. The same link
23 here.

24 They're connected redundantly in the sense,
25 you know, not just going clockwise, you also have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 counterclockwise connections. The signal is
2 transmitted continuously regardless of what the data
3 change is.

4 And what each node is going to do is it
5 maintains an entire memory map of the entire network.

6 And then when they transmit it, they transmit that whole
7 memory map to the next, and each node updates the
8 information as necessary. Memory information goes into
9 the two-port network and it's there, so when the
10 controller needs to access it, they access it again
11 asynchronously and just reads out what it needs.

12 To the right you see an example of what
13 happens when the node fails, say, the bottom middle one
14 fails. In this case the network will adjust, bypass
15 the failed node to ensure that you have data
16 communication continuing.

17 In a case where you have, say, a failure
18 of another module, a switch, a cable, some other
19 component of the network, then the network will adjust
20 using the IEEE Resilient Packet Ring protocol.

21 MEMBER BROWN: So the redundant paths are
22 both bypassed so that you don't use the redundant path
23 for the data flows?

24 MR. SAMPLES: They're transmitting the
25 same information back and forth both clockwise and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 counterclockwise all the time.

2 MEMBER BROWN: Even though that node has
3 been lost?

4 MR. SAMPLES: Yes. It just automatically,
5 the switch automatically adjusts to bypass, with this
6 example.

7 MEMBER BROWN: Is that an active switch or
8 a default, loss of power?

9 MR. SCAROLA: It's a passive optical prism,
10 where a spring holds the prism in one position and if
11 it loses power, or if the node tells it that it's not
12 being powered any more, then it's like a relay. It just
13 springs back to a alternate position.

14 MEMBER BROWN: An optical relay function?

15 MR. SCAROLA: Basically an optical relay.
16 So when it springs back it self-heals as you see in
17 that other picture. Normally --

18 MEMBER BROWN: Well, it doesn't heal, it
19 just bypasses the node.

20 MR. SCAROLA: That's healing. That's
21 self-healing. It self-bypasses that node.

22 MEMBER BROWN: That's fine.

23 MR. SCAROLA: Now we also have the ability
24 to manage a completely broken optical cable, or if the
25 optical switch completely fails, because you have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 bi-directional data path counterclockwise as well as
2 clockwise. So if a node can't send data via the
3 clockwise direction because the cable actually broke,
4 it'll send it the counterclockwise direction.

5 MEMBER BROWN: If a prism didn't switch
6 properly, then you'd break both paths.

7 MR. SCAROLA: That's effectively a broken
8 cable. That's the same as a broken cable. So if the
9 prism doesn't switch, now you have a signal path to
10 another node via the opposite direction on the ring.
11 Because you can get from any node to any other node via
12 two paths, counterclockwise or clockwise.

13 MEMBER BROWN: It's just you don't have a
14 circular path any more.

15 MR. SCAROLA: You don't have a circular
16 path any more. You just have a point-to-point path.

17 CHAIR STETKAR: Ken, do the operators know
18 when those contingencies have been invoked? I mean do
19 they get some sort of trouble alarm in the control room?
20 I mean obviously, you know, there must be LEDs or
21 something on the individual cards --

22 MR. SCAROLA: Well, they'll get alarms in
23 the control room if there is any self-diagnostic detected
24 failures. The extent that operators will actually
25 repair these versus technicians --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Operators will not do this.
2 It's just so that they're aware of that they might be
3 in a degraded condition, that's all.

4 MR. SCAROLA: One nice thing about this,
5 that design, is it's a handful of parts that's used
6 everywhere in the whole plant. So it's not
7 inconceivable that we can train operators to go get the
8 spare part and replace Module XYZ. It's not
9 inconceivable. We're not there yet, but --

10 CHAIR STETKAR: It's not inconceivable,
11 but I wouldn't bet the farm on it.

12 MEMBER BROWN: Well, aren't these A, B, C,
13 D, E, and F, aren't those equivalent of a pull-out card
14 in your card rack?

15 MR. SCAROLA: Well, yes.

16 CHAIR STETKAR: That's okay. Operators
17 typically in nuclear power plants don't go fool with
18 that stuff.

19 MEMBER BROWN: Well, that's fine. I'm
20 just saying from the ability to recover at some point,
21 it's not a major deal to do it.

22 CHAIR STETKAR: No.

23 MR. SCAROLA: Self-diagnostics are going
24 to tell them Cabinet 4, Rack 3, Module 6 has failed,
25 and there is only about six different modules in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 whole system. Not beyond comprehension, I mean, maybe.
2 Maybe. We're not there yet.

3 MR. SAMPLES: Okay, I'll move on down.

4 MEMBER BROWN: You didn't talk about the
5 real-time performance of this network. You said you
6 were going to talk about it at some point.

7 MR. SCAROLA: Yes, this is probably the
8 best place to talk about it. This is a one-gigabit
9 network, which means all data is updated every 100
10 milliseconds on this network at the maximum node capacity
11 of 256 nodes. We won't have 256 nodes, but if we did,
12 it's 100 millisecond update time for all data every
13 cycle.

14 And as Pat said, the entire memory map is
15 transmitted from node to node and it's a fixed memory
16 map. So each node knows where its data is in that memory
17 map, and when it gets the map it updates its data, and
18 then passes the whole map on to the next node.

19 MEMBER BROWN: So what you're telling me
20 is the safety bus, is that the one I'm talking about?

21 It's within this, is this the internal CPU
22 communications? I asked a little while ago about bus
23 mechanics, you know, the server, the unit bus, and the
24 safety bus. You said the unit bus is the same as the
25 safety bus. Is this the safety bus?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SCAROLA: This is the control network
2 technology. It's used for both the safety bus and the
3 unit bus. It's only one MELTAC technology for
4 multi-drop data communication that we call a control
5 network in the MELTAC language. In US-APWR, we call
6 it one application of this control network is the safety
7 bus. Another application of this same network
8 technology is the unit bus.

9 MEMBER BROWN: Okay, you said but the
10 refresh is every 100 milliseconds.

11 MR. SCAROLA: Correct.

12 MEMBER BROWN: That's a long time.

13 MR. SCAROLA: Come on.

14 MEMBER BROWN: Well, I mean you're
15 processing data. I mean when I look at your complete
16 input to output data processing, I think the number you
17 mentioned a little awhile ago is somewhere, it's like
18 300 milliseconds from input to output. That means 100
19 milliseconds is eaten up on this data transmission path
20 to refresh all of your plant parameters. And then if
21 you look at the ten-bucket sample period, that for
22 application code, I'm trying to figure out where all
23 that works into your, does that become involved in the
24 time response?

25 MR. SCAROLA: It's all considered in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 time response --

2 MEMBER BROWN: Yes, I understand that.
3 But now the MELTAC processing for application code said
4 it could be anywhere from 20 milliseconds to 100, to
5 one second, excuse me, 1,000 milliseconds. So somewhere
6 you're getting data in, and I'm trying to figure out
7 how often you're getting data that gets into the
8 calculations, the functional calculations for your
9 parameters.

10 MR. SCAROLA: Okay. Why don't we discuss
11 that when we show you the slide on response time
12 propagation.

13 MEMBER BROWN: That's fine. I'm just
14 bringing the point up, that's all.

15 MR. SCAROLA: It's a better place to talk
16 about it.

17 MEMBER BROWN: Okay.

18 MR. SCAROLA: We have a slide specifically
19 on response time.

20 MR. SAMPLES: It's several slides ahead,
21 but yes, we do get to it.

22 Some more communication independence, this
23 time independence from signals coming from outside that
24 could reprogram. Now the on-line Flash-ROM is protected
25 from alteration in this way. See here, the on-line

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 chassis? When the CPU module is inside this, the write
2 enable signal is not enabled. You can't write to it.

3 You can't write to it if it's inside. In
4 order to write to the F-ROM you have to actually pull
5 it out, put it inside a dedicated reprogramming chassis.

6 In this chassis there's connection made that enables
7 the write enable signal, and allows you to reprogram
8 it using the MELTAC engineering tool.

9 Similarly, the ROM and the FPGA is only
10 reprogrammable outside of the module chassis but only
11 at the factory. There is no reprogramming chassis for
12 them. So essentially these features are ensuring
13 there's no potential for inter-divisional data
14 communication to alter the software either basic
15 software or application software inside these CPU
16 modules on-line.

17 MEMBER BROWN: Okay, let me ask one
18 question. I don't have any problem with what you're
19 telling me here, it's just I mean these are flash
20 electrically erasable, read-only memory, at least that's
21 according to the words, which electrically erasable
22 means electrically erasable. You can change it.

23 And I guess if I'm in the application mode,
24 I've got it in the normally installed configuration
25 operationally, how have I bypassed or prevented some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 input coming in and modifying the set points application
2 code, what have you, which are stored in that ROM?

3 I mean it is electrical erasable so, now
4 there are ways to prevent that but the ones I'm familiar
5 with, and I'm not familiar with all of them, are it's
6 the way it's hardwired to make sure that that input port
7 is not accessible at all, or it's grounded or something
8 like that.

9 And there was no discussion of that as to
10 why that was, how it just said it couldn't be changed.

11 That's all it said. And sometimes I get just like John.

12 There's a detail that you'd like to have as to how do
13 you, in fact, do that? Is it a hardware or is it a
14 software turn-off of that bit that allows it to be
15 electrically erased?

16 MR. SAMPLES: No, it's hardware. I may not
17 have explained this clearly, but you do have to have
18 a hardware signal that actually enables you to write
19 to the module to the F-ROM, and it's disabled within
20 the on-line chassis. It just isn't enabled. There's
21 no connection made and you can't make it.

22 MEMBER BLEY: When it's plugged into the
23 cabinet you can't get to it.

24 MR. SAMPLES: The on-line chassis, yes.

25 MEMBER BROWN: The pin is disabled.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCAROLA: That's what this figure is
2 trying to show. The figure on the left is showing that
3 the write enable pin of the F-ROM is an open circuit.

4 MEMBER BROWN: So it's physically when you
5 transfer it, you --

6 MR. SCAROLA: Now we close the circuit when
7 we --

8 MEMBER BROWN: I just wanted to make sure
9 it wasn't a program when you plug it in now it feeds
10 back and says, okay, you can't write it any more, which
11 can get lost.

12 MR. SAMPLES: The hardware is open signal.
13 You can't write to it even if you were to connect and
14 try to write to it. You have to pull it out to the
15 dedicated chassis which --

16 MEMBER BROWN: Yes, I read all that part.
17 When it's in the chassis, the operational chassis, how
18 did you ensure it? You've answered the question. It's
19 an open circuit.

20 MR. SAMPLES: Okay.

21 MR. SCAROLA: This was originally an area
22 where we did not fully comply with ISG-04. And this
23 was a design change we made to comply with ISG-04 which
24 strictly says you must have a hardware method of
25 preventing rewriting.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BROWN: Good.

2 CHAIR STETKAR: Now let me -- no, no. Go
3 to the next slide and stop. There are five slides on
4 functional independence. I have a meeting that I must
5 attend at noon. Is there a chance that we can get through
6 these five slides in 15 minutes? I see shaking of heads.

7 I don't want to necessarily break a conceptual topic
8 in the middle because people have to run off for lunch.

9 So now we have another little bit of a sticky
10 situation is that we have another closed session
11 scheduled at 1 o'clock with the staff. And for a variety
12 of reasons I don't want to interrupt that.

13 So what I'd like to do now is break for
14 lunch. MHI and company, if you could return from lunch
15 at about 1:00, be outside at 1:15. We have to close
16 the meeting to you at 1:00 for a variety of reasons.

17 MR. TAKASHIMA: And also for Luminant.

18 CHAIR STETKAR: And Luminant also, anybody
19 who is not staff.

20 MEMBER BLEY: But it's on this topic?

21 CHAIR STETKAR: It's on US-APWR. So just
22 to make it clear, we'll break for lunch now. We'll ask
23 the staff to return at 1 o'clock, and we'll ask everyone
24 else to be available outside at 1:15. We don't know
25 whether it's going to run 15 or 20 minutes. I'm not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 going to let it run longer than 20 minutes. If I can
2 hold it to 15 we'll reconvene at 1:15. And with that
3 we'll recess for lunch.

4 (Whereupon, the foregoing matter went off
5 the record at 11:47 a.m. and went back on the record
6 at 1:01 p.m.)

7
8
9
10
11
12
13
14
15
16
17
18
19
20
21 A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

22 (1:37 p.m.)

23 CHAIRMAN STETKAR: Okay, we're back in
24 session. And this is an open session. So we're
25 continuing where we were this morning. Back to you,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Richard.

2 MR. SAMPLES: Okay, let's move on to
3 functional independence now. Each PCMS division
4 receives data from outside its own division. The data
5 comes from other PSMS divisions, from the PCMS, and from
6 DAS.

7 Functional independence ensures that the
8 data received from the outside divisions can't adversely
9 affect the safety function being performed within that
10 division.

11 We explained this functional independence
12 individually for each sub-system of the PSMS, RPS, ESFAS,
13 and SLS, because it's done differently. For detailed
14 conformance, that's described in the Technical Report,
15 Safety I&C System Description and Design Process.

16 Now, this figure here depicts functional
17 independence as we achieve it in the RPS and the ESFAS.

18 You see that the following signals are received from
19 across the PSMS train boundaries, reactor and ESFAS
20 partial trip status signal for the two-out-of-four trip
21 voting logics.

22 The ESFAS status signal of each trip
23 parameter for bypass interlocks, bypass allows the
24 channel be tested and allows failed channel to be taken
25 out of service. Now, authenticated messages can have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 spurious data or frozen data. And each train --

2 CHAIRMAN STETKAR: Up front, just be
3 careful to not hit your microphones, because our recorder
4 has very, very sensitive things in his ears and it really
5 bothers him. Thank you.

6 MR. SAMPLES: So authenticated messages
7 can have spurious data or frozen data, and each train
8 protects itself.

9 Essentially, each PSMS train is assuming
10 that the data coming from another train, it could be
11 wrong, it could be failed. So it protects itself.
12 There's no reliance at all on the data coming from the
13 other division being correct.

14 And these are some ways that each train
15 protects itself. First of all, for a partial trip the
16 two-out-of-four voting logic prevents a spurious trip
17 and ensures a trip when there are single failures.

18 And if you have all inter-division data
19 communication to fail, each division will initiate a
20 reactor trip and ESFAS.

21 Now, the bypasses, there's first-in
22 blocking logic that prevents having more than one bypass
23 channel. So once you have the first one bypassed you
24 can't have bypasses at the others.

25 CHAIRMAN STETKAR: Something you said, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I want to make sure I understand it. You said if all
2 inter-division data fails, each division will initiate
3 a reactor trip and ESFAS. Will it initiate an ESFAS
4 signal? I understand it'll initiate a reactor trip.
5 Will it initiate an ESFAS signal?

6 MR. SAMPLES: It does initiate a reactor
7 trip. It does --

8 (Off microphone comments)

9 MR. SAMPLES: In this case it does initiate
10 --

11 CHAIRMAN STETKAR: If communications fail
12 you get a high output for ESFAS actuation.

13 MR. SAMPLES: You'll get an actuation
14 signal.

15 CHAIRMAN STETKAR: Oh, okay.

16 MR. SAMPLES: Now, the following HSI
17 signals are transmitted to the PSMS from the operational
18 VDUs that are part of the non-safety PCMS. These are
19 component position commands, maintenance bypass
20 commands, operating bypass commands, ESFAS reset
21 commands, and component lock commands.

22 Now for all of these signals, the
23 unalterable priority logic within the PSMS ensures that
24 each PSMS division protect itself so that safety function
25 can't be adversely affected.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BROWN: How do they get there? I've
2 got to go back and look at one of your diagrams.

3 MR. SAMPLES: You're asking about --

4 MEMBER BROWN: Yes. You've got all this
5 stuff, I guess this connects a lot of dots, or some dots,
6 ESFAS reset commands, component position commands.

7 MR. SCAROLA: These are the signals that
8 come from the O-VDUs, the operational VDUs, via the unit
9 bus.

10 MEMBER BROWN: And then down to the safety
11 bus?

12 MR. SCAROLA: And then down into the COM,
13 then into the safety bus, and then back to the RPS.

14 MEMBER BROWN: So in order to do that they go into
15 that safety bus, I'll just refresh my memory. I have
16 to go back to that control network technology. That's
17 the concept that's used, right?

18 MR. SCAROLA: Well, you can --

19 MEMBER BROWN: And again, it's been awhile
20 since I looked at this kind of stuff, that's a LAN.

21 MR. SCAROLA: That was a resilient packet
22 ring.

23 MEMBER BROWN: I have no idea what the
24 difference is. But you showed six data input devices.
25 I guess there could be more. But they are all dumping

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 information onto that, one going in one direction, the
2 same data going the other direction.

3 So they're all dumping the information onto
4 those two buses. Something's controlling the timing.

5 Can you saturate that bus in terms of how is that
6 prevented?

7 MR. SCAROLA: All data's transmitted every
8 cycle. And there's a packet of data where the first
9 section of that packet represents the first node on the
10 network.

11 The second section of the packet represents
12 the second node all the way up to the nth node on the
13 network, up to 100-and-something nodes.

14 MEMBER BROWN: You showed six, right?

15 MR. SCAROLA: Yes. We only showed six.
16 You could have as many as 100-something nodes. But every
17 data map is the same. It's not dynamic. It's a fixed
18 location in memory.

19 So what happens is when a node needs to
20 update data, when it needs to send data, it puts new
21 data in its section of the packet and then just passes
22 the whole packet onto the next node.

23 So as the packet of data goes around, each
24 node is updating its piece of the packet. But the packet
25 is the same every time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BROWN: Its' fixed. It's a fixed
2 number of bits, bites, whatever it is. The field length
3 is fixed.

4 MR. SCAROLA: Fixed, and the data rate is
5 fixed.

6 MEMBER BROWN: So the only thing that --

7 MR. SCAROLA: And the destination is fixed.
8 Now remember, if I'm a node, I only send to the guy
9 next to me. That's as far as it goes. It's a
10 point-to-point data link. Then he sends it on to the
11 next guy.

12 MEMBER BROWN: But he adds his onto it.

13 MR. SCAROLA: He doesn't add, he updates
14 his piece. He updates his piece. He doesn't add
15 anything. Because that data's always there.

16 (Crosstalk)

17 MEMBER BROWN: So he would take whatever
18 part of that packet is his node's territory --

19 MR. SCAROLA: Correct.

20 MEMBER BROWN: -- or field length.

21 MR. SCAROLA: To make it right.

22 MEMBER BROWN: He updates that field length
23 and it just goes into the -- he replaces the old with
24 the new.

25 MR. SCAROLA: Right. And it may be exactly

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the same data. Because a lot of the data, cycle to cycle,
2 will never change.

3 MEMBER BROWN: Yes, I understand that.

4 MR. SCAROLA: But he still writes it, no
5 matter what. He still updates it. He still updates
6 with the same data again, over, and over, and over again.

7 So the data transmission is completely deterministic.

8 MEMBER BROWN: So every node, though, is
9 shifting from one node to the next all the way around.

10 They're all doing that simultaneously --

11 MR. SCAROLA: All doing it simultaneously.

12 MEMBER BROWN: -- as they are putting data
13 in. So it's not like a router-based LAN where you can
14 have collisions, and clog up the highway, and you can't
15 get out of one place and into the others.

16 MR. SCAROLA: That's why we can use this
17 technology for the safety bus, because it's 100 percent
18 deterministic.

19 MEMBER BLEY: But if there's an
20 interruption anywhere along, the whole train is
21 derailed.

22 MR. SCAROLA: For some milliseconds, until
23 it reconfigures.

24 MEMBER BLEY: But if it's still going node
25 to node, if there's a problem, if one node --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 MR. SCAROLA: It might never get passed.

2 MEMBER BLEY: Just a minute.

3 MR. SCAROLA: Every five milliseconds this
4 network is sending out, in addition to this data packet
5 that we talked about, each node sends around what's
6 called a protective packet. And that packet goes out
7 every five milliseconds to make sure that every node
8 is still there.

9 MEMBER BLEY: Still there and working.

10 MR. SCAROLA: And if one node is not there,
11 then that packet reconfigures the network to say, hey,
12 that's a missing node.

13 MEMBER BROWN: But that's got to be part
14 of each 100 millisecond packet, doesn't it? It's not
15 a different --

16 MR. SCAROLA: It's actually every five --
17 that goes out every five milliseconds. The 100
18 millisecond packet --

19 MEMBER BROWN: Why didn't it run into the
20 one that's sitting around, hanging around in a node?

21 MR. SCAROLA: Because it's going on in the
22 spaces in between the 100 millisecond transmission.
23 There's a lot of dead time in this network.

24 So what's happening is this node is sending
25 out this protection packet every five milliseconds.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 But at the 100 millisecond point, now it sends out the
2 data packet. And it sends out the five millisecond
3 packet.

4 MEMBER BROWN: So the lines are not blocked
5 --

6 MR. SCAROLA: The lines are never blocked.

7 MEMBER BROWN: -- in between.

8 MR. SCAROLA: Correct. They're not
9 blocked.

10 MEMBER SHACK: But it's bidirectional, so
11 it's sending to this node and to that node.

12 MR. SCAROLA: To the left and to the right
13 --

14 MEMBER BROWN: Yes. It goes to the left
15 and the right.

16 MR. SCAROLA: -- via separate data
17 transmission packs. There's a data buffer to go to the
18 right and a data buffer that goes to the left. So they
19 actually work completely independently as a buffer.

20 MEMBER BROWN: Now the two directions are
21 controlled by a separate machine to keep that data moving
22 through there?

23 MR. SCAROLA: Well, it's what we call the
24 communication interface module, which is one of the
25 modules that you saw --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 MEMBER BROWN: I don't know why I didn't
2 read this thing.

3 MR. SCAROLA: -- that's completely
4 separate from the CPU module, which is actually
5 asynchronously running the safety applications.

6 So you have a CPU that's looking at all the
7 field inputs, looking at all the inputs, and running
8 the bistables, running all the functions for the
9 application, running completely asynchronously from
10 this data communication that's running around the
11 network.

12 MEMBER BROWN: Yes, I understand that.
13 And that was what was bothering me relative to the
14 asynchronous transmission, because they're all running
15 all trains. All CPUs are running on a different clock,
16 well, the same frequency maybe. But they're not timed.
17 They're not synchronized.

18 MR. SCAROLA: Nothing's synchronized.

19 MEMBER BROWN: So everything's just coming
20 in randomly to these based on their particular clock,
21 wherever they are relative to this synchronous
22 performance, asynchronous performance.

23 MR. SCAROLA: We say it a little
24 differently. All the data is being updated in that
25 two-port memory. You might say that's random, because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that's basically going on on this ring.

2 But if I'm the CPU that wants that data,
3 I fetch it when I want it. It doesn't get pushed to
4 me when the network wants it. The network only puts
5 it in this thing we call a two-port memory.

6 And when the CPU that's executing the logic
7 functions says it needs the data, it's ready for the
8 data, it goes and gets it. It's a fetch operation, or
9 what we call a read operation.

10 It's a pull, not a push. There's no data
11 pushed into the CPU. It's pulled from that two-port
12 memory by the CPU. So the CPU controls it 100 percent.

13 MEMBER BROWN: I'm lost.

14 MR. SCAROLA: You're lost.

15 MEMBER BROWN: I understand the difference
16 between fetch and push. But the safety bus is what
17 transmits all that stuff down to the SLS. And that has
18 no pull to it. The data's not there.

19 MR. SCAROLA: Yes, but --

20 MEMBER BROWN: It's got to wait for the
21 packet to go through its 100, whatever it is before it
22 gets around. It's got the flags and the tags that says,
23 hey CPU, this is my data. And he pulls it out at that
24 point. He's waiting.

25 MR. SCAROLA: No. He doesn't wait at all.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 He reads that CPU probably five times before the data
2 actually gets refreshed. He might get the same data
3 over and over again.

4 For example, if the CPU has a 50 millisecond
5 cycle time, but the network has 100 millisecond cycle
6 time, the CPU may read the data, same data, read it again,
7 same data. But, oh, now I read it and it's updated.
8 The CPU has a completely asynchronous cycle.

9 MEMBER BROWN: So it's pulling from
10 whatever packet happens to be there at the time it asks
11 for information.

12 MR. SCAROLA: Correct. Only from the
13 sections of the data map that it has any interest in.

14 It may only be interested in the data from Node 3 and
15 Node 7. Well, it doesn't look at any of the other data.

16 MEMBER BROWN: So it's polling the nodes.

17 MR. SCAROLA: It pulls the data from that
18 memory, not polling, pulling.

19 MEMBER BROWN: I understand what you're
20 saying. You're saying it's not the same as polling.
21 But effectively it's looking into its nodes. And
22 there's information there and it pulls it out.

23 And information may be good information,
24 it may be bad information, or it may be the same
25 information. I don't want to argue about good and bad.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 MR. SCAROLA: Right. The only way we can
2 distinguish good and bad is by data at correctness format
3 language.

4 MEMBER BROWN: I really don't want to get
5 that started, that discussion, right now.

6 MR. SCAROLA: If a source node is saying
7 the valve should be open, but it's a point in time in
8 the plant, that transient, where the valve should
9 actually be closed, it could be an erroneous signal.

10 And that's what Pat is trying to explain,
11 that if it is erroneous, the protection system is going
12 to protect itself against that bad data by doing its
13 safety functions in a higher priority than any of this
14 other data may demand.

15 MR. SAMPLES: I am not sure we've answered
16 your question or not.

17 CHAIRMAN STETKAR: I'm not sure we have.

18 MR. SAMPLES: You still have that puzzled
19 look.

20 MEMBER BROWN: I have a slow integration
21 factor, so --

22 MR. SAMPLES: Maybe we can move on and --

23 MEMBER BROWN: Yes, we ought to move on.

24 CHAIRMAN STETKAR: Move on. He's not shy
25 about going backwards.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SCAROLA: Now we see some typical
2 priority logic. This is for manual operational signals.

3 One example that you're seeing is that the unit shows
4 you safety switches, examples of soft switches and safety
5 VDU, operational VDU. And that's safety VDU over here.

6 Now on the top here, this priority logic
7 here is going to ensure that signals from these safety
8 VDU switches always have priority over any signal from
9 the operational VDU, so that your safety signals always
10 get more priority than any kind of non-safety signal.

11 Down here what's going to happen is there's
12 more priority logic. But this priority logic does
13 something a little bit different. It ensures that
14 automatic signals, signals going through automatic
15 actuation such as the ESFAS here, higher priority over
16 manually initiated signals.

17 The reason that is, these automatic signals
18 are going to be safety, and the manual signals coming
19 from the operational VDU are non-safety. And they could
20 be wrong, could be spurious.

21 CHAIRMAN STETKAR: Let me ask you a
22 question about that. I tried to think through a lot
23 of stuff, but I'm pretty burned out.

24 There are some valves in the plant called
25 the emergency feedwater control valves and emergency

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 feedwater isolation valves that have two safety
2 functions. One is to close and one is to open. How
3 does SLS know which one it ought to do? Because they're
4 both safety functions.

5 MR. SCAROLA: That question is, is it
6 pertinent to the next slide?

7 MR. SAMPLES: I think it's the next slide.

8 CHAIRMAN STETKAR: Is it, okay, sorry.

9 MR. SAMPLES: There is yet one more kind
10 of priority logic. Let's go ahead and talk about it
11 now.

12 MR. SCAROLA: Now, before we go to that
13 slide, the slide we were on is simply discussing priority
14 of safety signals over non-safety signals. We're not
15 talking about state-based where we have to determine,
16 well, if I've got two safety signals --

17 CHAIRMAN STETKAR: Well, I mean in some
18 sense it, yes, this thing knows that, in this little
19 cartoon, it knows that it's better to start a pump than
20 to stop a pump.

21 MR. SAMPLES: In this one, no.

22 CHAIRMAN STETKAR: In this one?

23 MR. SAMPLES: It just knows that whatever
24 safety signal you're getting is why that presumably the
25 safety signal would be doing the correct thing for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 safety. The manual signal could be doing the right thing
2 too. But it just ignores it has a safety signal.

3 CHAIRMAN STETKAR: Okay. Let's get to the
4 other one. Because I still want to understand how those
5 valves know which way they ought to go.

6 MEMBER BROWN: Before you leave that,
7 there's the little box. Look at the operational VDU.
8 There's a start and a stop switch. And there's two
9 little boxes below those. Are those supposedly And
10 boxes?

11 MR. SAMPLES: Yes.

12 MEMBER BROWN: So in order for the
13 operational VDU to start something it has to have a
14 particular signal from the safety VDU. I know it's got
15 a line coming from it via that little X box, whatever
16 the X box is --

17 MR. SCAROLA: What it's saying is --

18 MEMBER BROWN: -- from a start line, which
19 was Ored, from either the start or the stop in the safety
20 VDU.

21 MR. SCAROLA: All it's saying here is that
22 for the operational VDU to do anything, either start
23 or stop, there must be no signal from the safety VDU.

24 If there's either signal from the safety VDU, then the
25 O-VDU is blocked. That's with that inverter going into

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the AND gate means.

2 MEMBER BROWN: Okay, it's a Not then.

3 MR. SCAROLA: That square is an inverter.

4 MR. SAMPLES: These squares with the bar,
5 that's an And. Circular, that's Or gates.

6 CHAIRMAN STETKAR: So all that says, even
7 if you're trying to start it from the safety VDU, you
8 could push start on the operational VDU all you want
9 to. And there will be no output.

10 MR. SCAROLA: There will be nothing
11 happening. If you are controlling from the safety VDU,
12 the O-VDU will do nothing.

13 MEMBER BROWN: What's this software
14 switch? That turns off the software and the other one
15 starts the software, or disconnects your processing?

16 MR. SAMPLES: No. You push a button on the
17 soft switch. Hard switch will be like if you turn the
18 light switch off in a room like this, a hard switch.
19 Push the button on a touch screen, that's a soft switch.

20 MEMBER BLEY: The software is processing
21 it. It's not hard wired from point to point.

22 MR. SAMPLES: It's made out of software.

23 CHAIRMAN STETKAR: They only distinguish
24 that because they have conventional switches that are
25 apparently real switches.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SAMPLES: That's touch screen. This
2 figure shows an interface between the PSMS and the DAS.

3 And what we're interested in here is this green box
4 down in the power interface module.

5 Down here, these conventional solid state
6 circuits implement a different kind of priority logic.

7 this is state-based priority logic. Now, you notice
8 that we have the DAS on one side and the PSMS over here.

9 Both are giving signals into the power
10 interface modules to operate a component. When this
11 component, such as a valve, we just select a safe state
12 and a non-safe state. For a valve, oftentimes the safe
13 state is closed, the non-safe is open.

14 In here, what this priority logic does,
15 regardless of where a signal comes from, either PSMS
16 or DAS, it gives priority to the signal that will acuate
17 it to its safe state.

18 MEMBER BLEY: Although the two arrows coming
19 out of the CPU look the same, one of them is an arrow
20 that's a safe state signal, and the other one is an arrow
21 that's a non-safe state signal.

22 MR. SCAROLA: Like an open and a close, or
23 a start and a stop. So this logic then just gives one
24 of them priority. And as you said, John, we do it based
25 on each component state.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 But we do have these few components in the
2 plant, like emergency feedwater isolation valves, where
3 it's difficult to determine the safe state. So there
4 what we do is we look at the normal state of the valve.

5 And we say emergency feedwater isolation
6 valves are normally open. And if they were to ever close
7 spuriously by an erroneous signal, we get an alarm.
8 And we put that up on this BISI thing. Because that
9 disables the emergency feedwater system. So
10 we take credit for the alarms that would spuriously close
11 these things during normal operation. So therefore we
12 can assume that these valves are open all the time.
13 Because if they're ever not open, they're immediately
14 alarmed and the operators can solve the problem.

15 So for the emergency feedwater isolation
16 valves, we define the safe state as closed. Because
17 that's the state that they need to automatically
18 reposition to if there's an accident.

19 CHAIRMAN STETKAR: Where is that
20 documented?

21 MR. SCAROLA: In the D3 coping analysis.

22 CHAIRMAN STETKAR: In the D3 coping
23 analysis? That's one place I didn't go.

24 MR. SCAROLA: Because it's dependent upon
25 the accidents. We have to look at the accidents and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 we've got to say, well, how are we going to protect for
2 that accident.

3 And what you're talking about is how do we
4 isolate a faulted steam generator, which is the issue.

5 We need to be able to make sure we're not --

6 CHAIRMAN STETKAR: Well, that's the issue
7 with one sort of philosophy, the philosophy you just
8 described. I'm trying to understand how --

9 (Crosstalk)

10 MEMBER BLEY: To have that valve actually
11 shut, and get an open signal and a shut signal, isn't
12 going to happen. It's really unlikely. That valve's
13 going to be open almost all of the time.

14 MR. SCAROLA: Now, if you're asking where
15 do we document the safe state for every component, the
16 answer is that's part of detailed design. We have not
17 gotten that far yet.

18 CHAIRMAN STETKAR: There are some
19 statements in the DCD that says for, I don't know, almost
20 all or for something like that, the safe state is, I
21 forgot, is well known, or something.

22 You want to start and EFW pump for example.

23 But for a few things, the example I used, EFW isolation
24 valves, and I didn't try to think of other things, but
25 --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SCAROLA: It's pretty clear that if the
2 purpose of the engineered safety feature is to get water
3 from Point A to Point B, that we want to have a flow
4 path open, right?

5 CHAIRMAN STETKAR: Right.

6 MR. SCAROLA: And it's also very clear that
7 if we are trying to isolate main steam isolation valves,
8 or isolate the containment, the safe state's closed.
9 So those are the easy ones.

10 CHAIRMAN STETKAR: Those are the easy
11 ones.

12 MR. SCAROLA: But there are some --

13 CHAIRMAN STETKAR: A few of the other ones,
14 like safety depressurization valves, EFW isolation
15 valves, where it's not as clear, especially if the safe
16 state is preventing operator intervention.

17 MR. SCAROLA: But what makes this whole common
18 cause failure thing very difficult to deal with is you
19 have these two systems. And you can never know, at any
20 point in time, which one is wrong and which one is right.

21 So you can't give the systems themselves
22 priority. You have to look down at the components and
23 say, well, where do we want this component to be. And
24 that's what this little logic does.

25 Now before, Charles, you had asked about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 is there a common cause failure in that PIF module.
2 And I said, well, it's so simple we can do 100 percent
3 testing. And this is representative of that logic in
4 that module. That's how simple the logic is.

5 MEMBER BROWN: What's the X?

6 MR. SCAROLA: That's an inverter.

7 MEMBER BROWN: Okay, I think --

8 MEMBER BLEY: Logically, it's a Not gate

9 MEMBER BROWN: I missed the definition when
10 they were running through their discourse a minute ago.

11 MEMBER BLEY: So I think I asked this
12 several years ago. And I think I remember the answer,
13 but I'm not sure.

14 So should the real world come up with an
15 oddball scenario where our logic isn't working right,
16 and it keeps a valve shut that somehow today I need to
17 open, how can the operator override the signals that
18 are keeping it closed?

19 And it's not an easy to get to valve with
20 a handwheel on it. Is there any way? My memory was
21 the answer is no. It's going to stay closed.

22 MR. SCAROLA: He could use a different
23 train.

24 MEMBER BLEY: But this one valve he can't
25 move. But something happens that generates the logic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that says go to the failsafe condition. And just today
2 we really need that valve open, or one of those multiple
3 valves open.

4 MR. SCAROLA: Let me address it two ways.

5 Let's assume that the spurious signal that's holding
6 that valve closed --

7 MEMBER BLEY: It might not be spurious.

8 MR. SCAROLA: Well, whatever the signal is,
9 is coming from the DAS. The operators have a DAS defeat
10 switch.

11 MEMBER BLEY: That's true.

12 MR. SCAROLA: They can defeat the DAS and
13 shut off the DAS so the DAS stops sending signals. So
14 for that one, we can defeat it. And now we can let the
15 safety system do whatever it wants to do. On the other
16 hand, on the safety side, we don't have a defeat switch.

17 MEMBER BLEY: There's just no way we can
18 get that valve open if we need to?

19 MR. SCAROLA: If the safety signal is
20 keeping --

21 MEMBER BLEY: Well, without going in --

22 MR. SCAROLA: Well, if the safety signal
23 is sending the safe state signal, and the operator will
24 ultimately --

25 MEMBER BLEY: Which all our analysis said

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 will always be the safe state, but today it's not. We're
2 stuck.

3 MR. SCAROLA: So they have to use a
4 different train.

5 MEMBER BLEY: Yes. But all the trains are
6 getting the same signal, because it's a condition where
7 we would have generated the safety signal. But we just
8 weren't complete enough in our thermohydraulics
9 analysis, or whatever, to get it right.

10 MR. SCAROLA: Now, I guess we could make
11 an argument that the operators can pull the module out
12 of the rack. But I know you don't like operators pulling
13 out modules.

14 MEMBER BLEY: Well, we don't like that.
15 But if you've got no other choice --

16 MR. SCAROLA: I don't have an answer other
17 than that.

18 MEMBER BLEY: That would be it, I guess.
19 We used to be able to use --

20 CHAIRMAN STETKAR: Operators, unless
21 they're really trained differently --

22 MEMBER BLEY: Are heavily trained not to
23 do this.

24 CHAIRMAN STETKAR: -- are heavily trained
25 not to mess around with electronic stuff. They don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 even like to mess around with electrical things. So
2 I think there would be a very high reluctance among
3 operators, licensed people in the control room, to do
4 that.

5 MEMBER BROWN: They can call on somebody
6 to go do it that's qualified for that. I presume they
7 have people on the side.

8 MEMBER BLEY: They can. And within an hour
9 or two they might get --

10 MEMBER BROWN: Well, that's fine. It's
11 doable. You don't have to wait three months to do it.
12 You can, I guess.

13 MEMBER BLEY: I don't know for sure if it's
14 even possible.

15 MR. SCAROLA: Well, yes. If they pull the
16 module, now the safe state signal's going to be gone.
17 And now they can find other ways to manipulate that.

18 MEMBER BLEY: Then they can turn it on
19 through --

20 MR. SCAROLA: Then they can manipulate that
21 valve in a different way.

22 MEMBER BLEY: Of course, can they pull just
23 the PIF module for this one valve?

24 MR. SCAROLA: Yes. Every component has
25 its own PIF on it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BLEY: And those are accessible,
2 yes. Okay, so there is a way around. But it would be
3 heavily trained against it.

4 MR. SCAROLA: A little cumbersome.

5 MEMBER BLEY: That's okay. On the day
6 we're in the SAMGs and we have to come up with a strategy,
7 that might be one we have to do. We used to do stuff
8 like that.

9 MR. SCAROLA: Now, one thing I will mention
10 is we've done a lot of work in Chapter 18 on risk important
11 human actions, which go down this -- I'm not going to
12 say the P word, because I'll get jumped on -- but it
13 looks like all these special actions that are based on
14 multiple train failures, we do not take credit for the
15 operators doing any of this stuff.

16 What we do take credit for is the operators
17 find an alternate success path. They don't attempt to
18 open that valve you're talking about. They find another
19 way to get the water in like use component cooling water
20 --

21 MEMBER BLEY: And they're really good at
22 that.

23 MR. SCAROLA: -- or a way to inject that.
24 And those kinds of things are probably a lot better
25 success paths than saying, okay, go try and find a way

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to open this valve.

2 MEMBER BLEY: I don't have a scenario for
3 that.

4 MR. SCAROLA: So we do a lot of that
5 evaluation.

6 MEMBER BLEY: I haven't planned a scenario,
7 but one day Mother Nature might. But I suspect that
8 whenever you get to SAMGs and that sort of thing they'll
9 probably have to deal with this kind of a nightmare.
10 That's my memory of asking this a long, long time ago.

11 CHAIRMAN STETKAR: Good memory. Let me
12 ask you a question on this. And I actually had a
13 scenario. And it has to do with EFW. And I didn't know
14 I wanted to ask it, so I'll ask it now since we're talking
15 about it.

16 EFW comes off. I've lost the feedwater.
17 I don't care. The main feedwater goes away. The EFW
18 comes on. All the valves are open. The operators don't
19 do anything.

20 EFW runs, and runs, and runs, and runs.
21 And the steam generators all fill up, because that's
22 what they will do. EFW doesn't automatically control
23 level, does it?

24 MR. SCAROLA: Well, EFW turns off at a level
25 setpoint. The valves close at a level setpoint.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN STETKAR: The valves close from
2 that safety --

3 MR. SCAROLA: It's not a modulating
4 control, but it is an on --

5 CHAIRMAN STETKAR: The valves close from
6 that safety signal that isolates the valves.

7 MR. SCAROLA: Correct.

8 CHAIRMAN STETKAR: Does that signal seal
9 in, because you say all safety functions seal in.

10 MR. SCAROLA: No.

11 CHAIRMAN STETKAR: That one doesn't.

12 MR. SCAROLA: That does not seal in. That
13 one's a cycling signal. What seals in is the EFW signal
14 that starts the pumps.

15 CHAIRMAN STETKAR: Okay. Thanks, that
16 helps me. Because I was getting in, there are many,
17 many statements that say all safety signals seal in and
18 can only be reset by manual operator action. That one
19 doesn't.

20 MR. SCAROLA: Well, the signal --

21 CHAIRMAN STETKAR: Where I was getting is
22 the priority logic, because if it's sealed in how does
23 the system then know that the valve's got to reopen,
24 because it's got a sealed in safe state signal.

25 MR. SCAROLA: The EFW actuation signal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 seals in at the system level. But the specific signals
2 that go to the valves do not seal in.

3 CHAIRMAN STETKAR: Okay. Then I
4 understand how it can work. Thanks.

5 MR. SAMPLES: And I'd like to mention a
6 couple of more things on this slide here before we move
7 on.

8 In addition to ensuring that the safe state
9 has priority over the non-safe state, this same logic
10 ensures that a failure of either the PSMS or the DAS
11 is not going to block the safety function.

12 Since we're making the PIF module out of
13 conventional solid state circuits, there's no potential
14 there for software common cause failure.

15 And if you notice, the isolation module
16 here, the non-safety DAS interface, it's hard wired with
17 this conventional isolator. And there's no digital
18 communication between the PSMS and the DAS.

19 Move on to the topic of determinism. You're
20 seeing here a CPU module. It's blown up with some
21 internal features shown. You're also seeing a bus master
22 module, which is taking data from plant components and
23 from sensors and pushing it to plant components.

24 You also see one of the control network
25 interface modules and another bus master module for data

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 link for this case here. All of these functions are
2 executing cyclically with single task processing.

3 They're operating with a fixed deterministic time
4 cycle in which the predetermined cycle, with the
5 predetermined steps, each step executed in the correct
6 order each time, Step 1 first, Step 2, Step 3, to the
7 end. Every step is executed.

8 The cycle time is 100 percent reproducible,
9 repeatable every time. There's no change in that
10 sequence at all. So what you're seeing is that the data
11 comes from either the sensors or the control network with
12 the data link.

13 It's placed here in these little green boxes
14 here. And each of those are two-port networks. That's
15 where the data is placed as it comes in.

16 MR. SCAROLA: Pat, two-port memory.

17 MR. SAMPLES: Am I saying two-port network?

18 Two-port memory, I keep saying something else. I'm not
19 sure why. But two-port memory is there and the data is
20 stored there.

21 Now, you see the CPU module going through
22 its time cycle, the various steps. When it gets to an
23 input cycle, it's going to need data. So what it's going
24 to do is go read data in from each of those two-port
25 memories into its data table.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Now when it's done, it goes to the next step.
2 It's the operations step. We actually use the
3 information in the data table. The next step is just
4 to check it, make sure it's operating properly. And we'll
5 talk about the different checks done there.

6 The output, in that case, it takes data from
7 the data table and writes it back to the two-port memories.

8 And all of these actions from each of these three here
9 in the CPU module on the top are all done asynchronously.

10 Again, the CPU module is reading in and
11 writing out. And no data is ever pushed into it. It's
12 controlling its own operation itself. Self- diagnostic
13 features, they're both in a step here. And there's also
14 some other ones in the time remaining section here.

15 Since they are part of the overall cycle,
16 the self-diagnostics, they don't affect the predetermined
17 fixed cycle at any time. And there are no interrupts
18 here, except by self-diagnostics.

19 The only time you get an interrupt if one
20 of these blocks senses an error condition, then they'll
21 cause the CPU module to transition to an error state and
22 get a lock.

23 And this time cycle can't be interrupted
24 by the other trains, or the unit bus, or anything outside
25 of it, just the internal diagnostic --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BROWN: Just finish your statement,
2 I'm sorry. I just didn't want you to leave.

3 MR. SAMPLES: Internal diagnostics. Okay,
4 stay here for something?

5 MEMBER BROWN: Yes, to try to put a specific
6 event, to make sure I understand this.

7 MR. SAMPLES: Yes.

8 MEMBER BROWN: This is executed by every
9 controller, every CPU unit.

10 MR. SAMPLES: Yes.

11 MEMBER BROWN: And I'm going to pick an
12 example. I'm just going to take Train A, Controller Group
13 1, whatever. There's a number of parameters evaluated
14 in that train CPU.

15 And there are a set of algorithms associated
16 with that process, determinants. Some of them may be
17 simple, numbers higher than this, numbers that are lower
18 than that.

19 There may be a conglomeration algorithm,
20 which takes other parameters and says you've got to look
21 at it regardless of what it looks like. There are those
22 functions that are evaluated by that controller. Are
23 every one of those functions evaluated on every cycle?

24 MR. SAMPLES: Yes.

25 MEMBER BROWN: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SAMPLES: That's RAM check.

2 MEMBER BROWN: I'm talking about plant
3 parameter function and recycling. Do I trip, do I not
4 trip, do I operate something, do I turn on a valve, do
5 I whatever.

6 If those functions are performed every time
7 in that controller, the same applies for the ESFAS
8 controller for the data that gets transmitted to that
9 during that period. Every function is done every time?

10 MR. SAMPLES: Yes.

11 MEMBER BROWN: All right. And the output
12 now is at the end of that operation it goes back into
13 to data table where it's then transmitted to whatever
14 other things that need to execute that output, or
15 monitoring, or what-have-you.

16 It goes out through those other links through
17 the output, the ones you show as output dual port, or
18 two-port memory units, with the bus controller.

19 MR. SCAROLA: And all completely
20 asynchronously.

21 MEMBER BROWN: Yes, I got that. And, all
22 right, let's see, I had another question. Where did it
23 go?

24 Now, you say there are no interrupts. And
25 I'm trying to recall now, at one point in the documents

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you said there were no external interrupts to this. And
2 I got that.

3 You did talk about two internal interrupts.

4 And I don't remember the difference. One of them was
5 diagnostics and another one some color peripheral interim
6 map.

7 I may be saying that wrong, but there were
8 two internal interrupts. And it seems to me you've only
9 talked about one when you've talked about the self-
10 diagnostics. And am I going to have to go find that?
11 That's going to be terrible.

12 MR. SCAROLA: I actually can't think of any
13 other interrupts --

14 MEMBER BROWN: But they are internal.

15 MR. SCAROLA: -- that are not
16 self-diagnostics. But there are two self-diagnostic
17 interrupts.

18 MEMBER BROWN: All right, that's fine. The
19 fundamental answer I wanted was that this is a single
20 time sample to cycle and that everything is executed in
21 turning, including constant time monitoring in the
22 remaining time, the part of the self- diagnostics that
23 you do in the remaining time you have left over each time.

24 MR. SAMPLES: Okay. I think the next slide
25 there, similar information on determinism. What you're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 seeing here is a signal path from a sensor through input
2 modules, CPU modules, other modules in Train A.

3 And it does pass through a data link into
4 Train B. And the signal eventually reaches the trip
5 breaker for a trip.

6 The cause of the deterministic cycles of
7 each of the modules that you see here, each of these
8 different blocks, the red and the green, each of these
9 have these deterministic cycles. We can calculate the
10 worst case, the longest time to perform the function in
11 each of them.

12 Now if you add all these up, the worst case
13 is through here. It's just simple addition. You can
14 see what we'd get worst case for. And this reactor trip
15 function is about 300 milliseconds max.

16 MEMBER BROWN: So the data link is the
17 transmission from Train B over to Train, and still you're
18 looking at the maximum amount of difference between the
19 asynchronous operations to show those two, the
20 compounding time frames, time steps.

21 MR. SAMPLES: That's because the data links
22 are deterministic. We can do that.

23 MEMBER BROWN: Yes. I'm not questioning
24 that.

25 MR. SCAROLA: And based on the voting logic,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 no train does anything without voting on data from another
2 train.

3 MEMBER BROWN: Yes. No, I understand that.

4 I got that. I just wanted to make sure I was totally
5 clear on the picture.

6 MR. SAMPLES: It's telling us that
7 determinism allows us to calculate worst case, and it's
8 never going to be worse. You can bound, and you can say
9 that 300 millisecond max is the longest time you're going
10 to have for a reactor trip function.

11 We also have an ITAAC that confirms that
12 the detail design meets these response time requirements
13 as defined in the technical report for a response time
14 on the safety I&C system.

15 MEMBER BROWN: How does this apply now when
16 you have to then, on a time response for the ESFAS
17 functions, obviously you've got the 300 milliseconds
18 associated with sending the reactor trips.

19 Now that same signal, in some circumstances,
20 needs to actuate some safeguards equipment. There's
21 another set of processors involved in that. I mean,
22 you're not talking about that time frame. Or is there
23 an analysis for --

24 MR. SCAROLA: In this same document, there
25 is a document that's entitled PSMS response time. We

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 model the reactor trip response time, and we model the
2 ESFAS response time. This slide only shows reactor trip.

3 MEMBER BROWN: But they are in series.

4 MR. SCAROLA: Correct, they are in series.

5 So for the ESFAS, you have another ESFAS CPU section
6 --

7 MEMBER BROWN: Okay, all right.

8 MR. SCAROLA: -- that's received from the
9 data link. Then you have the safety bus time, and then
10 you have the SLS time. So for ESFAS, there is a longer
11 signal propagation.

12 MEMBER BROWN: That's fine. I didn't look
13 at 09021.

14 MR. SCAROLA: Now, I would like to correct
15 something I said earlier. I had told you that the safety
16 bus, or the control network, has a response time of 100
17 milliseconds.

18 The hundred milliseconds is the unit bus
19 response time. Because the unit bus has many, many nodes
20 on it. The safety bus has a much fewer set of nodes.
21 And the response time is 50 milliseconds for the safety
22 bus.

23 MEMBER BROWN: Okay. That makes more sense
24 now, based on the numbers you all were throwing around.

25 Okay, thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SAMPLES: Now I'll discuss the issue
2 of diversity for software common cause failure. I have
3 the conventional analog DAS provided for Branch Technical
4 Position 7-19 to accommodate beyond design basis common
5 cause failures that could adversely affect the PSMS and
6 the PCMS when you have a concurrent AOO or postulated
7 accident.

8 The DAS provides automated reactor trip,
9 turbine trip, main feedwater isolation, emergency
10 feedwater actuation, and emergency core cooling
11 actuation.

12 And the DAS also allows the operator to
13 monitor critical safety functions and manually actuate
14 the safety system to achieve and maintain safe shutdown.

15 Earlier we talked about the RPS. We talked
16 about the four trains and how, in each of the four trains,
17 there are two different groups. And they monitor
18 different variables.

19 And now, I'm going to go ahead and talk a
20 little bit more about the RPS functional diversity. You
21 can see it monitors two diverse parameters to detect an
22 event and initiate a protective action.

23 These are processed in two separate
24 controller groups, two in each train. PRA shows some
25 significant benefits from this functional diversity.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Now, for instance, for the different protection
2 here in the far left column, a good example is loss of
3 heat sink.

4 You have Group 1 and Group 2. You see that,
5 for Group 1, the group is monitoring the variable of steam
6 generator water level and pressurizer water level. While
7 in Group 2 it's measuring pressurizer pressure. So it's
8 measuring two different sets of variables.

9 CHAIRMAN STETKAR: Is this table anywhere
10 in the DCD?

11 MR. SAMPLES: Yes.

12 CHAIRMAN STETKAR: It is? I think we cut
13 off the piece to it.

14 MR. SAMPLES: Yes, I've got it right here.

15 CHAIRMAN STETKAR: The ESFAS signals, I
16 couldn't find them. I had a question. There's a nice
17 comparative table for RPS that shows diversity of signals.

18 MEMBER BLEY: I thought the ESFAS was up
19 with that one.

20 CHAIRMAN STETKAR: Was it?

21 MEMBER BLEY: I thought it was both.

22 CHAIRMAN STETKAR: Okay, maybe I missed it,
23 thanks.

24 MEMBER BLEY: But I could be wrong.

25 CHAIRMAN STETKAR: I can find tables.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BROWN: No. I think there's one in
2 the ESFAS section.

3 CHAIRMAN STETKAR: Fine, I must have missed
4 it, thanks.

5 MR. SAMPLES: Now for simplicity. The
6 overall plant-wide simplicity is achieved through these
7 different ways.

8 MEMBER BROWN: Go back just one second
9 please. I did have a question. Okay. Some of these
10 have multiple -- okay, that's fine. I looked and I saw
11 a couple of these were doubled up in terms of pressurizer
12 pressure. No, I guess it'd be on Table 7.2-5. There
13 were two high pressure water levels in that.

14 CHAIRMAN STETKAR: Well, there was a
15 statement. In some cases where there wasn't functional
16 diversity you do split the same signal between both
17 groups.

18 MEMBER BROWN: Yes, I know. And that's
19 fine, except that I didn't see it. I didn't see it on
20 this table. There were two high pressure water levels
21 in Group 1, in the Table 7.2-5. And I quickly looked
22 down there. I did not see, oh no, there it is. There
23 are two pressurizers. Okay, never mind, go ahead.

24 MR. SAMPLES: Okay.

25 MEMBER BROWN: I understand your point,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 John. I remember seeing that also. I just hadn't
2 connected it.

3 MR. SAMPLES: Back to ways we achieve
4 overall plant wide simplicity. And first of all, oh --

5 CHAIRMAN STETKAR: Some of them are both,
6 but I was looking for a steam line break, LOCA-type stuff.

7 MR. SAMPLES: See, first of all we have the
8 one digital platform, the MELTAC platform. It's applied
9 to all safety and non-safety applications. There's one
10 system, the PSMS, provides all the safety functions.
11 One system, the PCMS, provides all non-safety functions.

12 We have a standard approach to a logical
13 independence but only four common isolators, power,
14 inputs, outputs, fiber optic communications. There's
15 standard approach to data communication using two common
16 interfaces, the data link and control network that we
17 discussed before.

18 There's a standard approach to
19 communication independence. This is the separate
20 communication controller, separate from the functional
21 controllers, the two-port memory, and the same human
22 system interface in both the main control room and the
23 remote-shutdown valves.

24 Now as far as simplicity related to software,
25 first of all the basic software and the application

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 software are separated. And what you're seeing here is
2 an example of an application software development
3 display.

4 The application developer will pull this
5 up, and what you're seeing here is, first of all, the
6 Application Program Interface 4 application software is
7 a set of pre-defined functional blocks, either AND, OR,
8 Timer and Latch, such things in back.

9 The developer will take these functional
10 blocks, ANDs, ORs, Latch, or whatever you seem to have,
11 connect them together, connect them to inputs and outputs,
12 and that way develop the software. And they do that using
13 the engineering tool offline.

14 Doing software development this way has some
15 advantages over doing it by writing lines of text code.

16 First of all, it's much easier for a verifier to take
17 a look at the graphical representation of the circuit
18 here and follow through different signal paths to verify
19 that it's correct. There's less likelihood of error when
20 programming.

21 CHAIRMAN STETKAR: If you're going to do
22 that, I presume each thing in here, such as just pick
23 one box, it says FX, that's a function?

24 MR. SAMPLES: Yes, function.

25 CHAIRMAN STETKAR: So I presume that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 function is a block of code that is pre-written and defined
2 for input, output --

3 MR. SAMPLES: I may not have explained that
4 as well. See, each of these AND, and OR, Timer, and the
5 function block you're talking about, you see them. But
6 it's actually the basic software implements them behind
7 the scene.

8 CHAIRMAN STETKAR: No, I understand that.

9 But when you've taken a block of code that executes that
10 with all its lines, and you've called it something so
11 you can put this into a diagram, when you do that, then
12 it pulls that out when you're programming. And it pulls
13 that code out and sticks it in whatever the appropriate
14 place it's supposed to be executed.

15 MR. SAMPLES: The basic software does
16 implement the function. I don't think it exactly
17 implements it in the way you describe it. But it is the
18 basic software running to execute the function block,
19 or the ANDs, ORs, other functions.

20 CHAIRMAN STETKAR: Maybe I'm not making
21 myself clear. If somebody's going to program using that
22 and they go pick that block, someplace there's got to
23 be a set of code that says what's in that block, line
24 by line, what the inputs are, what the outputs are, et
25 cetera.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And so when you do that, then in the
2 background that code is brought in and connected to the
3 other code that's going to interpose with it on the front
4 end and on the back end. Or you presume there's a library
5 that defines every one of these pieces.

6 MR. SAMPLES: Are you asking if there's a
7 library that defines what an AND gate is, for instance,
8 something that simple --

9 CHAIRMAN STETKAR: Well, there probably
10 would be if you're going to call for an AND gate itself.

11 But if you've got a function that's going to combine
12 three different parameters under some circumstances, then
13 you'd have to have a block of code that defines what that
14 code looks like.

15 MR. SCAROLA: Pat, let me in. In the MELTAC
16 technical report, which is one of the documents you have,
17 in the back there's an Appendix B that identifies every
18 library function that's part of this basic software.

19 So you'll see every type of function, three
20 input AND gates, two input AND gates, latches, One-shots,
21 timers. There's a whole library, several pages.

22 So the designer, as you say, simply has to
23 select the block he wants graphically. But when he
24 selects that, there's a whole bunch of code, as you said,
25 embedded in that block that he never sees.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 MEMBER BROWN: Yes. I've got that.

2 MR. SCAROLA: The application developer
3 never sees that code.

4 MEMBER BROWN: But what about a more complex
5 algorithm like your overpower delta T-high, which is more
6 than just an AND gate --

7 MR. SCAROLA: There's an integral block,
8 there's an integral function block, there's a summer
9 function block, there is --

10 MEMBER BROWN: But that function would have
11 already been a library developed for that function that
12 combines all those that you would then call up if you
13 were looking for that.

14 MR. SAMPLES: Those functions would have
15 been designed by the person who developed the basic
16 software. The application software developer ought to
17 have that.

18 MEMBER BROWN: Who checks all that?
19 Functionally, some of that stuff could change from design
20 application to design application.

21 MR. SCAROLA: No. I think that's what maybe
22 we're confusing you about. The software code that's
23 inside a block never changes. It's part of the basic
24 software. It's a library function that's encapsulated.
25 It's part of MELTAC. So you get those libraries --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BROWN: They know what all the
2 functional applications you're going to need in the
3 US-APWR for protecting the plant.

4 MR. SCAROLA: Well, I can tell you that the
5 function library has grown over time.

6 MEMBER BROWN: Okay, that's fine. You've
7 added to it.

8 MR. SCAROLA: There's 450 MELTAC
9 controllers --

10 MEMBER BROWN: Okay, that's fine. I'm just
11 saying MELTAC doesn't do that. So the designers have
12 to define what the function is for the plant. And then
13 you develop whatever library piece you need for it.

14 MR. SCAROLA: What will happen is the
15 application designers will look to build an application
16 with the existing function blocks. They may find that
17 there's not a function block that they really need.

18 Now they'll go back to MELCO. And MELCO
19 will build a new function block using their basic software
20 methodology, which includes full BTP 7-14 documentation,
21 independent verification --

22 MEMBER BROWN: A different side from that,
23 the designer tells them what the functionality they need,
24 and what influence --

25 MR. SCAROLA: Some kind of a specification.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BROWN: Some type of a specification
2 that tells them what that function needs to look like.

3 MR. SCAROLA: And that's how the library
4 has grown so big over time.

5 MEMBER BROWN: Who checks that MELCO does
6 it right. How do you check that?

7 MR. SCAROLA: Well, MELCO has an Appendix
8 B software development program.

9 MR. TAKASHIMA: The function was checked
10 by the designer. The designer may check.

11 MEMBER BLEY: Well, these are in the library
12 then, so you can check them. So your question is who
13 does that.

14 MEMBER BROWN: Yes. I understand the
15 designer providing here's the functionality you want.

16 MEMBER BLEY: Then he gets the package back
17 from MELCO.

18 MEMBER BROWN: And he gets it back.
19 Somebody needs to recheck it. There ought to be a QA
20 process that does that. And I was just asking a question
21 about if that's part of your overall software program.

22 MR. SCAROLA: It's part of the software life
23 cycle program, part of the software quality assurance
24 program, which includes not only independent verification
25 and validation within MELCO, but then independent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 oversight by MHI people as well. So there's multiple
2 layers of independence.

3 MEMBER BROWN: I'm not objecting. I just
4 want to know what you're doing, that's all. You were
5 doing this when I left my program. So I just wondered
6 how you all were doing it.

7 MR. SAMPLES: I think we can move on to
8 testability now. I&C systems of the US-VWR, they're
9 tested by a combination of automated self-testing and
10 manual tests.

11 So the continuous automatic self-testing
12 covers all digital system components. It includes
13 controller memory, inter-controller data communications,
14 all the way from input to output.

15 All program memory, including memory that
16 holds the self-testing and the setpoints, is confirmed
17 by continuous automatic self-testing.

18 Now for manual tests, there are diverse
19 manual surveillance tests. These are controlled by tech
20 specs, including the operability of the testing functions
21 that confirm the operability of each PSMS controller,
22 for example, the channel calibration test, trip actuation
23 device, operability test, memory integrity check, and
24 --

25 MEMBER BROWN: What is TADOT again?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SAMPLES: Trip actuation device
2 operability test.

3 MR. SCAROLA: It's the test that we run that
4 makes sure when you generate a signal the valve actually
5 moves. So you actually get an output from the system
6 to the valve, or the reactor trip breakers actually open.
7 That's a typical TADOT test.

8 MEMBER BROWN: Okay, thank you. Just
9 didn't know the acronym.

10 (Off microphone comments)

11 CHAIRMAN STETKAR: Keep that up at the
12 moment. I just want to make sure. I think we asked about
13 this once before, but I can't remember whether we asked
14 you or someone else.

15 As I understand it there's no, what I would
16 call, end-to-end operability test ever performed on this
17 system. In other words, you never inject signals into
18 a sensor and make sure that the valve closes. You rely
19 on all of the overlaps.

20 MR. SCAROLA: Only through overlaps,
21 correct.

22 CHAIRMAN STETKAR: Okay, thank you.

23 MR. SAMPLES: And the figure here, what
24 you're seeing are several hardware elements, a
25 communication interface module, a CPU, Bus Master module,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and both an input and output module.

2 Now the yellow over here, you're seeing the
3 several different automated individual checks, such as
4 for the CPU you see a clock check, a RAM check, a CPU
5 health check, for output module a read back check.

6 These self-diagnostic functions completely
7 test the hardware and the software. And all the memory
8 and other hardware that affects the safety function are
9 tested directly.

10 In addition to these individual checks that
11 cover the individual hardware elements, there are two
12 broad tests to detect erroneous function execution, first
13 of all, a watchdog timer.

14 It's a gross cycle time check by the hardware
15 and a periodic process time check. This is a precise
16 time cycle check by the software. And notice that one
17 of these is the hardware and software, so you have an
18 element of diversity there.

19 MEMBER BROWN: Are there three watchdog
20 timers in that controller? You use WDT three times
21 between the little arrows, one down in the memory aisle
22 communication circuit, one up in the CPU line, and another
23 one in the output memory concert breakthrough.

24 MR. SCAROLA: There are watchdog timers in
25 that communication module, watchdog timers?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BROWN: There's no box inside that
2 says watchdog timer. It shows a box that's independent.
3 But I presume that is.

4 If you look at the circuit card or whatever
5 controller card you've got, there would be a hunk of
6 hardware on it somewhere that's independent of all the
7 rest of the circuits. It's just sitting there
8 monitoring, waiting for time pulses, for the reset line
9 to go out back to the CPU.

10 MR. SAMPLES: I'm not sure I follow you.

11 MR. SCAROLA: I know your question. We need
12 to ask our MELCO representatives. Are there actually
13 hardware watchdog timers on the communication modules?

14 Yes, separate watchdog timers on the communication
15 modules and the CPU modules.

16 MEMBER BROWN: And the CPU modules. So the
17 bus master, the COM module, and the CPU all have distinct
18 hardware watchdog timers on them.

19 MR. SCAROLA: Correct.

20 MEMBER BROWN: Okay. And you're going to
21 talk about those next, right?

22 MR. SAMPLES: Yes. I'm going to go next and
23 let's talk about the watchdog timer, how that operates.

24 The watchdog timer itself is a counter. It's for the
25 hardware clock generator.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BROWN: Let me ask one question
2 before.

3 MR. SAMPLES: Sure.

4 MEMBER BROWN: It's related. You'd have to
5 go backwards, but you said gross time check. Each of
6 those three components, those three units, has a time
7 frame within which they're supposed to be starting and
8 stopping their processes. I'll just pick a number, say
9 it's 50 milliseconds. When you say gross, does it mean
10 --

11 MR. SCAROLA: Four or five times.

12 MEMBER BROWN: So it's really gross.

13 MR. SCAROLA: The hardware watchdog is
14 gross. The software is very precise, the software
15 watchdog. That's why there are two watchdogs.

16 MEMBER BROWN: Okay. I understand what
17 gross means.

18 (Off microphone comments)

19 MR. SAMPLES: Now, the watchdog timer, how
20 it's working here is it's reset at the beginning by the
21 basic software. And then it counts up and counts up as
22 the basic software, as the module performs its function.

23 Then once the module's done and it's operated
24 correctly it will reset the watchdog timer back to zero.
25 And it'll count up again.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Now, if the basic software doesn't reset
2 the watchdog timer, what's going to happen is it's going
3 to keep counting up. It'll go past, reach its predefined
4 timer value.

5 And at that point we'll get a fail, a module
6 going to failure mode, and get an alarm. When that
7 happens in the failure state you're going to get a partial
8 reactor trip and a fail as is for the ESFS system.

9 MEMBER BROWN: How do you get the partial
10 reactor trip? Is that executed by hardware, or is that
11 by you depending on the software that's not operational
12 anymore because it's not completing its -- that's not
13 illustrated as to how you phrased it in the MELTAC.

14 Its processing is monitored for
15 deterministic cycle time by watchdog timer, enforces a
16 fail safe processing termination. Nice words but how
17 is that executed? It doesn't say, or at least I couldn't
18 find it.

19 MR. SCAROLA: It depends on the watchdog
20 that's timing out. If a CPU watchdog times out, it's
21 simply going to tell the I/O module that there's no more,
22 the I/O module that's supposed to get the output is just
23 going to recognize that there's nothing else happening
24 from the CPU.

25 So now the I/O module is eventually going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to time out. Now the I/O module watchdog timer is
2 actually a hardware interface to the output that will
3 de-energize, for example, the undervoltage relay going
4 to the reactor trip breaker. So it's an actual hardware
5 interface.

6 MEMBER BROWN: So I'm effectively looking
7 at the bus master module then, which is the last one in
8 the line if I go back to the previous page. Is that
9 correct?

10 MR. SCAROLA: Yes.

11 MEMBER BROWN: Because it's involved in both
12 the input side before you get to the CPU, and somehow
13 it's on the output side, even though it's on the input
14 side.

15 (Off the record comments)

16 MR. SCAROLA: So the output module senses
17 that the watchdog timer has timed out in the bus master
18 module.

19 MEMBER BROWN: It would be nice.

20 MR. SCAROLA: We don't have a diagram for
21 it.

22 MEMBER BROWN: Okay. It would be nice if,
23 I'm not suggesting modifying the MELTAC, but if the DCD
24 included --

25 MR. SCAROLA: A diagram.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: -- a diagram and a discussion
2 of how the reactor trip is actually executed and that
3 it covers the waterfront relative the reactor trip as
4 well as the ESFAS functions.

5 MR. SCAROLA: I agree.

6 MEMBER BROWN: The failure modes, in terms
7 of tripping and/or fail as is, that's obviously the
8 direction. That's the fail safe direction for both of
9 those.

10 The only other thought process is if you
11 have a fail as is in the ESF how do the operators know
12 that you've got that?

13 I couldn't find anything relative to an alarm
14 signal or a warning signal saying system inoperable, or
15 train inoperable, or something like that, which seems to
16 be lacking. They ought to know if this thing times out.

17 The other question I had was in the
18 description, and I don't have the right part pulled up,
19 it talked about it terminates at n, and n could be equal
20 to more than one.

21 In other words, just as you show here, well
22 no, it's not as you show there, I'm sorry. In other words,
23 it implied that the watchdog timer would attempt to reboot
24 the CPU, or the I/O module, or the bus master, or whatever
25 was involved.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And it would try to do that two or three
2 times, or some number of times, before it generated the
3 reactor trip. Personal opinion is one is the only right
4 answer. So that point should be addressed as well. And
5 can we somehow make sure the operators know about it.
6 So those are the three points.

7 In other words, a figure that shows where
8 it is and how each of them performs, which one generates
9 the reactor trip and why it doesn't need to be done by
10 the other two, wherever they are, because it's important
11 that generation be independent of whatever software is
12 now not operating.

13 MR. SCAROLA: Good comment.

14 MR. SAMPLES: It's possible the watchdog
15 timer can fail. And the way you detect a failure of the
16 watchdog timer is by monitoring the counter, the value.

17 This is the watchdog timer clock check.
18 It's performed by basic software. Again, if the counter
19 stops, becomes askew, this indicates an abnormality of
20 the watchdog timer.

21 This watchdog timer's clock check is
22 performed periodically by the basic software. And if an
23 error is detected by this clock check, the controller
24 transitions to a failure state.

25 MEMBER BROWN: Same as the other one?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SAMPLES: Yes.

2 MEMBER BROWN: I like the feature of
3 checking the checker, or checking the timer. But I didn't
4 see where, when it said failure state, I didn't know what
5 that meant either. So if it generates the same result
6 as a watchdog timer trip it would be a good idea to just
7 expand that to say the same thing.

8 MR. SCAROLA: But we don't have a good figure
9 that shows it. And I agree with you there. We need to
10 have it.

11 MEMBER BROWN: Thank you. And the DCD would
12 be a good place. That way you don't have to go back into
13 the technical report if you're going to do a REV. It makes
14 it part of the licensing basis also.

15 MR. SCAROLA: Well, even if it's --

16 MEMBER BROWN: I guess all of them, they
17 all do, I'm sorry. You're right. I, yi, yi, come on.

18 CHAIRMAN STETKAR: Whatever page or
19 whatever document it's on.

20 MEMBER BROWN: Keep pounding on me. I
21 understand that.

22 CHAIRMAN STETKAR: Their decision.

23 MEMBER BROWN: I just like the DCD because
24 it's the precedent document. If you read the DCD it says
25 this takes precedence over everything else.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SAMPLES: Some more information on
2 testability, the self-testing detects hardware and
3 software errors in the PSMS. The logic algorithm
4 setpoints, time constant values, and inter-train
5 communication of the PSMS are self-tested.

6 Input/output is confirmed by manual
7 periodic tests. The manual periodic I/O test also
8 provides diverse confirmation of each controllers ability
9 to execute multiple diverse software functions.

10 All the memory that controls basic software
11 and application software is confirmed by the manual
12 initiated software memory integrity check. And that's
13 diverse from the self-tests.

14 Through the aggregate of all these tests,
15 all the safety function of the PSMS are confirmed. Also
16 the setpoint methodology technical report includes the
17 method of allowable value calculation used for testing.

18 Moving on to reliability now, the following
19 key features of the PSMS ensure high reliability. First,
20 the MELTAC platform, the digital platform operating
21 history demonstrates a long component mean time between
22 failure. And there are no software common cause failures
23 in the operating history.

24 The continuous self-testing, high coverage,
25 detect failures there. Periodic surveillance tests

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 ensure 100 percent test coverage. There's redundancy
2 between division and within divisions, including safety
3 bus, diversity within divisions to reduce the PSMS common
4 cause failure potential.

5 And if we do have a PSMS common cause failure
6 to occur, we have the DAS to mitigate the accidents. The
7 impact of the PSMS reliability is analyzed in DCD Chapter
8 15 in the PRA.

9 Now the key elements of the PSMS reliability
10 calculation in the PRA are these, the mean time between
11 failures of the digital I&C components, self-test
12 coverage, the rate to detect failures in the periodic test
13 intervals, common cause failure probabilities, and the
14 digital I&C modeling method.

15 All modules include the module performed
16 in the safety bus functions, including network interface
17 modules. Optical switches are modeled in the PRA.
18 Safety bus itself, what we'll hear it say, and it's just
19 the actual physical optical cables fiber itself, is not
20 modeled because the failure rate is negligible.
21 Everything else, except the actual physical fiber is
22 modeled.

23 CHAIRMAN STETKAR: By the way, I'm going
24 to remain silent for this presentation every time you say
25 PRA. I do have several comments on the PRA. I've asked

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the staff to have their PRA folks available when I talk
2 a little bit about that. So don't cringe every time you
3 say PRA. You'll get to cringe later.

4 MR. SAMPLES: Okay. As far as the mean time
5 between failures of the digital I&C components, these mean
6 time between failure values for each of these digital I&C
7 components that are used in the PSMS, we calculate these
8 based on the MIL handbook, 217F.

9 The actual mean time between failure values
10 that would get from the operating experience of the
11 platform are actually longer than the calculated values,
12 the analytical values. So we actually use the analytical
13 values for more conservatism.

14 The PSMS reliability is assured through the
15 Reliability Assurance Program in both the design and
16 operation phases. And the PSMS digital platform will be
17 included in the Design Reliability Assurance Program.

18 The self-diagnostic rate is estimated as
19 100 percent based on the FMEA of the platform. We used
20 the conservative value of 90 percent in the PRA to count
21 for uncertainty. The periodic test intervals used in the
22 PRA, these are provided in the DCD Chapter 16 tech specs.

23 Now the integral extensions from historical
24 standard technical specification values are shown to have
25 negligible effect on the core damage frequency per the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 PRA technical report in Attachment 18A.1 of that.

2 The summary will be added to the DCD in Chapter
3 19 and Appendix 19B in DCD REV 4. That will be a new
4 Appendix 19B, new to that report.

5 The 24-month sensory calibration interval
6 is the basis to channel uncertainty in the setpoint
7 methodology.

8 Now we use a zero percent self-diagnostic
9 rate for hardware devices not covered by self-diagnostics,
10 such as sensors, breakers, non-digital parts of I/O.
11 Obviously they can't diagnose themselves, so it's zero
12 percent there.

13 Now for common cause failure probabilities,
14 three different ways for different ones for basic
15 software, application software, and the hardware
16 components.

17 For basic software, we arrived at a figure
18 of ten to the minus seven per demand. We're assuming one
19 common cause failure through 20 million hours of operating
20 experience, again, even though none has actually happened
21 in the MELTAC platform.

22 MEMBER BLEY: How much operating experience
23 do we have for operating the platform?

24 MR. SAMPLES: Well, as you see here, what
25 actually we're talking about here is it's been in operation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 since 1987. Now we're talking about per controller, for
2 450 different controllers in 30 different plants.

3 Now each of those controllers, multiple
4 controllers, to implement any safety system or non-safety
5 system between 2,000, 200,000 hours per, averages out to
6 about eight years per controller.

7 MEMBER BLEY: Or 30 million.

8 MR. SAMPLES: When you get to 30 million
9 you just multiply 450 controllers by eight years average
10 per controller, then by 8,760. That's how many hours
11 there is in a year. You get up to about 30 million. But
12 the 20 million value we use --

13 CHAIRMAN STETKAR: Just because this is a
14 public meeting, you can't have nine women pregnant for
15 one month each and have a child. So saying you haven't
16 had any failures in 20 million hours doesn't mean that
17 you've actually operated anything for close to 20 million
18 hours. Because that's about 2,300 years. You've
19 operated a lot of things for a relatively short period
20 of time.

21 MEMBER BLEY: On the other hand --

22 CHAIRMAN STETKAR: Well, I'd say relatively
23 --

24 MEMBER BLEY: All our other equipment --

25 CHAIRMAN STETKAR: That's right, that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 right.

2 MEMBER BLEY: -- we're not looking for a
3 mean time to failure. We're looking at a failure rate.

4 CHAIRMAN STETKAR: That's right.

5 MEMBER BLEY: And from the experience they
6 have, this is a pretty conservative treatment.

7 CHAIRMAN STETKAR: It's pretty --

8 MEMBER BLEY: It says we've been awfully
9 lucky if that is the case.

10 MR. SCAROLA: We've been lucky?

11 MEMBER BLEY: Yes. If that's the failure
12 rate, we should have seen a bunch of failures by now, or
13 at least one. You're happy with what I said, even if you
14 aren't saying a lot.

15 CHAIRMAN STETKAR: You are. Just nod, yes,
16 he's right.

17 MR. SCAROLA: It seems like backdoor
18 happenings.

19 (Laughter)

20 MR. SCAROLA: I was trying to feel happy.

21 CHAIRMAN STETKAR: If you're a Bayesian
22 you'd understand.

23 MR. SAMPLES: Again, we're using the 20
24 million hour value for conservatism in the calculations
25 for basic software. For application software we have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 arrived at a value of ten to the minus fifth for demand.

2 We get there by crediting Class 1E life cycle
3 process management measures and many defensive measures,
4 including strict cyclic operation, constant loading, the
5 different things you see there.

6 Now for hardware, we start by trimming the
7 failure probability of a single module. And then we
8 consider redundancy and use the multiple Greek letter
9 method to calculate the common cause failure, probably
10 of the system depending on the level of redundancy. And
11 it's different for each module and each configuration of
12 redundancy.

13 MEMBER BLEY: In the hardware side, have
14 you had common cause failure?

15 MR. SCAROLA: We've had random failures.
16 That's the MTBF data, but no common cause failures. But
17 probably a better way to say it, no design defects, random
18 failure but no design defects. Because even after random
19 failures we'll look and see if this is possibly a design
20 defect, but no for random failures.

21 MEMBER BLEY: Back up to that one. You can
22 just help me understand a little bit. I suspect, are all
23 failures of the hardware announced somehow? Can we have
24 a latent failure sitting there of hardware that we don't
25 know until we get a demand on these cards?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 MR. SCAROLA: Until you get a test, yes.
2 As we said, self-testing covers everything that's within
3 the digital envelope of the system. But you have the input
4 side of an analog input module, which is an analog signal
5 filtering circuit.

6 So you can have failures that you don't see
7 until you run a test. So that's why we test, because we
8 don't want to wait for the demand to find out we have a
9 failure. That's why we --

10 MEMBER BLEY: If you get a failure and it
11 happens to be of that kind, do you check other modules
12 to see if you might have that common condition?

13 MR. SCAROLA: Absolutely.

14 MEMBER BLEY: And you've never found that.

15 MR. SCAROLA: Correct.

16 MEMBER BLEY: Okay. Now we have found it
17 on some other electronic cars. But you haven't seen any
18 on this.

19 MR. SCAROLA: We have not.

20 MEMBER BLEY: So when you use the MGL method
21 you don't have any common cause failures from which to
22 start. Go ahead.

23 MR. SAMPLES: Okay. Now for quality, first
24 of all discussing the quality of the MELTAC platform.

25 MEMBER BLEY: I just want to make a point,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 one more question. You don't have to go back to the other
2 one. But in the software side, we've got to use something,
3 maybe we have to use something.

4 But counting up hours probably isn't what
5 this is about. Because software doesn't age, it just sits
6 there. And the only way you're going to get a common cause
7 failure is if some event occurs whereby we're getting
8 inputs that aren't within the realm that we've actually
9 tested for. That's my opinion.

10 So it's only under really weird events where
11 we're going to see them, so that accumulating hours doesn't
12 really improve our confidence. But you're taking care
13 of it through other methods.

14 CHAIRMAN STETKAR: I didn't think about this
15 PRA thing until we started talking about this. But I
16 decided I'd go look at the model, because I hadn't looked
17 at this part.

18 You say you use the MGL method. It's not
19 clear to me that you actually do. Because the MGL method
20 looks at if I have a four train system.

21 You basically subdivide that system into
22 independent failures, and I've got four of those, failures
23 of two with common cause and independent failures of two
24 more, failures of three and an independent failure of one,
25 and then failure of all four.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The parts of the models that I've seen only
2 have a single basic event that says digital I&C hardware
3 failure. Now, it does fail all trains. That's the all
4 four. But it doesn't seem that you're picking up any of
5 the other intermediate parts, which is really the
6 application of the MGL.

7 MEMBER BLEY: That's right.

8 CHAIRMAN STETKAR: You do have a single
9 basic event that says all hardware fails. That's all four
10 together. You don't have any of the other logical
11 combinations of three of these and one of those, and
12 there's four of those, and two and two, and those geometric
13 combinations start to get really large really fast. At
14 least I haven't seen that anywhere in the digital I&C.

15 MR. SCAROLA: Didn't you say you were going
16 to save these questions for the PRA?

17 (Laughter)

18 CHAIRMAN STETKAR: Now this is not one of
19 the ones that I was going to say. Because I didn't come
20 across this until we started talking about MGL methods.

21 I have several others. I just wanted to make that
22 statement, because saying you --

23 MR. SCAROLA: It was developed to be able
24 to do exactly what John said.

25 CHAIRMAN STETKAR: -- saying you've applied

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the MGL method implies a certain logic structure to the
2 model. And that model does not seem to have that logic
3 structure.

4 Now, I'm a little bit hesitant because in
5 real time here in the last 15 minutes I've pulled up a
6 model to try to see that.

7 MEMBER BLEY: I would offer one other thing.
8 There are some fault tree codes that put this stuff in
9 for you, and you don't see it in the bigger model if you
10 select the option to do that.

11 CHAIRMAN STETKAR: It does, but they've used
12 that code and it has a separate flag for things where they
13 develop the logic. And this one isn't here. I've seen
14 it in other places. But for pumps and valves --

15 MEMBER BLEY: It's there.

16 CHAIRMAN STETKAR: -- you see the developed
17 --

18 MEMBER BLEY: You're right, the double --

19 CHAIRMAN STETKAR: -- the double diamond,
20 or double triangle. That's not here. You have to be
21 careful, in PRA in particular. When you say you've done
22 something you have to understand what that means, both
23 numerically and logically.

24 And saying that you've applied the MGL method
25 implies a certain logic to the models. And I'm not seeing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that here. And we'll just leave it there.

2 MR. SAMPLES: We may need to wait to address
3 that when --

4 CHAIRMAN STETKAR: Yes. That's fine.

5 MEMBER BLEY: Now, I'm sorry to divert. But
6 I just went back to look for something. Ken, earlier you
7 said the library of those models is in Appendix B in one
8 of the MELTAC reports. Maybe that's too big and we haven't
9 received it.

10 MR. SCAROLA: Well, I think you've, 07005
11 is the MELTAC topical report.

12 MEMBER BLEY: 005.

13 CHAIRMAN STETKAR: That's the one that used
14 to be a topical report in the --

15 MR. SCAROLA: Yes. It's a technical
16 report, excuse me, 07005, Appendix B.

17 MEMBER BLEY: Okay. I was looking in the
18 wrong one, which had an Appendix A and Appendix C, but
19 no B. But that's a different report. I was in the wrong
20 one.

21 CHAIRMAN STETKAR: Interpret silence as
22 proceed expeditiously.

23 MEMBER BLEY: Or we'll think up something
24 else.

25 (Crosstalk)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SAMPLES: Let's move quickly to quality
2 then and discuss --

3 MEMBER BROWN: I did, okay --

4 (Laughter)

5 MEMBER BROWN: This is easy, okay. In your
6 slide on the watchdog timer you talked about a partial
7 reactor trip. You mean a train trip. You don't really
8 trip the reactor, you mean one of the four. I presume
9 that's what you meant.

10 MR. SAMPLES: Yes, one of the four signals
11 --

12 MEMBER BROWN: So that's what you mean by
13 a partial reactor trip. I just --

14 MR. SAMPLES: Yes. One of the four signals
15 before it goes into the tool kit.

16 MEMBER BROWN: Yes, that's fine. I just
17 wanted to make sure I understood that point.

18 MR. SAMPLES: And any of the other trains
19 then, say the A train has --

20 MEMBER BROWN: They would create one. If
21 one of the other ones went, I'm just saying, when you had
22 one you were referring to that as a partial reactor trip.
23 That's fine.

24 MR. SAMPLES: Now the MELTAC here, the
25 quality, it says in quality assurance for the MELTAC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 platform, to begin, issue a criteria of quality.

2 Just a note, first of all, that the actual
3 model of MELTAC used for implementing the PSMS, the safety
4 related I&C, is the MELTAC Nplus S model of MELTAC. So
5 that's what that's telling you here.

6 Now for the hardware life cycle, it's the
7 components. The hardware is designed, manufactured, and
8 tested under an Appendix B Quality Assurance Program.
9 This life cycle also includes 30 years of support for
10 proactive obsolescence management and a corrective action
11 program.

12 For the basic software of the platform, the
13 basic software is developed and tested. All of the basic
14 software configuration items are developed and tested also
15 under an Appendix B Quality Assurance Program.

16 This Appendix B Quality Assurance Program
17 invokes the MELTAC basic software program manual. And
18 that manual satisfies the requirements of Branch Technical
19 Position 7-14 and complies with Reg Guide 1.152 and other
20 applicable IEEE standards.

21 You see there is an open item for this.
22 And MHI is to address how to flow down these requirements
23 to suppliers and to share this life cycle process of the
24 MELTAC platform.

25 Now moving to quality for the application

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 software, you see the design process for the application
2 software is governed by the software program manual. It
3 specifies pretty much standard software life cycle
4 processes.

5 All independent V&V activities are
6 performed by MHI in accordance with this SPM. The process
7 includes integration of a complete system that's hardware,
8 basic software, and application software, all together.

9 And there's an ITAAC that demonstrates compliance with
10 the SPM.

11 Now augmented quality is applied to certain
12 non-safety systems that have specific requirements. You
13 can see the different items, which are listed to have
14 augmented quality.

15 And you see the specific requirements listed
16 over here. For instance, safety function control by the
17 operational VDUs, they have the requirements of ISG-04.

18 MEMBER BROWN: What does augmented mean?

19 MR. SAMPLES: Essentially these are
20 non-safety systems, and the baseline is a non-safety QA
21 program. Then there's non-specific regulatory
22 requirement, that addition. But they don't go all the
23 way up to a full safety related program.

24 So for instance, if you look through this
25 Generic Letter 85-06, it gives specific additional things

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you need to do above the normal non-safety program, to
2 do that, to meet requirements for that.

3 MEMBER BROWN: I'm just not familiar.
4 Define a non-safety program, non-safety QA program.

5 MR. SAMPLES: One which I use is ISO 9001.
6 It's the basis of the non-safety. So that would become
7 the baseline for the non-safety, again, these additional
8 specific requirements that we get from regulations and
9 different industry standards.

10 MEMBER BROWN: Okay. No, I was just asking.
11 We don't have to beat this dead horse. I'll try to get
12 a better understanding of that.

13 MR. SCAROLA: Maybe to elaborate just a
14 little bit, augmented quality has really two aspects.
15 One aspect, for example, is that we apply an independent
16 review process to the design that you don't normally do
17 to non-safety systems.

18 Then beyond that, each one of these systems
19 has specific design attributes that are typically safety
20 system attributes. But we apply them to non-safety
21 systems.

22 For example, we talked about diverse
23 actuation system being tested to an equivalent level of
24 Seismic Category 1. Well, you don't normally do that for
25 non-safety systems. So it's a special requirement for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 this non-safety system. So we refer to it as augmented.

2 MEMBER BROWN: I didn't know what preceded
3 that. There's a non-safety system QA program somewhere.

4 MR. SCAROLA: That's the foundation.

5 MEMBER BROWN: And I was wondering where
6 the foundation was and how these are just adders to it.
7 That was where my question came from.

8 MEMBER BLEY: But just thinking about it
9 though, I know there are people who worry about having
10 some of this being non-safety. And this is, well, you're
11 better than non-safety or somewhere in between on the
12 quality.

13 MR. SCAROLA: But there is a lot of
14 precedence for this that came out of the ATWS rule
15 originally.

16 MEMBER BROWN: Yes, that's true.

17 MR. SCAROLA: Because ATWS systems are, in
18 fact, augmented quality. Because they have certain
19 safety attributes, but they're really non-safety systems.

20 Same thing with the SPDS that came out of
21 Three Mile Island, it has some safety significance, but
22 it's a non-safety system. So we apply augmented quality.

23 So there's nothing that doesn't have a lot of history
24 here.

25 MEMBER BROWN: And the treatment you're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 putting here for augmented quality is consistent with that
2 history.

3 MR. SCAROLA: With that history, correct.

4 CHAIRMAN STETKAR: It's the same as the
5 fifth line item down there. It's the stuff that's on the
6 DRAP list. In passive plants it's the --

7 MEMBER BROWN: Yes. I know some of it, but
8 I didn't know the whole package was a standard approach.

9 MR. SPRENGEL: One clarification, it is not
10 a genesis from a non-safety program. It's starting from
11 a non-safety classification and adding to it.

12 But we're not implying that there's a
13 separate non-safety program out there that we work on and
14 then switch it. We have one QA program that we follow.
15 And it's just a classification of the systems or
16 equipment.

17 MR. SCAROLA: That's a good point.

18 MR. SPRENGEL: So there was some phrasing
19 --

20 CHAIRMAN STETKAR: As if you had two
21 different quality assurance programs.

22 MEMBER BROWN: Yes, you've created new
23 confusion. You've got a QA program that applies, that
24 you use for safety systems, and then you augment it with
25 these. That's the average --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SPRENGEL: No. We have one QA system
2 that we apply for our work.

3 MEMBER BLEY: Some systems are safety, some
4 are augmented?

5 MR. SPRENGEL: One QA program. From
6 another time.

7 MEMBER BROWN: So you've got one QA program
8 that's a huge QA program that covers safety systems as
9 well, that you subtract stuff from to do non-safety
10 systems.

11 MR. SAMPLES: No, it's not that way. It's
12 basically we have one QA program. Then it's different
13 requirements for different levels, safety, augmented,
14 non-safety.

15 MEMBER BLEY: People with infinite budgets
16 require everything of everything. But not everybody has
17 that.

18 MEMBER BROWN: Our budgets were not
19 infinite.

20 CHAIRMAN STETKAR: Continue, I want to get
21 through two slides before we take a break. There's an
22 incentive here.

23 MR. SAMPLES: We'll move on to equipment
24 qualification now. Now the PSMS and the other safety
25 related components are qualified by type test to generic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 environmental seismic conditions that are expected to
2 envelope all potential sites.

3 Testing is performed in accordance with
4 applicable industry standards, such as the IEEE standards
5 there, and regulatory requirements. There's an ITAAC
6 that verifies that qualification test results envelope
7 actual site specific conditions.

8 For instrument sensing lines, these are
9 qualified to verify they comply with Reg Guide 1.151, which
10 endorses the ANSI standard, also including freeze
11 protection.

12 Lines that are connected to ASME Class 1
13 or Class 2, process piping or vessels, these are designed
14 as ASME Class 2 and Seismic Category 1.

15 For the MELTAC platform, for the
16 environmental test, the stats are for a mild environment,
17 for the temperature and humidity parameters that we expect
18 there.

19 For seismic it's tested for operating basis,
20 earthquake, safe shutdown, earthquake requirements.
21 It's also tested for conformance to IEEE Standard 344.

22 Also for electromagnetic capability it's
23 tested for conformance to Reg Guide 1.80. What you're
24 actually seeing in the picture over here, you see a MELTAC
25 cabinet. The door is open and it's undergoing an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 electromagnetic capability test.

2 CHAIRMAN STETKAR: Now, what I'd like to
3 do is, I know we're getting close to the end. But I had
4 some rumbling among the members here. So I'd like to take
5 a break now.

6 MR. SAMPLES: We have two sub-sections
7 before the end. So we still --

8 CHAIRMAN STETKAR: Yes. And I'm expecting
9 perhaps a little discussion on this. So what I'd like
10 to do is take a break and we'll reconvene at 3:30,
11 grudgingly.

12 (Whereupon, the meeting in the
13 above-entitled matter was concluded at 3:14 p.m. and went
14 back on the record at 3:30 p.m.)

15 CHAIR STETKAR: We're back in session.
16 Let's see if we can finish up MHI here anyway.

17 MR. SAMPLES: Okay, now for secure
18 development and operational environment. The security
19 of all PSMS software complies with SDOE requirements of
20 RG 1.152.

21 Complies during development by independent
22 V&V and configuration control processes defined in the
23 Software Program Manual, which also encompasses the MELTAC
24 Basic Software.

25 Complies during operation by system design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 features such as locked doors, alarms, module
2 reprogramming restrictions and the Memory Integrity
3 Checks.

4 Compliance to the SDOE requirements of the
5 RG 1.152 assures, one, that unintended functions haven't
6 been introduced at any point in development of the PSMS
7 software and, two, compliance assures that the system
8 contains design features that prevent and detect
9 unintended alterations during its operation.

10 MEMBER BROWN: Has the staff accepted that
11 your Software Program Manual is suitable? I mean, is
12 there an evaluation of that independently or is it just
13 a line item?

14 MEMBER BLEY: No.

15 MR. SCAROLA: It's a technical report that
16 the staff has reviewed.

17 (Crosstalk)

18 MR. SAMPLES: 07017. And the MELTAC
19 Software Program Manual is --

20 MEMBER BROWN: Did they review this or did
21 they just receive it?

22 MR. SPRENGEL: That's a question for the
23 staff.

24 (Crosstalk)

25 MR. TANEJA: I can answer it now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 (Crosstalk)

2 CHAIR STETKAR: We'll ask you when you get
3 up.

4 MR. TANEJA: Okay.

5 MEMBER BLEY: Yes, I had that on my list
6 earlier.

7 MEMBER BROWN: Okay, good. All right,
8 good.

9 MR. SAMPLES: Now, all safety functions of
10 the PSMS are installed in non-volatile memory that can't
11 be altered in any manner, excuse me, while operating.

12 If you did want to change this PSMS software,
13 this is what you have to do. You have to get access to
14 the equipment room. There's a lock that prevents that.
15 There's an alarm that says if you do that without
16 authorization.

17 Got to get cabinet access. The cabinet's
18 locked and there's alarm on the cabinet. You have to
19 remove the module. Again, this is alarmed and it's
20 controlled by tech specs.

21 You have to place the module into the
22 external chassis to reprogram it so you had to have the
23 chassis and you had to be able to put it in there.

24 MEMBER BROWN: That's in the maintenance
25 cabinet, right? Is that where that stuff is?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SAMPLES: It's the dedicated
2 reprogramming chassis.

3 MEMBER BROWN: Is that part of the
4 maintenance cabinet that's on the maintenance network or
5 is that just separate box that exists as a standalone?

6 MR. SCAROLA: A level of detail that has
7 not been defined.

8 MEMBER BROWN: Yes, I was going to ask that
9 because -- I can't remember if it was the DCD or the 07004
10 talked about the maintenance bus being independent and
11 having no external connections.

12 Are there internal connections or is it
13 something where something has to be moved from/to or can
14 you connect the maintenance bus to the safety bus or the
15 unit bus?

16 MR. SCAROLA: You cannot connect the
17 maintenance bus to any other busses. What you do is you
18 connect individual controllers to the maintenance bus to
19 diagnose --

20 MEMBER BROWN: You take them out of their
21 cabinet and stick them in or you --

22 MR. SCAROLA: No. I think we're confusing
23 two things. The maintenance bus is used for diagnosing.
24 If you have failures, you can now connect a controller
25 to the maintenance bus.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BROWN: How do you connect it is what
2 I'm saying. Is there a switch that you switch it from
3 out of its cabinet to the maintenance bus and then
4 diagnostically attack it or do you remove the controller
5 and put it into a cabinet where it gets --

6 MR. SCAROLA: No. No, there's no removal.

7 MEMBER BROWN: Well, but the reprogramming
8 involves removal and that's what I'm trying --

9 MEMBER BLEY: That's a different thing.

10 MR. SCAROLA: And that's what I'm trying
11 to say.

12 MEMBER BROWN: But that's what I'm trying
13 to differentiate when --

14 MR. SCAROLA: Reprogramming and maintenance
15 are two different things.

16 MEMBER BROWN: That's what I thought from
17 reading the stuff but I couldn't find a definition of what
18 the maintenance bus is. Where does it exist? Is it a
19 bunch of wires that run around the plant that somebody
20 take a switch and they connect this controller off to the
21 bus and therefore there's all these diagnostic tools they
22 -- what is it? There was just no definition, not a clear
23 definition. There's a picture somewhere that showed the
24 maintenance bus and some little modules but --

25 MR. SCAROLA: Do we want to bring up the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 back-up slide on the maintenance bus? Maybe this is a
2 good time. Can you get to it?

3 MEMBER BROWN: I didn't see anyplace else
4 to talk about it --

5 MR. SCAROLA: Do we have a back-up slide
6 for the maintenance bus?

7 MEMBER BLEY: Well, while you're getting
8 the slide, is this something you do in at the cabinet?

9 (Crosstalk)

10 MEMBER BLEY: Technician goes into that room
11 into the cabinet and --

12 MR. SCAROLA: Yes, he goes into the
13 equipment room. So it's locked and alarmed. He goes into
14 the cabinet, locked and alarmed. Now he connects a single
15 controller to the maintenance bus typically.

16 MEMBER BROWN: By turning a switch? That's
17 what we're trying --

18 MR. SCAROLA: I don't know that we've ever
19 defined --

20 MEMBER BLEY: Hooking up a cable to it or
21 --

22 MEMBER BROWN: That's what I've been asking.
23 How does it happen?

24 MR. SCAROLA: Have we decided how we're
25 going to make the maintenance bus connection, whether

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 we're going to plug a TCP/IP cable into the controller
2 or whether it's switched?

3 MR. SAMPLES: Yes, it's not showing on this.

4 MEMBER BLEY: And while everybody's looking
5 for stuff, are these requirements for being locked and
6 alarmed and all this, is this in Chapter 7? I don't
7 remember.

8 MEMBER BLEY: It is. Okay. Except for the
9 tech specs which are in the tech spec.

10 CHAIR STETKAR: Well, the tech specs, I
11 think the implication on the tech specs is the bypass
12 inoperable is controlled by the, you know, bitrain and
13 things like that. Tech specs don't specify alarmed and
14 locked.

15 MEMBER BLEY: No, no. But module removal
16 is controlled by tech specs.

17 CHAIR STETKAR: Yes. It says you can't have
18 multiple trains bypass --

19 MEMBER BLEY: That's the kind of control
20 we're talking about.

21 CHAIR STETKAR: That's administrative
22 control.

23 MR. SCAROLA: When you take something out
24 of service and now you're entering an LCO.

25 MEMBER BROWN: In the MELTAC there's a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Figure 4.3-23, the maintenance network configuration.

2 MR. SCAROLA: Yes, that's the one he's
3 trying to find for a back-up slide.

4 MR. SAMPLES: Can we switch the monitor over
5 to my personal machine, away from the main presentation?

6 CHAIR STETKAR: That's difficult to do.

7 MR. SAMPLES: Okay.

8 (Crosstalk)

9 MR. SCAROLA: So at least talk from that
10 figure then since you're -- while you're looking at it
11 in the MELTAC --

12 MEMBER BLEY: What's the figure number,
13 Charlie? We can all look -

14 MEMBER BROWN: It's Figure 4.3-23.

15 MR. SHUKLA: I think there is a switch you
16 can change.

17 MEMBER BROWN: No. There's a box called a
18 switching hub and that has --

19 MALE PARTICIPANT: You're talking about
20 different things.

21 (Laughter)

22 MALE PARTICIPANT: He's talking about
23 getting the picture up on the screen.

24 MEMBER BROWN: Oh, I'm talking about the
25 actual figure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BLEY: Say the number again.

2 MEMBER BROWN: 4.3-23.

3 MEMBER BLEY: 4.3-23.

4 MEMBER BROWN: Yes, I'm in the 07005,
5 4.3-23. Page 137.

6 MEMBER BLEY: Oh, well that's easier. Yes,
7 there it is. Well, that ain't much. I could have drawn
8 that.

9 MR. SCAROLA: This figure 4.3-23 shows wire
10 connections into every controller.

11 MEMBER BROWN: It shows a box called a
12 switching hub.

13 MR. SCAROLA: Switching hub, right.

14 MEMBER BROWN: And then it shows below it
15 three controllers with a dot, dot, dot going to the last
16 one. Line going into the switching hub and calling things
17 optical cables that go over to the switching hub.

18 And above that's got the MELTAC engineering
19 tool with another twisted-pair cable, ten megabit/half
20 duplex and then another engineering tool dot, dot, dot,
21 dot to another engineering tool.

22 MR. SCAROLA: So MELTAC engineering tools
23 are permanently in place. The hub is permanently in
24 place. The wires going from the hub to the controllers
25 are permanently in place but are disconnected from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 controller normally, so --

2 MEMBER BROWN: Through the switching hub?

3 MR. SCAROLA: No. That's what I'm trying
4 to ask MELCO, if they've decided if the wire's just going
5 to be hanging there and you have to plug it in under
6 administrative control.

7 You know, this is a TCP/IP cable like you
8 have on the back of your computer. So it could be the
9 wire's just sitting there unplugged and when you want to
10 plug it in you temporarily plug it in under administrative
11 tech spec control. But I don't think we've made a decision
12 whether or not we have a switch --

13 (Crosstalk)

14 MEMBER BROWN: There's a box that says,
15 "Note, the connection of the maintenance network and the
16 engineering tool to the controllers is normally
17 disconnected." Somehow.

18 MR. SCAROLA: But the disconnect, my point
19 is at the controller end, right where it goes into the
20 controller.

21 MEMBER BROWN: I would have imagined that
22 but it's whether it's a plug-in or a switch or -

23 MEMBER BLEY: We don't know yet.

24 MEMBER BROWN: Okay, it's undefined.

25 MEMBER BLEY: They don't know yet.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCAROLA: Well, my photo's telling me
2 it's just a plug. It's normally unplugged. You have
3 cables --

4 MEMBER BROWN: So you run around and you
5 see a bunch of plugs hanging out from the cabinet and laying
6 down across the front of the cabinet, right? I'm being
7 facetious but control of access is a little difficult if
8 they're just hanging there. That's --

9 MR. SCAROLA: But, see, they're inside the
10 locked cabinet.

11 MEMBER BROWN: Okay.

12 MEMBER BLEY: Inside the locked room. But
13 that's a mystery story you remember.

14 MR. SCAROLA: The plug and the socket are
15 inside the locked cabinet. Normally the plug is not
16 engaged in the socket.

17 MEMBER BROWN: Okay. I guess my next
18 question is how long is the cable to plug into the, I mean,
19 does it have to go ten feet -- I'm just. It's late, okay?

20 MALE PARTICIPANT: Just like the wire on
21 the little -

22 CHAIR STETKAR: Not as late as it's going
23 to be.

24 MALE PARTICIPANT: -- truck we used to take
25 around.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: I'm feeling open right now.

2 MR. SCAROLA: But so as not to get confused,
3 this has nothing to do with reprogramming --

4 MEMBER BROWN: I got that.

5 MR. SCAROLA: -- because you can't reprogram
6 through this. Okay.

7 MEMBER BROWN: You've got to take stuff out
8 and put it in something else to get the reprogram, yes,
9 and that's somewhere, whether they carry it outside the
10 plant or whatever they do with it. You haven't defined
11 that either.

12 MR. SCAROLA: We haven't defined. Very
13 frankly we don't expect a lot of reprogramming of safety
14 systems. It's not a common thing. Safety systems are
15 typically installed and, you know, safety systems, they're
16 very simple. The logic is simple and it is typically
17 stable, not like non-safety things where you tend to
18 optimize and tune and --

19 MEMBER BROWN: They're saying there's never
20 any software things, glitches that show up at some point?

21 Oh, we didn't expect that thing to happen and such,
22 therefore you have to go reprogram based on experience
23 in about 400 software changes.

24 MR. SPRENGEL: No, we're not saying that.

25 MEMBER BROWN: Okay, go on.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SPRENGEL: Pat, carry on.

2 MEMBER BROWN: You can get on. I'm
3 finished. You've answered my question.

4 MALE PARTICIPANT: Thank you.

5 MEMBER BROWN: It's somewhat undefined yet.

6 MR. SAMPLES: If you do manage to get through
7 all these different locks and alarms to change the
8 software, realize that you have to do this in four separate
9 I&C equipment rooms because these divisions, you know,
10 they're separated as we said before.

11 If you are successful in making some changes,
12 these unintended software changes are detectable by
13 periodic memory integrity check.

14 MEMBER BLEY: Are those automatic?

15 MR. SAMPLES: The periodic? No, that's the
16 manual initiated one. It's a diverse check initiated by
17 an operator using a MELTAC engineering tool.

18 Here you see some of the features of the
19 MHI development environment. It's talking about the
20 Corporate Electronic Archive System, essentially stores
21 basic software and application software.

22 It's password protected, physically
23 secured. Now, the system doesn't allow you to delete or
24 change. It's write-only and there's periodic backup.

25 Development environment itself, again, it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 access controlled. There is access control to
2 development machine by a password. You got to have a
3 password.

4 Just to get in and out there is controls
5 to control who can get in and out of it physically to the
6 development area, and this development environment and
7 computers and systems there are isolated from the
8 corporate network.

9 I believe this brings us up to a brief
10 overview of the status of open items for the draft safety
11 evaluation.

12 Now, for RAI 568, the topic is selection
13 of PAM criteria. That's selection criteria for the PAM
14 should be refined.

15 For RAI 753 the topic is the basis for the
16 inputs and the assumptions used in the D3 coping analysis.

17 Currently RAI response is under review by the NRC.

18 For 992 there was, one, sufficient evidence
19 to demonstrate that the use of the O-VDUs enhances the
20 performance of the safety system and that there is an ITAAC
21 that adequately verifies testing for normal and abnormal
22 data transmission conditions for all non-safety to safety
23 interfaces. MHI is still preparing this response.

24 For RAI 995 the concern is the process flow
25 down requirements for MELTAC to suppliers. For 993 it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the process to ensure the vendor's safety software
2 development process. For 988 the question is the basis
3 of the inputs and assumptions used in the D3 coping
4 analysis. For all three of these, this response is under
5 review by the NRC.

6 Now, for RAI 996 the concern is how the plant
7 would be adequately protected from PCMS failures,
8 including single failures, design defects including
9 common cause failures of software. MHI is still preparing
10 this response.

11 In summary, the digital I&C system provides
12 significant advancements over conventional analog plants
13 in that there's higher availability, higher accuracy, a
14 lower potential for human error, better performance,
15 improved operator command and control capability, a
16 reduction of maintenance workload and resources.

17 Now, the US-APWR, it employs proven digital
18 designs and many years' experience, of many years of
19 demonstrated reliability in Japan.

20 We have a conventional DAS that ensures plant
21 safety is maintained even if digital systems fail. We
22 are working closely with the NRC to complete U.S.
23 licensing.

24 MEMBER BROWN: You want to go back to Slide
25 81?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SAMPLES: We can.

2 MEMBER REMPE: That means he doesn't want
3 to.

4 MEMBER BROWN: Pardon?

5 MEMBER REMPE: It means he doesn't really
6 want to. He said he could.

7 MEMBER BROWN: No.

8 MR. SAMPLES: We're here to answer your
9 questions, so.

10 MEMBER BROWN: You call it this Corporate
11 Electronic Archive System.

12 MR. SAMPLES: Yes, sir.

13 MEMBER BROWN: And then you talk about the
14 development environment and then down in the development
15 environment you say it's isolated from the corporate
16 network yet it's connected up in the pictures to the
17 Corporate Electronic Archive System, which I presume is
18 part of the relative, has access from the corporate network
19 which it's not clear that this CEAS is isolated from the
20 corporate network and, if so, what does isolated mean?
21 Not connected at all?

22 MR. SCAROLA: No connection.

23 MALE PARTICIPANT: There's no connection
24 in this picture to the corporate network.

25 MEMBER BROWN: I understand that but if it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 a Corporate Electronic Archive System --

2 (Crosstalk)

3 MEMBER BROWN: -- it gives a very clear
4 connotation that there's other stuff from the corporation
5 that is stored in this archiving system.

6 So I guess I would question the fact that
7 is it really isolated from access by anybody if it's in
8 this particular overall corporate archiving system?
9 Since I hear dead silence, could that be answered at some
10 point?

11 MR. TAKASHIMA: No, no. This system is
12 completely isolated from the corporate network.

13 MR. SCAROLA: Presume he is saying yes.

14 MR. TAKASHIMA: Yes, yes.

15 MR. SCAROLA: This is only used for software
16 development. It's not used for other corporate
17 functions.

18 MALE PARTICIPANT: You have a case of a
19 confusing name.

20 MEMBER BROWN: You know, I just see the word
21 corporate in two different places which implies that
22 somebody else can use it. If it's dedicated only for the
23 development of US-APWR --

24 MR. SCAROLA: No, no, no, no. That's, I
25 think, where we have a misunderstanding. It is used for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 all software development activities in MELCO or MHI.

2 But it's for software development. That's
3 why it's called corporate. It's not only used for this
4 one project. It's used for software development. MELCO
5 does a lot of other types of software development.

6 MEMBER BROWN: Oh, other people have access
7 to this stuff if it's in this that are not associated with
8 the APWR program?

9 MR. SCAROLA: Correct, correct.

10 MEMBER BLEY: But it's not that the licensee
11 is corporate?

12 MEMBER BROWN: Pardon? Regardless, it
13 still has access by other people that aren't part of an
14 APWR --

15 MR. SCAROLA: Well, developers.

16 MEMBER BROWN: Well, developers for what?
17 Commercial plants?

18 MR. SPRENGEL: It would be under the
19 Appendix B QA Program though, so if there were other plants
20 being sort of developed it would be under a completely
21 different QA system and would have completely separate
22 information and storage requirements.

23 So other developers would have access to
24 it just as they do for all of our codes. I mean, the codes
25 are available within MHI under the MHI Appendix B QA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Program.

2 But if you're working on a separate, you
3 know, completely separate project within MHI unrelated
4 to US-APWR, you do not have access to that information
5 so it is still controlled.

6 MEMBER BLEY: Do they have separate code
7 libraries, that Appendix B set of modules that you can
8 paste together? If not, could we get some funny logic
9 injected somehow along the way?

10 MEMBER BROWN: It's a control of access
11 thing. I mean, if it's in the same overall memory bank
12 system that other people's stuff is stored, then those
13 memory banks are accessible and you're depending on some
14 type of password protection and/or software as opposed
15 to a hard, open circuit. That's all I'm looking for.

16 MR. SPRENGEL: Okay. Okay, we'll get some
17 clarification on that and we'll follow up on that.

18 MEMBER BROWN: I mean, it's a location where
19 somebody could muck around with the application code.

20 MR. SPRENGEL: Yes, right, I do. Yes, I
21 understand the question. It should be pretty
22 straightforward to answer, how we separate and control
23 I guess not only the access but also the potential
24 interactions.

25 MEMBER BROWN: Yes, that's it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SPRENGEL: Okay.

2 MALE PARTICIPANT: Okay? Good. Thank
3 you.

4 MR. SAMPLES: Again, we're at the end of
5 the presentation, the list of acronyms. I think we did
6 actually have one question but we might have answered that
7 earlier. Is any other general questions or anywhere you
8 want to go back? Again, we're here to answer your
9 questions.

10 CHAIR STETKAR: Do any of the members have
11 any more questions for -

12 MEMBER SHACK: Well, this RAI 99-7024 you
13 have listed as flow down here. In the SER there's also
14 a comment there that it's essentially dropping everything
15 about commercial dedication. That's part of this RAI?
16 That's part of your response?

17 MR. TAKASHIMA: Yes.

18 MEMBER SHACK: In the SER I see RAI 995-7024,
19 remove any reference to commercial grade dedication of
20 the MELTAC platform. Is that part of that response or
21 is that --

22 MR. TAKASHIMA: Yes.

23 MEMBER SHACK: Well, it's the staff since
24 they're asking them to address this in the RAI, and I guess
25 the next question is if they have prepared a response I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 sort of wondering what the answer is.

2 MR. SCAROLA: But he's just asking what the
3 answer is. Are we going to remove all reference to --

4 CHAIR STETKAR: Anything else for MHI? If
5 not, I'd like to thank you all. You covered a tremendous
6 amount of material. We're obviously way over-scheduled.

7 But I think it's really, really important
8 for the Subcommittee Members to get all the questions out
9 on the table, understand all of this. It's one of the
10 places where everything in the plant comes together so
11 it's really important that we understand it.

12 And kind of in closing before we let you
13 off the hook, sort of an observation that you received
14 a lot of detailed questions from us here and I know it's
15 difficult to field all of those questions.

16 From our perspective, we're able to ask the
17 detailed questions because you've actually presented a
18 real design in detail, which the ACRS has weighed in on
19 other design certifications that don't nearly have this
20 amount of detail, finality in the design and we really
21 appreciate this.

22 I know it's difficult to field all of these
23 questions about specificity, but you have a real design
24 that we can actually look at and gain some confidence and
25 sort of probe into little nooks and crannies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And my personal opinion anyway, it's a much,
2 much better situation than some of the other designs where
3 everything is left to DAC, ITAAC and DAC, after the plant
4 is built.

5 So I know it's difficult for you to hear
6 all of the probing but we really appreciate being able
7 to look at some engineering.

8 MR. TAKASHIMA: Thank you very much.

9 MR. SCAROLA: We appreciate your comments.

10 I just want to say it's actually not difficult to field
11 your questions because we have a detailed design. It
12 makes it much more difficult to answer your questions when
13 we don't have a detailed design.

14 CHAIR STETKAR: Good.

15 MEMBER BROWN: Some of us have noticed that.

16 CHAIR STETKAR: Thank you, and what we'll
17 do is --

18 MR. SPRENGEL: Real quick procedural
19 question.

20 CHAIR STETKAR: Yes.

21 MR. SPRENGEL: I think we have a few things
22 outstanding so obviously we're going to go through with
23 the staff's presentation but are we planning to kind of
24 revisit any topics tomorrow?

25 CHAIR STETKAR: Yes, yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SPRENGEL: Okay.

2 CHAIR STETKAR: Yes, I mean, we're going
3 to run over into tomorrow so if you jotted down a few notes
4 we can address them.

5 MR. SPRENGEL: Okay, so we'll plan to try
6 and follow up on a couple items tomorrow morning.

7 MR. SHUKLA: Yes, that's also on the agenda.

8 MR. SPRENGEL: Okay, just confirming.

9 MR. SHUKLA: It's on the agenda.

10 CHAIR STETKAR: No, we're not going to let
11 you hang.

12 MEMBER BLEY: We're only three hours behind.

13 CHAIR STETKAR: Yes, that's fine. I'm
14 trying to get the staff up here so we'll see if we can
15 bring the staff up and start that.

16 (Off microphone discussion)

17 CHAIR STETKAR: While we're shifting here,
18 since we're still on the record, let me float a couple
19 of notions because I want to get feedback from folks about
20 the schedule.

21 We're obviously running real late. Our
22 agenda for today shows us ending at 6:00. We've covered
23 a lot of material and I'm worried about burnout setting
24 in so I think that I'd like to hold to that 6 o'clock time.

25 One of the questions that I have is that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 on our agenda for tomorrow we also have to cover Chapter
2 2 sections for Comanche Peak and I'd like all of us --
3 our agenda shows us ending at noon tomorrow. I don't think
4 we'll be able to get through all of the material by noon
5 tomorrow.

6 But if we can work out internally some plan
7 to see if we can finish by sometime between 2:00 and 3:00
8 tomorrow afternoon it might help everybody. I know
9 Luminant has people coming in and I hate to have them come
10 in and not get to Chapter 2.

11 So what I'm asking is Members on the
12 Subcommittee and NRC staff, you know, if we can adjust
13 presentations. If there are some things that are
14 repetitive, if you can skip over in the staffing
15 presentations just so we can try to get everything in,
16 in particular the Chapter 2 material tomorrow afternoon.

17 So I'll just float that a little bit. We
18 will plan to end at 6 o'clock today just because I'm too
19 worried about people sitting here too many hours without
20 --

21 MEMBER BLEY: You're going to have some
22 burnout of course.

23 CHAIR STETKAR: Yes.

24 MEMBER BLEY: Before we get started with
25 staff here, may I add to your last comment?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: You may.

2 MEMBER BLEY: John's last comment about
3 appreciating the level of design detail we had here to
4 review and staff had to review and I guess it re-raises
5 those issues, not for this design but for others, ones
6 we've left with DAC, and we have an agreement to do some
7 getting ourselves involved in the DAC for those plants
8 later.

9 But the number of RAIs at the detailed level
10 that staff had and the number of questions that we have
11 when you get to the detailed level are significant, I
12 think, indicators of why we're going to need some
13 continuing interaction for those other plants. I just
14 wanted to get that out here. Thank you.

15 CHAIR STETKAR: And with that, we will let
16 the staff start. I don't know who. Tom?

17 MR. BERGMAN: Yes. Good afternoon. My
18 name's Tom Bergman. I'm the Director of the Division of
19 Engineering in the Office of New Reactors and I'm not
20 really going to be part of the actual briefing for MHI.

21 But the Committee recently issued a letter
22 on the mPower Chapter 7 Design-Specific Review Standard
23 and they've raised this issue on other designs, including
24 I think MHI in the past.

25 The letter related to data communications

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 from a common network bus, passing plant data from safety
2 systems to the main control room, technical support
3 center, emergency support center and plant control signals
4 back to the safety systems, that the staff's position to
5 date has been that those type of access issues were not
6 addressed in the design review, that that was a cyber
7 security issue addressed through the cyber security
8 program.

9 Our response to you, which its issuance is
10 imminent, says that we are reconsidering that position.

11 We do think we understand your concern. We do recognize
12 the general nature of the question.

13 The letter says, you know, we'll keep you
14 informed through upcoming meetings of our progress on it
15 with a final staff decision no later than the issuance
16 of the mPower DSRS, which means January 2014.

17 But in terms of interim sort of schedule,
18 the four branch chiefs involved, the three I&C branch
19 chiefs across NRR and NRO and the cyber security branch
20 chief from NSIR, are developing a set of options for
21 management.

22 We expect that to be completed in about three
23 weeks and then the division managers will see if we can
24 come to a consensus on a recommendation in the following
25 couple weeks.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And we look to have a meeting at the
2 office-director level very late in May or early in June,
3 so sometime this summer we should at least have a draft
4 position as to where we look to be headed so we'll keep
5 you informed as we make progress.

6 MEMBER BLEY: We'd appreciate that. Thank
7 you very much.

8 CHAIR STETKAR: Thanks a lot.

9 MEMBER BROWN: Can I make one observation?

10 CHAIR STETKAR: You may.

11 MEMBER BROWN: I'm just referring to your
12 initial lead in. The concern is not necessarily
13 communication between the protection systems and their
14 main control room.

15 It's the fact that the data's on a bus which
16 has access to some firewall to a corporate, or, like,
17 through a management computer or a firewall to corporate
18 systems and whatever they are. It's that interface, and
19 just to make sure I had that statement.

20 MR. BERGMAN: Yes, we understand.

21 MEMBER BROWN: I guess the other
22 observation, based on I didn't say it in the meeting the
23 other day, the informal meeting, but we'd like not to wait
24 for the DSRS thing. We'd like to have some interaction
25 when you come to a decision.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. BERGMAN: We will. We just wanted to
2 put a backstop in because this will be tracked by the EDO
3 for completion so we need to give them a date.

4 MEMBER BROWN: Oh, that's fine. That's
5 fine for commitment purposes but, I mean, if you come to
6 a decision in June or July, we ought to --

7 MR. BERGMAN: We will.

8 MEMBER BROWN: We ought to interact on this.

9 CHAIR STETKAR: Charlie, we'll set up
10 Subcommittee meetings. Don't worry. The important
11 thing was to hear from the staff that --

12 MEMBER BROWN: I appreciate that.

13 CHAIR STETKAR: -- indeed, they're moving
14 in response to some of our concerns.

15 MEMBER BROWN: I understand that.

16 CHAIR STETKAR: And that's important.

17 MEMBER BLEY: And our letters have laid out
18 on those.

19 CHAIR STETKAR: That's right. So we'll --

20 MR. BERGMAN: Yes, we're trying to move
21 quickly because depending where we go, which option we
22 would take, right, it can affect other activities already
23 ongoing in the agency, whether it's ongoing design
24 reviews, that. So we need to make a decision relatively
25 quickly. We're not trying to drag it out. We just needed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the facts out.

2 MEMBER BROWN: I wasn't trying to imply
3 that. It was just decision interaction before a final
4 paper's done. That's all. I mean, the informal paper.

5 CHAIR STETKAR: Thanks, Charlie.

6 MEMBER BROWN: That's it. Thank you, John.
7 Can I interrupt again? No.

8 CHAIR STETKAR: No.

9 (Crosstalk)

10 CHAIR STETKAR: We've had enough. Let's
11 get Jeff.

12 MR. CIOCCO: Yes, Jeff Ciocco, NRC staff.
13 No, I just wanted to say that we have the PRA people here
14 --

15 CHAIR STETKAR: Yes, good.

16 MR. CIOCCO: -- if you want to address that
17 issue now before we get started with the status
18 presentation.

19 CHAIR STETKAR: Yes, I think that's good
20 timing. That's sort of what I was looking for here. One
21 of the things, I'd asked the staff to bring their PRA people
22 down and in the earlier discussion I said I would try to
23 keep my mouth shut about PRA issues until now.

24 As I read through the DCD, there were several
25 references to the use of the PRA to demonstrate reliability

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of the design. There were also references to the use of
2 the PRA to demonstrate the fact that the design would work
3 with one channel completely out of service.

4 And as I was trying to follow up those
5 references, I found places in the technical bases for the
6 tech specs that refer to the PRA for justification, for
7 example, for the 72-hour completion time that's listed
8 in the tech specs.

9 Now, I have not reviewed the PRA in detail.

10 I did look at some of the specific parts of the models
11 that relate to the digital I&C system. I looked at them
12 earlier kind of very briefly when we were reviewing the
13 PRA Chapter 19.

14 I went back and did a little more digging,
15 in particular to see if I could follow up some of the words,
16 anyway, that are in the DCD and quite honestly the PRA
17 logic models, at least as they are presented in Revision
18 3 of the PRA report, are not structured to support the
19 types of analyses that are referenced in the DCD, I mean,
20 particular.

21 For example, it is not logically possible
22 to bypass both reactor trip breakers in the same train
23 in the PRA model, despite the fact the DCD asserts the
24 fact that that was examined. It is not possible to bypass
25 an entire channel train of input sensors.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And by that I mean, for example, each steam
2 generator has four level sensors, one from Train A, one
3 from Train B, one from Train C, one from Train D.

4 Train A level sensors, there's one in each
5 steam generator. In the PRA model you cannot logically
6 take out Train A simultaneously from all four steam
7 generators. You cannot do it. It's logically precluded.

8 The technical specifications allow you to
9 remove one train of sensors indefinitely. The tech specs
10 require that three trains must be operable and if a second
11 train becomes inoperable you have a 72-hour time. The
12 PRA models explicitly preclude you from having any more
13 than one train of sensors out, in fact, any more than an
14 individual sensor.

15 So it's not clear to me how the PRA model
16 can be used to examine the sensitivity to a 72-hour allowed
17 outage time that applies only when you have two coincident
18 sensors out of service when the PRA model does not
19 logically allow that. In fact, it logically precludes
20 it.

21 So I read the SER and the staff is really
22 careful about saying in terms of reliability we don't rely
23 on numerical values. We rely on qualitative arguments
24 about reliability.

25 My concern is that there is still a number

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of statements in the design certification document and
2 I think little bit bigger concern in the technical
3 specifications, which are part of the licensing basis for
4 this plant, that refer to the PRA for justification in
5 cases where I can't see where the PRA can provide that
6 information.

7 You would need to change the logic models
8 to do the type of analysis that is inferred in those
9 statements.

10 So, you know, as I said, I haven't reviewed
11 the PRA and if people can show me how they use the PRA
12 to draw those conclusions I'd be really happy, so that's
13 sort of one request.

14 If you can't show me how you use the PRA,
15 then I'm really curious about how the staff has reviewed
16 the PRA to that level of detail so that, indeed, the staff
17 can draw a reasonable assurance conclusion that the
18 technical specifications are appropriately justified and
19 that the statements in the design certification document
20 regarding the liability of the digital I&C system are
21 appropriately justified and that statements saying that
22 the PRA has been used to conclude that the reliability
23 is maintained with, for example, one channel completely
24 out of service.

25 I don't know whether MHI, I know you don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have your PRA people here so I wanted to kind of get it
2 into the record. If you can hear that, you can take it
3 back, Ryan, to your PRA folks.

4 I did look at the comparisons that were
5 alluded to in your presentation about the difference
6 between a 72-hour time and the time in the standard
7 technical specifications, but those are simply
8 comparisons on unavailability numbers of individual
9 sensors.

10 For the 72-hour time, I might have an
11 unavailability of x. With a different allowed outage time
12 I might have an unavailability of y. It's not the same
13 as taking an entire train out of service in a correlated
14 fashion, so.

15 MR. SPRENGEL: Yes, we've heard the message.

16 I know there's some ongoing discussion within MHI on this
17 topic and, you know, it's come up previously in our
18 discussions.

19 CHAIR STETKAR: Okay, yes.

20 MR. SPRENGEL: And we had mentioned about
21 some of additional informational briefings in the report.

22 CHAIR STETKAR: Yes, and that's fine. I
23 only wanted to bring it out because I'd mentioned it
24 earlier in the PRA reviews but it kind of really came home
25 to roost when I started digging in to some of the digital

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I&C model.

2 MR. SPRENGEL: Right, and I think some of
3 the things we're working on is removing that kind of
4 specific connection between the implied analysis that's
5 done and the conclusion so that is being worked on.

6 But I think your question goes a little
7 deeper than that and it's some of the specifics on kind
8 of what is actually potential in the model and what has
9 been used to kind of get this basis for these values.

10 CHAIR STETKAR: I mean, I hear statements
11 that are made that -- we had the little discussion about
12 MGL models. Okay, that's one thing, but if I look in some
13 of the PRA models, I mentioned earlier I couldn't find
14 SLS modules modeled consistently through all of the
15 systems. They seem to be in some places and not in others.

16 So when you say that the PRA model has
17 accounted for common cause failure of the SLS modules,
18 it can't consistently because it doesn't have the
19 wherewithal to be able to do that, so there are some of
20 those details.

21 How you resolve those, you know, in terms
22 of the design certification and the supporting information
23 to provide reasonable assurance conclusions for the design
24 certification is one issue. That's our concern right at
25 the moment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 We've already discussed in the other venue
2 the ability to use the PRA for risk-informed applications
3 post-COL issuance.

4 But for the moment, in terms of supporting
5 the reasonable assurance conclusions for the certified
6 design and the licensee basis for the plant, the tech
7 specs, I think we need to really be careful about
8 understanding what the PRA can and cannot, has and has
9 not been used to justify.

10 And if, indeed, it is used to justify some
11 of those conclusions, that has different implications in
12 terms of the level of detail of the staff's review of those
13 underlying models than perhaps might have been done just
14 to simply examine the models in the context of the DCD
15 Chapter 19 conclusions so I don't know, Lynn, if you want
16 to say anything or --

17 MS. MROWCA: This Lynn Mrowca. We
18 understand your concerns due to the previous ACRS meetings
19 that we held earlier this month. I just talked to Ian
20 Jung and we're going to get together and talk about this
21 and the specifics of how they reference the PRA and its
22 uses and review concerns.

23 CHAIR STETKAR: Okay, thanks. You know, if
24 we need to set up another, you know, Subcommittee briefing
25 or something else we can work through that but I --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 (Off microphone discussion)

2 MR. SPRENGEL: That's fine. We've heard
3 the concerns and, you know, the staff will be discussing
4 and we'll interact with the staff and then we'll have
5 future opportunities to address this.

6 CHAIR STETKAR: I'm confident there's a path
7 forward. I just wanted to make sure that you heard our
8 concerns and that the staff at least had their folks here
9 to hear that.

10 So with that, we'll let the I&C folks step
11 onto the hot plate.

12 MR. TANEJA: Thank you. Finally. Well,
13 thanks for giving us the opportunity to present our safety
14 evaluation of the US-APWR I&C design. We have a few open
15 items. I will go over that as we go through the
16 presentation.

17 And I am Dinesh Taneja. I am the senior
18 I&C engineer in our ICE Branch, Instrumentation, Control
19 and Electronics Engineering Branch, 2. And Ian Jung is
20 our Branch Chief. And along with me are the other staff
21 members that were part of the review of this US-APWR I&C
22 design.

23 Joe Ashcraft, you know, he was the primary
24 reviewer of Section 7.2 and 7.3, the RP, you know, reactor
25 system and the SFAS and he would be presenting, you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 on the redundancy part of the presentation.

2 Khoi Nguyen, he reviewed 7.6 and 7.9 so data
3 communication was primarily his review area and he'll be
4 talking about independence and simplicity.

5 And Erick Martinez, he is the primary
6 reviewer of the DAS system so he'll cover DAS.

7 And I have Jung. You know, he's sitting
8 over there on the side. He's my software guy that looked
9 at the SPM manual at the SDOE so we'll have him go through,
10 you know, his review process.

11 You know, we're going to focus our
12 presentation on the key technical areas rather than going
13 through the complete, you know, 350-some pages of our
14 safety evaluation.

15 So we'll, you know, focus on the redundancy,
16 independence, determinism, you know, the key I&C areas
17 that have been of interest to the Committee in our other
18 design center, so we're trying to focus our review on that
19 also.

20 And, next slide, so the other, you know,
21 technical topics I will want to cover today's presentation
22 is the Software Program Manual since we have an open item
23 in the PAM instrumentation area so we want to go over some
24 of that.

25 And then another open item we have on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 impact on safety due to failure in the PCMS system. So
2 we'll briefly brief the, you know, the Committee on a
3 non-concurrence that we had on the safety evaluation that
4 we put together.

5 So as a little introduction and background,
6 you know, the MHI submitted their application on December
7 31st and I realize that's been over five years that we've
8 been looking at that.

9 You know, there was a, slow getting started.

10 You know, didn't get to the acceptance review till about
11 six months later and then initially we had Oak Ridge, you
12 know, that was contracted to, you know, support us in this
13 technical evaluation.

14 So in April 2010, you know, I&C technical
15 review was on critical path and there were some technical
16 issues and challenges at that time that were really, you
17 know, challenging us from making progress in this area.

18 And MELTAC platform, you know, initially
19 the applicant wanted the MELTAC platform to review on its
20 own merits as a topical report so they can use it in
21 operating reactors in other places. And that become a
22 factor in us completing our US-APWR review.

23 The MELCO, you know, who is the supplier
24 and the, you know, subcontractor to MHI for MELTAC did
25 not have an Appendix B program and that also impacted the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 review that we were doing at that time.

2 And then there were significant number of
3 outstanding unresolved RAIs at that time that needed to
4 be controlled, and then we had significant issues with
5 data communication independence and that was also very
6 challenging.

7 So in August 2010, you know, put together
8 a closure plan to kind of, you know, get control of all
9 the situations here. We identified and, you know, worked
10 on a resolution plan of all outstanding RAIs.

11 The topical reports that were submitted for
12 MELTAC, you know, and safety I&C system, they turn into
13 technical reports and now they got reviewed as part of
14 the US-APWR design certification rather than a separate
15 review.

16 The Software Program Manual was revised to
17 address, you know, the software QA issues including MELTAC
18 Basic and Application softwares.

19 And the emphasis was placed on the key
20 digital I&C design principles and that's, you know,
21 primarily from our experience with the other design
22 centers and the feedback that we got from the Subcommittee
23 on, you know, the focus on the critical and the principal
24 design principles for digital I&C, so that became the
25 focus.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Simultaneously I think MELCO established
2 an Appendix B program, you know, for building the
3 multi-platform for the US-APWR. So these were some of
4 the things that were done to kind of get the project back
5 on track. Next slide.

6 To support our evaluation we also did two
7 significant audits. One was in Kobe, Japan, and one was
8 in Arlington, Virginia. You know, the topics of our
9 audits are listed here. And some of the things that I'm
10 going to add to that is that we also had the opportunity
11 to visit Oi nuclear power plant while we were there.

12 That plant uses MELTAC for RPS safety system
13 and non-safety reactor control, turbine control, in-core
14 instrumentation, control hard drive, rod positioning
15 indication and radiation monitoring system.

16 So we were not only able to see the equipment
17 in the plant but we were able to also talk to the plant
18 staff members and their experience with the MELTAC
19 equipment over there, so that was some of the supplemental
20 things.

21 And in addition to that, MELCO gave us
22 demonstration on MELTAC platform, demonstrating some of
23 our key technical areas that we wanted to confirm that
24 are in the DCD.

25 So we have six open items right now that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 we are dealing with. Two of the open items are located
2 in Section 7.1 of our SCR. One deals with the QA of the
3 vendors' safety software and the other is MELTAC platform
4 and the commercial-grade dedication issues.

5 And then we have another one in 7.5 which
6 is dealing with the basis for the PAMs variable and I'll
7 go over that when we get to, you know, what is going on
8 with that thing.

9 In 7.7 we have this new RAI that we just
10 issued recently and we haven't really gotten a response
11 back. It's the impact of PCMS failures, multiple, single,
12 whatever, on the safety systems.

13 And there's a number of questions that either
14 we are reviewing or waiting for response on D3 coping
15 analysis that are in 7.8.

16 And then there is one open item in 7.9 which
17 is dealing with the operational VDU interface to control
18 safety components.

19 CHAIR STETKAR: Dinesh, when I read through
20 the SER, there was one section that might not have been
21 updated and it's 7.1.4.9.3. Just go back and check that
22 because there are statements in there that says the staff
23 has identified several open items identified in the
24 previous section, which is part of 7.1, and that has to
25 do with channel checks and all of that kind of stuff.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I don't think that there are open items but
2 I wasn't sure whether something had been left out or not.

3 This body count kind of confirms that there aren't.
4 Might want to go back and --

5 MR. TANEJA: Yes, we'll go back and look
6 at it. There were but I think those responses were
7 acceptable and they should have been -

8 CHAIR STETKAR: Yes, I mean there was
9 nothing saying that, you know, we reached acceptance.
10 It just says several open items, a lot about standing RAIs
11 and that stuff. Okay.

12 MR. TANEJA: Well, that was the case one
13 time --

14 CHAIR STETKAR: No, no. I'm sure it was.
15 As I said, I think it's just an editorial thing but I
16 just wanted -- that table helps.

17 MR. TANEJA: Yes, all right. Well, we'll,
18 you know, go back and take a look at that.

19 You already, I think, heard about these
20 documents earlier today. In addition to the DCD, you
21 know, these technical reports and one topical report, you
22 know, these are the primary measure documents that we use
23 in our evaluation.

24 MEMBER BLEY: Well, this would be a good
25 time for me to ask the question that was linked to before,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 is they told us these all started out as topical reports
2 and have moved over. They decided not to be technical
3 reports. If they were topicals, you would have read them
4 and given an SER on them.

5 Now specific areas are referenced in the
6 DCD. I suppose your review of the DCD, anything that's
7 referenced out there, you're essentially reviewing that
8 part of the technical report as if it's part of the DCD,
9 is that right?

10 MR. TANEJA: That is correct.

11 MEMBER BLEY: So we get the same kind of
12 review we would have had only it's on the parts that are
13 of significance to the DCD?

14 MR. TANEJA: If it was a topical review
15 report, then it would have been a separate topical and
16 then you don't have a plant design to associate it with
17 that. So all you're looking at is the, you know, the
18 quality abilities of the MELTAC. Now, you don't have an
19 application so you really can't address those.

20 So when you look at the 603 criteria, some
21 of them apply some of them later, pending. So those become
22 like an action item in a topical report review.

23 MEMBER BLEY: But now as you're reviewing
24 it you're --

25 MR. TANEJA: We have the complete picture.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BLEY: You have the whole thing so
2 you're looking at the quality of the documents analysis
3 --

4 MR. TANEJA: Exactly.

5 MEMBER BLEY: -- as well as its
6 applicability to this --

7 MR. TANEJA: We're looking at the complete
8 picture. So what we did is not only the DCD. We also
9 looked at the technical reports. We also looked at the
10 Tier 1 ITAACs. So really we, you know, we looked at all
11 these things in its entirety.

12 And one of the things that I want to point
13 out here is that we coordinated our review with other
14 technical branches. You know, our review included
15 coordination with Reactor Systems, coordination with
16 Human Factors, coordination with Containment Systems, you
17 know, Tech Specs Branch, ITAAC Branch.

18 So it's like, you know, this review and the
19 PRA Branch. We did coordinate to a certain extent with
20 PRA Branch. John is looking at me with a grin on it but
21 that was part of our review, Dennis. Thank you.

22 CHAIR STETKAR: Now, before you leave it,
23 I'll ask you now that you're up here. Now, I think we
24 heard a long time ago today. I understand all of that
25 except you do have an SER on the one topical report on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 this list on 07006.

2 The DCD, at least Rev. 3 of the DCD, and
3 I believe the current SER refer to that topical report
4 pretty extensively. The design, as I understand it, has
5 changed and it is now different from the design that's
6 documented in that approved topical report.

7 What happens going forward? I mean, how
8 do we make sure that the information in the DCD and any
9 other associated technical reports reflect the real DAS
10 design going forward?

11 In other words, how do we know that the right
12 bits and pieces from MUAP-07006 that are still valid but
13 might not have been documented anywhere else are picked
14 up and documented elsewhere so that they become a valid
15 part of the licensing basis for the plant and the new
16 information is reflected somewhere, unless there's a plan
17 to reissue MUAP-006, whatever it is, 7006?

18 MR. TANEJA: I believe that's one of the
19 options that's been discussed but let me have Erick answer
20 these questions because he's been dealing with them
21 extensively.

22 MR. MARTINEZ: Yes, hi. This is Erick
23 Martinez for the I&C branch. When we were reviewing the
24 DCD and the coping analysis, which is still an open item,
25 the applicant references that topical report in several

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 sections.

2 But when you actually look at the details
3 from that topical report, it describes their process in
4 a very general way so when they reference that it's still
5 relevant to the DCD. Any information updated as part of
6 the DCD review supercedes the information from the
7 topical report.

8 So even if the topical report, for example,
9 states that there are only two DACs, the diverse actuation
10 cabinets, and the DCD has been revised and added four
11 cabinets, that information is the current design for the
12 US-APWR.

13 Any information referenced from the coping
14 analysis is just the general D3 approach for the US-APWR
15 but we don't take any sort of those details from the coping
16 analysis as far as the DCD.

17 CHAIR STETKAR: When you say coping, you
18 have to be careful because you keep saying coping analysis.

19 MR. MARTINEZ: Oh, I said coping, yes.

20 CHAIR STETKAR: Well, actually in the SER
21 you refer to 7014 for details of the design and they aren't
22 in there. They're actually in 7006. So even here in this
23 presentation, we have an example of my concern.

24 MR. MARTINEZ: Okay.

25 CHAIR STETKAR: The details of the design,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 a design, are in 7006. 7004 does not contain any details
2 of the design.

3 MR. MARTINEZ: Not as many details. In
4 general --

5 CHAIR STETKAR: It's a philosophy, if you
6 will.

7 MR. MARTINEZ: Yes.

8 CHAIR STETKAR: My concern is making sure
9 that going forward when the design is certified we have
10 a complete set of information for DAS in particular because
11 it's the only thing that is affected by that topical report
12 that has been reviewed by the staff and we have
13 traceability to documents that actually have --

14 MR. MARTINEZ: I agree with your concern.
15 I guess what we can do is --

16 CHAIR STETKAR: I'm just laying it out on
17 the table. There are different ways to approach it but
18 --

19 MR. MARTINEZ: Yes, we can verify that and
20 let's go back and just make sure that everything that is
21 referenced from that topical report, it is actually --

22 CHAIR STETKAR: It either needs to be
23 documented to that level of detail in the DCD itself or
24 it needs to be migrated into some other technical --

25 MR. MARTINEZ: Area, yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR STETKAR: -- report so we have that.

2 MR. MARTINEZ: I understand your concern,
3 all right, and I appreciate the comment. Thank you.

4 MR. TANEJA: You know, the staff identified
5 significant technical issues in the original design, the
6 complex architecture, bidirectional data communication
7 issues, the continuous connection between the safety
8 system and the maintenance network, capabilities to make
9 online software changes.

10 The DAS was two-out-of-two logic with two
11 cabinets and then use of time-critical manual actions from
12 DAS. Some of those are highlights of some of the, you
13 know, design issues that we found. Next slide.

14 And applicant, you know, MHI, MELCO, MAPI,
15 you know, they've been, very, very responsive to these
16 issues that we've identified and I think you've seen some
17 of the design details earlier today.

18 The data communication, you know, has been
19 reduced, the interface between the safety and non-safety.

20 Now it's only limited to the manual control of safety
21 components from operational VDU.

22 And there were automatic signals the
23 original design had coming from the unit bus into the
24 safety system. They have been removed. Now they come
25 via hardware interface and are using isolator scheme, so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the non-safety automatic actuation signals are no longer
2 coming on the unit bus.

3 The interface between the PSMS and the
4 maintenance network is now temporary. I think we saw the
5 details of that earlier today.

6 Software changes, they cannot be made
7 online. You know, they explain the process, how they are
8 done offline now.

9 And the enable/disable switch is added to
10 provide the capability to disconnect any input coming from
11 the operational VDU into the PSMS.

12 And the DAS got upgraded to four cabinets
13 and now it uses one-out-of-two taken twice logic instead
14 of two-out-of-two, you know. Next slide.

15 The time critical DAS manual actuation, they
16 got converted to automatic actions rather than the manual
17 actions.

18 Now, you know, priority logic is employed
19 throughout the safety system design. Before it was
20 limited use of priority logic, you know.

21 And the additional design details on data
22 communication, they got added to the DCD and technical
23 reports so we got a lot more technical information to be
24 able to, you know, base our review on.

25 CHAIR STETKAR: Dinesh, I haven't looked

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 through your slides. Are you going to talk more later
2 about those time critical operator actions or is this the
3 only time to ask about those?

4 MR. TANEJA: We are having a discussion on
5 DAS later on. I think Erick can explain a couple of the
6 time critical manual operator actions that were being
7 performed from DAS that got converted to --

8 CHAIR STETKAR: Were you planning to do that
9 later or now?

10 MR. MARTINEZ: We can do it now or later,
11 whichever. There's a slide specifically that will also
12 mention this so --

13 CHAIR STETKAR: Okay, that's fine. Let's
14 do it later when we're thinking about DAS then. Thanks.

15 MR. ASHCRAFT: My name is Joe Ashcraft and
16 I guess I drew the long straw so I got redundancy. This
17 will be the first of many slides addressing our principles.

18 I guess based on this morning there really
19 didn't appear to be any issues so I just wanted to comment
20 that we have no issues at this time in our SER.

21 I have noted several places in our evaluation
22 where we talk about redundancy and some of it is redundancy
23 of dual controllers, et cetera, that was used more in
24 reliability.

25 But our finding in this aspect is from single

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 failure we have no issues and there is an ITAAC to verify
2 that later on. So unless there's questions I think
3 there's a lot more pending issues.

4 MEMBER BROWN: The only question I would
5 have is we talked about the utilization of the priority
6 logic for both the DAS final output stages and, you know,
7 I kind of left that. We finished that discussion. I
8 mean, that's part of the safety systems for the DAS part
9 of it.

10 I presume you all got yourself comfortable
11 with that one point of common usage of logic, that it's
12 simple enough that in the testing of the 3 months and the
13 other 24 months was satisfactory to convince you that that
14 would maintain the sanctity of that particular use.

15 MR. TANEJA: The PIF module right, the power
16 interface module?

17 MEMBER BROWN: Right, yes.

18 MR. TANEJA: Actually that was one of the
19 item that we actually got our hands on when we were in
20 Kobe and ran some, do some testing on it, you know, so
21 we saw the hardware-based, non-software-based portion of
22 the board which is like separated from it and the input's
23 coming in and we saw a complete 100 percent test of a very
24 simple logic, you know.

25 So it was so many input, so many outputs

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and, you know, it was thoroughly tested and I believe every
2 board is going to be tested, you know, for each
3 application.

4 MEMBER BROWN: Well, that's on a design
5 basis. But, I mean, the operational they explained their
6 ability to operationally test it, like, every 90 days or
7 something and then every two years you had a complete test
8 where you actually saw that it -- I just wanted to make
9 sure you were satisfied with the lack of complexity and
10 the simplicity of it, the fact that that's a single point
11 now for both the DAS and the normal automatic systems and
12 it's just a question. You're shaking your head up and
13 down. I'm going to take you at your word.

14 MR. TANEJA: Yes, it's a single point. I
15 understand that, right? But, you know, if you look at
16 ESFAS, each component has its own unique PIF module, right?
17 So you have redundancy between Train A/Train B so, you
18 know, you have independence in that respect so they're
19 redundant.

20 So if you do fail, let's say, a random failure
21 of the PIF module you lose one component, one pump. You
22 still have the other train available to you so we were
23 okay with that.

24 MEMBER BROWN: Okay.

25 MR. TANEJA: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: That was it for my question
2 on that.

3 MR. ASHCRAFT: And following up with John's
4 wanting us to hurry up, these are just kind of follow-up
5 slides. We did talk about redundancy as they did at PCMS
6 but really this has nothing to do with our safety finding.
7 So unless there's questions, I'm done. Next slide.

8 MALE PARTICIPANT: Khoi.

9 MR. NGUYEN: Hi. My name is Khoi,
10 Instrumentation and Control Branch 2. The review of
11 independence cover four areas, physical, electrical,
12 functional and communication independence.

13 The staff found that with reasonable
14 assurance that the US-APWR design on physical, electrical
15 and functional independence met the regulation and
16 guidelines.

17 There are some issue and concern associated
18 with communication independence. Most of the concern and
19 issue would result either by the proposed design change
20 that you had heard this morning or the --

21 MEMBER BROWN: External communication or
22 are you talking about the watchdog timer?

23 MR. NGUYEN: No, some of these agenda we'll
24 cover later if you --

25 MEMBER BROWN: Oh, okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. NGUYEN: -- if you are interested and
2 either by the design change or the addition of the
3 significant amount of detail design, design details that
4 help the staff understand more about the design.

5 However, there's one issue that remain as
6 an open item that I will cover later. For the purpose
7 of this presentation I only focus on the communication
8 independence unless you have a question on other areas.

9 MEMBER BROWN: No, that's fine, fine. You
10 can go ahead.

11 MR. NGUYEN: Our staff review of
12 communication independence cover independence among the
13 safety trains and between safety and non-safety system.

14 This symbol plot diagram show the interface
15 between safety and non-safety system. Unless you have
16 question, I will skip this slide. And here are the
17 regulation and guidance that reveal independence.

18 Among the safety train, the communication
19 limited to voting logic, bypass status and status of the
20 signal and the communication performed by one-way,
21 point-to-point data link protocol with no communication
22 handshaking.

23 Failure or communication fail of a single
24 train will not affect the other train. All safety
25 functions are performed without interruption by any other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 signals. You heard a lot about the priority logic this
2 morning so I wouldn't address more about that.

3 CHAIR STETKAR: Khoi.

4 MR. NGUYEN: Yes.

5 CHAIR STETKAR: You heard a lot about it
6 and you heard a little bit of concern on my part about
7 how do we know that the safe state is really the safe state
8 for all events. Did you look at that, and particularly
9 SLS priority logic?

10 MR. NGUYEN: Well, I heard this morning from
11 MHI that they haven't come up with a final determination
12 which one is the safe state or not. But during the audit
13 in Kobe, we was able to witness the demonstration, the
14 priority logic if the safety signal or the signal including
15 the safety state signal had the priority over the non-safe
16 signal. But why safety signal to be on the list, I don't
17 know.

18 CHAIR STETKAR: So you haven't looked at
19 that?

20 MR. NGUYEN: At least I looked at some of
21 them but not the complete list.

22 CHAIR STETKAR: Why not?

23 MR. NGUYEN: We want to ensure that the safe
24 state signal had the priority over the non-safe state
25 signals and that's a --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR STETKAR: I understand that but, for
2 example, the example that I used for emergency feedwater,
3 there are two safe state signals. One is closed. One
4 is open.

5 Now, we heard a rationale about why they
6 selected the closed signal as the one that would have
7 priority. There might be a different rationale that said
8 the open signal might be the one that should have the
9 priority.

10 And there are a number of components, I'm
11 not sure how many because I certainly didn't do the review,
12 where there might be that type of disparity and I was just
13 curious whether you tried to identify those and give
14 yourself assurance that, indeed, the selected safe state
15 made sense.

16 MR. TANEJA: No, we did not go that far.

17 MR. NGUYEN: In order to answer your
18 question I need the coordination review with the reactor
19 system.

20 CHAIR STETKAR: Yes.

21 MR. NGUYEN: Because with the I&C review
22 perspective we don't look to that depth what signal should
23 be safety state or which one is not. We will ensure that
24 the safe state signal have the priority over the non-safe
25 state signal.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. TANEJA: Because I believe what we are,
2 you know, hearing is that safe state really depends on
3 the mode of operation.

4 CHAIR STETKAR: Yes.

5 MR. TANEJA: Right? Now, we are getting
6 into the details of modes of operation and I think we had
7 similar -- when we were dealing with the development of
8 the post-action monitoring parameters, similar kind of
9 concerns because it's a performance-based list.

10 So we're really looking at, you know, how
11 do you manage certain events and whether you use what's
12 available, right? So here I think I'm hearing is the same
13 thing, that I need the level of detail where I know exactly,
14 you know, what is a safe state for what given mode of
15 operation?

16 The I&C Chapter 7 did not go into that depth.

17 It's just basically looking at priority scheme, you know,
18 how do they handle priority scheme?

19 CHAIR STETKAR: Given a safe state, does
20 the system invoke that safe state?

21 MR. TANEJA: Right.

22 CHAIR STETKAR: The problem is that if you
23 look at Chapter 15 analyses, the Chapter 15 analysis for
24 a steam line break inside containment, we'll want to close
25 certain valves. A separate Chapter 15 analysis for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 another type of trans-interaction, might want to open
2 those same valves.

3 So Chapter 15 doesn't look at the
4 integration. Chapter 7 doesn't look at the integration.
5 Nobody looks at the integration?

6 MEMBER BLEY: Could Chapter 18 look at the
7 integration? Is there anybody here who's --

8 CHAIR STETKAR: Chapter 18 is human factors.

9 MEMBER BLEY: Al was here all day but he's
10 disappeared. Well, it is but it's the interface too and
11 they are looking at accident scenarios and all of that.

12 So I don't know where it gets looked at but with this
13 design because --

14 MR. TANEJA: But it's a very good question
15 I think.

16 MEMBER BLEY: -- because you cannot override
17 that unless you get in and manually manipulate things
18 operators don't usually manually manipulate. It ought
19 to get looked at. It could be very significant.

20 CHAIR STETKAR: There may not be all that
21 many places where you have this potential conflict. I
22 mean, I'll give you the fact that starting a high-pressure
23 injection pump or starting an emergency feedwater pump
24 on -- I'm not quite sure when you might want to shut them
25 off unless you can overfill --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BLEY: In a cold --

2 CHAIR STETKAR: Right.

3 MEMBER BLEY: -- cold fracture thing but
4 maybe they're immune from that. I would hope so. I
5 didn't look at that yet.

6 CHAIR STETKAR: They have other protections
7 against that particular one but the whole notion is going
8 through that. There is a rationale somewhere. MHI said
9 it's an internal document so it's not anything that we've
10 seen.

11 MEMBER BLEY: I meant to ask but I didn't.
12 I don't know if one day there will be a table of all the
13 safe states. It's not there now.

14 MR. TANEJA: We'll follow up on this. I
15 think it's a valid question.

16 CHAIR STETKAR: Okay, thanks.

17 MR. TANEJA: You know, so we'll follow up
18 on it, you know, because I think what we hear is that,
19 you know, you really can't override some of these
20 functions, I mean, meaning like --

21 MEMBER BLEY: The system wins, yes. You
22 can't --

23 MR. TANEJA: Yes, if the system says that
24 a safe state is open, it'll open it, you know, and if you
25 want to --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BLEY: It will stay open unless you
2 go into the, you know, disable the logic.

3 MR. TANEJA: Okay. I'll follow up on this.

4 MEMBER BLEY: That's not a terribly hard
5 thing to do but it's not what we like people to do with
6 power plants.

7 CHAIR STETKAR: Yes.

8 MEMBER BLEY: We used to go in and use
9 popsicle sticks to jimmy relays and things and jumpers
10 and we don't do that anymore.

11 CHAIR STETKAR: We don't do that anymore.

12 MEMBER BLEY: Because it leads to --

13 CHAIR STETKAR: People leaving popsicle
14 sticks and jumpers in places where they ought not to be.

15 MEMBER BLEY: That was a few years ago but
16 it was real.

17 MR. TANEJA: Beyond design basis.

18 (Laughter)

19 MR. NGUYEN: Okay, this design feature you
20 saw earlier today so I don't repeat it.

21 On this diagram I would like to point out
22 the communication between safety and non-safety system.

23 You can see the arrow of the data flow. The non-safety
24 signal can only go into the safety system through the COM-2
25 at the sub-communication system and I will cover that later

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 on.

2 Communication from non-safety to safety
3 system through COM-2 are limited to manual control
4 commands of the safety component from operational VDU and
5 manual operating maintenance, bypass, lock, reset command
6 from operational VDUs.

7 CHAIR STETKAR: Khoi, let me ask you before
8 you get to this one and you can tell me maybe you'll address
9 it later.

10 As part of the non-safety to safety
11 communications in the SER, there's a statement that says,
12 "The applicant responded," and it's to RAI 7785866,
13 Question 07.09-24 -- I only mention that because in case
14 you need to look it up tonight -- "on November 28th, 2012,
15 and stated that the applicant has decided to employ the
16 hardwired interface design for non-safety automatic
17 control signals from the PCMS to the PSMS to make the data
18 communication design simpler."

19 What does that mean? Because I didn't hear
20 anything about any hardwired anything or other this
21 morning.

22 MR. NGUYEN: I think we already cover but
23 maybe in different language. Originally the non-safety
24 automatic signal was connected to the safety signal
25 through the unit bus and we said that's very hard for us

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to review. It's very complicated.

2 So after, you know, several RAI trials and
3 public meetings, MHI had agreed that, okay, we don't
4 connect those signal through the unit bus. We will
5 hardwire and those signal no longer, you know, connected
6 to the safety system via unit bus, so --

7 CHAIR STETKAR: Do you have an example of
8 a non-safety automatic signal that is processed this way?
9 I mean, I understand the manual stuff so --

10 MR. TANEJA: Yes, the typical automatic
11 signals are like existing PWRs. They have some balance
12 of plant signals that are preempted that may come into
13 the safety system.

14 CHAIR STETKAR: I'm asking for some -- I
15 want to understand what we're talking about here.

16 MR. TANEJA: Well, I think a handful of
17 signals that come in -- pressurizer level you said?

18 Pressurizer heaters? You know, I guess I
19 can elaborate on the signals. So what happens is the unit
20 bus is connected to the entire plant, right? So these
21 data is available on unit bus. Now, one way to do it is
22 just bring it down into COM-2 and just come in and do the
23 action.

24 CHAIR STETKAR: Yes, right.

25 MR. TANEJA: Now, here what we felt is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 manual action we know when they're being taken by the
2 operator using the operational VDU. So if there is a
3 malfunction because of whatever reason, at least you know
4 that, you know, you just took an action so you're more
5 aware of it.

6 But if an automatic signal is floating around
7 on the unit bus and can come in any time, we didn't feel
8 comfortable with that one. We were trying to ask more
9 questions.

10 So one alternate was they said, all right,
11 what we'll do is we'll bring it in hardwired to isolators
12 into an I/O module that eliminate use of the unit bus and
13 that interface where it would be coming in.

14 And if there was a fault on that signal,
15 now it's a non-digital signal so it can be treated as a
16 traditional interface. That's really what the issue is.

17 CHAIR STETKAR: So essentially in the
18 context of this diagram, you'd have a non-safety automated
19 controller someplace floating around up there at the top
20 with a wire that comes down to the safety bus that finally
21 gets processed.

22 MR. TANEJA: Right.

23 CHAIR STETKAR: Is that the way to think
24 about it?

25 MR. TANEJA: See, the way it is is on each

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 controller, right, ESFAS controller, let's say, or RPS
2 controller, you have the I/O modules, right? So the
3 inputs come in, outputs go out.

4 So the input that's coming in from non-safety
5 site, you know, you bring it in, you put in an isolator,
6 the traditional isolator like we saw for the DAS. And
7 then you bring the signal in from that way.

8 CHAIR STETKAR: And when you say ESFAS
9 controller, you really mean down at the SLS level or do
10 you mean up at the --

11 MR. TANEJA: Any one of the controller,
12 right? I mean, we are really treating that signal as a
13 traditional interface and that isolator, which is a Class
14 1E isolator, becomes our boundary of safety.

15 So what we are saying is we take credit for
16 that so any failure of the signal on the other side would
17 not have an adverse impact to safety.

18 CHAIR STETKAR: Got you, got you. Thank
19 you.

20 MR. TANEJA: Thank you.

21 MR. NGUYEN: For the data communication
22 between the safety and non-safety system, the staff used
23 digital I&C interim staff guide in ISG-04 as the key
24 guidance. And the following support the staff finding.
25 All safety function, whether manual or automatic, are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 performed without interrupt by the non-safety signal
2 regardless of whether the known safety signal are valid
3 or erroneous.

4 And, again, the priority logic provide that
5 prioritization for safety function over non-safety
6 signal. And these are design feature we cover earlier
7 so unless you have question I will cover those design
8 features.

9 MEMBER BROWN: Let me ask. You don't have
10 to go back to anything but relative to John's question,
11 the question of the, you know, input from the non-safety
12 place, the operational VDU.

13 I went back and I looked at the figure that
14 MHI, you know, the overall figure for the ESFAS and SLS.

15 And I don't see any lines that give the
16 impression of going directly to the safety bus other than
17 coming down through the safety VDU from the remote console
18 or from the operator console, the operational VDU.
19 Everything else seems to come down through the unit bus
20 and the COM, COM-1 or COM-2.

21 (Crosstalk)

22 MR. NGUYEN: Yes, because there is no data
23 below --

24 MEMBER BROWN: It's Figure 7.3-1 that you
25 have the general picture. I mean, it's kind of a very

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 high-level picture.

2 MR. NGUYEN: Right, it is a high level. It
3 doesn't get into the --

4 MEMBER BROWN: But I would have expected,
5 based on what you were talking about, it's something manual
6 or automatic. I didn't see --

7 MR. TANEJA: Well, the manual controls are
8 still coming from operational VDU, right? That's an open
9 item that we are still --

10 MEMBER BROWN: Yes, well, right now those
11 come through that COM-2 --

12 MR. TANEJA: They come through the COM-2.
13 COM-2 --

14 MEMBER BROWN: -- and down to the safety
15 bus before they get to the SLS.

16 MR. TANEJA: Right. Now, there were also
17 previous design had automatic signals from non-safety side
18 that were coming in as well.

19 MEMBER BROWN: And John's looking for some
20 examples of that. I mean, I understand pressurizer heater
21 control is an obvious --

22 MR. TANEJA: Well, there's a handful of
23 signals that do come in, you know. I don't know where,
24 you know, those come in through and since they have the
25 entire plant on the unit bus, so you have that data

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 available in that data packet on the unit bus so you can
2 use it anywhere you would need to use it. So it's a
3 convenient way of getting to it, you know.

4 MEMBER BROWN: Well, that data comes from
5 the RPS system, right, the plant parameter evaluate.
6 That's where the parameters are actually, the sensors come
7 into the --

8 MR. TANEJA: The non-safety signals are
9 coming from your non-safety side of the plant. Those are
10 the signals that are used to maybe take some protective
11 action preemptively which they don't take credit for,
12 maybe like the turbine trip, for example. That signal
13 does not come in over the unit bus. You know, it comes
14 in through the hardwired interfaces. That's what you're
15 talking about. Some of those --

16 MEMBER BROWN: All right, go on. I'm just
17 trying to get a handle on it. Go ahead.

18 CHAIR STETKAR: I got it. You know, there
19 was just that one paragraph in the SER. I understand
20 what's being done.

21 MR. TANEJA: I don't think the cartoon shows
22 that.

23 CHAIR STETKAR: No.

24 MEMBER BROWN: No, it doesn't. It's not on
25 here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR STETKAR: Well, probably because it's
2 not a general function. You know, like you said, there's
3 probably a handful of specific applications, if you will,
4 that would have that feature.

5 MR. NGUYEN: Again, on this slide the design
6 features have been covered by MHI earlier. Maybe slightly
7 different but basically the design features are the same
8 so if you have any questions --

9 MEMBER BROWN: This question is open right
10 now relative to, I mean, we discussed this with MHI
11 relative to how does the watchdog timer actually execute
12 a partial reactor trip in a train if it locks up, if the
13 timer times out.

14 So this says what it's supposed to do but
15 they agree to do something relative to providing a figure
16 --

17 MR. NGUYEN: Detail design on how to escape
18 it.

19 MEMBER BROWN: -- how the watchdog timer
20 operates and how it actually executes that. I'm not
21 working on the four times gross, whatever it is. That's
22 not unusual, okay, and that's in the transcript.

23 There's a series of two or three questions
24 that they said they would do something with relative to
25 providing it, hopefully in the DCD or someplace where it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 documented, whether they revise the technical report or
2 whether they do a DCD revision to show that.

3 So I'm just saying just the words themselves
4 as long as, that's an open issue as far as I'm concerned
5 until we see how that gets done.

6 MR. NGUYEN: Okay.

7 MEMBER BROWN: Okay?

8 MR. NGUYEN: The staff state earlier that
9 they perform audits. The purpose of the audits was to
10 reveal the documents and to confirm the key design feature
11 as described and listed in the technical and topical
12 reports. The staff had witnessed the demonstration on
13 the actual MELTAC controllers to address the staff
14 concern.

15 There's one open item associated with the
16 independence review. The staff request the applicant to
17 justify the use of the non-safety component to operate
18 safety equipment. In this case it's operational VDU.

19 The justification for the use of operational
20 VDU is based on HFE. That's enhanced performance of
21 safety function. That's including reduce the task burden
22 and reduce the potential of human error.

23 So the staff had been coordinate with the
24 human factor experts and also we request the applicant
25 to provide more testing or quantitative analysis to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 demonstrate that the use of operational VDU actually
2 enhance the performance of safety function.

3 Also staff request the ITAAC to test all
4 the transmission conditions, either normal or abnormal
5 of the safety and non-safety signal interface.

6 MR. TANEJA: We have not received the RAI
7 response yet.

8 MR. NGUYEN: These are ongoing items.

9 MEMBER BROWN: This seems kind of
10 subjective. I mean, how do you gauge enhancement?

11 MR. NGUYEN: That's why we need the --

12 MEMBER BROWN: Is there a metric of --

13 MR. NGUYEN: -- in-depth review and more
14 detail.

15 MR. TANEJA: Well, there are two issues
16 here. Okay, when we look at the ISG-04 guidance, you still
17 have to assure that interface from non-safety to safety
18 does not adversely impact any of my safety function.

19 That is independence question that, you
20 know, has to be answered, that we have reasonable assurance
21 that there is no adverse impact with that connection to
22 the safety functions. That's one issue.

23 And I think we have criteria in our ISG-04
24 which says don't make that connection unless you have some
25 enhancement to safety. I mean, there has to be a good

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 reason for you for making that connection.

2 So that's a separate way of answering that
3 question but regardless of what the answer is independence
4 has to assure that there is no adverse impact to safety.

5 CHAIR STETKAR: I understand that. But
6 there's a difference between no adverse impact and
7 enhancement.

8 MR. TANEJA: Right.

9 CHAIR STETKAR: If it's no adverse impact
10 and neutral to safety, that's not enhancement but it's
11 no adverse impact.

12 MR. TANEJA: Right.

13 CHAIR STETKAR: And I think my concern
14 personally from having operated a plant where you had to
15 have two people control feedwater because the controls
16 were widely separated and a single person couldn't do it
17 and you lost feedwater a lot because of that, having a
18 control for a non-safety charging pump located in one place
19 and a control for the safety-related charging valve
20 because it's safety related because it gets a containment
21 isolation signal, for example, in another place, strikes
22 me as not necessarily being the best way to run a nuclear
23 power plant exactly.

24 And so, you know, this subjective HFE thing
25 is not really subjective when you get in the real world

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 and try to operate things, like controlling feedwater or
2 charging or letdown or, you know, anything that the
3 operators really get involved in, so.

4 MR. TANEJA: And that's where we are
5 interfacing with the Human Factors Branch to, you know,
6 get that assessment from them to see, you know, is there
7 any objectivity to it or is it all subjective that there
8 is enhancement?

9 CHAIR STETKAR: Well, I think what I'm
10 trying to understand here is I personally absolutely agree
11 with this notion that no non-safety to safety interface
12 should adversely affect the safety function. I agree with
13 that.

14 On the other hand, if the burden of proof
15 is for MHI to prove to you that that enhances the safety
16 function, I got a really problem with that personally
17 because that's a much different burden of proof. So if
18 you're asking MHI to prove that that connection must
19 enhance the safety function, I have a real question about
20 that.

21 MR. TANEJA: Well, see, this is still, you
22 know, we don't have any acceptance criteria on any
23 qualitative number. What does that really mean,
24 enhancement, right?

25 CHAIR STETKAR: Well, I'm asking. You said

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 this is still an area of open discussion.

2 MR. TANEJA: It is.

3 CHAIR STETKAR: You haven't gotten response
4 but I'm trying to get a sense back from you who've written
5 the RAI and will have to review the response to that RAI,
6 are you as a staff essentially asking MHI to prove that
7 that connection enhances safety?

8 MR. TANEJA: Yes, that's our question.

9 CHAIR STETKAR: That is the question?

10 MR. NGUYEN: To make it clear, to ask MHI
11 to prove that the connection enhances safety is very
12 subjective and very big and is almost impossible to do
13 it.

14 But we actually asked the MHI to justify
15 how the connection enhance the performance of safety
16 function. That's a different thing. That's something
17 to do with HFE. The safety concern is safety function.

18 MEMBER BLEY: I kind of agree with Mr.
19 Stetkar here on this one.

20 MR. SPRENGEL: Well, unfortunately some of
21 the staff are not here to discuss this but the
22 communication we've received from the entire staff is
23 looking at the global perspective as you're pointing out
24 and mainly from an HFE perspective the staff agree with
25 you and they do see the safety benefit.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR STETKAR: Okay, thanks. And sort of
2 hearing your feedback I'm a little bit less concerned about
3 this notion of proof of enhancement versus sort of a global
4 assessment of, you know, one ought not to hurt it but --

5 MR. SPRENGEL: And I think whenever we
6 discuss collectively with the different areas the same
7 perspective comes out.

8 CHAIR STETKAR: Yes, okay. Thank you.
9 Thanks.

10 MR. TANEJA: And I guess the status of the
11 RAI response, this morning's presentation, it was
12 mentioned that MHI would do a quantitative analysis on
13 this one. It was on their Slide 82. I think that's what
14 they're proposing to send so we'll see what that looks,
15 you know.

16 It says, "MHI can provide RAI response
17 demonstrating safety merits on operational VDU including
18 quantitative analysis for reduced task burden."

19 CHAIR STETKAR: Okay. Thank you.

20 MR. NGUYEN: That's all I have for
21 independence. Do you have any question regarding the
22 independence?

23 CHAIR STETKAR: Anything else? No. Good.

24 MR. TANEJA: So next topic we want to talk
25 about is determinism and these were the regulation and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 guidance that are applicable to our review for
2 determinism.

3 And our findings verified that, you know,
4 software failures of system malfunction, you know, are
5 the system malfunction that accommodated by the internal
6 diagnostics that are built in and the watchdog timers,
7 you know.

8 You, I guess, saw that they showed you each
9 function is executed, cyclical similar task processing.

10 Cycle times are predetermined and fixed for all of the
11 processors and the message size and communication rates
12 are constant and that's what we found. Next slide.

13 One other thing that we did ask the question
14 that we found out was that it was on processor loading.

15 Now, what we were told, that based on their design that
16 the processor can run 100 percent loading in a very
17 deterministic fashion. However, their design practice
18 limits it to 80 percent loading to allow for margins and
19 everything else.

20 MEMBER BROWN: Well, all you're talking
21 about is they leave enough time in the cycle time that
22 they're not pushing it right out to the edge every time.

23 MR. TANEJA: Right.

24 MEMBER BROWN: And that should be the case.
25 With a fixed cycle processing, that should not be a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 problem at all.

2 The only time it is is when you have
3 interrupt-driven execution, you know, executive program
4 which decides to do all kinds of miscellaneous things at
5 variable times where you can jam the thing up with what
6 I call background tasks instead of doing your main cycle
7 programming.

8 MR. TANEJA: Right.

9 MEMBER BROWN: The fixed cycle just works,
10 makes everything kind of easy.

11 MR. TANEJA: Yes, so they have that, you
12 know, the spare time diagnostics that they run and whatever
13 the time allowed is, you know, but it's a fixed cycle time.

14 You had a question about the external
15 interrupts versus internal interrupts. You know, what's
16 in there, what we saw, was that there are two internal
17 interrupts. One is a CPU interrupt and one is a peripheral
18 interrupt.

19 MEMBER BROWN: Yes, I read those.

20 MR. TANEJA: Right. CPU interrupt is the
21 one that halts the processing and generates a fail-safe
22 output and then --

23 MEMBER BROWN: Logical thing to use.
24 That's called --

25 MR. TANEJA: And then the peripheral

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 interrupt is kind of alarmed but the process continues,
2 you know, so that's a distinction between the two of them,
3 you know. And the rest of the information is pretty much
4 what we saw this morning. Next slide.

5 And we also reviewed the response time
6 analysis that is part of the technical report on response
7 time for I&C systems. So the way that whole report is
8 put together is that there is an analytical limit which
9 is based on Chapter 15 so that becomes the timing that
10 they assign. It's the allocated time for that function,
11 safety function, okay?

12 So the calculated time has to be for the
13 entire, from the sensor to the operating component needs
14 to be bounded by this allocated response time that's in
15 Chapter 15.

16 So that's really what the report is based
17 on, is this gives us a list of all the allocated time that
18 came from Chapter 15. Then it adds up every single timing
19 factor including all the transmission rates for each of
20 the loop.

21 And then there's an ITAAC in place which
22 will actually test, calculate the minimum and maximum time
23 and verify that the functions are performed within the
24 allocated times that --

25 MEMBER BROWN: That's from input to output,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 input to output?

2 MR. TANEJA: From the sensor operation to
3 the actual component -- the biggest delays usually are,
4 you know, you got valves that have 15-second operating
5 time maybe on a motor-operated valve.

6 Your transmitter or your level sensor
7 probably have a bigger time delay than the digital system
8 may. You know, I mean, we heard 50 millisecond. We
9 heard, you know, 100 millisecond, 300 millisecond.

10 But when you look at some of these times,
11 it's like 2 seconds, 3 seconds in Chapter 15 analysis.

12 So, you know, so those, you have to account for the other
13 components, you know, so. Next slide.

14 Any questions on determinism? Okay.
15 Erick, you want to start with D3?

16 MR. MARTINEZ: Yes. Well, this slide
17 pretty much is a quick overview of just the DAS design
18 features. That was discussed earlier this morning so
19 unless you want me to go over them in the interest of time
20 I'll keep going. Does anybody want me to discuss just
21 the basics for the DAS? Okay. This is the policy and
22 guidance that the staff used. Next slide.

23 CHAIR STETKAR: Yes, actually, I did want
24 to ask a couple of things. In the DCD there's a discussion
25 about a couple of different switches and I didn't ask MHI

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 this morning for a variety of reasons.

2 There's one switch that's called a
3 permissive switch for DAS HSI and in the old design where
4 you only had two DACs that switch enabled power to DAC
5 1 such that if that switch was open because it was a
6 two-out-of-two logic you couldn't get DAS actuation.

7 MR. MARTINEZ: Yes.

8 CHAIR STETKAR: There's another, I'll call
9 it a switch because I don't know what else to call it.
10 There's a diverse actuation signal defeat switch which
11 basically defeats all of DAS.

12 MR. MARTINEZ: Which is actuated in the --

13 CHAIR STETKAR: Both trains.

14 MR. MARTINEZ: I think it's in the VDU.
15 It's shown in there, yes. Yes, there is a switch.

16 CHAIR STETKAR: Because all I have is, you
17 know, cartoon schematics. First of all, those are two
18 separate switches. There's one that defeats all of DAS
19 and a second one that -- does the power switch still exist
20 in the new design?

21 MR. MARTINEZ: Yes.

22 CHAIR STETKAR: It does. What does it do?
23 It shuts off power to two of the cabinets now, because
24 it's one-out-of-two taken twice.

25 MR. MARTINEZ: What power switch

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 specifically? You're talking about in the --

2 CHAIR STETKAR: Well, all I have is names
3 of things.

4 MR. MARTINEZ: Do you know the specific
5 section that you're going through? Maybe I can --

6 CHAIR STETKAR: Of the SER or DCD?

7 MR. MARTINEZ: SER, yes.

8 CHAIR STETKAR: Well, it's the DCD.

9 MR. MARTINEZ: Or DCD, yes. Either one.

10 CHAIR STETKAR: E is Section 78111, and this
11 might be a take-away if you want to come back tomorrow,
12 that talks about the permissive switch for DAS HSI. And
13 that's simply a power on/off switch.

14 MR. MARTINEZ: That's the second sentence
15 in the last paragraph in DCD?

16 CHAIR STETKAR: I don't know. I excerpt
17 these things from -- don't hold me to lines or --

18 MR. MARTINEZ: Okay, okay. I think from the
19 draft Rev. 4 version that we have, that name is being taken
20 out for the sake of confusion but --

21 CHAIR STETKAR: Yes, hence, my confusion.

22 MR. MARTINEZ: Yes.

23 CHAIR STETKAR: But let me ask either you
24 or maybe MHI can help me on this. I didn't ask this morning
25 because I have a different question for the staff.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 But just to avoid my confusion, in the new
2 design where you now have four DAAC cabinets, is there
3 still a switch that cuts power to two of those cabinets?

4 I'm assuming it has to be two because otherwise it
5 wouldn't be different.

6 MR. MARTINEZ: Yes, but for the sake of --

7 CHAIR STETKAR: If we don't have a quick
8 answer, let me just get it out on the table. I want to
9 understand whether there are one or two switches first
10 of all.

11 I know that there is some sort of DAS defeat
12 switch because we've already established that that exists
13 and in the design document that DAS defeat switch defeats
14 all of DAS. I don't care where they're at, you know, two
15 trains or two cabinets or four cabinets. DAS is out of
16 there.

17 I'm trying to find out whether there is also
18 an additional power supply switch that cuts off power to
19 half of DAS such that regardless of the DAS defeat switch,
20 you know, DAS won't work.

21 MALE PARTICIPANT: And now.

22 MR. SCAROLA: Okay. First let me talk about
23 the DAS defeat switch.

24 CHAIR STETKAR: Yes.

25 MR. SCAROLA: That's actually defeating all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the automated functions in DAS so that you can shut down
2 the plant.

3 For example, one of the automatic inputs
4 in DAS is low pressurizer pressure. Well, I have to defeat
5 that otherwise I can't depressurize, right? So that's
6 what the defeat switch does, blocks all the automated
7 functions.

8 Now, there are two manual switches. There's
9 an actuation switch for each individual function on the
10 diverse HSI panel so, for example, there's an actuation
11 switch for safety injection, a system-level actuation.

12 There's an actuation switch for main steam isolation
13 valves.

14 However, we don't want a single switch
15 failure to give us these spurious actuations so we have
16 this second switch that is probably misnamed but it's
17 called, I think, DAS power disconnect switch.

18 So when you activate the power disconnect
19 switch, you get one half of the two-out-of-two logic for
20 all the manual functions. You get one out of the two,
21 the second one-out-of-two, to give you two-out-of-two is
22 the individual switch. So the power disconnect gives you
23 one leg for every function or it eliminates one leg
24 normally. In normal operation you don't have that leg.

25 CHAIR STETKAR: Okay. So, now, if I'm the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 operator sitting in the control room and some alarm goes
2 off that says DAS, DAS, DAS, I must actuate that switch
3 --

4 MR. SCAROLA: The power disconnect switch.

5 CHAIR STETKAR: The power, and then I must
6 go to the DAS panel and push the appropriate button for
7 manual.

8 MR. SCAROLA: They're both at the DAS panel.
9 The power disconnect is like a master manual enable switch
10 at the DAS panel.

11 CHAIR STETKAR: Okay, it is on the DAS panel?

12 MR. SCAROLA: On the DAS panel.

13 CHAIR STETKAR: All right. Now, to MHI in
14 this, I needed to find out if there were two switches or
15 one switch.

16 Now that I know that there are two switches,
17 this power disconnect switch, in the DCD this, I'll call
18 it the power switch for lack of confusion, is located in
19 the main control room but physically separated from the
20 DHP. Physically separated from the DHP to minimize the
21 effect of fire propagation. You just told me it's on the
22 DHP.

23 MR. SCAROLA: I'm wrong.

24 CHAIR STETKAR: So now if I have a -- oh,
25 you're wrong.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SCAROLA: I got confused. It's on the
2 DHP at the US-Basic HSI simulator in Pittsburgh. However,
3 we recognized in the design that we could have a fire inside
4 the DHP itself.

5 CHAIR STETKAR: Hence my question about
6 where is it.

7 MR. SCAROLA: Therefore we decided that we
8 needed to have some physical separation.

9 CHAIR STETKAR: Yes.

10 MR. SCAROLA: So one is actually on the DHP
11 and another one is physically separated. We have not
12 identified a specific location.

13 CHAIR STETKAR: You don't know where it is?
14 My question was going to be where is it and did the staff
15 look at where it is such that if I have a fire, wherever
16 it is, I can both disable a bunch of stuff in my normal
17 plant in that location and disable DAS? Because if that
18 switch is open, DAS doesn't work.

19 So is there then a fire location in the
20 control room that will both affect normal safety systems
21 and DAS because of the location of that switch? Because
22 it's not on the DAS panel and it's not clear whether --
23 I'm not sure I want it on the DAS panel.

24 But I want to make sure it's in a place in
25 the control room where if I get a fire in that location

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I don't somehow simultaneously affect things that, you
2 know, both of those functions. And you've told me that
3 you don't know where it's going to be located yet.

4 MR. SCAROLA: It's a detailed design aspect.

5 All we know is that we have to maintain a fire barrier
6 between the two switches and we have not identified a
7 specific location for that switch.

8 CHAIR STETKAR: Yes, I'm more concerned
9 about what else is around the -- if this is a separate
10 switch like a light switch on a post in the wall, I'm
11 probably okay with that.

12 If it's a switch on one of the panels in
13 the control room, I'd be pretty interested on what else
14 is in that panel or in proximity to that panel. So that's
15 something that hasn't been looked at obviously because
16 you don't know where the switch is.

17 MR. MARTINEZ: We'll look into it. Thank
18 you, yes, and they don't specify the specific location
19 --

20 CHAIR STETKAR: No, all it says is it's
21 separated and I can understand why it should be because
22 I wouldn't want a fire in the DAS panel to inadvertently
23 cause DAS actuation, which it could if the switch was
24 there.

25 On the other hand, if it's located somewhere

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 else, the other place of its location can be important
2 because a fire there could affect now two functions.
3 Sorry, for the long, involved thing. It took me a while
4 to --

5 MR. MARTINEZ: No. Thank you.

6 CHAIR STETKAR: -- get to the point where
7 I could even ask an incoherent question.

8 MR. MARTINEZ: Okay, I guess I will
9 continue. The next slide, part of the staff's review,
10 and I guess we already discussed the involvement on the
11 topical report SE and the staff will look into that.

12 As part of the SE for this topical report,
13 there were a couple of application-specific action items
14 that were developed as part of the SE for the topical
15 report. The staff addresses those in the SER.

16 Additional information here is pretty much
17 that the applicant references that topical report and the
18 D3 coping analysis technical report MUAP-07014. Basic
19 information that the DAS functions are design based on
20 a best estimate D3 coping analysis and that their review
21 of the D3 coping analysis is coordinated with the experts
22 from Human Factors and Reactor Systems.

23 Here is a slide about pretty much the basic
24 DAS design changes that occurred during our review. I'm
25 going to go over them real briefly here. The ECCS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 actuation from manual actuation was converted into
2 automatic.

3 And I guess this would be a good point to
4 -- you had a question earlier about the automatic actions
5 or the manual actions from DAS that you wanted to ask
6 earlier. I guess this would be a good slide if you had
7 anything there.

8 MEMBER SHACK: Yes, you had an earlier slide
9 and you said you --

10 (Crosstalk)

11 CHAIR STETKAR: Yes. Let me, I've got a few
12 questions on DAS and the review.

13 MALE PARTICIPANT: Time critical operator.

14 CHAIR STETKAR: Yes, I understand. You've
15 got two slides. Get to the end and then --

16 MR. MARTINEZ: The last one? All right.

17 CHAIR STETKAR: Then I'll raise the
18 questions I had.

19 MR. MARTINEZ: Okay, perfect, okay.

20 CHAIR STETKAR: It's easier.

21 MR. MARTINEZ: Quick changes in the DAS.
22 DAS upgraded to seismic classification to Category 1.
23 The DAS cabinets were changed from two to four using
24 one-out-of-two taken twice logic and there were a couple
25 of other upgrades based on the internal and external

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 hazards done to DAS.

2 And this is my final slide on this so I'll
3 take questions after this. For the staff's open item,
4 the staff has a couple of outstanding RAIs related to the
5 current review of the D3 coping analysis and their reactor
6 systems folks are working on evaluating and they are
7 awaiting additional responses to these RAIs. And I guess
8 I'll take any questions you have on these areas at this
9 point.

10 CHAIR STETKAR: Before I get into human
11 factors, there were a couple of things in the SER that
12 I had questions about.

13 In SER Section 7.8.4.4, where you talk about
14 ATWS, it's noted that an instrument power supply
15 independent of the power supplies for the existing RPS
16 provides the power for the logic and actuation device for
17 the ATWS mitigation system, in the context of DAS now.

18 Well, that was true under the old DAS design
19 where it had non-1E power supplies. As I understand it
20 now, each of the four DAC cabinets are supplied from the
21 Class 1E power. I believe I read that.

22 MR. MARTINEZ: Yes.

23 CHAIR STETKAR: Which seems to be the same
24 power supply for the reactor trip system. So I was curious
25 whether that conclusion in the SER about the diversity

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of power supplies for the ATWS function still is valid
2 under the new design with its Class 1E power supplies.

3 I don't know how you make that --

4 MR. MARTINEZ: The way we looked at the Class
5 1E UPS change for the DAS is that even if you lose power
6 you still have that UPS which is a, pretty much a battery,
7 correct? So you still have DAS capabilities even if you
8 lose power.

9 But you are correct. It is still Class 1E
10 and that is something that the last couple days we noticed
11 and that is something that we want to clarify in terms
12 of the independence from the Class 1E for the DAS to the
13 Class 1E for the RPS. So you are correct and we are aware
14 of that and we're looking into it. That is a small but,
15 yes, thanks for mentioning it and yes.

16 CHAIR STETKAR: Okay. Hang on a second.
17 Let me write a note. You'll find as you get older you
18 don't remember anything more than about five minutes and
19 if you don't write it down it's gone.

20 This does not affect new design. This is
21 rather convoluted. There apparently was some question
22 from the staff about the particular parameter indications,
23 I think, on the DAS panel. And in particular there, I
24 guess, was a question about containment pressure
25 indications.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And I won't read the whole response here.
2 I'll try to paraphrase it. In the response to the RAI
3 MHI apparently said, well -- oh, I know. It was the status
4 indication of containment isolation valves.

5 MALE PARTICIPANT: Right. Yes.

6 CHAIR STETKAR: That's it. I'm trying to
7 read quickly through my notes. And MHI said, well, we
8 have containment pressure indication and we can use that
9 as a surrogate for the information that the containment
10 is isolated.

11 And in the SER it says even though monitoring
12 containment pressure is more comprehensive than
13 monitoring the position of the containment isolation
14 valves because it encompasses any breaches in the
15 containment, not just penetrations related to automatic
16 isolation valves, the containment isolation function can
17 be indirectly monitored by the containment pressure
18 instrumentation on the DAS panel. The staff found this
19 approach acceptable.

20 Well, I understand how that sort of applies
21 for a large penetration that's directly open to the
22 containment atmosphere like the containment purge valves,
23 for example.

24 It's not at all clear to me how I understand
25 whether fluid systems are isolated by looking at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 containment pressure. For example, the normal letdown
2 line is connected to the reactor coolant system. It gets
3 an isolation signal on containment isolation.

4 Since the reactor coolant system is, until
5 we get a really big LOCA or core damage, not connected
6 to the containment air space, I'm not sure how I can use
7 containment pressure to understand that the letdown line
8 is isolated or a lot of other fluid systems.

9 MR. MARTINEZ: We did raise that concern
10 as you saw from the RAI. The staff did communicate that
11 concern with the Containment Branch folks.

12 And after their conversations, they came
13 to the conclusion that because the DAS uses a best estimate
14 analysis, the containment pressure would be -- we found
15 the RAI responses here. The containment pressure would
16 be a sort of offbeat indicator for containment isolation.

17 When you actuate containment isolation on
18 the DAS, we assume that that function has occurred as
19 needed, right? So --

20 CHAIR STETKAR: Well, that's actually the
21 answer, is you have assumed that when you push the
22 containment isolation button on DAS --

23 MR. MARTINEZ: Correct.

24 CHAIR STETKAR: The lawyers tell me that
25 I assume that all of the valves go closed, and that's fine.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 If the lawyers tell me that that's what happens, then
2 I don't care what containment pressure is because the
3 lawyers have told me that all the valves are closed.

4 I don't need a technical justification from
5 that point because the technical justification doesn't
6 make sense. I don't care whether you say best estimate
7 or design. I'm sorry, I don't understand how you can use
8 containment pressure to understand whether or not the
9 letdown line is isolated.

10 Or if containment pressure is increasing
11 slowly but increasing, do I know -- I'm an operator now.

12 I don't know lawyers. Do I know that it's increasing
13 slowly because there's a certain energy release rate into
14 the containment or that there's a larger energy release
15 rate but I have a small line open somewhere? And if I
16 have a small line open, which line is it? I mean, I don't
17 know. You know, I don't have that perfect knowledge as
18 an operator.

19 So my concern is the staff's acceptance of
20 an argument as if it's a technical argument and this notion
21 of a best estimate analysis to say, well, containment
22 pressure is an adequate surrogate for understanding that
23 the valves are closed. I just don't understand that.

24 I can understand a legal argument in the
25 same way as we accept design basis accident analyses that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 no more than one piece of equipment can fail or in this
2 case since DAS is designed for beyond design basis
3 accidents that we can presume that all equipment works.

4 I understand those types of legal arguments.

5 But it bothers me that the staff acceptance
6 of a particular condition is somehow justified from some
7 pseudo-technical argument that I don't understand. Maybe
8 I don't understand the technical argument but I'm not
9 hearing a lot of convincing response in that area.

10 MR. MARTINEZ: Well, maybe I can't express
11 it very well because I'm not an expert in the containment
12 area. If there's a foul, you would use containment
13 pressure in this aspect to have an adequate indication
14 of containment isolation.

15 MR. JUNG: John, we'll take it back and --

16 (Crosstalk)

17 MR. MARTINEZ: I guess what we can do is
18 take it back.

19 CHAIR STETKAR: I mean, there are a lot of
20 lines, you know, main feedwater lines and there are a lot
21 of lines that don't connect to the --

22 MALE PARTICIPANT: Understand. We'll take
23 it back and --

24 MR. MARTINEZ: I apologize for not being
25 able to give you a straight answer. We'll take it back

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and --

2 CHAIR STETKAR: Okay, thanks. Thanks.
3 Now, hang on a second because as I said -- on the human
4 factors engineering, I need to read my notes here and I'm
5 also a slow reader.

6 In the sense of time, I'll just ask one of
7 the questions. There are statements in here about you
8 mentioned that there's this notion of any actions that
9 had a time window of nominally less than ten minutes are
10 now automated so that's why we have some of the automated
11 DAS functions.

12 MR. MARTINEZ: Yes.

13 CHAIR STETKAR: I understand that many, if
14 not all, I hope that the word all is closer to many, of
15 the DAS manual actions will be included in the human
16 factors engineering verification and validation process
17 so that, indeed, there are nominal times in there.

18 You get times like 31-1/2 minutes because
19 it's assumed that the operators will take 30 seconds to
20 energize the DAS panel from this switch that we don't know
21 where it is and 30 seconds to pull out the right procedure
22 and 30 seconds to push the right button.

23 Now, that minute and a half presumes that
24 the operators immediately and perfectly know that they
25 must use DAS for any conceivable event. There's reference

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 made to, you know, a unique alarm.

2 MR. MARTINEZ: Prompting alarm, yes.

3 CHAIR STETKAR: Prompting alarm, that that
4 prompting alarm immediately and perfectly comes in at Time
5 0 and the operators immediately and perfectly always know
6 at Time 0 such that the time window doesn't have any delays
7 in it.

8 For example, the operators don't have any
9 delays to say, hey, what's going on here? Maybe I ought
10 to try to use the thing that I live with day in and day
11 out every day of my life and then go to use DAS.

12 But that's fine. I have some confidence
13 that, indeed, the human factors engineering verification
14 and validation will sort out those times and still give
15 you confidence that you have margin the same way as the
16 local actions in the plant that right now have a nominal
17 30 minutes.

18 However, for the 30-minute one, in the SER
19 it says the applicant explained that since actions after
20 30 minutes are not considered time critical the HFE
21 evaluation is conducted to confirm HSI suitability and
22 availability with reasonable consideration of time
23 constraints. That's my minute and a half thing.

24 The applicant indicated that it does not
25 plan to document a detailed assessment of the time margin

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 between time available and time required based on the steps
2 in special event EOPs.

3 That means that for any action with greater
4 than 30-minute time available, they're not going to look
5 at the amount of margin to that available time limit.

6 In other words, if for some reason they feel
7 it can be completed in 29 minutes and 58 seconds, that's
8 okay and that kind of bothers me. We've had some
9 discussions about this before, is why --

10 MEMBER BLEY: Actually the guidance was
11 revised to account for those concerns.

12 CHAIR STETKAR: Well, yes. On the other
13 hand, the guidance was but in the SER for this particular
14 it says --

15 MEMBER BLEY: Yes. No, I'm saying this is
16 not in accordance with my understanding of the latest
17 guidance.

18 CHAIR STETKAR: The staff finds this to be
19 a satisfactory plan. Manual actions performed within 30
20 minutes of event initiation are validated and the results
21 documented in accordance with regulatory guidance. True.

22 Manual actions performed after 30 minutes
23 are also validated but detailed documentation of the
24 margin between time required and time available is not
25 planned and there is no regulatory guidance that suggests

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to do so.

2 MEMBER BLEY: I think that's not true.

3 CHAIR STETKAR: It's not clear.

4 MEMBER BROWN: No, we actually -- yes.

5 MEMBER BLEY: Yes.

6 MEMBER BROWN: We actually put stuff out

7 --

8 (Crosstalk)

9 MALE PARTICIPANT: That guidance has
10 changed --

11 MR. JUNG: John, we'll take it back. As you
12 know, 7-19 we worked with you, issued --

13 CHAIR STETKAR: Yes, yes.

14 MR. JUNG: -- late last year or so, right?

15 CHAIR STETKAR: I'm just a little concerned
16 because you said going in that you've had a lot of
17 interactions with your human factors engineering folks
18 so if you have and they signed off on this it means somebody
19 hasn't gotten the message.

20 MR. JUNG: So given that new guidance that
21 came, we'll take a look at it.

22 MEMBER BROWN: Well, there was an ISG for
23 it and then it was put in the BTP --

24 (Multiple agreement)

25 MEMBER BROWN: -- 14 or 19, whichever one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 --

2 CHAIR STETKAR: Okay. Anyway, Ian's got
3 the right answer. Thank you. I just wanted to get it
4 into the record.

5 MR. MARTINEZ: You have additional
6 questions? Anything you want --

7 CHAIR STETKAR: Let's plan for timing.
8 Let's get through the slides on simplicity if there aren't
9 any more questions on DAS because there's only a couple
10 more questions, then we've kind of hit all of the basic
11 technical issues.

12 MR. NGUYEN: Hi, this is Khoi Nguyen again.

13 The staff we approach on review of the simplicity is that
14 the guidance discuss simple mean to address the hazard
15 for specific design aspect like data communication and
16 obviously that more complex design alternatives require
17 a more in-depth and detailed review by the staff.

18 There are several design changes that make
19 the system more simple and one of the examples that we
20 covered several times this morning is the change in the
21 connection of the non-safety automatic signal to unit bus,
22 to the hardware.

23 Also additional of the enable and disable
24 switch to disconnect the non-safety signal to the safety
25 system.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR STETKAR: When you say
2 enable/disable, that's the -- I think it's called a
3 permissive switch on the safety VDU or is this a separate
4 switch?

5 MR. NGUYEN: That's a separate switch.

6 CHAIR STETKAR: It's a separate switch,
7 okay.

8 MR. NGUYEN: Yes, based on a separate VDU
9 we call enable/disable switch.

10 CHAIR STETKAR: Oh, okay.

11 MR. NGUYEN: Whenever you need to disconnect
12 the non-safety signal from safety system, you, that's a
13 soft switch not the hardwire switch.

14 CHAIR STETKAR: Is it one for each of the
15 four divisions?

16 MR. NGUYEN: Yes.

17 CHAIR STETKAR: Okay.

18 MR. NGUYEN: On each except the VDU.

19 CHAIR STETKAR: If I go to the VDU, Train
20 A VDU, and I hit this switch, does that just disable the
21 non-safety into Train A or does it disable it for all four
22 of them? So to completely cut off, I've got to hit it
23 on all four of the safety VDUs?

24 MR. NGUYEN: That's correct.

25 MEMBER BROWN: To disconnect the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operational, the non-safety VDU?

2 CHAIR STETKAR: Yes.

3 MEMBER BROWN: Okay.

4 CHAIR STETKAR: Yes.

5 MR. NGUYEN: For simplicity, actually we
6 don't have any regulation or guidance so for -- a good
7 engineering practice we would like to review simplicity
8 throughout all the design of the US-APWR and the following
9 is data support the staff finding to support the
10 simplicity. Suggest a single platform, the MELTAC
11 controllers, be used for the entire branch, both safety
12 and non-safety side.

13 Last is the hardwired analog system, not
14 complex. It's not digital so it's not complex. All
15 functions are executed with cyclical single task
16 processing and no external interruption.

17 All the software module are executed during
18 the fixed cycle time in a predefined order. Application
19 software is written in a graphical symbolized manner so
20 that function can be easily understood, verified and
21 validated. And no dynamic allocation of memory. That
22 will be fixed. Is not dynamic.

23 CHAIR STETKAR: I think for a variety of
24 reasons what I'd like to do is to stop the presentation
25 here if that's okay with the staff, unless you have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 conflicts with coming back tomorrow morning. Is it --

2 MR. JUNG: John, we're okay. We can come
3 back tomorrow morning.

4 CHAIR STETKAR: You can come back tomorrow
5 morning? Okay. The reason is when we get into the
6 Software Program Manual and some of the nonconcurrency,
7 they're linked and there's no way that we're going to get
8 through all of the slides this evening.

9 So I think what I'd like to do is ask the
10 Members if you have any more questions on the topics that
11 we've just covered and, if not, we'll pick up tomorrow
12 morning with your presentation, finish that out and if
13 MHI has any follow-up items you want to bring back from
14 questions that were raised, that's fine. We'll do that.

15 I'd like to thank the staff a lot for
16 streamlining your presentation. I know that you all
17 wanted to say a lot of things but I really appreciate.

18 We're back much closer to being on time and we have, I
19 think, pretty good hope of actually finishing tomorrow.

20 Maybe not by noon but I really appreciated that.

21 And with that, we are recessed until tomorrow
22 morning.

23 (Whereupon, the meeting in the
24 above-entitled matter was concluded at 5:50 p.m.)

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 US-APWR Subcommittee Meeting

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Friday, April 26, 2013

Work Order No.: NRC-4166

Pages 1-155

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 US-APWR SUBCOMMITTEE

8 + + + + +

9 FRIDAY

10 APRIL 26, 2013

11 + + + + +

12 ROCKVILLE, MARYLAND

13 + + + + +

14 The Subcommittee met at the Nuclear Regulatory
15 Commission, Two White Flint North, Room T2B1, 11545
16 Rockville Pike, at 8:30 a.m., John Stetkar, Chairman,
17 presiding.

18
19 COMMITTEE MEMBERS:

20 JOHN W. STETKAR, Chairman

21 DENNIS C. BLEY, Member

22 CHARLES H. BROWN, JR., Member

23 JOY REMPE, Member

24 STEPHEN P. SCHULTZ, Member

25 WILLIAM J. SHACK, Member

26 **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 NRC STAFF PRESENT:

2 GIRIJA SHUKLA, Designated Federal Official

3 JEFF CIOCCO,

4 BRAD HARVEY,

5 IAN JUNG,

6 ERICK MARTINEZ,

7 STEPHEN MONARQUE,

8 KHOI NGUYEN,

9 TARUN ROY,

10 SESHAGIRI RAO TAMMARA

11 DINESH TANEJA

12 TUNG TRUONG

13

14 ALSO PRESENT:

15 TIM CLOUSER

16 KEVIN LYNN

17 MARVIN MORRIS

18 ROB REIBLE

19 HITOMI SASKI

20 KEN SAROLLA

21 RYAN SPRENGEL

22 DON WOODLAN

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

TABLE OF CONTENTS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ITEM:	PAGE
1. Opening Remarks and Objectives (JOHN STETKAR, ACRS)	4
2. Discussion of the ACRS Questions on Chapter 7 from previous day (ACRS MEMBERS)	4
3. Project Overview and NRC Staff Introduction (STEPHEN MONARQUE, NRO)	5
4. Discussion of the Comanche Peak, COLA Chapter 2, Site Characteristics, Sections 2.0 - 2.3 (OPEN) (LUMINANT)	72
5. Discussion of the SE for the Comanche Peak COLA Chapter 2, Site Characteristics, Sections 2.0 - 2.3 (OPEN) (STEPHEN MONARQUE, NRO)	84

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

P R O C E E D I N G S

8:30 a.m.

CHAIR STETKAR: The meeting will now come to order. We'll resume where we were yesterday. All of the logistics remain in effect.

I will remind people to silence your cell phones, please, and if you have anything to say from the audience, please come up to the microphone and make sure you identify yourself.

Jeff, I don't know if you want to say something for introduction or --

MR. CIOCCO: No. I think we are ready to go, John. Thank you.

CHAIR STETKAR: Okay. And the bridgeline is open.

Folks on the bridgeline, if you can hear us. We keep the bridgeline on mute. I will open up the bridgeline for comments after we finish the discussion of Chapter 7.

For logistics, I don't know if MHI has any responses to any items that we discussed yesterday.

Ryan, do you have anything?

MR. SPRENGEL: We do. There was --

CHAIR STETKAR: You do. Okay. What I'd like to do is finish the staff's presentation, get your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 input and then transition to the COL Chapter 7, so we
2 just sort of keep the DCD and COL organized that way.

3 And, with all of that, Dinesh, it's your
4 turn.

5 MR. TANEJA: Good morning.

6 So I hope everybody got a little bit of rest
7 and now they are fresh to -- we appreciate yesterday's
8 very constructive feedbacks, and I think it will only
9 make the design better, you know, what we get from you
10 guys.

11 So, what we'll do is, we'll start off with
12 the software program and we'll wrap up the presentation.

13 Then we have some feedback that we can give you from
14 yesterday, and then just kind of go over some of the,
15 you know, items that we took down from yesterday's
16 meeting and, you know, I'm just going to run through
17 them.

18 With that, I'm going to turn it over to Tom.

19 MR. TRUONG: Okay. Good morning. My name
20 is Tung Truong. I work in the Office of New Reactors,
21 and today we are discussing the software program manual,
22 MUAP-07017 Rev. 4 and also the Appendix C, the SDOE,
23 the software development operational environment.

24 The US-APWR SPM describes the software life
25 cycle, process he used to develop the protection

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 system/monitoring system, and this description has
2 provided twelve separate plans in the SPM.

3 And some of those plans are the software
4 development plan, software quality assurance plan,
5 software verification/validation plan, software
6 configuration master plan and so on.

7 And the majority of the software plans in
8 the SPM are also applicable to the EPSMS augment quality.

9 These are the regulations and guidance the
10 staff used. GDC-1, for example, states, in part, "The
11 safety systems must be designed, fabricated, installed
12 and tested to the quality standards commensurate with
13 the importance of safety functions to be performed."

14 And the staff used mainly BTP 7-14 technical
15 position 714 to do these evaluation. The staff has used
16 twelve separate plans against 714 and the associated
17 regulatory guides and endorsed IEEE standards.

18 For the security development operational
19 environment -- that is Appendix C of the US-APWR software
20 program. That was reviewed against Reg Guide --
21 Regulatory Guide 1.152, Rev 3.

22 MEMBER BROWN: That is the one we just went
23 through? That's the most recent revision that we
24 discussed a year or two ago?

25 MR. TRUONG: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Something like that?

2 MR. TRUONG: Yes, sir. And I think, Member
3 Brown, you had a question yesterday concerning SDOE.

4 MEMBER BROWN: Well, yes. A question to
5 them.

6 MR. TRUONG: Yes.

7 MEMBER BROWN: Hadn't gotten to you.

8 MR. TRUONG: Okay.

9 MEMBER BROWN: Other than yesterday after
10 the meeting.

11 MR. TRUONG: I'm sorry. So, the staff went
12 back to look at the -- based on the slides, that image
13 I presented yesterday, that the -- the cartoon or the
14 -- the diagram for -- I'm thinking of one, if you're
15 looking at it, MHI.

16 The corporate electronic archive system and
17 development environment system, so the staff found --
18 found that diagram -- not in the SPM, but in the -- in
19 the UAP-07005.

20 And it is consistent, Member Brown, with
21 what is in the last evaluation there. However, during
22 the discussion yesterday, Member Brown and MHI was
23 learned that, besides nuclear, perhaps other projects,
24 not -- like nonnuclear. So that would be a concern.
25 So, that's something the staff needs to discuss and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 then we try after the fact.

2 MEMBER BROWN: Okay.

3 MR. TRUONG: Is there any other question
4 that you had?

5 MEMBER BROWN: No, no. It was on that.

6 MR. TRUONG: There is one open item, like
7 Dinesh alluded to yesterday, and that is the staff
8 requested the applicant MHR to explain or describe the
9 process it plans to use to ensure that it's going to
10 -- the safety software development process and the
11 resulting software conform to NRC regulation and
12 guidance.

13 And, in addition, the staff requested the
14 applicant to include ITAAC to provide a fabrication of
15 such a process.

16 Are there any other questions for the SPM
17 or SDOE?

18 MR. TANEJA: I'll see if I can -- I think
19 we just received a draft response. We haven't had a
20 chance to --

21 MR. TRUONG: Yes. We have received a draft
22 response from MHI earlier this week.

23 MR. TANEJA: Yes. But we haven't had the
24 opportunity to review it.

25 MR. TRUONG: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: All right. We'll wait and
2 see how that works out.

3 MR. TRUONG: Next is PAM's.

4 MR. TANEJA: Yes. The postaction
5 monitoring parameters, MHI made a decision to include
6 in the DCD the list of PAM variables, and the existing
7 plans list, based on our Regulatory Guide 197, Rev 2
8 and Rev 3.

9 In that list, we have tables that proscribe
10 for BWR type plans and PWR type plans what parameters
11 we consider required for postaction monitoring.

12 All the new designs, you know, their list
13 needs to be performed on the basis of Reg Guide 197,
14 Rev 4, which is a performance-based. Okay. There is
15 no list, so you have to use -- it endorses IEEE 497,
16 which requires you to have EOP's and AOP's, and based
17 on your management of these events, you know, what you
18 -- what the instruments you need to use becomes your
19 basis for developing this list.

20 EOP's and AOP's do not exist, and I guess
21 they will exist after we license. So, one of the options
22 was to have this thing as a COL action item, but they
23 chose to proceed with a list at this stage.

24 So, we've been working with MHR. We've
25 made a lot of progress. You know, we are almost there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So, we had to use alternate methods, you know. I guess
2 what they gave us to look at is -- the emergency response
3 guidelines are in draft.

4 They have prepared them, so we audited the
5 Emergency Response Guidelines to see how those events
6 are describe. And I guess, since it is a PWR 4-loop
7 unit, a lot of the PWR PAM variables are directly
8 applicable.

9 So we had asked MHI to do a comparison
10 between the Rev 3 list versus their list to look at the
11 delta. I guess there are some design differences.

12 MEMBER BROWN: Rev 3 of the DCD was --

13 MR. TANEJA: Rev 3 of the Regulatory
14 Guideline 1.97.

15 MEMBER BROWN: 1.97.

16 MR. TANEJA: Okay.

17 MEMBER BROWN: Yes.

18 MR. TANEJA: Which provides a proscribed
19 list of parameters.

20 MEMBER BROWN: That's before --

21 CHAIR STETKAR: As if every plant in the
22 world is precisely the same.

23 MEMBER BROWN: No, I understand that.

24 When I asked that question I just -- I wanted
25 to understand. At one point you're talking about 1.97.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. TANEJA: 1.97. Right.

2 MEMBER BROWN: Now, when was changed to a
3 performance-based? Is that Rev 4?

4 MR. TANEJA: Rev 4. Rev 4.

5 MEMBER BROWN: You know, when --

6 MR. TANEJA: Right.

7 MEMBER BROWN: -- was that done?

8 MR. TANEJA: Oh, that was done back in 2007,
9 I think.

10 MEMBER BROWN: Okay. I just -- it was
11 before --

12 MR. TANEJA: Yes.

13 MEMBER BROWN: -- before I got here.
14 That's all I wanted to know.

15 MR. TANEJA: Well, it was -- right. It was
16 changed and the intent was that all new licensees coming
17 in --

18 MEMBER BROWN: Yes, I got that --

19 MR. TANEJA: -- they, you know --

20 MEMBER BROWN: Let me get on with this.

21 MR. TANEJA: Okay. All right.

22 MEMBER BROWN: So, what I'm trying to
23 figure out is why do we need the mouse-milk? What
24 parameters are monitored -- I mean, PWR. You put a bunch
25 of parameters in that are consistently knowing, now

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 we're going to evaluate whether we only need half of
2 those --

3 MR. TANEJA: Well, this is --

4 MEMBER BROWN: -- because of --

5 MR. TANEJA: This -- this regulation --

6 MEMBER BROWN: I'm not going to argue
7 against a --

8 MR. TANEJA: Right.

9 MEMBER BROWN: This seems like a mindless
10 application of performance --

11 MR. TANEJA: Well, this regulation, is it
12 a result of the TMI accident. Okay. After the --

13 MEMBER BROWN: I understand why that came.

14 MR. TANEJA: Right. Post-TMI, there was
15 a requirement to have a dedicated set of parameters based
16 on what events you are going to manage, whether they
17 need to be Class 1E, whether they need to be redundant.

18 So, they were categorized. You know,
19 Categories A, B, C, and A being full category. Make
20 two sets. If one doesn't work, I have another one
21 available.

22 So, you know, we -- yes. We all know we
23 have all these key parameters that we do need, you know.

24 But, EOP's will dictate, you know, hey, for me to manage
25 this event, I must have this information available to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 me.

2 And that's really -- you know, it's a
3 limited set. It's not an unlimited set, you know. So,
4 what set -- so we are really working with them and they've
5 been very, you know, forthcoming with a lot of the
6 information.

7 And I have reactor systems. I have tech
8 specs people. I have human factors people. They are
9 working with me, because I need systems people. I mean,
10 I really -- we don't have the EOP, so I need the
11 operations, so --

12 MEMBER BROWN: This is my problem, and it's
13 just -- you've got a list. I mean, it's -- I'm asking
14 a different question. I mean, I just --

15 MR. TANEJA: Okay.

16 MEMBER BROWN: You're worried about
17 because they don't have EOP's, and yet they've provided
18 a minimum list and it's based on past PWR operations,
19 so at least you've got a decent start, and it's something
20 to work from instead of, you know, well, gee, you only
21 need half of these or something like that.

22 CHAIR STETKAR: That was my question,
23 honestly. I mean, if I -- I read the open item and I
24 read the SER. It sounds like you're trying to extend
25 this out into the COL space when -- when MHI is doing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 something that very few of the other vendors have chosen
2 to do.

3 They've actually taken the initiative to
4 try to specify this at the design phase so that we --
5 we have a little bit better handle on what, indeed, will
6 be displayed, you know, either over on the safety panels
7 or -- or only on the nonsafety panels.

8 And now they seem to be being penalized
9 because they don't have EOP's written. So, my question
10 to you, since -- since this is an integrated review
11 effect, and we have thousands of people here now with
12 a lot of experience in the nuclear power industry.

13 What particular indications that are not
14 on this list does the staff want on the list, and why?

15 MR. TANEJA: Well, because --

16 CHAIR STETKAR: Because, you know, that's
17 part of the review responsibility.

18 MR. TANEJA: Right.

19 CHAIR STETKAR: You can't just say bring
20 me the world and I'll tell you I don't have enough
21 information, and you need to bring me more information.

22 What concerns do you have specifically with
23 the list that they have?

24 MR. TANEJA: Well, the --

25 CHAIR STETKAR: And unless -- and I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 asking the staff to tell us that.

2 MR. TANEJA: Yes.

3 CHAIR STETKAR: I want that information.

4 MR. TANEJA: Right.

5 CHAIR STETKAR: As a subcommittee. So --

6 MR. TANEJA: So a couple of --

7 CHAIR STETKAR: -- that's a take-away item
8 that I want the staff to answer.

9 MR. TANEJA: Yes. A couple of areas that
10 we are remaining to work on, I'm in -- like I said, the
11 exercise has been, you know, looking at -- like, for
12 example, Category 8, based on Rev Guide 1.97, Rev 4 are
13 the parameters that are credited manual actions that
14 are in Chapter 15.

15 CHAIR STETKAR: Sure.

16 MR. TANEJA: So we have Chapter 15. We
17 know what the required manual actions are. Now, those
18 manual actions, the parameters that you use to take those
19 actions, they need to be categorized as Category 8,
20 highest category.

21 They've had agreed, read them, and all that.

22 In that area, the way Chapter 15 has already accepted
23 is the use of alarms to take manual actions. And we
24 worked diligently on -- listen, alarms are not
25 safety-related.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR STETKAR: That's true.

2 MR. TANEJA: So, how can we put those on
3 this list?

4 CHAIR STETKAR: That's right.

5 MR. TANEJA: While these are -- Chapter 15
6 has already accepted it. What's your problem? So, I
7 went to Chapter 15. I said, "Did you guys accept it?"

8 "Yes." Alarm initiates my action and I
9 have this much time to take my action, and I can do it.

10 CHAIR STETKAR: And that's -- and that's
11 fair.

12 MR. TANEJA: Right.

13 CHAIR STETKAR: That's a fair --

14 MR. TANEJA: So, now, what is the source
15 of that alarm.

16 CHAIR STETKAR: Right.

17 MR. TANEJA: So, you know, we rectify that
18 problem to -- went back to which parameters.

19 CHAIR STETKAR: Okay.

20 MR. TANEJA: Now, one of the open area right
21 now is, I guess it's the steam generator tube rupture
22 event, where we have, I guess -- M16 is the direct way
23 to really see which -- which is your affected steam
24 generator.

25 M16's are nonsafety-related in the existing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plans and -- but, you know, the interesting dilemma is
2 that EPR made them safety-related, and they are using
3 them as a primary means of detecting.

4 So -- so that's the area we are still working
5 with reactor systems, to see, you know, what they are
6 okay with. You know, the alternate options that you
7 have in front of you, I mean, Jeff Schmidt that I'm
8 working with, he's a former operator and he said, "You
9 know, I always looked at M16's, whether they were there
10 or not, and I really didn't have any regulatory basis
11 to really judge whether I need to make them
12 safety-related. But, now you're saying Reg Guide 1.97,
13 Rev 4. So maybe I need to relook that idea." So, these
14 are the areas we are --

15 CHAIR STETKAR: Has the RAI's, because we
16 -- we have access to the RAI's --

17 MR. TANEJA: Yes.

18 CHAIR STETKAR: -- but don't, in practice,
19 read all of them. Have the RAI's been to that level
20 of specificity because what I read in the -- in the SER
21 --

22 MR. TANEJA: Yes.

23 CHAIR STETKAR: -- is pretty broad.

24 It seems to be saying, you know, we can't
25 make these decisions until we have the procedures and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that just sends to kick it --

2 MR. TANEJA: Right. RAI is about -- I
3 think it's about a 60-page RAI response right now.

4 CHAIR STETKAR: Okay.

5 MR. TANEJA: So we are like that second or
6 third revision to that RAI response and --

7 CHAIR STETKAR: And it does get to the
8 specificity --

9 MR. TANEJA: Oh, yes.

10 CHAIR STETKAR: -- of signal? Okay.
11 Good.

12 MEMBER REMPE: What is the number of RAI?

13 CHAIR STETKAR: Yes. What is that?

14 MR. TANEJA: Seven -- question number
15 7.18-15. 7.5-18 --

16 CHAIR STETKAR: If it's --

17 MR. TANEJA: -- is the question number, but
18 it's on the last page --

19 MR. CIOCCO: It is RAI 568-4588.

20 MEMBER REMPE: 568 --

21 MR. CIOCCO: 4588.

22 MR. TANEJA: 4588.

23 MR. CIOCCO: 4588, and then Dinesh said
24 it's 7.05-18?

25 CHAIR STETKAR: Yes. I suspect -- I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 suspect we have it. It's --

2 MR. TANEJA: Yes, it's --

3 MR. CIOCCO: What you don't have is some
4 of the draft responses that are being worked on that
5 aren't -- aren't complete yet.

6 CHAIR STETKAR: Yes.

7 MR. TANEJA: Yes. We just received a, you
8 know, the last draft, you know, like beginning of April.

9 CHAIR STETKAR: Okay.

10 MR. TANEJA: And I had Paul, you know,
11 looking at that and yesterday Paul was here and today
12 he could not be here.

13 But, basically, Paul said that we are almost
14 there.

15 CHAIR STETKAR: Okay.

16 MR. TANEJA: You know, so we are almost
17 there.

18 CHAIR STETKAR: That is encouraging.

19 MR. TANEJA: Yes.

20 CHAIR STETKAR: I'll take a look at that.

21 MR. TANEJA: You know, so we've -- we've
22 done a lot of work in that area. And, because we are
23 trying to establish a list, in the absence of actually
24 EOP's/AOP's, so we are really having to understand --

25 CHAIR STETKAR: Well, but in the absence

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of EOP's in the sense of what precisely is written in
2 Step, you know, 1.2.3.7, in terms of accident
3 management, I don't think you need that level of
4 specificity.

5 MR. TANEJA: Right.

6 CHAIR STETKAR: Chapter 15 and the general
7 knowledge of people for -- as you said, this is a PWR.
8 There are design differences.

9 MR. TANEJA: Right. Right.

10 CHAIR STETKAR: You know, you don't need
11 a level --

12 MR. TANEJA: Yes.

13 CHAIR STETKAR: -- in the RWSP for
14 switchover, for example --

15 MR. TANEJA: Yes.

16 CHAIR STETKAR: -- because there isn't any
17 switchover.

18 MR. TANEJA: Exactly.

19 CHAIR STETKAR: So, you know, the
20 availability of that level instrument --

21 MR. TANEJA: Yes.

22 MR. JUNG: John --

23 CHAIR STETKAR: -- is the question.

24 MR. JUNG: I know you have -- the initial
25 reaction was very strong --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: If -- if the -- if the
2 RAI's have some of that specificity -- and I'll go back
3 and look at them -- some of that initial reaction will
4 be --

5 MR. JUNG: You know, overall --

6 CHAIR STETKAR: -- satisfied. But -- but
7 I -- as I read the SER, the impression that I got was
8 here is one of the few people coming in in the design
9 certification stage who has actually taken the
10 initiative to provide the list, where other people have
11 just said, "Oh, no, no. We're not going to do it. We
12 don't have to do it according to the regulations. The
13 heck with you. We're going to leave it to the post-COL
14 issuance.

15 MR. JUNG: Right. The staff -- the staff
16 believes this is the better way to do it.

17 CHAIR STETKAR: It's absolutely the better
18 the way, and I don't -- I'm hoping that we don't penalize
19 someone for actually taking the better path.

20 MR. JUNG: I don't think that there's any
21 intention of that. I think we started with actually
22 the focusing on the delta, understanding the delta
23 better, so that we can establish the list --

24 CHAIR STETKAR: Okay.

25 MR. JUNG: -- with a good confidence that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it will remain the same, rather than later revisions
2 to the DCD --

3 CHAIR STETKAR: Right.

4 MR. JUNG: -- type of things. So, that was
5 our intent.

6 CHAIR STETKAR: Yes.

7 MR. TANEJA: Yes. So, you know, what the
8 RAI response does, it actually attaches changes to the
9 DCD, which explains all these variables and the basis,
10 you know, why they selected it.

11 And then, I think one of the technical
12 report either gets it, the comparison between the Rev
13 3 of the -- the list of the Rev 3, and -- and the US-APWR
14 list.

15 CHAIR STETKAR: Yes. I looked -- well, I
16 looked at that.

17 MR. TANEJA: Right. And then that
18 comparison is there and then I believe the other thing
19 that -- well, the list, actually, that's in DCD of the
20 actual PAM variables.

21 I know we have had like some, then, from
22 Category B to A. Some got added. So, there's been an
23 ongoing -- in a revision to that, and maybe a couple
24 of parameters got added.

25 And, you know, containment isolation I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 think, valve position indications got added. You know,
2 we were trying to use the containment pressure. The,
3 I guess, you know, the -- when we worked on it, said,
4 you know, come on. Those are safety-related. What's
5 the big deal? Why don't we add them to that, you know?

6 So, all the -- you know, all the containment
7 isolation valve positions were -- you know, so it's --
8 it's a work-in-progress. We've had a lot of -- a lot
9 of progress on that.

10 So, we're almost there, and I think we
11 should be done with it next month or so.

12 CHAIR STETKAR: Good. That's -- that's
13 encouraging --

14 MR. TANEJA: Yes.

15 CHAIR STETKAR: -- because that's a
16 different impression, certainly, that I got from reading
17 the SER and the old item. It sounded like --

18 MR. TANEJA: Well, we didn't have much to
19 go on in Rev 3, you know, to write the case, you know.

20 CHAIR STETKAR: Okay.

21 MR. TANEJA: So -- all right. So, the next
22 slide is regulation, and I think I've already discussed
23 the open item.

24 CHAIR STETKAR: Yes.

25 MR. TANEJA: On page 49. Any other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 questions on postaction monitoring?

2 (No response.)

3 MR. TANEJA: Okay. Go to the PCMS strike.

4 MR. MARTINEZ Good morning. This is Erick
5 again. Can you hear me all right?

6 CHAIR STETKAR: Yes.

7 MR. MARTINEZ I can't tell. Better.

8 CHAIR STETKAR: Just be careful not to hit
9 the microphone.

10 MR. MARTINEZ Thank you. And so this slide
11 is to pretty much give you a quick overview on an RAI
12 that the staff recently sent out to MHI. You might have
13 seen that already in MHI's presentation where the last
14 RAI that they talked about in their slides.

15 The staff pretty much issued this RAI to
16 get a better understanding on how the PCMS failures are
17 -- are addressed and they don't affect the safety
18 function of the -- of the PCMS.

19 So, pretty much, we're asking for
20 additional clarification and details on just how
21 specifically the PCMS does not affect the safety
22 function. And, unless you have anything to add to that
23 there is just no --

24 CHAIR STETKAR: Erick, is --

25 MR. MARTINEZ -- way that we --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: And I have to -- in the
2 interest of time, I'm not going to try to shuffle through
3 all of my notes, so I'll just ask you here.

4 As it's -- as it's presented on the slide
5 here, it just says the affects of control system failures
6 on the safety function.

7 Does -- does that include both -- I
8 understand the manual signals that come in through the
9 unit bus and COM-2 and all of that stuff. I don't really
10 understand it, but I can say those words today, and
11 they're probably wrong.

12 Does it also include the effects of those
13 automatic control signals that I asked about yesterday
14 that I was confused that are now hard-wired from the
15 automatic controls into PSMS?

16 Because, those are -- I'm trying to find
17 out what the scope of that open item applies to --

18 MR. TANEJA: The genesis of this question
19 is, in DCD 7.7, I guess there is statements in there
20 that claim that any failures in the PCMS is bounded by
21 Chapter 15 analyses for AOO's and PA's. Okay.

22 Now, the PCMS being software-based, okay,
23 we wanted to make sure -- you know, traditional plants
24 feed pretty much analyze failures of feedwater system
25 and its consequences and, you know, some of the turbine

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 trip and its consequences.

2 But, these are taken one at a time.

3 CHAIR STETKAR: Yes.

4 MR. TANEJA: Now, could there be a
5 concurrent failure of multiple things and has that been
6 analyzed?

7 CHAIR STETKAR: Okay.

8 MR. TANEJA: Right?

9 CHAIR STETKAR: Yes.

10 MR. TANEJA: Now, I guess the -- and, you
11 know, and yesterday's presentation, what we saw and
12 which I say that they will demonstrate how the analyses
13 in Chapter 15 bound these multiple -- potential multiple
14 failures of the PCMS.

15 So, I think that's the gist of the whole
16 question.

17 CHAIR STETKAR: So, at that level, we don't
18 --

19 MR. TANEJA: Yes.

20 CHAIR STETKAR: -- it doesn't distinguish
21 between manual or automatic or any --

22 MR. TANEJA: It's just simply --

23 CHAIR STETKAR: -- it's just PCMS --

24 MR. TANEJA: Right. Globally.

25 CHAIR STETKAR: Globally. Okay. Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I just wanted to make sure I understood, in my own head
2 --

3 MR. TANEJA: Right.

4 CHAIR STETKAR: -- what that scope was.
5 Thanks.

6 MR. TANEJA: You know, back -- I guess it
7 was August when we had the SE with Open Items ready to
8 go. One of the NRC employees submitted a nonconcurrency
9 on the SE, and raised three issues, namely,
10 commercial-grade dedication of MELTAC system, and basic
11 question on the lifecycle development process for the
12 basis software and, you know, issues with the US-APWR
13 data communication, specifically interface of
14 operational VDU with the DSMS. Next slide.

15 So, for the benefit of people that may not
16 be familiar with a nonconcurrency, I'm going to read
17 a statement that comes out of our procedure here.

18 "The NRC strives to establish and maintain
19 an environment that encourages all employees to properly
20 raise concerns and differing views without fear of
21 reprisal and to promote methods for raising concerns
22 that will ensure its strong safety culture and support
23 agency's mission.

24 "Individuals are expected to discuss their
25 views and concerns with their immediate supervisors on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 a regular basis and ongoing basis. If informal
2 discussions do not resolve concerns, individuals have
3 various mechanism for expressing and having their
4 concerns and differing views heard and considered by
5 management.

6 "The nonconcurrency process allows
7 employees to document their differing views and concerns
8 early in the decisionmaking process, have them responded
9 to and attach them to proposed documents moving through
10 the management approval chain."

11 And that's exactly what took place. And
12 it's Management Directive MD-10.1.5.8 that allows this
13 nonconcurrency process to take place.

14 CHAIR STETKAR: And just -- just for the
15 record and to make sure that I understand the process
16 correctly, a nonconcurrency is raised during the staff's
17 reviewed by a member of the staff who was involved in
18 that review.

19 MR. TANEJA: That is correct.

20 CHAIR STETKAR: And that -- and that
21 nonconcurrency must reach some level -- must be
22 resolved, anyway, by the time the Safety Evaluation
23 Report is listed. Is that correct?

24 MR. TANEJA: The normal process is the
25 already contributing individuals. And, in this case,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 our product is the Safety Evaluation Report on Chapter
2 7 concur.

3 CHAIR STETKAR: Yes.

4 MR. TANEJA: Right?

5 CHAIR STETKAR: Right.

6 MR. TANEJA: And we actually -- you know,
7 every individual concurs when we are done with the
8 product and we are sending.

9 So, at that time, if you have issues with
10 that, I guess the first step is informal discussions
11 with your supervisor and, you know -- and even the
12 management at that level to raise your concerns and
13 issues.

14 And I guess that went through -- we went
15 through that process and it went beyond that and then
16 it got documented, and these three issues were
17 documented as being issues of concern.

18 CHAIR STETKAR: Where I was going is, I
19 wanted to make sure I understood the process.

20 MR. TANEJA: Right.

21 CHAIR STETKAR: At the point when the
22 Safety Evaluation Report -- the final SER is issued,
23 there's still another opportunity called a Differing
24 Professional Opinion, which --

25 MR. TANEJA: That is correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: -- which can actually be
2 raised, it's my understanding, by anyone.

3 MR. TANEJA: Yes.

4 CHAIR STETKAR: It's not only restricted
5 -- the nonconcurrency is restricted to people who have
6 been actively involved --

7 MR. TANEJA: Right.

8 CHAIR STETKAR: -- in the review activity.

9 MR. TANEJA: Yes.

10 CHAIR STETKAR: The DPO could be those
11 people if they don't feel their concerns have been
12 adequately resolved, or any other individual, but that's
13 after the final SER is issued.

14 MR. TANEJA: That is correct.

15 CHAIR STETKAR: Okay. I just --

16 MR. TANEJA: That is correct.

17 CHAIR STETKAR: -- wanted to make sure for
18 the record that -- that I understood the differences
19 between the nonconcurrency and the DPO process.
20 Thanks.

21 MR. TANEJA: So in this process, the
22 nonconcurring individual wrote his concerns. The
23 concerns were given to, you know, the branch chief, and
24 branch chief proceeded to summarize those concerns and
25 then the staff provided a written response to each of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 the, you know, three issues that were summarized.

2 And then, the -- our management looked at
3 the nonconcurring views and looked at the staff's
4 response, and they discussed it with us and they
5 discussed it with nonconcurring individuals, and then
6 they provided us with the actions that need to be taken
7 to resolve the nonconcurrency.

8 So, the actions that are listed here on
9 these slides, actually were followed up and turned into
10 RAI's and they are right now in our SER captured as open
11 items.

12 CHAIR STETKAR: Okay.

13 MR. TANEJA: So I'll just quickly go
14 through these items. The first item was related to the
15 MELTAC. Originally, like I think we were mentioning
16 that MELTAC was being commercially-dedicated because
17 MELCO did not have a QA program.

18 So, you know, that is the genesis of that
19 concern and now there has been a shift.

20 MEMBER BROWN: That wasn't a QA. They got
21 a QA. It's just not a -- an Appendix B.

22 CHAIR STETKAR: It's not an Appendix B QA.

23 MEMBER BROWN: B QA program.

24 CHAIR STETKAR: Right.

25 MR. TANEJA: It's a Japanese QA program on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that. Right.

2 MEMBER BROWN: I'm just saying, because
3 they have a QA program.

4 MR. TANEJA: Exactly.

5 MEMBER BROWN: It's just not an Appendix
6 B program.

7 MR. TANEJA: Right.

8 MEMBER BROWN: That's all.

9 MR. TANEJA: So now they have established
10 an Appendix B program and the way that DCD states right
11 now is that they are procuring the system as a Class
12 1E from an Appendix B vendor. Right?

13 So the question it's asking is to, you know,
14 verify that all the critical characteristics of the
15 MELTAC are documented in the DCD, and then the ITAAC
16 is there that verifies these critical characteristics
17 on the as-built machine.

18 They are there but, you know, the idea is,
19 now we want to close the loop to ensure that, you know,
20 because the way you do commercial grade dedication is
21 you identify all the critical characteristics and you
22 verify that they are all verified. And that's a method
23 of doing commercial grade dedication.

24 CHAIR STETKAR: Okay. But they are not
25 going to do that?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. TANEJA: They are not going to do that,
2 but we do have the like MELTAC technical report. All
3 the details are there. So, you know, we want to make
4 sure that all the critical characteristics are defined
5 in the -- in the docketed DCD material for MELTAC, and
6 then the ITAAC's are there to verify that those are all
7 properly working and functioning. So that was the
8 action that was endorsed.

9 CHAIR STETKAR: Let me ask you, because I'm
10 not a QA person at all. Let's say you didn't have this
11 history of MHI, MELCO, MELTAC, whatever, and somebody
12 came into you clean and said, "I'm a Vendor X. I'm
13 building -- I'm designing this particular power plant
14 and I have a subcontractor who is supplying, you know,
15 a widget."

16 MR. TANEJA: Yes.

17 CHAIR STETKAR: "And my subcontractor --
18 I, the Vendor X have an Appendix B quality" -- this is
19 -- the widget has to be a safety-related widget.

20 "I have an Appendix B QA program and my
21 subcontractor has asserted that they have an Appendix
22 B QA program."

23 In terms of the staff's review of -- of that
24 situation, would you be requiring Vendor X to be listing
25 critical characteristics of the widget in their DCD?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. TANEJA: Well, I'll take a simple
2 example. Right. Now, let's say a reactor vessel
3 component. Same QA issue, right. I mean, we have our
4 design and the DCD will tell us all the critical
5 features, the materials --

6 CHAIR STETKAR: Okay. Right.

7 MR. TANEJA: -- size, valves, all that
8 stuff. Right?

9 And they are -- you know, our QA program
10 that we have in the NRC on vendor inspection and
11 ratification. So, the ultimate responsibility for
12 quality lies with the licensee. Correct?

13 CHAIR STETKAR: Yes.

14 MR. TANEJA: The licensee has to ensure
15 that their vendors are supplying good stuff.

16 CHAIR STETKAR: Right.

17 MR. TANEJA: And they have the oversight
18 process -- at least that's what I understood when I
19 interacted with our QA people.

20 So, in the MELTAC case -- you know, when
21 we initially had gotten the documentation on commercial
22 grade dedication, they prepared a number of pages, we
23 actually went to our QA for their assistance.

24 So, basically what they said there is,
25 approving that we have in the NRC where our vendor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 inspection branch periodically inspects the people that
2 have a QA program, and we'll make sure that this is a
3 good stuff, because we do that inspection part.

4 CHAIR STETKAR: But they inspect against
5 those -- those attributes that are listed in the DCD?

6 MR. TANEJA: They inspect their QA process.

7 CHAIR STETKAR: Okay. Right.

8 MR. TANEJA: Okay. And what they told me
9 is this way, is that MELCO -- they will look at their
10 purchase order.

11 CHAIR STETKAR: Right.

12 MR. TANEJA: Right. So the purchase
13 order, let's say, comes from MHI to MELCO and what we
14 expect that purchase order to say, "Give me this widget
15 that does this thing."

16 CHAIR STETKAR: Right.

17 MR. TANEJA: "What's in the DCD." Right?

18 CHAIR STETKAR: Yes.

19 MR. TANEJA: And so, when my vendor branch
20 goes and looks at MELCO then, hey, where's your purchase
21 order? Let's see what you are supposed to build. Are
22 you doing what you're supposed to be doing?"

23 CHAIR STETKAR: Okay. Right.

24 MR. TANEJA: Are you doing what you're
25 supposed to be doing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Okay.

2 MR. TANEJA: Right. I think that's my
3 understanding.

4 CHAIR STETKAR: Okay. Okay. Yes.

5 MR. TANEJA: Yes.

6 CHAIR STETKAR: I think that helps a little
7 bit. I'm still a little vague, but go on.

8 MR. TANEJA: I wish I could get the QA
9 people here. They are all caught up another meeting
10 this week. So --

11 CHAIR STETKAR: Sorry.

12 MR. TANEJA: You know. So that was the one
13 item. And then the second item.

14 MEMBER BROWN: Let me ask one other
15 question.

16 MR. TANEJA: Yes.

17 MEMBER BROWN: I just went back and looked
18 at the version of the MELTAC platform we have here and
19 Section 6.3 talks about the establishment of the 10 CFR
20 Part 50, Appendix B QA program and the MELTAC
21 Reevaluation Program.

22 MR. TANEJA: Yes.

23 MEMBER BROWN: Why, if that's in the
24 technical report, does that mean they've already
25 completed that or does that mean they are going to do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 it or why does this -- why is this hanging fruit still
2 hanging there if there's that level of documentation
3 -- or at least that statements --

4 MR. TANEJA: Well --

5 MEMBER BROWN: -- in the technical report,
6 Rev 8?

7 MR. TANEJA: When we receive the MRP, I'll
8 give you a little bit of background. The MRP document
9 was, I think, 500-plus pages. Right?

10 MEMBER BROWN: MRP.

11 MR. TANEJA: Reevaluation.

12 MEMBER BROWN: Reevaluation. Okay.

13 MR. TANEJA: Reevaluation Program. I'm
14 sorry.

15 MEMBER BROWN: That's okay.

16 MR. TANEJA: Okay. MELTAC Reevaluation
17 Program. Now, what that document gave us is, here are
18 the critical characteristics.

19 Method of verification, they wrote down a
20 specification number, or a drawing number. Right?
21 There were -- I don't know, maybe -- I would say close
22 to hundreds of documents that were listed there, and
23 then some test report number.

24 Now, what does that document tell me?
25 Nothing. Right. So, when I took it to vendor, he was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 like, "Come on, guys. You don't need" --

2 MEMBER BROWN: When you took it to who?
3 When you took it to who? Your --

4 MR. TANEJA: Our vendor inspection people
5 here.

6 MEMBER BROWN: Oh.

7 MR. TANEJA: Right. I said, "You know, how
8 do you look at these things?" They said, "We're going
9 to have to go and, you know, either you audit every single
10 one of them or we'll do it under the vendor inspection
11 program where we go and we do checks on that."

12 So there was an inspection done and, you
13 know, they invited us to come along with that. So, we
14 were able to inspect most of those documents.

15 And I think our finding that we came up with
16 was a one finding because they did not adequately
17 document the burn-in period. I think the guideline that
18 they were using was a pre-Guideline which says, "If
19 you're going to use a commercial PLC in a safety
20 application" -- that's really what it says.

21 If you are going to take this commercial
22 PLC and put it in a safety application, burn it for 28,
23 48 hours or something like that and make sure that there
24 aren't latent failures before you put it in here.

25 And this eval, we do burn in, you know, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 there was no proper documentation of that. So, that
2 was the only finding that we came up with.

3 It's like, you know, when you say -- so what
4 the decision was made at that time --

5 MEMBER BROWN: Let me interrupt for just
6 a --

7 MR. TANEJA: Yes.

8 MEMBER BROWN: I just want to understand
9 your -- what you're saying is you effectively -- when
10 the platform was designed --

11 MR. TANEJA: Right.

12 MEMBER BROWN: -- and built and used in
13 other applications, there was a level of QA system
14 processes that applied.

15 MR. TANEJA: Right.

16 MEMBER BROWN: Now, you're going backwards
17 and looking at what was done to see if those items
18 contained the metrics, the judgment metrics for meeting
19 the Appendix B requirements --

20 MR. TANEJA: Right.

21 MEMBER BROWN: -- in terms of the details,
22 how long was it burned in, you know, what were the
23 temperatures they get it to, what were the current
24 levels, what were the data rates, whatever applies to
25 the particular component.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TANEJA: Right.

2 MEMBER BROWN: And what you're saying is,
3 if you go back and look at that documentation, the one
4 you found is that it didn't have the documentation.

5 And I faced this, looking at what people
6 have done in the world I've worked in in the last 13
7 years and qualifying stuff.

8 You go say, "Well, hold it." You got --
9 you say it tested okay. You go back and look at the
10 test -- well, hold it. There's no temperatures here.
11 There's no humidities. There's no voltage variations.
12 There's no -- you didn't write down what you tested
13 it to.

14 So, is that the -- that's the type of stuff
15 you're -- you didn't document it as part of the overall
16 -- in those days.

17 MR. TANEJA: Right.

18 MEMBER BROWN: Whereas, if you were -- so,
19 you have to make a judgment, is that okay --

20 MR. TANEJA: Yes.

21 MEMBER BROWN: -- or does it have to be
22 redone. Is that -- am I correct?

23 MR. TANEJA: Well, so their corrective
24 action was, when we build machine for the US-APWR --

25 CHAIR STETKAR: Yes. That's what I was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 going to say. What they did in the past is a bit of
2 a moot point as far as --

3 MEMBER BROWN: Well, no, it's not if they
4 actually --

5 CHAIR STETKAR: But they're taking a
6 different approach now.

7 MEMBER BROWN: Yes. I'm just saying, it's
8 not a -- it's not a moot point if they, in fact, tested
9 it.

10 MR. TANEJA: Correct.

11 MEMBER BROWN: They need the values and
12 documented in the manner that something has to be done
13 to get you through that hoop if they didn't.

14 And so now you're telling me, when they
15 build the units for APWR, the lead unit, whatever it
16 is, they're going to do something.

17 MR. TANEJA: Right.

18 MEMBER BROWN: And that something is --

19 MR. TANEJA: They are going to burn it in
20 for X number of hours --

21 CHAIR STETKAR: Well, they don't talk to
22 the Appendix B program --

23 MEMBER BROWN: Yes. They'll do it for the
24 Appendix B program.

25 CHAIR STETKAR: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: So that what -- does that
2 mean they will run the unit -- unit, okay, because you
3 don't do it to every unit, I guess, through a complete
4 Appendix B qualification program.

5 MR. TANEJA: Right.

6 MEMBER BROWN: So there will be no
7 shortcuts, there will be no loss of data --

8 MR. TANEJA: Right.

9 MEMBER BROWN: -- or anything like that.
10 So you will have that.

11 MR. TANEJA: Right.

12 MEMBER BROWN: And that's what's committed
13 to where? In the test report --

14 MR. TANEJA: In the DCD.

15 MEMBER BROWN: -- or in the DCD?

16 MR. TANEJA: DCD.

17 MEMBER BROWN: Yes, I'm looking at the
18 report right now, so I didn't see it.

19 MR. TANEJA: Yes. DCD says that the MELTAC
20 is a Class 1E Appendix B program.

21 CHAIR STETKAR: Built under Appendix B.

22 MEMBER BROWN: Okay.

23 CHAIR STETKAR: That's what I got from the
24 DCD.

25 MR. TANEJA: Right. So it's built under

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Appendix B program and now, as a result of this question
2 that we raised I believe MHI has committed to clean up
3 the documentation to kind of clarify that we are not
4 mostly dedicating any year, we are basically building
5 it under the Appendix B program.

6 You know, so let's see how the documents
7 get clean --

8 MEMBER BROWN: Okay. I just wanted to
9 understand --

10 MR. TANEJA: Right.

11 MEMBER BROWN: -- the flow of what you were
12 -- and put that in relation to the nonconcurrency. How
13 it is going to be resolved --

14 MR. TANEJA: Right.

15 MEMBER BROWN: -- as opposed to with
16 hand-waving.

17 MR. TANEJA: So, you know, the follow-up
18 to our inspection was, you know, like on that finding,
19 MELCOR committed to adding to their procedures a, you
20 know, actual documentation of the burning and of all
21 the cabinets.

22 The way they explained it to us is that the
23 existing cabinets, they actually, when they build it
24 and when they are testing it, it says it's
25 continuously-powered. It's getting burned-in all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 time, you know. So, that's what they take credit for,
2 versus actual, you know, --

3 CHAIR STETKAR: But Dinesh, I'm still
4 sitting here saying, "I don't care what they did in the
5 past."

6 MR. TANEJA: Right. That's right.

7 CHAIR STETKAR: I only care what they are
8 going to do for this --

9 MR. TANEJA: For the licensee.

10 CHAIR STETKAR: For the equipment that they
11 construct and install in our licensed US-APWR.

12 MR. TANEJA: Correct.

13 CHAIR STETKAR: I don't care what they did
14 in the past. And I don't care how they did it.

15 MEMBER BROWN: Well, but see, the problem,
16 John, is if you look at the table --

17 CHAIR STETKAR: I don't care --

18 MEMBER BROWN: No. Hold it.

19 CHAIR STETKAR: Okay.

20 MEMBER BROWN: Just let me finish. You'll
21 know that I'm talking about.

22 CHAIR STETKAR: Yes.

23 MEMBER BROWN: They have a column of
24 Appendix B based QAP requirements, and then there's
25 another column that says "Previous QAP," and there's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sporadic listings. Not covers everything, but a
2 sporadic listing, and I guess my concern is, is do they
3 view that as already saying they're okay, or is it, as
4 Dinesh is stating, they're going to redo those when they
5 build the next unit?

6 CHAIR STETKAR: I think in the technical
7 report you're seeing a snapshot in time with remnants
8 of an attempt to still try to justify commercial grade
9 dedication.

10 MEMBER BROWN: Well, I don't see them
11 rushing -- they're shaking their head up and down.

12 MR. SPRENGEL: No. I agree, and I think
13 the kind of adjustment that Dinesh is referring to is
14 in alignment with what -- what you are saying.

15 MEMBER BROWN: Yes.

16 MR. SPRENGEL: We are looking forward and
17 trying to clean up some of the language to kind of clarify
18 that -- that these are really future commitments and
19 a commitment for the ultimate kind of procured and
20 purchased, I guess, design to meet requirements that
21 are in the DC.

22 MEMBER BROWN: So, is part of that they
23 found they had to change something, you'd make a change
24 if it didn't pass?

25 MR. SPRENGEL: Correct. And it would be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 done under the existing community programs.

2 MEMBER BROWN: Yes. Okay.

3 MR. SPRENGEL: Right. And it's not to say
4 that the information that is in that technical report
5 won't be credited, but it will be part of the -- part
6 of the entire process.

7 MEMBER BROWN: Thank you.

8 MR. SCAROLLA: Excuse me, John. Can I make
9 --

10 CHAIR STETKAR: You may, Ken.

11 MR. SCAROLLA: Ken Scarolla. Well,
12 Charlie, I want to make sure there's no misunderstanding
13 here.

14 There was no issue --

15 MEMBER BROWN: You might make this worse.

16 MR. SCAROLLA: -- with regard to the type
17 testing the design.

18 MEMBER BROWN: There was no what? Say that
19 again.

20 MR. SCAROLLA: There was no issue in the
21 finding with regard to the type testing of the design,
22 qualification. This was a recurring burn-in for
23 production systems where there's a requirement for the
24 system to sit on the factory floor for some number of
25 weeks before you ship it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 This has nothing to do with a design test.

2 MEMBER BROWN: I understand that point.

3 MR. SCAROLLA: Okay.

4 MEMBER BROWN: Okay. I understand that
5 point, and the fact is, I like burn-in, okay, based on
6 personal experience.

7 MR. SCAROLLA: Okay.

8 MEMBER BROWN: So, I'm not going to -- I've
9 saved a lot of equipment by watching it explode on the
10 factory floor before we shipped it, so -- not "explode,"
11 but kind of melt down. So, burn-in does work.

12 I even turned TV's back into a Macey's at
13 one time because I took it home, started turning it on
14 and off and all of a sudden the solid state channel
15 changer broke. I just took it back to them. Thirty
16 days, but every day I operated it, cycled up and down,
17 took it back, got a new TV. It's amazing how it works.

18 They don't do that when they build TV's.

19 They just put them together and ship them.

20 MR. TANEJA: So you did the burn-in.

21 MEMBER BROWN: I did the burn-in. If you
22 do it in time, then you can get a new one.

23 CHAIR STETKAR: All right. That's --

24 MEMBER BROWN: Well, that one works. I'm
25 not kidding you. It's happened twice. I got two new

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 TV's out of that. Solid state TV's. So, that's why
2 I'm a fan of burn-in.

3 MR. TANEJA: All right. Well, you know,
4 we agree with you on that one.

5 CHAIR STETKAR: Well, that was the first
6 one. What's the second one?

7 MR. TANEJA: Second one has to do with the
8 basic software for the MELTAC. You know, so we -- the
9 issue is that, you know, I guess we are not evaluating
10 or -- you know, the -- you know, so our -- the basic
11 software program.

12 The basic software program is predeveloped
13 for MELTAC, so it's not something that needs to be
14 developed by US-APWR MHI. It's something.

15 So, I guess the concern was that, you know,
16 NRC should review and evaluate the software program
17 manual for the basic software, whereas -- I think maybe,
18 you know, Jung, you can elaborate on, you know, that
19 one -- you know, the concern the way you understood it
20 and what we need to do to wrap it up.

21 MR. TRUONG: I think the staff's concern
22 was the basic -- the basic SPM which was originally
23 docketed and later withdrawn.

24 CHAIR STETKAR: Can you just speak up a
25 little bit so that we --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Put the mic a little closer.

2 CHAIR STETKAR: Put the mic closer to you
3 or scream a little bit louder. Thank you.

4 MR. TRUONG: I think the staff will raise
5 the nonconcurrency had concern that the basic SPM which
6 was originally docketed, but then later was withdrawn,
7 you know, and the staff that wrote a nonconcurrency,
8 had concern that because it -- basically it's not been
9 reviewed, that the staff may not be able to assess the
10 software quality for the basic software which MHIS had
11 went over briefly, which is the systems, the system of
12 software.

13 CHAIR STETKAR: Okay. I think I
14 understand at least the concern, what's the -- what's
15 the resolution?

16 MR. TRUONG: So there's -- so staff wrote
17 a RAI, you know, and MHIB responded this week and we
18 will be evaluating the RAI.

19 CHAIR STETKAR: Okay. Is -- well, we'll
20 let the -- we'll let that process work itself out.

21 MR. TANEJA: Right. The question of the
22 RAI is how -- what we see on the slide, you know. And
23 the third issue was, you know, I guess controlling safety
24 components from, you know, nonsafety control
25 Operational VDU in this case.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And the concern is, you know, multiple-
2 fold, I guess, you cannot use nonsafety-related or
3 controlled safety-related components and, you know, so
4 --

5 CHAIR STETKAR: We had some discussion of
6 this yesterday.

7 MR. TANEJA: Right. So the -- you know,
8 I guess -- so the ITAAC, we -- you know, the action that
9 we were asked to take was to have the applicant provide
10 additional clarification on this connection that we have
11 between Operational VDU and the ESMS.

12 And one was the, you know, that results in
13 enhancement of safety function performance, you know,
14 a demonstration of that. You know, so that really is
15 words coming out of the ISG-4.

16 We use the ISG-4 as a guidance to evaluate
17 this connection, and I believe that's the only one that
18 remains to be, you know, verified. Others, we found
19 them to be --

20 MEMBER BROWN: And, of course, the adverse
21 effects you're -- it doesn't have any adverse -- that's
22 -- there's two pieces to that if I remember the
23 discussion.

24 MR. TANEJA: Right. There are two pieces
25 to that. Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: One that doesn't provide any
2 adverse effect --

3 MR. TANEJA: Right.

4 MEMBER BROWN: -- to the PSMS. The other
5 is that, even if it has no adverse effect, it should
6 provide whatever this -- and we had this discussion
7 yesterday. And what do we mean by "enhancement"?

8 MR. TANEJA: Right.

9 MEMBER BROWN: And there was -- you know,
10 if it's neutral, does it mean that you can't do it or
11 does it have to have some significant benefit, like
12 reducing complexity of operations or something.

13 MR. TANEJA: Right.

14 MEMBER BROWN: And that's the part that's
15 open yet for your evaluation?

16 MR. TANEJA: Correct.

17 MEMBER BROWN: And that's an active open
18 item at the present time?

19 MR. TANEJA: That is an active open item,
20 right.

21 CHAIR STETKAR: Does that -- okay. Does
22 that -- but that somehow relates also to the concern
23 about no failures in PCMS resulting in anything that
24 has been not analyzed in Chapter 15, doesn't it?

25 MR. TANEJA: Sort of, because --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Aren't they related
2 somehow?

3 MR. TANEJA: -- you know, PCMS is also
4 connected on the unit bus.

5 CHAIR STETKAR: Yes. I mean --

6 MR. TANEJA: Right.

7 CHAIR STETKAR: -- last I checked, an O-VDU
8 is part of the PCMA.

9 MR. TANEJA: Right. So, the way we
10 evaluated the connection from operational VDU to PSMS
11 is that the PSMS has the protective features built into
12 it which protects itself against anything bad coming
13 in. Right?

14 So, that's really our focus of review here,
15 was to look at the -- the shield that's built around
16 the PSMS that protects itself from something penetrating
17 that.

18 Okay. I only want what I want. I don't
19 want anything undesirable. So, that's what I asked you
20 for guidance, provided us the tools to evaluate that
21 interface.

22 The PCMS failure is more of a system-level
23 discussion, and if systems fail --

24 CHAIR STETKAR: Yes. Okay. Yes. Okay.

25 MR. TANEJA: -- right, how do they affect.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So, here we are talking about data
2 communication. There we are talking about systems.

3 MEMBER BROWN: Well, but the operational
4 VDU also connects through the COM system down to the
5 safety bus which --

6 MR. TANEJA: That's really what we are
7 talking about here.

8 MEMBER BROWN: That's what he's talking
9 about here --

10 MR. TANEJA: Yes. Right.

11 MEMBER BROWN: -- in this specific --

12 CHAIR STETKAR: Well, from the PCS, but
13 that's -- the safety bus is part of the PSMS.

14 MR. TANEJA: True.

15 MEMBER BROWN: So it does have a direct
16 connection to that and --

17 MR. TANEJA: It does.

18 MEMBER BROWN: -- so that's -- that's where
19 you needed to look at that from a shield standpoint.

20 MR. TANEJA: Right. Exactly.

21 MEMBER BROWN: I want to make sure that's
22 what we're talking about.

23 MR. TANEJA: Got it.

24 MEMBER BROWN: So you're satisfied that it
25 does not provide -- it does not adversely affect the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 PSMS by being a direction action. There's no mode, no
2 failure mode of the O-VDU that -- that could impact or
3 impair the performance of the safety bus in performing
4 demands made from -- onto it from the PSMS?

5 MR. TANEJA: I believe you've done a lot
6 of looking in that area. You know, we -- actually, the
7 audits and the inspections we did, we spent a lot of
8 time on that part of it, that special led interface
9 issues.

10 MEMBER BROWN: And you think it's okay?

11 MR. TANEJA: And, you know, like I said,
12 you know, we use the ISG-4 -- I mean, reason -- you know,
13 reasonable assurances there. I mean, I can never say
14 a hundred percent sure.

15 MEMBER BROWN: Did you come --

16 MR. TANEJA: Yes.

17 MEMBER BROWN: -- to your conclusion, yes,
18 it's a reasonable assurance --

19 MR. TANEJA: It's a reasonable assurance.

20 MEMBER BROWN: -- you quit working on that
21 now?

22 MR. TANEJA: Yes. It's reasonable
23 assurance and that's it.

24 MEMBER BROWN: That should be a yes or a
25 no.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. TANEJA: Yes. Right.

2 MEMBER BROWN: Okay. The only one open is
3 the enhancement part?

4 MR. TANEJA: Right.

5 MEMBER BROWN: Okay. I just wanted to make
6 sure where you all stood right now.

7 MR. TANEJA: Right.

8 MEMBER BROWN: Sorry. I just needed to
9 make sure I --

10 CHAIR STETKAR: No, no. That's --

11 MEMBER BROWN: -- understood that point.

12 CHAIR STETKAR: That is important.

13 MR. TANEJA: Right. So that's really the
14 three issues. And so we have those as an open item and
15 we are going to work through this process that our
16 management -- and let the -- you know, let the NRC's
17 Management Directive, you know, handle, you know, how
18 we handle this nonconcurrency.

19 And this step concludes our presentation
20 and we really thank you for your feedback and I'm open
21 for any discussion or comments at this time.

22 CHAIR STETKAR: Thank you. Do any of the
23 members.

24 MEMBER BROWN: Yes. Just one -- just, when
25 you say "finish it," I presume that at some point

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 management, then, has to agree with your conclusions
2 that this other stuff, when you finish -- when you
3 resolve the nonconcurrency within the management
4 structure in accordance with the nonconcurrency
5 process.

6 MR. TANEJA: Right. So what we have on the
7 nonconcurrency process is an actions that we need to
8 take.

9 MEMBER BROWN: Okay.

10 MR. TANEJA: So I need to provide feedback
11 to my management the result of the action that we have
12 taken.

13 MEMBER BROWN: And they have to agree?

14 MR. TANEJA: And they have to agree with,
15 you know, what we come up with.

16 CHAIR STETKAR: Oh, they have to -- right
17 now it's in the context of open items.

18 MEMBER BROWN: Yes. I understand --

19 CHAIR STETKAR: Under the SER --

20 MEMBER BROWN: I just --

21 CHAIR STETKAR: -- and those open items
22 will be resolved through the normal process of --

23 MEMBER BROWN: The final, the final
24 process.

25 CHAIR STETKAR: -- of, you know, closing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 out open items. The nonconcurrency, itself, is my
2 understanding, is -- has been disposed of. Let me just
3 put it that way.

4 MR. TANEJA: Yes.

5 CHAIR STETKAR: So there's no feedback to
6 the nonconcurrency. It's now in the context of these
7 open items. Right, Ian?

8 MR. JUNG: That is correct, John. The only
9 thing to add is the final SER, the Phase 4 stage. The
10 resolution of these open items would be documented.

11 CHAIR STETKAR: Right.

12 MR. JUNG: The nonconcurring individual
13 has an opportunity --

14 MEMBER BROWN: Sure. That's --

15 MR. JUNG: -- to agree and disagree and gets
16 another opportunity --

17 MEMBER BROWN: Right. Right.

18 MR. JUNG: -- to express their views.

19 CHAIR STETKAR: Because that individual is
20 still part of the status --

21 MR. TANEJA: Correct. After that decision
22 is made with FSER, the individual and anybody else could
23 raise through the EPO process --

24 CHAIR STETKAR: Right.

25 MR. TANEJA: -- if they have any --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Okay. I just wanted to make
2 sure whoever that, somehow that non -- management
3 decision still got fed back and still was subject to
4 additional discussion --

5 MR. TANEJA: Yes. Oh, yes.

6 MEMBER BROWN: -- within that process with
7 the nonconcurring individual.

8 CHAIR STETKAR: Or anybody else involved.

9 MEMBER BROWN: Or anybody else.

10 CHAIR STETKAR: You know, someone --

11 MEMBER BROWN: Exactly. Got it.

12 CHAIR STETKAR: -- else involved in the
13 review might disagree --

14 MEMBER BROWN: Okay.

15 CHAIR STETKAR: -- with -- with the
16 close-out of one of these particular open items.

17 MEMBER BROWN: That's all I have.

18 CHAIR STETKAR: Anything else for the
19 staff?

20 If not --

21 MR. TANEJA: I have one thing that --

22 CHAIR STETKAR: -- some folks that we had
23 some feedback, so let's hear that.

24 MR. TANEJA: Khoi has the list that you
25 asked us which safety functions -- or which nonsafety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 functions are coming wire-hardwired.

2 CHAIR STETKAR: Oh.

3 MR. TANEJA: Okay?

4 CHAIR STETKAR: Good.

5 MR. TANEJA: So, you know, that is a -- you
6 know, RAI -- I mean, response to the RAI which is an
7 update to the Chapter 7.

8 CHAIR STETKAR: This real is full. Thank
9 you.

10 MR. TANEJA: These are not all, but these
11 are the significant ones.

12 CHAIR STETKAR: Significant ones.

13 MR. TANEJA: Significant one, I guess I
14 should say.

15 CHAIR STETKAR: I've learned not to use
16 words like "all" and "none."

17 MEMBER BROWN: So these will be -- this will
18 be part of Rev 4 of the DCD?

19 MR. TANEJA: Yes.

20 MEMBER BROWN: Okay.

21 MR. TANEJA: Yes. They are part of the Rev
22 4. And in the -- can we go over this list now or --

23 CHAIR STETKAR: I don't think -- in the
24 interest of time. We're trying to get through Chapter
25 7 and COL Chapter 2 Sections, and get people out for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 airplanes.

2 So, as long as the subcommittee members
3 agree, I think we can look at this list, and if we have
4 questions about it, we can -- we can get back to you.

5 MR. JUNG: Yes, John. We'll -- we are --
6 we developed a list of action items. We will work with
7 Girija and the committee to make sure we are capturing
8 all your action items.

9 CHAIR STETKAR: Great. I think that's --
10 that's the most time-effective way to treat it.

11 MR. TANEJA: Okay. All right.

12 CHAIR STETKAR: And I really appreciate
13 getting us the list this quickly.

14 MEMBER BROWN: Now, to read this paper,
15 just -- this is a summary of the items here, the first
16 page?

17 MR. TANEJA: The first page --

18 MEMBER BROWN: And the other part is --

19 MR. TANEJA: In the DCD.

20 MEMBER BROWN: -- in the DCD.

21 MR. TANEJA: Yes.

22 MEMBER BROWN: That's the Rev -- Rev stuff.

23 Okay.

24 CHAIR STETKAR: Anything else?

25 (No response.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Nothing? If not, thank
2 you very much. You covered a lot of material. I really
3 appreciate the -- the shortcuts that you took to get
4 through the slides and get us in some reasonable sense
5 of schedule, and I think we had a good discussion.

6 So, I really appreciate that. Thank you
7 very much.

8 MR. TANEJA: Thank you. Thank you.

9 CHAIR STETKAR: What we'll do now is, MHI,
10 I believe, had some number of items that you wanted to
11 respond to.

12 MEMBER BROWN: Somebody is standing at the
13 mic. Do you want him up front, or do you --

14 CHAIR STETKAR: No. He can stand.

15 MEMBER BROWN: He can stand back there.
16 That's fine.

17 CHAIR STETKAR: So the longer he stands and
18 the less comfortable he is, the happier I am.

19 MR. LYNN A portion of the people can't see
20 me back here, so I'm okay.

21 CHAIR STETKAR: Just identify yourself and
22 speak with sufficient clarity and volume.

23 MR. LYNN This is Kevin Lynn from MNES.
24 I wanted to clarify one of the questions you asked
25 yesterday in regard to reactor vessel water level.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 You'd identified in one section of the DCD,
2 and then there was a table in the DCD, and it seemed
3 like there was an inconsistency between the two.

4 The DCD section referred to the water level
5 of the reactor vessel from the top of the fuel alignment
6 plate to the reactor vessel head, whereas the DC table
7 said the bottom of the hot leg to the top of the vessel.

8 In MHI's phraseology, the top of the fuel
9 alignment plate is the same as the upper core plate which
10 is at the bottom of the hot leg.

11 CHAIR STETKAR: Oh. Okay.

12 MR. LYNN: So the two descriptions are --

13 CHAIR STETKAR: Okay.

14 MR. LYNN -- identical in application,
15 although different terms are used.

16 CHAIR STETKAR: Okay. So that level
17 indication just tells me I'm below the bottom of the
18 hot leg?

19 MR. LYNN Yes.

20 CHAIR STETKAR: Okay.

21 MR. LYNN: If it was zero, then you would
22 know that it was --

23 CHAIR STETKAR: If it was zero. Okay.

24 MR. LYNN: -- below that --

25 CHAIR STETKAR: Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Anything else?

2 MS. SASAKI: I am Hitomi Sasaki, Mitsubishi
3 Electric Corporation. I'll explain about this DOE.
4 Would you have a look at yesterday's presentation
5 material, Sheet No. 81. Sheet No. 81.

6 CHAIR STETKAR: Okay.

7 MS. SASAKI: I will explain what --

8 CHAIR STETKAR: Give us a chance. We are
9 old. At least I am. Okay. I have the slide now.
10 Thanks.

11 MS. SASAKI: It's DOE's --

12 CHAIR STETKAR: Yes.

13 MS. SASAKI: -- presentation material.

14 CHAIR STETKAR: Yes.

15 MS. SASAKI: First, I'd like to say these
16 DC -- these two system incorporate electric card COM
17 system CAS, and development environment, nuclear
18 dedicated system.

19 CHAIR STETKAR: Okay.

20 MS. SASAKI: Next, CAS points in
21 development environment points extreme. I will
22 explain.

23 CAS points these one, two, three, four, five
24 -- five points. One point, stores basic software and
25 the application software. Two point, access control

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 by password. Three point, physical security. Four
2 point, system does not allow, prior delete or change
3 only.

4 Part one, POD backup. And additional one
5 point, I'd like to use -- CAS is isolated from the
6 corporate network.

7 Next, development environment, three
8 points. One point, access control to development
9 machine by password. Two point, entry/exit control of
10 the development area. Three point, isolated it from
11 the corporate network.

12 CHAIR STETKAR: Okay.

13 MS. SASAKI: My explanation is all.

14 CHAIR STETKAR: Okay. Thank you. And I
15 think we heard from the staff this morning that -- that
16 they are going to actually look into this a little bit
17 more and make sure that they have --

18 MEMBER BROWN: Yes.

19 CHAIR STETKAR: -- satisfaction that it,
20 indeed, is a plausible control --

21 MEMBER BROWN: Yes. This is the same thing
22 we talked about yesterday, but --

23 CHAIR STETKAR: -- environment, so.
24 Unless the staff has anything to add --

25 MR. TRUONG: I just want to ask -- so,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 yesterday's conversation it was brought up, perhaps,
2 that other projects besides nuclear, but now you are
3 confirming that it's only nuclear. It is only US --
4 US-APWR projects?

5 CHAIR STETKAR: I think she's -- I think
6 she said only nuclear. She -- I didn't hear only
7 US-APWR.

8 MR. SPRENGEL: That's correct.

9 CHAIR STETKAR: I think -- I think we've
10 heard --

11 MR. SPRENGEL: That's a point of
12 clarification --

13 CHAIR STETKAR: -- both things and it's my
14 -- in the interest of time here --

15 MEMBER BROWN: They ought to resolve that
16 separate --

17 CHAIR STETKAR: -- I think the staff can
18 --

19 MR. SPRENGEL: Are there any other, I guess
20 --

21 MEMBER BROWN: No. My fundamental issue
22 is --

23 MR. SPRENGEL: Had a good control --

24 MEMBER BROWN: -- archiving -- who has
25 access to the archiving area. Not arguing with all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 other, you know, points that are made. They were here
2 yesterday about passwords.

3 I mean, we can argue about how good is
4 password security all day.

5 MR. SPRENGEL: Sure.

6 MEMBER BROWN: That can be hacked by almost
7 anybody that's halfway smart if you're
8 computer-literate.

9 So -- not me, per se, because I couldn't
10 do it but they -- the issue is how many people have access
11 via their passwords to get into this database, and what
12 is the accessibility of multiple databases within this
13 archive, because it's electronic. So, you know --

14 MR. JUNG: John, the staff will take this
15 as an action and they will work with MHI, too.

16 MEMBER BROWN: Yes. Yes.

17 CHAIR STETKAR: Yes. I mean, that sounds
18 like --

19 MEMBER BROWN: Okay.

20 CHAIR STETKAR: I think that it -- there's
21 some assurance from what we heard this morning that it
22 isn't quite as open as -- as we may have thought
23 yesterday, but I think it still merits a little bit of
24 discussion.

25 MR. SPRENGEL: Okay. And then the last

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 topic, I think it's more for clarification. It's on
2 the -- it's the load rejection for -- is it turbine
3 bypass? -- for turbine bypass control.

4 I wanted to understand better what -- I have
5 some more details on it, but I'm not sure what the real
6 concern is.

7 CHAIR STETKAR: That -- that actually --
8 in sense -- Ryan, that was more my curiosity. It is
9 not -- in the purview of the ACRS, it is not a safety
10 issue.

11 MR. SPRENGEL: Okay.

12 CHAIR STETKAR: I was just curious because
13 I understand that your plant is designed to
14 automatically run back to island mode operation.

15 Whether it successfully does that or not,
16 quite honestly, in my mind, is not a safety concern
17 because, if it doesn't, the reactor is going to trip.
18 It's not an unanalyzed type of event.

19 I just couldn't figure out from the
20 information that I saw in the drawings how -- how it
21 would actually accomplish that run-back and, you know,
22 maintain generation.

23 But that's -- that's not, in my mind,
24 anyway, a safety concern.

25 MR. SPRENGEL: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: So, I -- I personally,
2 since I raised the question, I don't personally feel
3 it's necessary to -- to follow-up on that. It's more
4 a curiosity --

5 MR. SPRENGEL: Okay.

6 CHAIR STETKAR: -- as I was trying to
7 understand that --

8 MR. SPRENGEL: Okay. Well, what I'd like
9 to do, then, and it might be along the way, but we have
10 additional detail that's actually in Chapter 10, but
11 it's not showing up until Rev 4.

12 CHAIR STETKAR: Okay.

13 MR. SPRENGEL: Of the DC --

14 CHAIR STETKAR: Great. Thank you. That
15 -- that will help.

16 MR. SPRENGEL: So, we'll track that and --

17 CHAIR STETKAR: Sure.

18 MR. SPRENGEL: -- keep it as an item for
19 our -- the next time we interact for Chapter 10 as a
20 discussion point you will have --

21 CHAIR STETKAR: Great.

22 MR. SPRENGEL: -- just to -- it adds more
23 detail on that. And if you want to know, the Section
24 is 10.2.2.3.1.5.

25 CHAIR STETKAR: 10.2.2.3.1.5.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SPRENGEL: Yes. And again, that will
2 be coming in in August.

3 CHAIR STETKAR: Yes. Thank you.
4 Anything else?

5 MR. SPRENGEL: Nothing else on our side.

6 CHAIR STETKAR: Okay. What I'd like to do
7 is -- because we've -- we've been at Chapter 7 for the
8 DCD now for an awfully long time -- is ask if we have
9 any members of the public or anyone in the room who would
10 like to make any comments, in particular related to
11 Chapter 7 of the DCD.

12 We have the bridgeline open. Is there
13 anyone out there? If we can open the bridgeline so I
14 can ask for comments. It just -- it just helps, rather
15 than waiting till the end to get through the COL and
16 Chapter 2 if we close out any comments on this particular
17 subject.

18 It's a low-budget operation. We -- we
19 don't have any indications when it's open. I -- someone
20 has to come in and say they think it's open. With
21 Sequestration, we're going to install Campbell soup cans
22 in individual strings throughout the United States.
23 We'll know it better then.

24 Okay. Thank you.

25 PARTICIPANT: -- show the line is open.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR STETKAR: No, great. Thanks a lot.
2 I appreciate that because, as I said, we don't have
3 any other indications.

4 So, is there anyone out there? We now know
5 the line is open. Is there anyone out there who does
6 have a comment or a question?

7 (No response.)

8 CHAIR STETKAR: Okay. Hearing none, we
9 will re -- we will reclose the bridgeline and put it
10 on mute -- Thanks Girija. -- and call Luminant up to
11 hear about the COL Chapter 7, which I trust will be
12 somewhat less complex.

13 And, Don and Bob, I'll just remind you, just
14 be careful of those microphones when you're shuffling
15 things up there. It's really difficult for our
16 recorder.

17 Don, it's yours.

18 MR. WOODLAN: Well, I was going to say good
19 afternoon, but I'll probably say good morning.

20 I'm Don Woodland. I'm the licensing
21 manager for Luminant and we are here to present Chapter
22 7 from the -- our COL application for Comanche Peak Units
23 3 and 4.

24 As Bob is going to address, Chapter 7 is
25 primarily a chapter where we've incorporated, adopted

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the design information from the standard plant design
2 for the US-APWR.

3 There are a few locations where there is
4 site-specific information that needs to be provided to
5 supplement the standard plan information, and that's
6 what Bob Reible is going to present.

7 Bob.

8 MR. REIBLE: Thank you.

9 My name is Bob Reible. I'm the lead for
10 Chapter 7. Today we're going to discuss three specific
11 areas and introduction, site-specific aspects and then
12 a short summary.

13 The COL uses incorporated-by-reference
14 methodology, and for FSAR, Chapter 7, there are no
15 departures from the US-APWR DCD.

16 The current version of the CPNPP COLA is
17 Revision 2 which was June of 2011, and the next revision
18 is Revision 3, which is due in June of 2013.

19 MR. WOODLAN: No. Rev 3 was filed in June
20 of 2012. Right?

21 MR. REIBLE: No. Is our slide incorrect?

22 MR. WOODLAN: No. The slide is correct.

23 CHAIR STETKAR: The slide is correct. We
24 have Rev 3.

25 MR. WOODLAN: They have Rev 3.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. REIBLE: Okay.

2 MR. WOODLAN: Rev 4 is coming out in
3 November.

4 CHAIR STETKAR: November of this year?

5 MR. WOODLAN: Of this year. Correct.

6 MR. REIBLE: Right. Excuse me.

7 MR. WOODLAN: That's all right.

8 MR. REIBLE: And there no contentions
9 pending before the ASLB.

10 The following sections of the Chapter 7 are
11 a hundred percent IBR. That's Section 7.0, 7.1, 7.2,
12 7.3, 7.6, 7.7, 7.8 and 7.9 with no departures for
13 supplements.

14 Section 7.4, Systems Required for Safe
15 Shutdown is IBR with the following site-specific
16 editions. The editions are related to the normal
17 components and indication that would be necessary for
18 safe shutdown. These editions would be related to the
19 ultimate heat sink. The NRC SER summary has no
20 outstanding issues.

21 For Section 7.5, Information Systems
22 Important to Safety is IBR with the following
23 site-specific editions. Section 7.5 editions are the
24 D PAM variables, performance of safety systems and the
25 E PAM variable meteorology monitoring and radiation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 protection or core radiation protection associated with
2 site-specific components and monitoring.

3 These postaccident sampling variables are
4 associated with the site-specific normal components
5 associated with the ultimate heat sink and the EOF,
6 emergency operations facility.

7 In addition, there is a short section
8 discussion of the space in the displays that are found
9 in the emergency operations facility and in the
10 technical support center.

11 The NRC SER summary has no outstanding
12 issues.

13 CHAIR STETKAR: Well, that was short. The
14 bad news is, I have a couple of questions.

15 On the EOF description it says, "Displays
16 associated with CPNPP Units 3 and 4 are common to both
17 units with a multidisplay selection -- with a unit
18 display selection capability."

19 That gives me the impression is you have
20 one set of displays and if I want to see what's going
21 on in Unit 3, I have a switch in one position and if
22 I want to see what's going on in Unit 4, I switch over
23 to see what's going on in Unit 4. Is that correct?

24 MR. REIBLE: It's my understanding that
25 that's going to be modified because the requirements

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of the EP rule now are that you have the ability to
2 display both units at the same time or all four units
3 at the same time.

4 CHAIR STETKAR: Okay. So you're actually
5 --

6 MR. REIBLE: Yes. Our anticipation is
7 that --

8 CHAIR STETKAR: Okay.

9 MR. REIBLE: -- we will have displays for
10 all four units.

11 CHAIR STETKAR: I was going to raise the
12 question in the context of post-Fukushima, but it --
13 it comes up in several different venues.

14 So, you are expecting to change that.
15 Thank you.

16 MEMBER BROWN: When do you expect to do
17 that? I mean, you say "expecting to do that." Does
18 that mean you're going to do it or you're just thinking
19 about it?

20 MR. REIBLE: No. We are going to do it.
21 We are in the process of doing it on our operating units
22 right now.

23 MEMBER BROWN: Okay. That's fine. I just
24 -- I was confused between the word "expecting" --

25 MR. REIBLE: Sorry.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: -- as opposed to "doing."

2 MR. REIBLE: Thank you.

3 MR. SHUKLA: The EP rule has a deadline.

4 MEMBER BROWN: Yes. That's fine. We
5 don't need to -- we're done.

6 CHAIR STETKAR: I just wanted to make sure
7 that, if --

8 MEMBER BROWN: I got it.

9 CHAIR STETKAR: -- they were doing it,
10 when. Then, I understand the expectation versus
11 commitment in a public meeting. So, that's fine.

12 The other question that I had, because I
13 do take notes, and MHI, yesterday, had their Slide 8,
14 which shows their -- their current design for protecting
15 essentially communications between the unit and the
16 station bus and communications between the station bus
17 and the outside world, separated.

18 And their -- their slides, just for
19 reference, shows that the station bus communicates to
20 the EOF and the ERDS system but, in particular, I was
21 thinking about the EOF because, obviously, the EOF is
22 shared among all four units now.

23 And the question I raised yesterday, and
24 they said, "Well, it's a COL issue," so I'll raise it
25 to Luminant, is -- what protections are available on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 -- is there a single station bus, and is there a
2 protection provided that prevents information coming
3 in from the outside world, let's say, on the Unit 2 part
4 of that station bus propagating back through?

5 Now, supposedly, the protections that they
6 show between the Unit 3/4 unit bus and the station bus
7 would prevent that from coming back to Units 3 and 4.

8 But I was just curious what -- whether there are
9 protections over on the Unit 1 side that are similar
10 -- functionally similar to what's shown now on the Unit
11 3/4 side, in particular on the station bus.

12 MR. REIBLE: Yes. And the answer to that
13 is, yes, there are. The protections are very similar
14 to what is being proposed by Mitsubishi.

15 There is a deterministic isolation device
16 between the control aspects and then for -- between the
17 EOF and the outside, there is a deterministic --

18 CHAIR STETKAR: Okay.

19 MR. REIBLE: -- isolation valve.

20 CHAIR STETKAR: Okay.

21 MEMBER BROWN: When you say
22 "deterministic" you mean hardware, one-way?

23 MR. REIBLE: Yes.

24 MEMBER BROWN: Similar to what is shown
25 that --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. REIBLE: Exactly.

2 MEMBER BROWN: -- connect any external
3 networks --

4 MR. REIBLE: Right.

5 MEMBER BROWN: -- it's just separate from
6 the one that would be around for the Units 3 and 4?

7 MR. REIBLE: That's correct.

8 MEMBER BROWN: Okay. So it's there today.

9 CHAIR STETKAR: Yes. That was the only
10 question in terms of --

11 MEMBER BROWN: Yes. Yes, this is a
12 hangover --

13 CHAIR STETKAR: So that's --

14 MEMBER BROWN: -- from yesterday.

15 CHAIR STETKAR: -- that's good. Thank
16 you.

17 Any of the members have any questions for
18 MHI? I'm sorry. Whoever you are. Luminant. I've
19 spent a week here in the last two days.

20 (No response.)

21 CHAIR STETKAR: If not, thank you very
22 much. And you actually got to answer some questions,
23 so that was exciting.

24 And we'll have the staff come up on the COL
25 Chapter 7.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. MONARQUE Okay. Good morning, my name
2 is Stephen Monarque. I'm the lead project manager for
3 Comanche Peak safety review application, and today I'm
4 going to do the staff's presentation on the safety
5 evaluation report for Chapter 7, Instrumentation and
6 Controls.

7 I'm the lead project manager for this
8 combined license application review, and Bill Ward was
9 a project manager, and Eugene Eagle was a technical
10 reviewer for the Instrumentation Controls Branch.

11 There were no open items, as Luminant
12 described earlier. Most of the sections were IBR with
13 the exception of 7.4, 7.5, which is systems required
14 for safe shutdown and information systems important to
15 safety.

16 And with that, that concludes our
17 presentation. We're now ready for any questions.

18 CHAIR STETKAR: This may be a record.

19 MR. MONARQUE I'm glad they --

20 CHAIR STETKAR: No. In terms of number of
21 slides. Usually we get some -- some more introduction
22 -- thank you very much.

23 Seriously, any -- any questions for the
24 staff?

25 (No response.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: If not, Stephen, thank you.

2 MR. MONARQUE Thank you.

3 CHAIR STETKAR: And I believe that closes
4 out the discussion of Chapter 7 for both the DCD and
5 the COL.

6 MR. MONARQUE I need to get the reviewers
7 for Chapter 2, if you wish to commence on that.

8 CHAIR STETKAR: Yes. We'll -- we'll take
9 a break. Is 15 minutes long enough for you to do that?

10 MR. MONARQUE Yes.

11 CHAIR STETKAR: Okay. Before we do -- do
12 that, I mean, start summoning them.

13 As we usually do, I'll go around the table
14 and see, at least for the Chapter 7 part of the
15 proceedings.

16 Do members have any final questions or
17 comments? Joy?

18 MEMBER REMPE: No.

19 CHAIR STETKAR: Charlie?

20 MEMBER BROWN: Just one relative to --
21 there's going to be a final SER, obviously --

22 CHAIR STETKAR: Yes.

23 MEMBER BROWN: -- and since there's open
24 items. And the -- at least a couple of items that I
25 discussed yesterday on the watchdogs and the -- now,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I've forgotten what the other one was. Whatever it was,
2 it was written down. It's on my sheet.

3 Oh, the control of access, which they said
4 they would have upgraded. I'm presuming that we will
5 get to see the final setup, how those are finally
6 resolved.

7 CHAIR STETKAR: Yes. No, we -- we will
8 -- the ACRS must write a letter --

9 MEMBER BROWN: Yes.

10 CHAIR STETKAR: -- based on the final SER.

11 MEMBER BROWN: I was just trying to make
12 sure I knew where we were relative to that. I know we're
13 not going to do one right now, and I just -- because
14 I did want to see the final results in the DCD as to
15 how these were shown for execution purposes on the
16 watchdog as well as seeing it finally cranked in on the
17 control of access thing.

18 CHAIR STETKAR: The whole purpose of having
19 these exchanges on the Draft SER with Open Items is for
20 subcommittee members and the ACRS, through our interim
21 letters, to provide some -- some early feedback to the
22 staff in terms of areas of concern.

23 And the staff and MHI will work toward
24 closing out the existing open items if they feel they
25 need to issue additional RAI's as a result of these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 discussions. They'll -- they'll issue them.

2 In some cases, you know, we get feedback
3 directly from the staff or from MHI to answer questions
4 where -- where they feel sufficient information is
5 available.

6 But, in answer to your concern, we certainly
7 do get another opportunity to review the entire final
8 SER.

9 MEMBER BROWN: Good.

10 CHAIR STETKAR: And I can raise -- you know,
11 if we don't feel our current concerns are resolved by
12 that point we can --

13 MEMBER BROWN: Have another try.

14 CHAIR STETKAR: -- keep them open and --
15 and we have the opportunity to raise additional concerns
16 at that time. So, we're not done with this by a long
17 shot.

18 MEMBER BROWN: Okay. Other than that, I
19 -- you know, the only other comment is I wanted to thank
20 MHI and the presenters. They really did put together
21 a good presentation which clarified and made very clear
22 what was going on, made sure we understood -- I
23 understood it, and that was good. That's a real plus
24 on this review.

25 MEMBER SHACK: I will just echo Charlie's.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I mean, yesterday's discussions were very helpful for
2 a nonexpert.

3 CHAIR STETKAR: And I will say the same
4 thing. I -- I -- you know, I'm sorry we ran over in time,
5 but I think it was well worth the time spent. I --
6 especially MHI. I really appreciate the effort you put
7 into all of the presentations, your ability to answer
8 our questions here. I think we -- we really appreciate
9 that.

10 I think it -- it helped our confidence, both
11 in the understanding of the design and I hope it helped
12 you to -- to hear a few of our concerns, and I think
13 it was a really useful process.

14 With that, I will take a break and hopefully
15 the staff can get your Chapter 2 reviewers here in a
16 timely manner, and we will recess until 10:10.

17 (Whereupon, a short recess was taken from
18 9:54 a.m. until 10:12 a.m.)

19 CHAIR STETKAR: We are back in session.
20 We are going to hear about the Comanche Peak Combined
21 License Application, in particular FSAR Sections 2.0,
22 2.1, 2.2, 2.3.

23 I understand that the remaining sections
24 of Section 2 will come in at some later date. We're
25 not quite sure when that will be yet. We don't have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 it on the -- on our agenda, anyway.

2 With that, Don, welcome back.

3 MR. WOODLAN: Thank you.

4 CHAIR STETKAR: It's been a long time.

5 MR. WOODLAN: Thanks, John.

6 We are ready to go. As you pointed out,
7 we are presenting a portion of Chapter 2, primarily
8 regarding the site characteristics.

9 As the title implies, this is not as IBR,
10 as many of our other sections. We do have quite a bit
11 of site-specific information in there.

12 The general agenda we are going to follow
13 is our standard agenda. We will start with an
14 introduction. We do have one SER open item that we'll
15 discuss and then we will get into a summary or a high
16 level overview of the site-specific information
17 provided.

18 In our introduction, again, we do follow
19 the IBR methodology, and there is material that is
20 incorporated from the standard plant design. We are
21 taking no departures from the standard plant design in
22 these sections.

23 All COL items that were included in this
24 -- in the standard plant are -- have been addressed
25 in the FSAR.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 As I mentioned, we have one open item, SER
2 open item. We have no confirmatory items that remain,
3 and we have no contentions pending before the ASLB.

4 I'll address the open item first. The open
5 item really was initiated by us from the standard plant.

6 There was a -- some changes made to the layout of the
7 standard plant, and those were made to address seismic
8 concerns.

9 Those changes, however, do affect some of
10 our dispersion calculations in that those are very
11 location-dependent so if a discharge point moves a
12 couple feet, that changes the calculation. We need to
13 adjust the calculation to address that.

14 We have done all those adjustments. We
15 have updated the tables in the FSAR, and that information
16 has been provided to the staff. All the differences
17 were very minor. Second decimal point kind of thing.

18 CHAIR STETKAR: Did you have to move the
19 buildings around very much?

20 MR. WOODLAN: We -- well, we personally
21 didn't move them, but the standard plant did. They --
22 you may remember the power block was a multiple set of
23 buildings and they moved it into a single power reactor
24 building complex now.

25 CHAIR STETKAR: Oh, hum.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WOODLAN: And so that, as a result, some
2 of the buildings moved two or three feet, maybe. Some
3 of the discharge points elevations may have changed a
4 couple feet.

5 MEMBER BLEY This is for the regular, the
6 --

7 CHAIR STETKAR: That's -- that's for -- and
8 it's in the certified design now?

9 MR. WOODLAN: Yes.

10 CHAIR STETKAR: So it's not a
11 site-specific.

12 MR. WOODLAN: That's correct. It's part
13 of what we are IBR'ing.

14 CHAIR STETKAR: Okay.

15 MR. WOODLAN: And I assume that will all
16 be presented once we get to the site --

17 CHAIR STETKAR: That will be --

18 MR. WOODLAN: -- presentations.

19 CHAIR STETKAR: Yes. Well, we haven't
20 heard that part of the DCD yet, either --

21 MR. WOODLAN: Right.

22 CHAIR STETKAR: -- in terms of seismic.
23 So, thank you.

24 MR. WOODLAN: With that, I'm going to cover
25 2.0. We had a choice. I had the first choice, so I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 picked 2.0.

2 And the primary, I think, points of interest
3 there are the key parameters in the DCD. There are a
4 set of parameters which were used to complete the
5 standard plant design, and the site-specific
6 applications are supposed to confirm that we're within
7 those bounds, therefore, justifying that the standard
8 plant analyses are applicable to us and do apply.

9 And we have done that, and the table shows
10 that. I will state that some of the material in there
11 is still ongoing. Some numbers, I expect, are going
12 to change, and we're -- we're following that.

13 We update the -- the DCD -- as the DCD gets
14 updated, we do update the FSAR to correspond to that.

15 And I know of nothing, no changes at this point in time
16 in which we do not remain bounded by the standard plant
17 parameters.

18 With that, we'll move to 2.1 and I'm going
19 to turn it over to Tim Clouser.

20 Tim.

21 MR. CLOUSER: Good morning. As Don said,
22 I'm Tim Clouser. I'm going to talk just briefly about
23 Section 2.1 and then I'll turn it over to Bob Reible
24 for Section 2.2 and then I'll come back for 2.3 and wrap
25 it up.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So, a proposed site for --

2 MR. WOODLAN: And then go catch an
3 airplane.

4 MR. CLOUSER: Hopefully, because it may
5 actually be delayed again.

6 Our proposed site for Units 3 and 4 is
7 co-located with our Unit 1 and 2 site. We are located
8 in North Central Texas on a site that's just under 8,000
9 acres. We are about 40 miles southwest of downtown Fort
10 Worth, Texas.

11 The nearest population center which is
12 defined as a city of greater than 25,000 people Cleburne,
13 Texas, and that's 24 miles east of the plant. And that
14 is our basic geography and demography.

15 Any questions?

16 CHAIR STETKAR: Yes. The demography
17 numbers in the FSAR are based on the 2000 Census data,
18 extrapolated through some modeling process to, first
19 2007, and then taken out to, I think, 2056.

20 That assumes a construction completion date
21 of 2016, which you're -- I'm just going to guess. You're
22 probably not going to make that.

23 MR. CLOUSER: Probably no.

24 CHAIR STETKAR: My question was, Texas, in
25 the 2000's, certain areas of Texas experience pretty

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 dramatic population growth. I ran out some 2010 Census
2 figures and compared them to 2000 in areas -- like
3 Granbury, in particular, increased about 40 percent
4 population over that decade.

5 Fort Worth is also about 40 percent.
6 Glenrose, not so much, about 15 percent. Cleburn, about
7 15 percent.

8 Since your construction date -- I'm
9 guessing -- most likely will be later than 2016, have
10 you thought about updating your demographics to account
11 for the 2010 Census, rather than something that's now
12 13 years old, projected out over, you know, the next
13 50 years or 60 years or 70 years or something?

14 MR. CLOUSER: That's a fair question.

15 MR. REIBLE: I can answer part of that.

16 MR. CLOUSER: Okay.

17 MR. REIBLE: Part of that is that, for our
18 operating units, because of the EP rule change, we had
19 to revisit our demographics and reassess our ETD's for
20 evacuation, and incorporate the new population
21 statistics.

22 Those will be incorporated into our COLA
23 so, with that process, we will do a revision to the 2010
24 population.

25 CHAIR STETKAR: And we see new statistics

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 -- the 2010 Census?

2 MR. REIBLE: Yes.

3 CHAIR STETKAR: Okay. Good. Thank you.

4 MR. CLOUSER: All right. If there's no
5 other questions, then Bob is going to talk to you about
6 nearby industrial, transportation and military
7 facilities.

8 MR. REIBLE: The nearby industrial,
9 transportation and military facilities, CPNPP Units 3
10 and 4 design is bounded by the DCD, Section 2.2.

11 Evaluated the design basis events for
12 hazardous materials and activities in the vicinity of
13 the site, and no additional mitigation was required.

14 CHAIR STETKAR: Now, you didn't bring your
15 maps, so I'm going to have to walk through this orally.

16
17 There are some airways that are looked at.

18 I looked at the airports and I looked at the airways,
19 and this may be a better question for the staff, but
20 I'll ask you first.

21 The Standard Review Plan has some guidance
22 in it that's kind of stylized, but the guidance says
23 that, for example, you can presume that the probability
24 of an aircraft crash is -- it says the probability is
25 considered to be less than an order of magnitude of ten

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to the minus seven per year by inspection -- whatever
2 that means.

3 If the distances from the plant meet all
4 of the criteria listed below, a couple of the criteria
5 are a number -- it's Item B, "The plant is at least five
6 statute miles from the nearest edge of military training
7 routes."

8 Item C, "The plan is at least two statute
9 miles beyond the nearest edge of a Federal airway."

10 I did some calculations looking at the
11 military and civilian airways and there's a military
12 airway, VR-158 that, if I take the standard widths of
13 airways, its closest edge seems to be less than five
14 miles from the center of the plant.

15 The center line is more than five miles,
16 but not the closest edge, because they're -- they're
17 about, I think, 10 or 11 nautical miles wide.

18 And the nearest edge of civilian airway
19 V-17-18-568, depending on the resolution that I can get,
20 seems to be just about two miles from the center point
21 of the plant.

22 So, I was curious why, by inspection for
23 those two particular airways, I could presume that the
24 frequency of crashes is less than ten to the minus seven,
25 in other words, how those two airways satisfy those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 criteria.

2 I'll ask the staff more about this because
3 they, indeed, have no open items and they look at the
4 standard review plan.

5 But I just wanted to note that. You
6 probably don't have answers unless you have a lot of
7 maps with you and really close distances. But when I
8 ran out the distances and I checked them a couple of
9 different ways, at least the military aircraft --
10 airway, I don't see any way that you can say that --
11 that the nearest edge of that airway is more than five
12 miles from the center -- the center point of the two
13 units.

14 The civilian airway, I could get it -- it's
15 -- I got it to be 2.0 miles, but that's -- that pretty
16 coarse, given the maps I was using, so --

17 MR. REIBLE: I think the current -- the FSAR
18 list, the VR-158, within 10 miles and, you know, based
19 on your comment, I think we need to --

20 CHAIR STETKAR: That's the center --

21 MR. REIBLE: -- revisit that.

22 CHAIR STETKAR: That's the center line
23 distance, though. It's actually -- my mapping stuff
24 put it at 7.8 miles, which is in -- which is within 10
25 miles but if you then take the -- the normal width of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 those airways, you know, you get within much less than
2 five miles from the nearest edge.

3 So, you may want to -- you may want to think
4 about that. I -- I realize we are not going to get a
5 resolution on that today, and I am more interested in
6 how the staff reached their conclusion, given this
7 information. So, I just wanted to raise that point
8 about the airways.

9 You are far enough away from the airports.
10 Just -- just barely from DFW, but that's okay.

11 MR. CLOUSER: Are you all done, Bob?

12 MR. REIBLE: Yes.

13 MR. CLOUSER: Any other questions for
14 Section 2.2?

15 (No response.)

16 MR. CLOUSER: All right. I'll cover
17 meteorology, then. As I mentioned earlier, we're in
18 North Central Texas, which is about 280 miles from the
19 coast, so we don't see a lot of hurricane activity.

20 However, in reviewing the hurricanes since
21 1900 in the State of Texas, we did have one Category
22 1 hurricane that approached within 50 miles.

23 CHAIR STETKAR: Let me interrupt you.

24 MR. CLOUSER: Okay.

25 CHAIR STETKAR: I'm sorry about that. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 know people have flights to make, but we have things
2 to do also.

3 So, -- and I didn't realize this. Bob, the
4 pipeline -- as I read through the FSAR, there were a
5 couple of assumptions -- and, in particular, I'm talking
6 about the Sunoco Oil pipeline, the close one there.

7 MR. CLOUSER: Right.

8 CHAIR STETKAR: There were a couple of
9 numbers in the FSAR regarding assumed durations of leaks
10 from that pipeline. And, in particular, it says that,
11 for a large break of the pipeline in Section 2.2.3.1.2.3,
12 it says the flow rate, which is 47 cubic feet per second,
13 is assumed for a one-minute duration, the time to detect
14 and isolate the large break.

15 It's also noted in the FSAR that there are
16 no valves within five miles of CPNPP and the nearest
17 station associated with the pipeline is over 30 miles
18 away.

19 So, I was curious about how people
20 effectively detect and isolate a break in that pipeline
21 within one minute. That's -- sounds darned good to me.

22 So, I'm interested to find out -- since
23 that's in the FSAR, I'm interested to learn what the
24 basis for that -- did you -- you know, did you get
25 information from the pipeline company, what sort of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 detectors do they have, what sort of assurance that,
2 within a one-minute time after this -- it has to be a
3 large rupture, but those things actually happen as we're
4 well-aware, in pipelines, how you can get assurance
5 that it would be isolated within a minute.

6 And then, there's a small-break case that
7 says the largest -- for the small break, the flow rate
8 is .62 cf -- cubic feet per second or about 275 gallons
9 per minute.

10 It says that leak rate was assumed for a
11 period of 32 hours, and that's -- it says the rate is
12 based on the largest undetectable leak and the longest
13 period of time the spillage would go on observed.

14 So, I was curious what the basis for that,
15 32 hours and the detection within that time period.
16 I'm, quite honestly, less concerned about the small
17 leak, obviously, than the large leak, but -- but there
18 didn't seem to be any bases in there for those times.

19 I'm a -- I'm a, as I said, a little more
20 questioning about that one minute.

21 MR. REIBLE: Okay.

22 CHAIR STETKAR: Okay.

23 MR. REIBLE: Yes, I can see the specific
24 references that you are making, and we'll take that as
25 an action --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Yes. They are both in
2 2.2.3.1.2.3.

3 MR. REIBLE: Right.

4 CHAIR STETKAR: There's a large-break case
5 and a small-break case.

6 MR. REIBLE: Right.

7 CHAIR STETKAR: Thank you. And I'm sorry.

8 MR. REIBLE: That's all right.

9 CHAIR STETKAR: I don't read all that
10 quickly here.

11 MR. REIBLE: Okay. Back to Section 3?

12 CHAIR STETKAR: Yes.

13 MR. REIBLE: We were talking about the
14 hurricanes and the one that was recorded in the last
15 160 years was in 1900, and it was -- exited the 50-mile
16 radius around the plant at about 65 miles an hour.

17 So, although our maximum hurricane site
18 characteristics are bounded by the US-APWR Reg Guide
19 1.221. So, a likely candidate for concern are tornados
20 and, in the 56-year period from 1950 to 2006 there were
21 three tornados sighted in Summervell County, which is
22 the location of the plant site, and maximum tornado
23 site characteristics are bounded by the US-APWR Reg
24 Guide 1.76.

25 Any questions?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR STETKAR: Yes. Several. Since you
2 mentioned hurricane first let me look at my hurricane
3 notes here.

4 There's a statement in the FSAR that says,
5 "Assuming a" -- there's a model in there. It says,
6 "Assuming a maximum landfall wind speed of 208 knots,
7 a translational velocity of 16 knots, and a distance
8 of 400 miles from the CPNPP site to Galveston, gives
9 a maximum possible wind speed of 61 miles per hour at
10 the CPNPP site. This could -- should be considered as
11 the upper bound of possible hurricane wind speed at the
12 CPNPP site."

13 That's in the FSAR.

14 MR. CLOUSER: Yes.

15 CHAIR STETKAR: You mentioned 65 miles per
16 hour. I looked up the hurricane data, and within 50
17 miles of the site there was an unnamed hurricane on
18 September 9th, 1900 that had a wind speed of 74.8 miles
19 per hour, and Hurricane Carla, on September 12th, 1961
20 that had a wind speed of 69 miles per hour. That's within
21 the 50-mile radius of the site.

22 So, I'm curious, given that evidence, why
23 the upper bound of possible hurricane wind speeds at
24 the site is 61 miles per hour.

25 MR. CLOUSER: Do we have any assistance on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that question?

2 CHAIR STETKAR: I understand how the model
3 calculated that wind speed. I sort of like to look at
4 data.

5 MR. CLOUSER: Right. Understand.

6 CHAIR STETKAR: Okay. If you don't, let
7 me --

8 MR. MORRIS: This is Marvin Morris. The
9 discussion -- can you hear me okay?

10 CHAIR STETKAR: I think so.

11 MEMBER BROWN: Try to get closer so the
12 recorder can pick you up.

13 MR. WOODLAN: Try to get closer to the mic.

14 MR. MORRIS: Okay. Thank you. Marvin
15 Morris. The discussion in the FSAR is just an example
16 of the decay of hurricane wind speeds as they go inland
17 due to friction and also due to loss of the driving force,
18 water temperature that -- that goes away as it crosses
19 inland.

20 And that's just an example of the decay,
21 you know, an exponential type decay as it goes inland,
22 you know, and the assumption was 240 mile per hour
23 hurricane hitting the coast and decaying exponentially
24 and they come up with 61 mile per hour as a -- as what
25 that translates to.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR STETKAR: Right. Yes. And I
2 understand that's from someone's model of hurricane wind
3 speed decay, and I wouldn't have any problems if it's
4 presented in the FSAR as here's an example of some way
5 that people have calculated possible wind speeds, and
6 here is our data -- here are our data.

7 But, that was -- what I quoted was from the
8 FSAR and it uses words of "a maximum possible wind speed
9 of 61 miles per hour. This should be considered as the
10 upper bound of possible hurricane wind speed at the CPNPP
11 site."

12 MR. MORRIS: Right. Based on -- based on
13 that assumed 240 mile an hour wind speed at the coast.

14 However, what we're using for the design
15 basis is from Reg Guide 1.221, which is 160 miles per
16 hour at the site. So, it just -- it shows a degree of
17 a conservatism.

18 CHAIR STETKAR: That's -- I'm sorry.
19 That's the design basis. We're trying to compare what
20 margin you have between actual experience and the design
21 basis.

22 MR. MORRIS: Yes.

23 CHAIR STETKAR: I understand what the --
24 and I'll grant if, for hurricanes, I think you have
25 substantial margin available.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 However, I'm also interested in not
2 mischaracterizing numbers as maximum possible upper
3 bound of the highest wind speed we could ever expect
4 at the site when there is actual evidence from data that
5 -- that leads me to suspect that number.

6 So, that's my biggest concern about that.

7 It's -- I'm not -- I'm going to -- in this particular
8 case, I'm not actually questioning do you have adequate
9 margin.

10 MR. MORRIS: Right.

11 CHAIR STETKAR: It's just the way that --
12 that --

13 MR. MORRIS: It's been phrased.

14 CHAIR STETKAR: -- the hurricane wind speed
15 model is characterized, given -- given data.

16 Now, in particular, let me raise a different
17 question here before I get to tornados and a couple of
18 other things.

19 In the meteorological section you've used
20 basically 30 years of meteorological data from Fort
21 Worth and there are a few -- there are a few met stations
22 they use, Fort Worth -- they make a lot of reference
23 to DFW.

24 MR. MORRIS: Right.

25 CHAIR STETKAR: And there's a couple of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 others. I've forgotten the names. I've got them listed
2 here somewhere.

3 But, the point is that the -- the database
4 that you've used for essentially looking at fairly rare
5 events spans 30 years.

6 Now, I went back into Weather Service
7 records and for DF -- I'm sorry. Let me get the -- so
8 I'm correct on the record here. DFW is limited because
9 DFW didn't exist for very long back in history.

10 But if I look at weather records for Fort
11 Worth Meacham Field, KFTW, they go back to 1945. Dallas
12 Love, KDAL are back to 1946. Mineral Wells, KMWL are
13 back to 1948. DFW is only back to '74 in terms of daily
14 records because, you know, it didn't exist.

15 So, my question is: Because we're trying
16 to project very rare extreme events and, indeed, I have
17 data available back for, I don't know, 60, 65 years,
18 why haven't I used all of that data? Why have I
19 restricted myself to only 30 years from 1971 through
20 2000, whatever the -- whatever the database period was?

21 MR. CLOUSER: And that is a very good
22 question. I don't have an answer for that, but we can
23 get back to you --

24 CHAIR STETKAR: Okay.

25 MR. CLOUSER: -- with that data and see if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we need to expand that.

2 CHAIR STETKAR: Where it comes up in some
3 of my concerns is you're close to the margin on a couple
4 of meteorological parameters. One is the maximum --
5 however it's characterized -- zero percent exceedance
6 frequency dry bulb temperatures, 115 degrees. That's
7 the design value.

8 And, indeed, August 19th, 1984 there was
9 a recorded high daily temperature of 115 degrees at Glen
10 Rose. Not DFW. Not Fort Worth. Not -- at Glen Rose.

11 And that's -- that's right at it. That
12 doesn't give me a lot of margin. I don't know what the
13 temperatures were if I go back another 30 years back
14 into the historical record.

15 It doesn't give me a lot of confidence about
16 margin to that maximum temperature in the certified
17 design. So that's one case where having more
18 meteorological data might discover data points that,
19 indeed, exceed it, or it might give you greater
20 confidence that -- that whatever -- however you
21 characterize the zero percent exceedance, and I know
22 there's a stylized notion of what that means, you can
23 have greater confidence that you are not actually going
24 to exceed that over the next 60 years of the plant.

25 MR. CLOUSER: Sure. So what I understand

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that you're saying is you're concerned that some
2 parameters don't have as much margin as we might like
3 to see and we have more data available than we have used
4 to do some analysis, and we might want to take a look
5 at that and see if we need to --

6 CHAIR STETKAR: Yes. Exactly.

7 MR. CLOUSER: -- make an adjustment.

8 CHAIR STETKAR: Exactly. Exactly.

9 MR. WOODLAN: Marvin, do you have anything
10 to add?

11 MR. MORRIS: Yes. I was going to -- I was
12 going to add that, you know, the criteria definition
13 that we use for determining zero percent exceedance,
14 which is not what you might think is zero percent
15 exceedance which would be you would never exceed.

16 CHAIR STETKAR: Right.

17 MR. MORRIS: Zero percent exceedance, the
18 definition that we've used and the same definition that
19 was used in AP-1000 plants is the temperature that's
20 only exceeded two hours in a 30-year period of record.

21 And so that's -- that's one we've used and,
22 you know, that -- that implies enough -- you know, it
23 says you should use a 30-period of the record, which
24 is what -- what we did.

25 CHAIR STETKAR: And, quite honestly, if you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 had much larger margins in that 30-year period perhaps
2 I wouldn't be as concerned, but since, in the period
3 -- even in that 30-year period of record, you've hit
4 -- apparently hit that value.

5 And I'm not sure about two hours and all
6 of that --

7 MR. MORRIS: Yes.

8 CHAIR STETKAR: -- stuff, but --

9 MR. MORRIS: But I think if you look at it
10 in terms of plant operation, if you hit it -- hit it
11 for one hour, it has no effect on plant operations.

12 CHAIR STETKAR: I'm trying to understand
13 where -- we're now transitioning from the certified
14 design to the Glen Rose site. And I'm trying to
15 understand what margins are available under the
16 regulatory basis at the site to the design, because that
17 gives us a measure of confidence in terms of -- of where
18 you -- how much margin you have on those external
19 effects.

20 What -- what the impact of exceeding 115
21 degrees for ten minutes or two hours or whatever, is
22 a different issue. But the certified design says 115
23 degrees is what it's --

24 MR. MORRIS: Right.

25 CHAIR STETKAR: -- is what it's built to.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WOODLAN: I think we understand the
2 question. We don't have an answer today --

3 CHAIR STETKAR: So, in terms of the two
4 things to try to keep the discussion going, the two
5 things that I found, the one where -- I think that the
6 entire story about meteorology would benefit from
7 looking at longer than the 30-year period.

8 In particular, I'm not quite sure about the
9 margin on temperature. Rainfall, you got a pretty good
10 margin. Wind speeds you can't do much with,
11 three-second wind gust speeds, because they weren't
12 recorded in that way back before the -- I don't remember,
13 Marvin, 1980's or even later than that sometimes.

14 So, you can't really go ferret out, you
15 know, wind -- straight-line wind speed data. Rainfall,
16 you can lead up pretty good margins there. Temperature,
17 you certainly can. Everybody has recorded temperature.

18 Okay. And we talked about the hurricane.
19 TORNADOS. You know, I'm going to ask the staff about
20 tornados. I know what you did. I'm going to ask the
21 staff. It's better to ask them. So, I'll let you off
22 the hook on that.

23 MR. CLOUSER: Okay. Any other questions
24 on Chapter 2?

25 CHAIR STETKAR: Oh. Yes. You have to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 excuse me. I -- I take a lot of notes and then, now,
2 out of order, so I have numbers that I have to look at.

3 Somebody's rubbing things on a microphone.

4 Please stop. You get two warnings and then it's not
5 pretty after that.

6 In Section 2.3.1.2.8 on precipitation,
7 there's a statement that says "Probable Maximum
8 Precipitation, PMP." Sometimes called "Maximum
9 Possible Precipitation," which, depending on whose
10 reference you look at, there is -- there is a notion
11 that PMP is a meteorological limit for the absolute upper
12 bounds of the amount of precipitation that can occur.

13 There are other interpretations of that
14 term. It says, "Probably Maximum Precipitation,
15 sometimes called Maximum Possible Precipitation for a
16 given area and duration is the depth which can be
17 reached, but not exceeded under known meteorological
18 conditions." So, in this sense it's -- it's the worst
19 it could possibly get.

20 For the site area, using a 100-year return
21 period, the PMP for 6, 12, 24 and 48 hours is 6.9, 8.3,
22 9.5 and 11.0 inches, respectively. And there's a table
23 that lists those values.

24 Now, if the PMP is the maximum possible that
25 could ever occur, why do we have a PMP with a 100-year

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 return period?

2 MR. CLOUSER: I don't have the answer to
3 that question.

4 CHAIR STETKAR: That's an exceedance
5 frequency. It's not a maximum upper bound. In
6 principle, if this is the hundred-year, if I ask you
7 what the thousand-year is, you'd probably get larger
8 values. For the million-year, you'd get even larger
9 values.

10 And, in some place, if you actually
11 interpret the PMP as the absolute maximum, it couldn't
12 get any bigger than that.

13 But, this notion -- the way it's presented
14 in the FSAR, the notion of PMP has a recurrence frequency
15 attached to it which -- I've never seen that.

16 Have you, Bill? You're a PMP guy?

17 THE WITNESS: No, that's a -- that's a new
18 one.

19 CHAIR STETKAR: Okay. So I'll raise that
20 issue.

21 MR. CLOUSER: Okay. I understand the
22 question to be why do we have a recurrence factor on
23 a maximum value --

24 CHAIR STETKAR: Right.

25 MR. CLOUSER: Basically.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: And -- and have you -- I
2 mean, one of the questions I asked you earlier on
3 demographics, you said that you've reevaluated the
4 demographics for Units 1 and 2 for emergency planning.

5 Have you developed PMP estimates for Units
6 1 and 2, and are they the same as these?

7 MR. CLOUSER: How do I say that, Bob?

8 CHAIR STETKAR: I'm suspecting that, as
9 post-Fukushima things you will be doing that, but --

10 MR. CLOUSER: Right. Right. Right.

11 CHAIR STETKAR: But, I was just curious.
12 I mean, it --

13 MR. CLOUSER: Well, I can't give you a full
14 answer, but I can give you an answer based on what I
15 read. First of all, there's several PMP values,
16 depending on the -- the situation you are trying to
17 evaluate, and PMP will vary based on various zones within
18 the watershed.

19 CHAIR STETKAR: Sure.

20 MR. CLOUSER: And so, yes, Unit 1 and 2 has
21 values, but they are a quarter of a mile away. Their
22 values are actually different. Their zoning is
23 different.

24 CHAIR STETKAR: Okay.

25 MR. CLOUSER: And so they have a different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 number than we use, and we actually use several PMP
2 values, one for flooding in Squaw Creek Reservoir, one
3 for actual water development on the site and local water
4 levels on the site.

5 CHAIR STETKAR: Right.

6 MR. CLOUSER: Because they are --

7 CHAIR STETKAR: So that has to do with
8 drainage --

9 MR. CLOUSER: And whether or not you're
10 looking at a short term, because it's a higher number
11 per minute if you're looking for a very short-term event.

12 But if you're looking for a 24-hour event, it's a
13 different number.

14 CHAIR STETKAR: Sure.

15 MR. CLOUSER: So, yes, we do have differing
16 numbers. I'm not saying they're inconsistent.

17 CHAIR STETKAR: Yes. Those are -- those
18 are intensity values.

19 MR. CLOUSER: Yes.

20 CHAIR STETKAR: You know, but they're
21 still -- they're still -- in everything that I've seen,
22 they are still going back to this hundred-year
23 recurrence frequency. They are all -- they are always
24 considered. That's whether or not you believe that the
25 maximum -- the probably more realistic thing to look

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 at them is a hundred years.

2 MR. CLOUSER: Oh. Oh, yes.

3 CHAIR STETKAR: But that's a different
4 question. That's a different question.

5 MR. CLOUSER: Yes. And, as we said, we --
6 we will take an action --

7 CHAIR STETKAR: Okay.

8 MR. CLOUSER: -- to try and clarify that
9 wording.

10 CHAIR STETKAR: And, with that, I don't
11 think I have anything more on 2.3.

12 MR. CLOUSER: Okay.

13 CHAIR STETKAR: But I had a lot of details,
14 but a lot of the details essentially -- oh. Yes. I
15 was going to ask the staff about a lot of these because
16 a lot of the details go back to better confidence using
17 a broader meteorological database than the 30 years.

18 MR. CLOUSER: Right.

19 CHAIR STETKAR: So, with that, do any of
20 the members have any questions for Luminant?

21 (No response.)

22 CHAIR STETKAR: You don't?

23 MR. CLOUSER: All right. Then this
24 concludes our presentation.

25 CHAIR STETKAR: That was not too bad.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Thank you.

2 And we'll ask the staff to come up and hear
3 from them.

4 Stephen, do you want to say anything?

5 MR. MONARQUE: No, thanks. We'll just go
6 ahead and start our presentation and I'll turn it over
7 now to Tarun Roy, who is a project manager for Chapter
8 2.

9 MR. ROY: Yes.

10 CHAIR STETKAR: And, again, make sure you
11 are really careful about your paper not hitting those
12 microphones. Thank you.

13 MR. ROY: My name is Tarun Roy. I am an
14 NRO project manager responsible for coordinating staff
15 review for Chapter 2, site characteristics, COLA
16 application.

17 The NRC technical review involved with the
18 review of the Comanche Peak Unit 1 and -- 3 and 4. Mr.
19 Seshagiri Rao Tammara, physical scientist here in and
20 Kevin Quinlan, physical scientist, hydrology and
21 metrology branch, and the staff reviewer.

22 During this meeting, the staff plans to make
23 a presentation of the Chapter 2, only Section 2.0, 2.1,
24 2.2 and 2.3, security relation report with open item.

25 In summary, staff issued a ten questions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on 2.1, 2.2 to the applicant, requesting additional
2 information. There is no open item in that review.

3 The second item, the staff issued a total
4 of 49 questions in 2.3 to the applicant, requesting
5 additional information. There is one open item in the
6 review.

7 If you have any question regarding this
8 chapter, I would turn over to presentation -- over to
9 the technical reviewer, Seshagiri Rao Tammara or the
10 Section 2.1 and 2.2.

11 MR. TAMMARA: My name is Seshagiri Rao
12 Tammara. I'm a technical reviewer for the Chapter 2,
13 Section 2.1 and 2.2.

14 2.1 covers the geography and demography.
15 2.2 covers the nearby industrial transportation and
16 military facilities.

17 CHAIR STETKAR: Again, please be really
18 careful not to hit that microphone. It's really, really
19 sensitive. Both Tarun -- thanks.

20 If you had the things plugged in your ears
21 that our recorder has -- we have amplifiers on these
22 microphones -- you'd appreciate why we say that.

23 MR. TAMMARA: 2.1, geography and
24 demography covers the site-specific information
25 pertaining to site location, exclusion area boundary,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 population distribution projections, population center
2 and population density.

3 The applicant addressed all this
4 site-specific information. Based on the staff's review
5 of this information and information obtained from the
6 publicly-available sources and also independent
7 confirmatory calculations.

8 The staff concludes that the applicant
9 addressed the information is appropriate, adequate and
10 acceptable, as it conforms, the requirements meets the
11 acceptance criteria and also satisfies the NRC guidance,
12 and there are no open items.

13 The Section 2.2, nearby facilities pertains
14 to the first, Section 2.2.1-2.2.2, describes the
15 locations and also descriptions of the products and the
16 facilities in the nearby plant within particularly five
17 miles, or up to the 10 miles in the airports and airways.

18 Most of the information is -- what are
19 applicable is incorporated by reference, but this is
20 mostly site-specific information, therefore, the
21 site-specific information covered nearby industrial,
22 transportation and military facilities, pipelines, gas
23 wells and also the existing units are also considered
24 as nearby facility, Units 1 and 2, and also on-site
25 chemical storage facilities.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The applicant addressed all these specific
2 -- site-specific information. Based on the staff's
3 review of this information and also information obtained
4 for the locations and the products from the
5 public-available sources.

6 The staff concludes the applicant has
7 addressed the information appropriately and it conforms
8 the requirements, meets the acceptance criteria, and
9 there are no open items.

10 CHAIR STETKAR: Let me ask you about the
11 airways now. Why is the nearest edge of military airway
12 V-158 more than five miles from the center of the plant?

13 MR. TAMMARA: Well, the edge of the plant
14 is around 7.8 miles, so we looked at the map, but in
15 any event, what we have considered is we have not --
16 I mean, it has been considered to calculate the
17 probability in the Chapter 3.

18 Even though -- you know, even though the
19 airway is designated as at one but in the evaluation
20 of aircraft impacts in 3.6 -- 3.5.1.6, we have evaluated
21 what is the potential probability of the military
22 aircraft, and addressing that impact section.

23 This -- this Chapter 2.2.1 uses only the
24 description, but the evaluation is performed and the
25 impacts are evaluated in that section, aircrafts impact

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 section.

2 CHAIR STETKAR: Well, we haven't had the
3 benefit of --

4 MR. TAMMARA: Right. I think it is --

5 CHAIR STETKAR: -- yet?

6 MR. TAMMARA: Yes. That's correct. But
7 if you -- I mean, I have also completed that section.
8 Now, --

9 CHAIR STETKAR: Now --

10 MR. TAMMARA: -- it might be too early to
11 --

12 CHAIR STETKAR: Yes. No, I -- I don't to
13 open up that discussion at the moment because it's not
14 fair to -- to anyone to do that. But, I guess, you know,
15 I'm a bit frustrated because now I'm not quite sure why
16 we do the Chapter 2 review at all.

17 The Chapter 2 review is supposed to look
18 at -- at acceptability of the site, compared to guidance
19 in the regulations.

20 MR. TAMMARA: Right.

21 CHAIR STETKAR: And the site is deemed to
22 be acceptable if the frequency of aircraft crashes is
23 deemed to be less than ten to the minus seven, and there
24 are some presumed crash frequencies based on distances.

25 And, if you meet those distances, it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 presumed that the crash frequency is less than ten to
2 the minus seven.

3 MR. TAMMARA: That's true.

4 CHAIR STETKAR: Now, that's not actually
5 true. If you do a real aircraft crash analysis -- I
6 did a little back-of-the-envelope calculation for one
7 of the civilian airways that is nominally acceptable
8 and, if you look at flight densities -- and it depends
9 on the type of carrier and the type of model that you
10 use, I can get crash frequencies greater than ten to
11 the minus seven.

12 So, it's all stylized, but for screening
13 there are criteria that says it's okay if I'm more than
14 five miles from the nearest edge of a military airway.

15 Your safety evaluation report says it's
16 okay. It doesn't say they have to do a site-specific
17 calculation. It says it's okay.

18 MR. TAMMARA: No, that is --

19 CHAIR STETKAR: They meet the regulations.
20 Then, I don't understand how they meet the regulations.

21 MR. TAMMARA: That is okay -- the five-mile
22 is okay for the civilian, but there is one more clause,
23 I think, in the SRP, if it is a military, they have to
24 look at it should not be more than 1000 flights and which
25 would give a -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR STETKAR: The quote -- the quote from
2 the SRP, just to get it on the record, is SRP 3.1.5.
3 -- 3.5.1.6, Item B. "The plant is at least five statute
4 miles from the nearest edge of military training routes,
5 including low-level training routes, except for those
6 associated with usage greater than 1000 flights per year
7 or where activities, such as practice bombing may create
8 unusual stress situations."

9 That says to me that you need to do a
10 site-specific analysis if you have more than a thousand
11 flights per year regardless of the distance or, if you
12 are less than five miles from the nearest edge.

13 This plant is less than five miles from the
14 nearest edge. In your safety evaluation report I saw
15 no mention of the fact that this plant must do, according
16 to this standard review plan, a site-specific analysis
17 for that particular airway.

18 Now, the same question for a civilian airway
19 where, depending on how you read the word "at least two
20 statute miles" when you come up to something that
21 calculates to be 2.0.

22 Why the SER for Chapter 2 didn't say that
23 site-specific analyses are required -- why it just says,
24 "This site is acceptable."

25 MR. TAMMARA: No. That is -- that is being

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 done as a part of 3.5.1.6.

2 CHAIR STETKAR: Okay.

3 MR. TAMMARA: It is only in 2.2.1 is
4 identification of the facilities and descriptions.
5 Nothing --

6 CHAIR STETKAR: I hear what -- I hear what
7 you are saying.

8 MR. TAMMARA: So that --

9 CHAIR STETKAR: Then, we'll revisit it in
10 --

11 MR. TAMMARA: Yes.

12 CHAIR STETKAR: -- in Section 3.

13 MR. TAMMARA: So, in the -- if you go the
14 3.5.1.6, we have evaluated and we have concluded, based
15 upon the real FAA data, we looked at it and then we
16 confirmed it is -- it meets the -- you know, the
17 conclusion was made in that section.

18 But it -- it did not regard the SER
19 presentation.

20 CHAIR STETKAR: Yes. No, we'll -- we'll
21 look at that when we get to Chapter 3. But it's -- it's
22 still -- okay. I understand the philosophy. I don't
23 have to agree with it. I don't --

24 MR. TAMMARA: But some of the applicants,
25 what they do is, they will put a point of saying that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the impact analysis is done or what -- what the reader,
2 so that they will go and take a look at the analysis
3 in 3. -- Chapter 3.

4 CHAIR STETKAR: Right.

5 MR. TAMMARA: So, maybe it might be
6 advisable to add a sentence saying that the impacts are
7 evaluated in Chapter 3 so that the reader will have a
8 pointer to go there. Maybe that -- that can be probably
9 the resolution.

10 CHAIR STETKAR: I mean, I would have
11 thought that at least in Chapter 2, as a reviewer, you
12 would have made note of the fact that this particular
13 site doesn't satisfy those criteria in the SRP.

14 MR. TAMMARA: Since that section deals with
15 the description we stopped it there. Of course, we can
16 -- we can put that pointer, saying that the evaluation
17 is performed and concluded in Chapter 3.5.1.6.

18 CHAIR STETKAR: Okay. Well, we'll
19 certainly revisit this Section 3.5, whenever that comes
20 to us.

21 MR. MONARQUE: Now, Chairman Stetkar.

22 CHAIR STETKAR: Yes.

23 MR. MONARQUE: Was there another issue
24 where you found a discrepancy between the distances and
25 FSAR and your own examination?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR STETKAR: No. No. No. No, I -- I
2 did a couple of double-checks on that. The distances,
3 the center line distances all seem to gibe.

4 It was just when I -- when I then expanded
5 the edges of those air routes, there were -- this
6 military air route that's -- the nearest edge is
7 well-within that five-mile limit.

8 The estimates in the FSAR say three to four
9 hundred flights per year so you don't trip over the --
10 the thousand flights per year. But -- but the nearest
11 edge is well-within the five miles.

12 The other one is right -- seems to be right
13 -- it's a civilian airway and it seems to be right at
14 two miles, and you're comparing --

15 MR. MONARQUE: Yes. Just the --

16 CHAIR STETKAR: You're comparing the edge
17 of the airway with the center point of the two units,
18 so there's -- there's a -- you know, a few hundred yards
19 one way or the other. It's pretty close.

20 MR. MONARQUE: Yes. Pretty close.

21 CHAIR STETKAR: Okay. Okay.

22 MR. TAMMARA: So, the Section 2.2.3 is the
23 evaluation for potential accidents. The evaluation of
24 potential accidents to the new units, due to the
25 potential -- I mean, include explosions, gas due to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 sources gas pipelines, fires, aircraft hazards which
2 are addressed in 3.5.1.6, toxic chemicals from the
3 control room habitability and liquid spills and the
4 collision with intake structures.

5 The applicant analyzed and addressed the
6 potential hazards from these identified nearby sources,
7 and the new -- for the new units from the potential
8 accidents.

9 Based on the review of the applicant's
10 information provided in the FSAR, attending to the
11 potential accidents, and also a review of the
12 information provided by the applicant as responses to
13 the staff's requested for additional information, and
14 also staff's independent confirmatory analysis.

15 The evaluation of all the applicant's --
16 staff concludes that the applicant has addressed the
17 information appropriately, adequately and acceptably
18 and, as the information is meeting the acceptance
19 criteria, and satisfies the guidance, and there are no
20 open items.

21 CHAIR STETKAR: I had a question about the
22 toxic chemical conclusion. And this is another issue
23 where we have regulations and then we have people. The
24 applicant noted that they could not conclude that the
25 frequency of tanker truck accidents on Farm-to-Market

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Road 56 was -- well, their -- their conclusion was
2 results show the total frequency for road-based
3 hazardous material release is higher than the ten to
4 the minus six screening frequency of Regulatory Guide
5 1.7.8.

6 They then did a release analysis, assuming
7 that they had a dual tanker truck full of chlorine.

8 MR. TAMMARA: Right.

9 CHAIR STETKAR: And -- and looked at
10 concentrations in the man control room and concluded
11 that, indeed, the concentrations remained below the
12 immediately dangerous to life and health limit of 10
13 ppm for chlorine.

14 Their analysis goes on to say that human
15 detection threshold for chlorine is about 0.08 ppm,
16 eight one hundredths -- 0.08 ppm, and that would occur
17 at approximately a quarter of a minute, .25 minutes,
18 and the concentration reaches the maximum concentration
19 8.0 ppm in about 16 minutes.

20 That's from their stylized analysis. So,
21 maximum concentration of eight is less than the ten,
22 so you're not going to kill anybody.

23 And I looked at a couple of different
24 scenarios that they -- they evaluated, and those
25 scenarios are 5.7 to 8 ppm maximum concentration in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 control room.

2 Now, there are no toxic gas sensors in this
3 plant, so it's presumed that the operators -- there's
4 a quote that says, "Regulatory Guide 1.78 states that
5 it is expected that a control room operator will don
6 a respirator and protective clothing or take other
7 mitigating action with two minutes after detection.

8 "Also, during a toxic gas emergency, the
9 control room operators have the option of manually
10 actuating emergency isolation mode of the main control
11 room HVAC system."

12 Do we have any problems with having main
13 control room operators operating in respirators or with
14 concentrations in the main control room that might not
15 kill me, but chlorine is a really nasty substance, and
16 I pretty much don't want to stay in there in those kind
17 of concentrations.

18 In other words, has there been any
19 consideration by the staff to examine toxic gas monitors
20 at this plant, given -- given this site-specific
21 situation?

22 MR. TAMMARA: Okay. This is a -- this
23 aspect of control room habitability is an interface
24 between the Chapter 2 and Chapter 6. I mean, I want
25 to picturize what -- what we evaluated and what they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 do, whatever.

2 As far as the -- as far as the Chapter 2
3 is concerned, what we are doing here is -- is there any
4 problem with the -- any of the hazardous or chemicals
5 that have the potential to exceed the limit in
6 concentrations in the control room?

7 If -- because there are hundreds of
8 chemicals --

9 CHAIR STETKAR: Right.

10 MR. TAMMARA: -- being addressed from the
11 various sources and also on-site storage.

12 So, it is very difficult for all the
13 chemicals to really analyze in Chapter 6.

14 CHAIR STETKAR: Yes.

15 MR. TAMMARA: Therefore, Chapter 2 is
16 looking at all the chemicals which can be screened out
17 --

18 CHAIR STETKAR: Yes.

19 MR. TAMMARA: And identify those chemicals
20 which have the potential, but my have a control room
21 habitability issue.

22 CHAIR STETKAR: Okay.

23 MR. TAMMARA: So, from that respect to what
24 Chapter 2 does is we gather all the information from
25 various sources, various products and identify the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 chemicals --

2 CHAIR STETKAR: Okay.

3 MR. TAMMARA: -- and go through our
4 screening methodology and see what would be the
5 concentration from a source to the control room intake.

6 If that control room intake concentration
7 is higher than the limiting concentration for that
8 chemical, then we conclude, A, this chemical has a
9 potential. It might have an impact in the control room.

10 CHAIR STETKAR: Yes.

11 MR. TAMMARA: So we will pass on to control
12 room habitability. Say, "Hey, take a look at this
13 chemical from the perspective of your control room
14 scenario, the dilution, the flow, the release -- I mean,
15 the intake --

16 CHAIR STETKAR: Yes.

17 MR. TAMMARA: -- and whatever the
18 mechanisms you have in the control room and see whether
19 that -- that concentration is lower than the limiting
20 concentration.

21 If not, what are the mitigating to emergency
22 want to institute whether, you know, you want to bring
23 in a bottle of fresh water -- air, or whatever.

24 So, that is all done in 6.4.2.

25 CHAIR STETKAR: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TAMMARA: But what I'm saying, because
2 that is the purview of their -- your question and answer
3 should be more -- that conclusion should be in 6.4.2.

4 CHAIR STETKAR: But let me see if I can make
5 sure I understand this, though. In this particular
6 case, their analysis shows that the concentration is
7 lower than the IDLH.

8 MR. TAMMARA: Correct.

9 CHAIR STETKAR: So does that mean that, in
10 Chapter 6, they don't need to look at chlorine because
11 it's --

12 MR. TAMMARA: No, they --

13 CHAIR STETKAR: -- effectively --

14 MR. TAMMARA: -- look at -- they
15 independently -- because it is outside the concentration
16 it is higher than what it is -- it is exceeding.

17 So, therefore, they will take a look at what
18 -- how -- you know, they will take a look at how rapidly
19 the concentration is going down and what it is and then
20 they will conclude, even though intake concentration
21 is higher than the limiting concentration.

22 But the control room habitability is -- is
23 okay or not okay.

24 CHAIR STETKAR: Okay.

25 MR. TAMMARA: If not okay, what are the,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you know, remedies. I do not know, but I -- I haven't
2 --

3 CHAIR STETKAR: I got it. I made the note.
4 We'll look at -- Chapter 6 is another one we haven't
5 gotten to yet.

6 MR. TAMMARA: Right. These are the
7 interviews that I want to explain because --

8 CHAIR STETKAR: It's on the list.

9 MR. TAMMARA: -- that is not my area of
10 expertise --

11 CHAIR STETKAR: Okay.

12 MR. TAMMARA: -- to answer you fully.

13 CHAIR STETKAR: Okay. Thank you.

14 MR. TAMMARA: Are there any questions for
15 me from my presentation?

16 CHAIR STETKAR: Anything else on this
17 section?

18 (No response.)

19 CHAIR STETKAR: Good.

20 MR. TAMMARA: Thank you, Chairman.

21 MR. QUINLAN Good morning. Can you hear
22 me okay?

23 My name is Kevin Quinlan. I'm a
24 meteorologist in the Hydrology and Meteorology Branch
25 within the Division of Site Safety and Environmental

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Analysis. I'll be discussing Section 2.3 of the SER
2 for meteorology.

3 This incorporates Comanche Peak FSAR's
4 Section 2.3 of the US-APWR DCD. There are five
5 subsections in SER Section 2.3 related to regional
6 climatology, local meteorology, the on-site
7 meteorological measurements program, short-term
8 atmosphere dispersion estimates for accidental releases
9 and long-term atmospheric dispersion estimates for
10 routine releases.

11 Comanche Peak Supplemental Item 2.0, Part
12 1 includes Table 2.0-1R, which is a comparison table
13 for the US-APWR DCD site parameters and the Comanche
14 Peak site characteristics.

15 SER Section 2.3.1 describes the review of
16 the meteorological -- the regional climatological
17 information and addresses 1 US-APWR COL information item
18 and one supplementary information item.

19 The information item states, in part, that
20 the Applicant should provide site-specific information
21 related to regional climatology. The Comanche Peak
22 Supplemental Information Item 2.3, Part 1 states that
23 the applicant provides a description of the meteorology
24 for its site and its surrounding areas.

25 This resulted in the comparison between the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 site meteorological characteristics and the DCE site
2 parameters.

3 This section also addresses the 50- and
4 100-year return period of three-second gust wind speeds.

5 The wind speeds were confirmed by the staff through
6 the use of figure 6-1A of the ASCE 705 document and by
7 examination of the NOAA Coastal Services Center
8 Hurricane Database.

9 The maximum tornado wind speed of 230 miles
10 an hour was determined through the use of Regulatory
11 Guide 1.76, Revision 1. Because the applicant
12 identified the most conservative tornado site
13 characteristic by following the NRC guidance, the staff
14 found it acceptable.

15 The staff compared the extreme wind speed
16 against the guidance provided in Reg Guide 1.221, Design
17 Basis Hurricane and Hurricane Missiles for Nuclear Power
18 Plants and found the hurricane wind speeds and the
19 missiles were bounded by the tornado wind speed
20 characteristics.

21 To determine the maximum winter
22 precipitation roofload, the applicant followed the
23 guidance provided in Interim Staff Guidance Document
24 7, Interim Staff Guidance on Assessment of Normal and
25 Extreme Winter Precipitation Roofloads on the Roofs of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Seismic Category 1 Structures. Because the applicant
2 followed this guidance, the staff found the analysis
3 to be correct and acceptable.

4 Ambient temperature and humidity site
5 characteristics were confirmed through the use of 30
6 years of National Climatic Data Center Records for the
7 Dallas/Fort Worth National Weather Service Reporting
8 Station.

9 The calculation of 100-year return period
10 temperatures, used a method endorsed by the ASHRAE
11 Fundamentals Handbook, and because the applicant
12 followed the NRC guidance and a conservative method,
13 the staff found their analysis to be acceptable.

14 The applicant presented this information,
15 FSAR Section 2.3.1, and the staff found that all the
16 Comanche Peak site characteristics were bounded by the
17 US-APWR DCD site parameters and, therefore, found it
18 acceptable.

19 The US-APWR COL information Item 2.3, Part
20 1, also states that the applicant should provide
21 site-specific information related to local meteorology.

22 This section of the FSAR addresses the potential
23 cooling tower-induced effects on ambient temperature,
24 moisture and salt deposition.

25 This section of the FSAR also provides

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 detailed information showing that the Comanche Peak
2 meteorological data are representative of the site area.

3 The applicant presented the information in
4 Section 2.3.2 of the FSAR and the staff found it correct
5 and adequate.

6 Next slide.

7 CHAIR STETKAR: No, not next slide.

8 MR. QUINLAN Oh. Sure.

9 CHAIR STETKAR: Why -- what we are trying
10 to do here is to understand -- we understand what the
11 design is, as in specified values, and we're trying to
12 understand the margins between this particular site
13 and the design values.

14 And, in many cases, although we don't like
15 to use probabilistic risk assessment in these areas,
16 there are many inferred probabilities and frequencies
17 and stylized methods that are designed to give us some
18 measure of confidence about what margins we have to that
19 design.

20 Words like "conservate" get thrown around.

21 Words like "probably maximum" get thrown around.

22 Words like "hundred-year exceedance " get thrown
23 around.

24 My question is: Why is it okay to use only
25 30-years worth of data when we are trying to look at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 very rare events and gain confidence that the particular
2 conditions at this site either will not exceed the design
3 conditions or give us some confidence about how close
4 to those design conditions we come.

5 You heard the discussion before but, in
6 particular, if the design conditions say the maximum
7 temperature -- and I don't want to get into the stylized
8 analyses of should it be greater or less than 2.0 hours
9 under somebody's inference of what might be good enough.

10 If the design says I shouldn't have a
11 temperature, exterior, higher than 115 degrees and I
12 have a data point that says, "In Glen Rose, Texas, in
13 1984 it got up to 115 degrees," that doesn't give me
14 a lot confidence in the margin for this particular site
15 to the design.

16 And why is it okay just to take a snapshot,
17 especially if I've got 60 to 70 years worth of data from
18 only 30 years to support that confidence from the staff's
19 perspective.

20 MR. QUINLAN Well, you asked about the
21 reason we used 30 years.

22 CHAIR STETKAR: Yes.

23 MR. QUINLAN At some point, NOAA determined
24 that 30 years was a climatological period.

25 Now, often we use -- we use more than that,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and I think in this case I pulled data from some other
2 sources and found that Dallas/Fort Worth, their hourly
3 data set was the most representative of the site area,
4 and provided the -- the more conservative estimates.

5 CHAIR STETKAR: DFW in particular?

6 MR. QUINLAN Correct. Yes, that's why I
7 used Dallas/Fort Worth --

8 CHAIR STETKAR: DFW only goes back to the
9 Seventies. It didn't exist.

10 MR. QUINLAN Yes.

11 CHAIR STETKAR: That's why -- that's why
12 I pulled up values for Fort Worth and -- because --
13 because Meacham Air Field has existed for a long time.

14 Love Field existed for a long time, and I was surprised
15 Mineral Wells I can go back and get data from the Forties.

16 I didn't mine the data, but I know it exists.

17 MR. QUINLAN As far as the analysis goes,
18 you know, I employed the hourly data and run some --
19 some programs on the hourly data to find the maximum
20 two-hour period which I don't -- didn't want to get into,
21 but --

22 CHAIR STETKAR: I've done that, too.
23 That's the most convenient data set that you could
24 download to run those programs.

25 MR. QUINLAN Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Fine. I'm asking about
2 confidence not only based on historical data, but
3 projecting out over the next 70 years or so how close
4 we're going to come to the margins on this plant.

5 MR. QUINLAN Well --

6 CHAIR STETKAR: And if we're well-away from
7 the margins I can understand using convenience.

8 MR. QUINLAN Yes.

9 CHAIR STETKAR: If we're not so far away
10 from the -- from the design, it seems that it would
11 require a little bit more effort.

12 MR. QUINLAN Well, I think -- I didn't, you
13 know, write the guidance or the DCD. But I think, as
14 far as a hundred-year return period goes, it represents
15 a --

16 CHAIR STETKAR: Hundred years being three
17 times longer than 30.

18 MR. QUINLAN Yes, but it --

19 CHAIR STETKAR: Okay.

20 MR. QUINLAN Well, it represents a one
21 percent chance of this being exceeded in any given year.

22 CHAIR STETKAR: Yes.

23 MR. QUINLAN So, over the life, you know,
24 say, even a 40-year life of the plant you could expect
25 --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR STETKAR: Let's say a 60-year.

2 MR. QUINLAN Okay. Then you could
3 reasonably expect --

4 CHAIR STETKAR: Sixty percent probability
5 that this will --

6 MR. QUINLAN That there will be better
7 exceeded over the --

8 CHAIR STETKAR: Better than even?

9 MR. QUINLAN Yes. So, I don't think the
10 -- at least in this case, the hundred-year return period
11 is meant to bound something that has almost no chance
12 of happening, something like a tenth to the seventh
13 probability of happening.

14 CHAIR STETKAR: What would you do if you
15 went back -- and I'm not saying that it existed. When
16 you went back and mined those data sets and you found
17 two events in the last 70 years where the temperature
18 was 120 degrees, what would you do?

19 MR. QUINLAN Well, it's happened in some
20 of the other applications that we received.

21 CHAIR STETKAR: Two events in 70 years is
22 one in 35 years, which is a lot more than a hundred-year
23 event. So, it's not even a hundred-year event. You'd
24 expect it to occur once in a 30-year plant life.

25 MR. QUINLAN Well, in that case, I would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 expect that our analysis would show a greater than --
2 well, I mean, at least 120-degree temperature for the
3 hundred-year return period which, at that point I would
4 have sent an RAI to the applicant, asking them to --

5 CHAIR STETKAR: Well, you didn't go back
6 and look for that, did you?

7 MR. QUINLAN I -- I don't want to say
8 hundred percent certainty. I know I downloaded other
9 data sets.

10 CHAIR STETKAR: Okay.

11 MR. QUINLAN And I found Dallas/Fort Worth
12 to be -- to provide the -- not only the ones that are
13 most likely to recur at the site or the most
14 representative, but I think it also provided the -- the
15 most conservative estimates.

16 CHAIR STETKAR: When I looked at the local
17 meteorology data, the site, FSAR seems to say Mineral
18 Wells seems to track it a lot better than DFW.

19 MR. QUINLAN I don't know that I downloaded
20 --

21 CHAIR STETKAR: It seems to be a little
22 further away. I don't know why that is, but they seem
23 to focus on Mineral Wells rather than these DFW for a
24 few things.

25 MR. QUINLAN Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Anyway, I've raised the
2 point enough. I'm just troubled by some of these
3 things, especially when the data exists. I understand
4 if you're limited for -- you know, you're out in the
5 middle of nowhere and there hasn't been a station
6 anywhere within 50 miles for any time.

7 I understand that. But -- but in cases
8 where you have the data, I just don't understand why
9 you don't use it, and I've belabored that point too long,
10 so I'll just stop that there.

11 Let me ask you about tornados. The
12 applicant provided a table of tornado experience. It's
13 in Table 2.3-209 where they actually list tornados in
14 a -- I think it was a five-county -- I could be wrong
15 about that.

16 MR. QUINLAN No, area --

17 CHAIR STETKAR: Area. 3,414 square miles.

18 And they -- they presumed a .21 square mile average
19 tornado footprint which, you know, you can do that.

20 And they just estimated an overall tornado
21 strike frequency of 1.7 times ten to the minus four.

22 MR. QUINLAN Yes.

23 CHAIR STETKAR: That's for any intensity
24 tornado. It's just, you know, that gives you a sense
25 of -- of the tornado frequency.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 They then went back and, as I gather, in
2 response to an RAI, did the analysis -- redid the
3 analyses according to the methodology in NUREG/CR-4461,
4 and determined that the site characteristics for
5 tornados are acceptable because, according to that
6 analysis the frequency of tornados with wind speeds that
7 exceed 95th percentile confidence level of 217 miles
8 per hour is less than ten to the minus seven per year.

9
10 Okay. That's -- that's one way to do
11 things. I did it a little different way. Now, we're
12 going to get into enhanced Fujita versus Fujita
13 intensities and uncertainties about wind speeds, and
14 that -- we could take up a lot of time talking about
15 that.

16 But again, in the sense of my confidence
17 to design margins, I don't want to get into the fine
18 structure, that fine structure detail.

19 In -- in the applicant's table, they also
20 give Fujita intensities for each of the tornados, and
21 I'm assuming that's on the old Fujita scale because the
22 data were compiled from 1950 to 2006.

23 And there was one F-4 tornado in that area.

24 And, if I take their methodology of just saying an F-4
25 tornado has .21 square mile footprint which is -- which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 is actually optimistic because the big tornados have
2 big footprints. So, that's probably optimistic.

3 But if I just move that tornado around in
4 their 3414 square miles and look at the exposure period,
5 I get about a ten to the minus six strike frequency,
6 about an order of magnitude higher.

7 MR. QUINLAN Okay.

8 CHAIR STETKAR: And in old Fujita, you
9 know, terminology an F-4 was 207 to 260 miles per hour,
10 with an average of 233, which is -- let's just say close
11 to their design value of 230.

12 So, my question is, now, from that sort of
13 perspective, how do I have confidence that this
14 particular site meets the design tornado wind speed?

15 MR. QUINLAN Well, I think it's important
16 to keep in mind that the enhanced Fujita scale, which
17 is what our newest regulatory guidance is based off of,
18 dramatically reduced tornado wind speeds.

19 The old Fujita scale overestimated the
20 maximum -- maximum wind speeds in a tornado, so I went
21 with the new revision to Reg Guide -- to the Reg Guide
22 came out, then, you know, it brought all of the wind
23 speeds down.

24 So, I don't know that the -- relying on wind
25 speeds for tornados that occurred a long time ago, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 know, with the old Fujita scale really applies anymore.

2 CHAIR STETKAR: Well, I guess I don't know
3 why it doesn't. So, what -- my concern here is we're
4 talking about really small numbers of really severe
5 events.

6 We've learned that we need to be careful
7 about really small numbers for really severe events.

8 Mother Nature has taught us that sometimes we don't
9 understand those really small numbers.

10 And, from my perspective, given this
11 evidence, why aren't we at least performing a more
12 sophisticated analysis tornado strikes for this site
13 than kind of the stylized analysis in the NUREG, or even
14 the simplistic analysis that I just did, which was just
15 moving a -- you know, moving a footprint around in an
16 area.

17 MR. QUINLAN Sure. Well, I don't --

18 CHAIR STETKAR: You know, why do -- why do
19 we have confidence that the frequency of a tornado that
20 challenges that nominal 230 miles per hour is -- is less
21 than ten to the minus seven per year. That's a really
22 tiny number.

23 Now, I'm not saying anything about damage
24 to the plant, even if we do get a tornado, that it exceeds
25 230 miles per hour. That's a different story.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 But we're just saying, nominally, tornados
2 are not an issue here, and I -- I don't understand that
3 confidence.

4 MR. QUINLAN Well, they used the -- Region
5 I in Reg Guide 1.76 is the area for the most extreme
6 -- extreme -- where you would expect the most extreme
7 tornados to occur, and so that's what they based their
8 --

9 CHAIR STETKAR: That's good, because they
10 --

11 MR. QUINLAN -- characteristics on. Yes,
12 exactly.

13 So, with that, the 230-mile-an-hour maximum
14 wind speed, you know, was used and that's why I was saying
15 that's based off of the -- the enhanced Fujita scale
16 now.

17 So, I may not -- I may not be able to explain
18 --

19 CHAIR STETKAR: There's some -- as I
20 understand it -- you know, I'm not a meteorologist.
21 As I understand it, there's -- there was when -- when
22 folks transitioned to the enhanced Fujita scale a --
23 and you may correct me because you -- you do have the
24 background -- kind of a negotiated scaling that was done.

25 So there seems to be some uncertainty about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 how enhanced Fujita relates to old Fujita, if you will.

2 MR. QUINLAN Sure. Well, the --

3 CHAIR STETKAR: Recognizing that, even
4 given that, there are -- pretty uncertainty abounds in
5 those -- in those wind speed ranges.

6 MR. QUINLAN Sure. Well, the enhanced
7 Fujita scale uses a -- well, I was going to say, the
8 enhanced Fujita scale is based off of the amount of
9 damage that -- that they observed.

10 So, if there was a building that they didn't
11 think was built to withstand 150-mile-per-hour winds
12 and it was completely destroyed, then they can say that,
13 necessarily the tornado was more than 150 miles an hour.

14 The old Fujita scale was based off of, from
15 what I understand, an upper bound physical limit that
16 they understood at the time, you know, because you --
17 it's almost impossible to get direct measurements inside
18 of a tornado.

19 So I think, just as the, you know, modeling
20 got better, maybe some observations were taken using
21 some advanced radars now, yes, they worked with the
22 enhanced Fujita scale and, like you said, it is a bit
23 of a -- an estimation.

24 CHAIR STETKAR: It's an estimation and
25 there's -- there must be uncertainty. I'll let you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 speak in a second here.

2 Uncertainty involved, and my problem is,
3 because there is uncertainty and because we are talking
4 about really small frequencies.

5 MEMBER SHACK But this is a stylized design
6 basis world. I mean, you know, we -- we set up limits.

7 You know, we think those limits are big enough to
8 accommodate uncertainties but, you know, once you're
9 there, you're there.

10 And, you know, it's like saying, you know,
11 okay, I've set the limit here to account for
12 uncertainties, but now that I'm close to that limit,
13 do I really want some more, and that's just not the way
14 we do design basis world.

15 I mean, you know, if we -- if we're in a
16 different world, I'd understand your concern, but --

17 CHAIR STETKAR: Well, but some --

18 MEMBER SHACK -- in the design basis world,
19 you know, the ten to the minus seven is a fictional
20 number, too.

21 CHAIR STETKAR: That's -- but that's what
22 I was going to say. This is -- this is --

23 MEMBER SHACK But, you know, it's an
24 agreed-upon number in the Reg Guide that, you know, we
25 -- you know, we can go back and argue over that again,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 but I think, you know, it's -- it's within the Reg Guide
2 limits. It's a design basis world. It's acceptable.

3 MR. HARVEY: This is Brad Harvey with the
4 Office of New Reactors. That was one in compliance that
5 I was going to make. The Reg Guide is one acceptable
6 method that the applicant can use, and if they meet that
7 criteria in the Reg Guide then, legalistically, it
8 becomes difficult for us to challenge them to go further
9 than what we've already pointed out as -- as an
10 acceptable approach the staff has used.

11 The other point I want to make, in terms
12 of the analysis, Mr. Chairman, that you did -- and I
13 applaud you for going to a level of detail, but you talked
14 about a 2.1 square mile footprint.

15 CHAIR STETKAR: No. 4.21.

16 MR. HARVEY: 4.21.

17 CHAIR STETKAR: That's what they used.
18 They -- they actually had some path linked information
19 and you know how the data are. You don't get that path
20 linked information --

21 MR. HARVEY: No.

22 CHAIR STETKAR: -- very well --

23 MR. HARVEY: But the point I was trying to
24 make is that you've got the -- in a four tornado, that
25 is theoretically the highest intensity in that tornado,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 but the entire footprint is not in that four. It's going
2 to be other -- and the assumptions are, when the Reg
3 Guide -- was it 4461, made the assumption that it wasn't
4 all a hundred percent F-4 footprint.

5 CHAIR STETKAR: Yes. No.

6 MR. HARVEY: So, I think that would bring
7 your strike probabilities up a little bit.

8 CHAIR STETKAR: Well, as I said, I was --
9 I was just trying to get ballpark numbers out of this,
10 and they used a .21 based on the information they had
11 from the -- however many tornados there were in the --
12 in their database. I've lost it already.

13 Some -- some number of tornados. A hundred
14 -- 158 tornados, but they didn't have path links for
15 nearly all of those. They just took a limited -- they
16 just added them up and divided by n and said, well, it's
17 .21, and applied that to -- whether it was an F-1 or
18 an F-4 or anything.

19 So, it's -- there's a lot of uncertainty
20 in that, obviously, also, not even getting into the
21 distribution of the -- of the peak wind speed over the
22 -- you know, the cross-section of the tornado.

23 My point here is not to try to get into
24 details of the calculation. My point is trying to probe
25 and see how much analysis should be done to develop a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 -- a level of confidence in margins.

2 For example, I looked at the probable
3 maximum precipitation. I don't understand what a
4 hundred-year probable maximum precipitation is, but I
5 looked at all of those estimates, and the margins are
6 so large -- you didn't hear me asking about those
7 absolute values.

8 I was asking about temperature because
9 there's a data point. I was asking about tornados
10 because it's not clear to me.

11 I didn't ask about hurricanes even because,
12 although the stylized 61 miles per hour, there's still
13 a lot of margin there. But in areas where --

14 MR. HARVEY: Well, would you -- a hurricane
15 and a tornado, there's no question which winds at this
16 site.

17 CHAIR STETKAR: No, that's right. There's
18 absolutely no question, but even in the sense of
19 hurricanes -- but my point is, in places where we do
20 a simple stylized -- we can call it a design basis
21 analysis or a stylized analysis, and it indicates that
22 we -- we might not have a very large margin, there doesn't
23 seem to be any emphasis of going beyond that and saying
24 can we -- do we need to fine-tune it a little bit. It's
25 just a -- a pass/fail.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And I understand one of the philosophies
2 of it's a design basis is the design basis is the design
3 basis, but --

4 MR. HARVEY: Well, you know, I mean, we
5 could do a best estimate with uncertainties and, you
6 know, you get very different answers when you do that
7 and it's a different approach.

8 We've decided that both are acceptable and,
9 you know, but to somehow ask to do the design basis plus
10 the uncertainty analysis is -- you know, that's -- it's
11 sort of a mix and match kind of thing and --

12 Now, you might have a better argument for
13 arguing if the ten to the minus six wind speed is 191
14 miles an hour, did we suddenly see the hundred -- the
15 ten to the minus six tornado.

16 CHAIR STETKAR: Well, that's another way
17 of looking at it.

18 MEMBER SHACK That's another way of looking
19 at it.

20 CHAIR STETKAR: But there is some chance
21 that we have.

22 MR. HARVEY: Yes, there is. There is.

23 CHAIR STETKAR: I mean, there is --

24 MR. HARVEY: I mean, you know, there's some
25 chance that we have -- you know, I'd be more sympathetic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 if you argued that there was something wrong with the
2 way we came up with the design basis than I am, you know,
3 once we make the argument that, you know, we've got the
4 design basis, and now we -- now we did a let, but --

5 CHAIR STETKAR: I -- I just sort of raised
6 the issue. I -- I -- in those two particular areas,
7 temperature, where you might gain more confidence
8 looking at a broader set of meteorological data, and
9 -- and tornados where, depending on different ways of
10 doing the analysis, you might have different conclusions
11 about a ten to the minus seven exceedance frequency for
12 a 230-mile-per-hour design basis wind speed.

13 I'll just raise it and leave it there. I
14 -- I personally feel uncomfortable. Bill doesn't,
15 obviously, you know, and in the subcommittee meetings
16 all you're hearing is feedback from individual members
17 of the subcommittee which, you know is not an ACRS
18 opinion. So I'll just leave it there.

19 Anything else on meteorology from anyone
20 else who likes rainfall and wind speeds and all that
21 stuff?

22 (No response.)

23 CHAIR STETKAR: Okay.

24 MR. QUINLAN I only have a little bit more.

25 CHAIR STETKAR: Good.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. QUINLAN Yes, so we're on 2.3.3.
2 US-APWR COL Information Item 2.3.1 states the applicant
3 should describe site-specific on-site meteorological
4 measurements program. Section 2.3.3 describes a review
5 of this program. That addresses this information item.

6 The staff determined the applicant
7 adequately provided all the relevant information in FSAR
8 Section 2.3.3. The staff verified the location of the
9 meteorology towers representative of the site area and
10 meets the guidance provided in Regulatory Guide 1.2.3
11 in Revision 1.

12 Next slide, please. SER Section 2.3.4
13 describes the review of the short-term atmospheric
14 dispersion estimates or chi/Q values that are used to
15 evaluate design basis accidental releases to the
16 exclusion area boundary, the outer boundary of the
17 low-population zone and the control room.

18 US-APWR COL Information Item 2.3, Part 2,
19 states that the applicant should provide site-specific
20 short-term atmospheric dispersion estimates.

21 Using NRC-approved computer models, the
22 applicant provided this information and staff has
23 accepted it as correct and adequate.

24 US-APWR COL Information Item 2.3, Part 3,
25 states that the applicant shall provide site-specific

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 atmospheric dispersion estimates for routine releases
2 of radioactive materials to the atmosphere.

3 SER Section 2.3.5 describes a review of
4 long-term atmospheric dispersion estimates that are
5 used to evaluate releases of radiological effluence to
6 the atmosphere during normal plant operation.

7 Again, using NRC-approved computer models,
8 the applicant provided the information and the staff
9 accepted it as correct and adequate.

10 Next slide. In conclusion, all the
11 Comanche Peak site characteristics presented in FSAR
12 Section 2.3 have been found to be acceptable and bounding
13 -- or bounded by the corresponding US-APWR site
14 parameters.

15 Section 2.3 of the Comanche Peak COL FSAR
16 has been reviewed by the staff and been found to adhere
17 to all regulatory requirements.

18 Section 2.3 of the SER has been submitted
19 with no open items -- sorry -- one open item. No
20 exemptions and no departures. The one open item is
21 related to updated control room chi/Q values as part
22 of the integrated seismic closure plan. Thank you.

23 CHAIR STETKAR: Great. Anything else for
24 the staff?

25 (No response.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: If not, thank you. It's
2 probably more than you expected.

3 What I'd like to do, get the bridgeline
4 open. We need to ask for comments.

5 I'll ask for any comments or questions from
6 anyone in the room if we have any. We'll get the
7 bridgeline open and see if anyone out there wants to
8 add anything. It sounds like a crackle pop.

9 Well, if someone is out there, just please
10 make some utterance so that we can confirm the bridgeline
11 is open. Just say something. Is someone trying to
12 speak?

13 Honestly, if someone said something I --
14 we -- it sounded like something was coming through, but
15 it was really garbled. So, if someone's out there,
16 could you actually try to say something again, please.

17 I guess not. I thought I heard something.

18 MEMBER SHACK Well, I think we heard a
19 random noise.

20 CHAIR STETKAR: Okay.

21 MEMBER SHACK But, if we can't repeat it,
22 we'll assume it was random, rather than purposeful.

23 CHAIR STETKAR: So, hearing no comments,
24 I would like to thank the staff and Luminant for a good
25 presentation. I think we have some things to follow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 up in other chapters of -- of the FSAR 3 and 6, in
2 particular.

3 And let me do what we always do. Joy, any
4 final comments?

5 MEMBER REMPE: No.

6 CHAIR STETKAR: Charlie?

7 MEMBER BROWN: Negative.

8 CHAIR STETKAR: Bill?

9 MEMBER SHACK No.

10 CHAIR STETKAR: I don't have anything, and
11 occasionally miracles do happen. We are adjourned.
12 Oh. On time.

13 (Whereupon, the meeting was concluded at
14 11:44 a.m.)

15

16

17

18

19

20

21

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



US-APWR Chapter 7 Presentation for ACRS

April 25-26, 2013

Mitsubishi Heavy Industries, Ltd.

Contents



1. Introduction.....	Slide 2
2. Safety Related Systems.....	Slide 9
3. Non Safety Systems.....	Slide 21
4. Diverse I&C Systems.....	Slide 33
5. Safety Criteria Conformance.....	Slide 41
6. Open Items.....	Slide 82
7. Summary.....	Slide 85

1. Introduction



Topics

- ✓ Topical/Technical Reports
- ✓ I&C Systems
- ✓ Main Control Room Layout
- ✓ System Architecture
- ✓ Data Flow to External Networks

1. Introduction



Topical / Technical Reports

DCD	Design Bases, Requirement & Description				Analysis, Evaluation & Methodology, etc.
	I&C System	HSI System	Hardware Basic Software	Application Software	
7.1	MUAP-07004	MUAP-07007	MUAP-07005	MUAP-07017	MUAP-07030 & 08015
7.2		-		-	MUAP-09022 & 11014
7.3		-		-	MUAP-09020 & 09022
7.4		-	-	-	-
7.5		MUAP-07007	-	-	MUAP-07014 08015 & 09022
7.6		MUAP-07007	-	-	-
7.7		-	MUAP-07005	-	-
7.8	MUAP-07006			-	MUAP-07014 & 09022
7.9	MUAP-07004	-	MUAP-07005	MUAP-07017	MUAP-07014 & 09021

- MUAP-07004: Safety I&C System Description and Design Process
- MUAP-07005: Safety System Digital Platform -MELTAC-
- MUAP-07006: Defense-in-Depth and Diversity
- MUAP-07007: HSI System Description and HFE Process
- MUAP-07014: Defense in Depth and Diversity Coping Analysis
- MUAP-07017: Software Program Manual
- MUAP-07030: US-APWR Probabilistic Risk Assessment
- MUAP-08015: US-APWR Equipment Qualification Program
- MUAP-09020: Function Assignment Analysis for Safety Logic System
- MUAP-09021: Response Time of Safety I&C System
- MUAP-09022: Instrument Setpoint Methodology
- MUAP-11014: Mitsubishi Design Bases for Over Temperature ΔT and Over Power ΔT Reactor Trip Functions

1. Introduction



I&C Systems

- **Protection and Safety Monitoring System (PSMS)**
 - ✓ Four train redundant, fully digital system for safety-related I&C
- **Plant Control and Monitoring System (PCMS)**
 - ✓ Duplex redundant, fully digital system for non-safety I&C
- **Diverse Actuation System (DAS)**
 - ✓ Analog system that is hardwired for diverse and independent control
- **Main Control Board (MCB)**
 - ✓ Consists of the large display panel (LDP), safety VDUs (S-VDUs), non-safety VDUs, and conventional switches
- **Data Communication System (DCS)**
 - ✓ Consists of multi-drop networks and point to point data links, fully redundant, self-testing

1. Introduction




Main Control Room Layout



1. Introduction

System Architecture



DAS : Diverse Action System PSMS : Protection and Safety Monitoring System HSIS : Human System Interface System PCMS : Plant Control and Monitoring System

DCD Figure 7.1-1

1. Introduction



Data Flow To External Networks (1/2)

- **DCD Section 7.9 describes:**
- **Data flow to the station bus**
 - ✓ The station bus provides information to plant and corporate personnel and to EOF and ERDS
 - ✓ The station bus receives information from DCS via the unit management computer
 - ✓ The unit management computer provides a firewalled interface, which allows only outbound communication
 - ✓ There are no other connections from external sources to DCS
- **Data flow to the external networks**
 - ✓ The only interface from the PCMS and PSMS to external networks is via the firewall within the unit management computer
 - ✓ The unit management computer provides an outbound only interface to the plant station bus to allow communication to EOF computers, the NRC (via ERDS), corporate information systems and plant personnel computers

1. Introduction

Data Flow To External Networks (2/2)

- MHI feels it is necessary to add a hardware device (e.g., data diode) to ensure unidirectional data flow from PSMS and PCMS to the station bus and the external networks in DCD Chapter 7.9



2. Safety Related Systems



Protection and Safety Monitoring System Topics

- ✓ PSMS Scope
- ✓ Configuration of Reactor Protection System (RPS)
- ✓ Configuration of Engineered Safety Features Actuation System (ESFAS) and Safety Logic System (SLS)
- ✓ PSMS Interfaces
- ✓ PSMS Data Communication Systems
- ✓ Systems Required for Safe Shutdown
- ✓ Safety-Visual Display Unit (S-VDU)
- ✓ Interlock Systems Important to Safety
- ✓ Information Systems Important to Safety
- ✓ Reactor Trip on Turbine Trip
- ✓ Turbine Trip on Reactor Trip

2. Safety Related Systems



PSMS Scope

- **PSMS consists of five digital subsystems:**
 - 1) Reactor Protection System (RPS)
 - 2) Engineered Safety Features Actuation System (ESFAS)
 - 3) Safety Logic System (SLS)
 - 4) Communication Subsystem (COM)
 - 5) Safety-related human system interface system (HSIS)


- **I&C safety functions of US-APWR are implemented using one or more of these subsystems**

2. Safety Related Systems



Configuration of RPS

- Trip functions are distributed to 2 controllers per train to achieve functional diversity




DCD Figure 7.2-1

2. Safety Related Systems

Configuration of ESFAS and SLS

➤ Redundant controllers within each train increases reliability



DCD Figure 7.3-1

2. Safety Related System



PSMS Interfaces

- **PSMS interfaces with safety sensors and actuators**
- **PSMS interfaces with the following non-safety I&C systems:**
 - ✓ Non-safety Human System Interface System (HSIS)
 - ✓ Reactor Control System
 - ✓ Turbine Protection System
 - ✓ BOP Control System
 - ✓ Diverse Actuation System
- **Interfaces with other systems do not negatively impact functions of PSMS due to PSMS independence**

2. Safety Related Systems



PSMS Data Communication Systems (DCS)

- **There are only two types of inter-divisional data communication interface methods applied in the PSMS**
 - ✓ Point-to-point Data Link
 - Between RPS trains for partial trip
 - Between RPS and ESFAS for partial ESF actuation
 - Between multi-divisional S-VDU trains for monitoring information
 - ✓ Multi-drop Network
 - Between PSMS and non-safety systems via Unit Bus for monitoring and control information to non-safety systems, and manual control commands from O-VDUs
- **PSMS safety function is ensured by functional and communication independence**
 - ✓ Failure of one PSMS division does not negatively impact functions of other PSMS divisions
 - ✓ Failure of non-safety system does not negatively impact functions of any PSMS division

2. Safety Related Systems



Systems Required for Safe Shutdown

- Normal shutdown can be achieved and maintained using Operational VDUs (O-VDUs) from MCR or RSR
- Safe Shutdown (hot and cold) can be achieved and maintained using only PSMS from MCR or RSR
- S-VDUs or O-VDUs can be used with PSMS to achieve safe shutdown from MCR or RSR
- MCR-RSR Master Transfer switches are provided for each PSMS train and PCMS
- Master Transfer switches are located on the pathway between MCR and RSR, and within RSR (2/2 actuation)

2. Safety Related Systems



Safety VDU (S-VDU)

- **S-VDU consists of S-VDU processor and S-VDU panel**
- **There are two type of S-VDUs:**
 - ✓ Single divisional S-VDU
 - Four train redundant
 - Control and monitor all safety related functions of each safety train
 - ✓ Multidivisional S-VDU
 - Two train redundant
 - S-VDU display parameters from all four trains for accident mitigation and safe shutdown
 - This S-VDU has no control capability
- **S-VDU consists of the same digital platform as PSMS and satisfies all safety criteria and requirements**

2. Safety Related Systems



Interlock Systems Important to Safety

- **Interlocks implemented in PSMS are credited in DCD Chapter 15 to prevent accidents and to help ensure availability of safety systems**
- **Interlocks important to safety are:**
 - ✓ CS/RHR Hot Leg Isolation Valve Open Permissive Interlock
 - ✓ CS/RHR Valve Open Block Interlock
 - ✓ Primary Makeup Water Line Isolation Interlock
 - ✓ Accumulator Discharge Valve Open Interlock
 - ✓ CCW Supply Line Isolation Interlock
 - ✓ RCP Thermal Barrier HX CCW Return Line Isolation Interlock
 - ✓ Low-pressure Letdown Line Isolation Interlock

2. Safety Related Systems




Information Systems Important to Safety

- **Post Accident Monitoring (PAM)**
- **There are five types of PAM parameters:**
 - ✓ Type A – credited manual actions
 - ✓ Type B – critical safety functions
 - ✓ Type C – potential breach of fission product barriers
 - ✓ Type D – performance of safety systems
 - ✓ Type E – radioactive release
- **Type A and B parameters have spatially dedicated continuously visible displays on S-VDUs and LDP**
- **Type A, B and C parameters have Class 1E power, are processed by PSMS, and are displayed on S-VDUs**
- **The performance of PAM variables, such as range, accuracy, response time, required instrumentation duration, and reliability, have been selected in accordance with Clause 5 of IEEE 497-2002**
- **The selection basis for PAM variables to demonstrate complete accident coverage is an Open Item**

2. Safety Related Systems



Reactor Trip on Turbine Trip




- Anticipatory trip functions, and not credited in DCD Chapter 15 analysis
- Cannot be Class 1E due to non-safety turbine and non-seismic turbine building location, but designed to be highly reliable:
 - ✓ Seismically and environmentally qualified sensors
 - ✓ Powered from Class 1E sources
 - ✓ Diverse and redundant sensors
 - ✓ Separation of sensors and cables
 - ✓ Both RT functions are maintained by Tech Spec., including periodic surveillance tests

2. Safety Related Systems



Turbine Trip on Reactor Trip



- Turbine Trip Signal from PSMS and Turbine Protection System are combined (1-out-of-2 logic) in hardwired portions of PIF module
- Turbine Protections System is a dedicated system, consists of four redundant digital sub-systems
- Turbine Control System is a dedicated system, consists of duplex redundant digital sub-systems
- Independent sensors, including speed sensors, are used for Turbine Protections System and Turbine Control System

3. Non Safety Systems



Plant Control and Monitoring System Topics

- ✓ Plant Control System
- ✓ Shared Sensors
- ✓ Alarms for Credited Manual Actions
- ✓ Non-Safety Data Communication Systems (DCS)
- ✓ Information Systems
- ✓ Operational Visual Display Unit (O-VDU)
- ✓ Turbine Bypass Valves Interlock

3. Non Safety Systems



Plant Control Systems

- **Non-safety systems are controlled by PCMS**
- **Control functions are distributed to multiple PCMS controller groups to ensure transients due to spurious signals from one control group are bounded in DCD Chapter 15 AOOs analysis**
- **Controller redundancy and distributed functions to multiple control groups minimize the potential for single or complete control function failure**
- **Input and Output (I/O) redundancy applied to components (e.g., I/O for feedwater regulation valves) that could cause plant trip**
- **Spurious actuations cause by PCMS failures, including software design defects, are being examined for plant affects as an Open Item**

3. Non Safety Systems



Shared Sensors

- **PCMS shares sensors with RPS for many control functions**
 - ✓ Sensor sharing reduces pressure boundary penetrations and local maintenance work in accordance with ALARA
- **PCMS avoids adverse control/protection interaction by using multiple redundant sensors and the Signal Selection Algorithm (SSA)**
 - ✓ SSA selects 2nd highest of 3 or 4 sensors
- **Sensor failure does not cause adverse control system actions while PSMS is in a degraded state from that same sensor failure (IEEE-603)**
- **Augmented quality has been applied to SSA**

3. Non Safety Systems




Alarms for Credited Manual Actions (1/2)

- **In accordance with SECY-93-087, the reliability of alarms to prompt manual actions credited in the safety analysis is assured by the following design features:**
 - ✓ Redundancy is provided for all HSI alarm components
 - ✓ Separation between redundant segments is provided
 - ✓ Testability is provided from self-diagnosis of PSMS, PCMS and HSI computers
 - ✓ Alarm functions have Augmented Quality
 - ✓ In addition to alarms, abnormal indications for credited manual operator actions are provided on safety VDUs

3. Non Safety Systems



Alarms for Credited Manual Actions (2/2)



3. Non Safety Systems



Non-safety Data Communication Systems (DCS)

- **DCS is non-safety and consists of the plant-wide Unit Bus and Station Bus**
- **Unit Bus interfaces with all I&C systems of US-APWR including information and controls for MCR, RSR, and TSC**
- **Unit Bus interfaces with Station Bus, which is an information technology network via the unit management computer**
- **Station Bus is the plant's information technology network, provides information to NRC via ERDS, to EOF and to plant personnel, it contains systems such as:**
 - ✓ Work order management
 - ✓ Personnel management
 - ✓ Long term data archiving

3. Non Safety Systems



Information Systems

- **Non safety information systems include safety parameter display system and bypassed and inoperable status indication**
 - ✓ Safety parameter display system (SPDS)
 - Key parameters for critical safety functions and dynamic safety function status trees (per EOPs)
 - Key parameters for performance of normal and emergency systems used to maintain/restore critical safety functions
 - ✓ Bypassed and inoperable status Indication (BISI)
 - Availability status of emergency systems for all critical safety functions
- **Displayed in MCR, RSR, TSC, and EOF**

3. Non Safety Systems



Operational VDU (O-VDU) (1/3)

- **Non-safety components and safety components in all divisions, can be operated from non-safety O-VDUs**
- **PSMS protects itself from any adverse interaction from O-VDUs based on compliance with IEEE 603 independence criteria**
 - ✓ Physical and Electrical independence
 - ✓ Communication independence
 - ✓ Functional independence (priority for all safety functions, including S-VDUs)
- **O-VDUs enhance plant safety by**
 - ✓ Reducing operator task burden resulting in:
 - Reduced time for operator actions, improved margin to safety
 - More mental resources available for plant-wide situation awareness
 - ✓ Reducing potential for human performance errors
- **Safety enhancements have been validated through full scope simulator testing using 13 crews of US SROs and ROs**

3. Non Safety Systems



O-VDU (Hyperlink Design) (2/3)


- Hyperlinks among the non-safety HSIs reduce operator task burden, potential for human errors, and time required for safety action responses

Alarm VDU




O-VDU

Hyperlinks



Hyperlinks


Procedure VDU



3. Non Safety Systems



O-VDU (Graphical User Interface GUI) (3/3)




- GUI reduces mental processing time for both monitoring and control actions
- GUI reduce the potential for operator selecting the wrong component
- Using the same screen, allows a single operator to coordinate safety and non-safety success paths more easily than two operators at separate interfaces

- Safety is enhanced when time for operator action is reduced, potential for errors is reduced, and tasks are simplified
- MHI is in the process of quantitatively evaluating the safety advantages of O-VDU use in response to an Open Item

3. Non Safety Systems



Turbine Bypass Valves Interlock (1/2)




- Erroneous Turbine Bypass Control signals are prevented by the PSMS which controls redundant non-Class 1E permissive solenoids from SLS trains A and D
- Turbine Bypass Control function output signals are provided by the reactor control system in PCMS to I/P converters and trip open solenoids

3. Non Safety Systems



Turbine Bypass Valves Interlock (2/2)



- **Block Turbine Bypass Valve signal is generated under the following conditions:**
 - 2-out-of-4 RCS loops indicate low-low T_{avg}
 - Turbine inlet pressure via SSA does not indicate the rate of decrease in the turbine load
 - Condenser is not available
- **At hot full power, condition b is established, and Block Turbine Bypass Valve signals are generated in PSMS trains A and D**

Diverse Actuation Systems Topics


- ✓ Basic Architecture
- ✓ DAS Function
- ✓ Actuated Components
- ✓ Monitored Variables
- ✓ Diverse RT and ESF Actuation Signal Selection
- ✓ D3 Coping Analysis
- ✓ Augmented Quality

4. Diverse I&C Systems



Basic Architecture

- ✓ For RT DAS trips MG-Set and PSMS trips RTB
- ✓ For ESF DAS and PSMS share PIF



- Four divisions, actuated automatically or manually via the diverse HSI panel, and is seismically qualified
- D3 Coping analysis shows critical safety functions are maintained to achieve hot standby despite CCF, with concurrent accident, fire, flood or seismic events


4. Diverse I&C Systems



DAS Function

- Actuated if accident is detected and safety components are not actuated successfully

e.g., no reactor trip, turbine trip, SI pump actuation or EFW pump actuation



Note: Actuation status signal (aux. contact etc.) via hardware of the PSMS

4. Diverse I&C Systems



Actuated Components

Safety Function or Associated Components	Actuation Type
Diverse Reactor Trip (Motor-Generator Set Trip)	Automatic/Manual (MCR)
Turbine Trip	Automatic/Manual (MCR)
EFW Pump	Automatic/Manual (MCR)
Safety Injection Pump	Automatic/Manual (MCR)
Safety Depressurization Valve	Manual (MCR)
Main Steam Depressurization Valve	Manual (MCR)
SG Blowdown Isolation Valve	Automatic/Manual (MCR)
MFW Regulation Valve (Close)	Automatic/Manual (MCR)
EFW Control Valve	Manual (MCR)
Containment Isolation Valves	Manual (MCR)
Main Steam Line Isolation Valve	Manual (MCR)

Sourced from DCD Table 7.8-5

4. Diverse I&C Systems



Monitored Variables

Critical Safety Function	Variables	Number of Channel
Reactivity Control	Wide Range Neutron Flux	1
RCS Integrity	Pressurizer Pressure *	1
	Reactor Coolant Pressure	1
Core Heat Removal	Reactor Coolant Cold Leg Temperature	1 per Loop
RCS Inventory Control	Pressurizer Water Level	1
Secondary Heat Sink	SG Water Level *	1 per SG
	Main Steam Line Pressure	1 per SG
Containment Integrity	Containment Pressure	1

* These variables are used for automatic actuation functions

DCD Table 7.8-2

4. Diverse I&C Systems



Diverse RT and ESF Actuation Signal Selection

- **DAS has three automatic diverse RT and ESF actuation signals:**
 - ✓ High pressurizer pressure
 - ✓ Low pressurizer pressure
 - ✓ Low steam generator water level
- **These signals were selected to be the minimum set required to mitigate occurrence of a Chapter 15 AOO or PA concurrent with a CCF**
- **Adequacy of these three DAS RT and ESF actuation signals is demonstrated by D3 coping analysis**

4. Diverse I&C Systems



D3 Coping Analysis

- **Demonstrates pressure boundary integrity, core coolability, and offsite dose limits for Chapter 15 events with concurrent CCF**
- **Analysis considers partial actuation and failure to actuate with false indications**
 - ✓ **Partial Actuation**
 - AOO and PA analyzed with failure of PSMS and PCMS, failure of only PSMS
 - The only failure of concern is a partial failure that blocks DAS, this could occur due to:
 - Conflicting Commands - Mitigated by PIF state based priority logic
 - Erroneous Blocking Signals – Mitigated by blocking signals hardwired from actuated plant components, not PSMS
 - Erroneous actuation of components not monitored by DAS – Mitigated by normally open valves in series with pumps monitored by DAS, and abnormal valve position alarms
 - ✓ **Failure to actuate with false indication that actuation has occurred**
 - Analysis demonstrates this would require CCF of multiple software blocks which is beyond the scope of BTP 7-19
- **MHI is justifying the inputs and assumptions of D3 Coping Analysis in response to an Open Item**

4. Diverse I&C Systems



Augmented Quality

- **DAS is an augmented quality, non-safety system, as defined by Generic Letter 85-06 and described in Subsection 7.1.3.20**
- **Attributes of the augmented quality program of DAS are:**
 - ✓ Designed using a nuclear quality program that meets the US-APWR QAP descriptions and the guidance of GL 85-06
 - ✓ Uses components with a history of successful operation
 - ✓ Uses components commonly used in conventional non-digital safety systems
 - ✓ Design process includes an independent review
 - ✓ Seismic testing method is equivalent to that for seismic category I

5. Safety Criteria Conformance



Essential Safety Criteria

- ✓ Overview
- ✓ Redundancy
- ✓ Independence
 - Physical, Electrical, Communication, Functional
- ✓ Determinism
- ✓ Diversity
 - Software, Functional
- ✓ Simplicity
- ✓ Testability
- ✓ Reliability
- ✓ Quality
- ✓ Equipment Qualification
- ✓ Secure Development & Operational Environment (SDOE)

5. Safety Criteria Conformance



Overview


- **DCD and related I&C reports demonstrate PSMS design conformance to essential safety criteria**
- **Overall conformance to the essential safety criteria is described in DCD Chapter 7 Section 7.1.4**
- **Detailed conformance is described in “Safety I&C System Description and Design Process,” MUAP-07004**
 - ✓ Section 3.0 “Applicable Code, Standards and Regulatory Guidance”
 - ✓ Appendix A “Conformance to IEEE 603”
 - ✓ Appendix B “Conformance to IEEE 7-4.3.2”
 - ✓ Appendix F “Safety-related Digital I&C Design Detail Conformance to Essential Safety Criteria”

5. Safety Criteria Conformance



Redundancy

A/D: Analog to Digital Converter
 PIF: Power Interface
 RTB: Reactor Trip Breaker



➤ PSMS consists of 4 redundant and independent trains

➤ RPS performs its function with any 2-out-of-4 trains tripped

➤ The ESFAS, SLS, COM and HSIS perform their function by any 2-out-of-4 trains to actuate safety systems with 50% capability, or any 1-out-of-2 trains with 100% capability, depending on the mechanical system design

5. Safety Criteria Conformance



Independence


- **Independence of the redundant PSMS divisions is achieved through four methods:**
 - ✓ Physical Independence
 - ✓ Electrical Independence
 - ✓ Communication Independence
 - ✓ Functional Independence
- **Methods of ensuring Physical, Electrical and Communication independence are common throughout the entire PSMS**
- **Functional independence is application dependent**

5. Safety Criteria Conformance



Physical Independence

- Four PSMS trains are separated into four I&C equipment rooms
- Four Reactor Trip Breaker (RTB) trains are separated into two equipment rooms, which are separated from the Motor Generator (M/G) set room
- PCMS is located in the Non-Safety I&C equipment room




* Wall mounted MCR/RSR Transfer Switches, one is located outside MCR fire zone, and another in RSR

5. Safety Criteria Conformance



Electrical Independence (1/3)




- Each PSMS train is electrically independent from each other and from the non-safety systems
- Electrical independence between PSMS trains, between PSMS and PCMS, and between MCR, RSR, and I&C equipment rooms is maintained through qualified fiber optic data cables (**red lines**)
- Electrical independence between PSMS and DAS is maintained through qualified conventional electrical signal isolation devices (**green lines**)
- Electrical independence between PSMS power sources is maintained through conventional electrical power isolation devices (**blue lines**)

5. Safety Criteria Conformance



Electrical Independence (2/3)

Optical Fiber Isolation



- Optical fiber isolation is used for the digital interfaces in PSMS
- Fiber cables are constructed using only non-conducting materials to ensure inherent blocking of electrical faults

E/O: Electrical/Optical Converter
O/E: Optical/Electrical Converter


5. Safety Criteria Conformance




Electrical Independence (3/3)

- Conventional type isolation modules are used for hardwired interfaces, for the DAS, to and from the PSMS, etc.
- Isolation modules are qualified for non-safety side faults of AC480Vrms+10% and \pm DC270V in both transverse and common modes by the isolation tests

Analog Isolation Module



Digital Isolation Module



5. Safety Criteria Conformance




Communication Independence (1/4)

- **Data is communicated between PSMS divisions, and between PSMS and PCMS (O-VDU)**
- **Communication independence allows two digital systems to exchange data while ensuring there is no potential for one digital system to alter the execution of the other digital system in any way**
- **The PSMS meets all communication independence guidance of DI&C ISG-04**
- **There are only two types of on-line inter-division communication interface methods applied in the PSMS**
 - ✓ Point-to-point Data Link for communication between RPS trains, and between RPS and ESFAS
 - ✓ Multi-drop Network for Unit Bus Interface to the PSMS
- **Both types of communication ensure independence by using two port memory, separate communication processors and unalterable memory**

5. Safety Criteria Conformance




Communication Independence (2/4)



- All communication uses 2-Port memory with a separate communication controller and CPU function processor
- Functional processors access 2-port memory asynchronously
- Transmitted signals have pre-defined format, length, and message content

5. Safety Criteria Conformance

Communication Independence (3/4)



- **Controllers are interconnected over redundant optical networks**
- **Signals are transmitted continuously regardless of data change**
- **Each node maintains a memory map of the entire network, each controller reads only what it needs for its application programs**



5. Safety Criteria Conformance



Communication Independence (4/4)


➤ On-line F-ROM Alteration Protection

On-line Module Chassis




The write enable signal is disabled, therefore the F-ROM cannot be re-programmed.

Dedicated Re-programming Chassis



Remove the CPU module and move to the re-programming chassis for re-writing



The write enable signal is enabled and, therefore the F-ROM can be re-programmed.



Re-programming

➤ ROM/FPGA is only reprogrammable outside of the module chassis and only at the factory (the code and reprogramming tools are not provided to end-users)

5. Safety Criteria Conformance




Functional Independence (1/5)

- **Each PSMS division receives data from outside its own division:**
 - ✓ From other PSMS divisions
 - ✓ From the PCMS (O-VDU)
 - ✓ From DAS
- **Functional Independence ensures the data received from outside the division cannot adversely affect the safety function being performed within the division**
- **Functional Independence is explained individually for each section of the PSMS – RPS, ESFAS, SLS**
- **The detailed conformance is described in Technical Report “Safety I&C System Description and Design Process,” MUAP-07004**
 - ✓ Appendix F “Safety-related Digital I&C Design Detail Conformance to Essential Safety Criteria”

5. Safety Criteria Conformance

Functional Independence (2/5)



- **The following signals are received from across the PSMS train boundaries:**
 - ✓ Reactor and ESFAS partial trip status signal for two-out-of-four trip voting logics
 - ✓ Bypass status signal of each trip parameter for bypass interlocks, bypass allows channel to be tested and allows failed channel to be taken out of service

- **Authenticated messages can have spurious data or frozen data, each train protects itself to ensure the safety function is not affected**
 - ✓ Partial Trip
 - 2-out-of-4 logic prevents a spurious trip and ensures a trip when there are single failures
 - If all inter-division data communication fails, each division will initiate Reactor Trip and ESFAS
 - ✓ Bypass
 - First-in blocking logic prevents more than one bypassed channel

5. Safety Criteria Conformance



Functional Independence (3/5)

- **The following HSI signals are transmitted to the PSMS from the Operational VDUs of the non-safety PCMS:**
 - ✓ Component Position commands (on/off, open/close)
 - ✓ Maintenance Bypass commands
 - ✓ Operating Bypass commands
 - ✓ ESFAS Reset commands
 - ✓ Component Lock commands


- **For all signals, unalterable priority logic within the PSMS ensures each PSMS division protects itself so that its safety function cannot be adversely affected**

5. Safety Criteria Conformance




Functional Independence (4/5)

Typical Priority Logic For Manual Operational Signals



- The priority logic within the SLS of each train ensures Class 1E interlocks or ESFAS signals have priority over all manual component position commands, including commands from O-VDU
- All safety components controlled from O-VDUs have ESFAS or Class 1E interlock

5. Safety Criteria Conformance




Functional Independence (5/5)

- The PIF module, PSMS and DAS use common conventional solid state circuits
 - ✓ There is no potential for software CCF
- The non-safety DAS interface is hardwired with conventional isolators
 - ✓ There is no digital communication
- PIF logic ensures priority is given to the safety function
 - ✓ It is state based, not system based
 - ✓ It ensures failures of active PSMS or DAS cannot block the safety function

5. Safety Criteria Conformance



Determinism (1/2)



- All functions execute cyclically with single task processing
- Inputs from input modules and data communication modules, are updated cyclically, but asynchronously, from periodic function processing
- The function processor reads data cyclically from two port memory.
- Self-diagnostics run with no affect on the pre-defined fixed deterministic time cycle
- There are no interrupts, except by self-diagnostics
- Time cycle cannot be disrupted by other trains or Unit Bus

5. Safety Criteria Conformance




Determinism (2/2)

➤ Response Time

- ✓ Each module runs in a cyclical deterministic sequence
 - Worst case (basis of safety analysis)
Input is updated just after input polling (T_{max})
- ✓ Calculation Result
 - Worst case response time is
 $T1_{max} + T2_{max} + T3_{max} + T4_{max} + T5_{max} + T6_{max} + T7_{max}$

➤ ITAAC confirms the detailed design meets response time requirements as defined in Technical Report "Response Time of Safety I&C System," MUAP-09021


- ✓ 300 msec max for digital throughput for reactor trip functions



5. Safety Criteria Conformance



Interface between PSMS and DAS System




Diversity for Software CCF

- Conventional, analog/binary DAS is provided per BTP 7-19, to accommodate beyond design basis CCFs that could adversely affect PSMS and PCMS, with a concurrent AOO or PA
- DAS provides automated reactor trip, turbine trip, MFW Isolation, EFW actuation and ECCS actuation
- DAS allows operator to monitor the critical safety functions and manually actuate safety system to achieve and maintain safe shutdown

5. Safety Criteria Conformance

RPS Functional Diversity (1/2)

Two Separate Sub-systems in each RPS train



5. Safety Criteria Conformance



RPS Functional Diversity (2/2)

- Two diverse parameters are used to detect an event and initiate protective actions
- Processed in two separate Controller Groups in each train
- The PRA shows significant benefit from functional diversity

Protection	Group-1	Group-2
Over Power	Over Power Delta-T High PR Neutron Flux Rate High	PR Neutron Flux High
Core Heat Removal	RCP Speed Low Over Temp. Delta-T High	RC Flow Low Pressurizer Press. Low
Loss of Heat Sink	SG Water Level Low Pressurizer Water Level High	Pressurizer Press. High
Nuclear Startup	SR Neutron Flux High IR Neutron Flux High	PR Neutron Flux High (Low Setpoint)
Primary Over Pressure	Pressurizer Water Level High	Pressurizer Press. High
Loss of Coolant	C/V Press. High	Pressurizer Press. Low-Low
Steam Line Break	C/V Press. High-High	Main Steam Line Press. Low

5. Safety Criteria Conformance




Simplicity (1/2)

- **Overall plant-wide simplicity is achieved through**
 - ✓ One digital platform applied to all safety and non-safety applications
 - ✓ One system, PSMS, provides all safety functions
 - ✓ One system, PCMS, provides all non-safety functions
 - ✓ Standard approach to electrical independence
 - Only 4 common isolators – power, inputs, outputs, fiber optic communications
 - ✓ Standard approach to data communication
 - Only 2 common interfaces – Data Link, Control Network
 - ✓ Standard approach to communication independence
 - Separate communication controllers with two-port memory
 - ✓ Same HSI in MCR and RSR

5. Safety Criteria Conformance

Simplicity (2/2)

Example of Application Software Development Display




- Basic software and application software are separated
- Basic software block is represented as simple predefined functional blocks, such as, AND, OR, Timer and Latch, etc.
- Application software is developed using the off-line Engineering Tool that graphically connects the functional blocks and links those blocks to the I/O
- The application software execution data is simply a list of function block connections

5. Safety Criteria Conformance



Testability (1/5)




- Continuous automatic self-testing covers all digital system components, including all controller memory and inter-controller data communication, from input to output
- All program memory, including memory that controls the self-testing and setpoints, is confirmed by continuous automatic self-testing
- Diverse manual surveillance tests controlled by T-Spec., including the operability of the self-testing functions, confirm the operability of each PSMS controller
 - ✓ CHANNEL CALIBRATION
From sensor through controllers and data communication to VDUs
 - ✓ TADOT
From VDUs through data communication and controllers to plant components, including RTBs
 - ✓ MEMORY INTEGRITY CHECK
Divers test (from memory self-test) of all Basic and Application Software

5. Safety Criteria Conformance

Testability (2/5)

- The Self Diagnosis function completely tests H/W and S/W
- All memory and other H/W that affect safety functions are tested directly
- There are two broad tests to detect erroneous function execution:
 - ✓ Watchdog Timer (WDT) – gross cycle time check by hardware
 - ✓ Periodic Process Time Check – precise cycle time check by software




5. Safety Criteria Conformance

Testability (3/5)

➤ Watchdog Timer

- ✓ The WDT consists of a counter with a hardware clock generator, and predefined timer value (for WDT time-out)
- ✓ The timer counts up, basic software resets the timer at regular intervals (i.e., for each operation cycle) to start recounting from zero
- ✓ If basic software does not reset the WDT within a predefined timer value then the WDT times out, the controller transitions to a failure state with an alarm, failure state results in partial reactor trip and fail as-is for ESF system signals



5. Safety Criteria Conformance




Testability (4/5)

➤ Watchdog Timer

- ✓ A failure of the WDT can be detected by monitoring the counter value (WDT clock check)
- ✓ If the counter stops or becomes askew, this indicates abnormality of WDT

CPU Module



- WDT clock check is periodically performed by the Basic software
- If an error is detected by this clock check, the controller transitions to failure state

5. Safety Criteria Conformance



Testability (5/5)

- Self-testing detects hardware or software errors in PSMS
- Logic, algorithms, setpoints, time constant values, and inter-train communication of PSMS are self-tested
- I/O is confirmed by manual periodic tests
- Manual periodic I/O tests also provide diverse confirmation of each controller's ability to execute multiple diverse software functions
- All memory that controls Basic Software (including self-testing) and Application Software (including all logic, setpoints and time constants) is confirmed by the manually initiated software MEMORY INTEGRITY CHECK (MIC) which is diverse from the self-test
- Through the aggregate of these tests, all safety functions of PSMS are confirmed
- Setpoint Methodology Technical Report, MUAP09022, includes the method of allowable value calculation for testing

5. Safety Criteria Conformance



Reliability (1/4)

- **Following key features of PSMS ensure high reliability**
 - ✓ Digital platform (MELTAC) operating history, which demonstrates long component MTBF and no software CCFs
 - ✓ Continuous self-testing with high coverage to detect failures
 - ✓ Periodic surveillance test to ensure 100% test coverage
 - ✓ Redundancy between divisions, and within divisions including safety bus
 - ✓ Diversity within divisions to reduce PSMS CCF potential
 - ✓ Should a PSMS CCF occur, DAS to mitigate accidents
- **Impact of PSMS reliability is analyzed in DCD Chapter 19 PRA**
- **Key elements of PSMS reliability calculation in PRA are:**
 - ✓ Mean Time Between Failures (MTBF) of digital I&C components
 - ✓ Self-test coverage (rate to detect failures) and Periodic test intervals
 - ✓ Common cause failure probabilities
 - ✓ Digital I&C modeling
 - All modules, including modules to perform the safety bus functions, such as network I/F modules and optical switches, are modeled in the PRA
 - Safety bus itself (redundant optical cables) is not modeled because failure rate is negligible

5. Safety Criteria Conformance



Reliability (2/4)

➤ MTBF of digital I&C components

- ✓ The MTBF value of each digital I&C component used in the PSMS is calculated based on MIL standard (MIL-HDBK-217F)
- ✓ The actual MTBF values determined from field operating experiences of the digital platform (MELTAC) are longer than the calculated MTBF values
- ✓ PSMS reliability is assured through the Reliability Assurance Program (design phase and operations phase)
- ✓ PSMS digital platform will be included in D-RAP

Reliability (3/4)

➤ Periodic test intervals and self-diagnosis rate to detect failures

- ✓ The self-diagnosis rate is estimated as 100% based on the FMEA of the platform, conservative value of 90% is used in the PRA to account for uncertainty
- ✓ The periodic test intervals used in the PRA are provided in the DCD Chapter 16 T-Spec
 - The interval extensions from historical STS values are shown to have negligible effect on CDF, MUAP-07030 “PRA”, Attachment 18A.1
 - The summary will be added in DCD Chapter 19 Appendix 19B in DCD Rev.4
 - 24-month sensor calibration interval is the basis of channel uncertainty in the Setpoint Methodology
- ✓ 0% self-diagnosis rate is used for the hardware devices not covered by self-diagnosis (e.g., sensor, breaker, non-digital part of I/O modules, etc.)

5. Safety Criteria Conformance



Reliability (4/4)

➤ Common cause failure (CCF) probabilities.

- ✓ Basic Software CCF: 1E-07/demand
Assuming one CCF through 20-million-hour operating experience, no CCF has occurred in MELTAC platform
 - MELTAC platform has been:
 - In operation since 1987 in Japan
 - Applied to approximately 450 controllers in 30 plants
 - Each controller has 2,000 to 200,000 hours operating history (average 8 years).
 - Platform Operating Experience was approximately 30 million hours (8760 hours/year x 8 years x 450 controllers) as of February 2011
 - “20 million hour” value was used for CCF probability calculation as a conservative estimation at the time of PRA was conducted
- ✓ Application Software CCF: 1E-05/demand
Crediting many Class 1E life cycle process management and many defensive measures (e.g., strictly cyclic operation, constant loading of communication and processing buses, static memory allocation and asynchronous operation)
- ✓ Hardware CCF
Summing the unavailability of each module multiplying with the generic component parameters of the MGL

5. Safety Criteria Conformance



Quality (1/3)

- **MELTAC Nplus S Hardware Lifecycle**
 - ✓ Design, manufacture, and test hardware products under the Appendix B QAP
 - ✓ Provide 30 years support proactive obsolescence management and corrective action program
- **MELTAC Nplus S Software Lifecycle (Basic Software)**
 - ✓ Develop and test Basic Software configuration items under the Appendix B QAP
 - ✓ The Appendix B QAP invokes the MELTAC Basic Software Program Manual which satisfies the requirements of BTP 7-14 and complies with RG1.152 and other applicable IEEE standards
- **MHI is to address how to flow down the requirements, and ensure the life cycle process of the MELTAC platform to address Open Items**

5. Safety Criteria Conformance



Quality (2/3)


➤ Design Process for Application Software is governed by the “Software Program Manual (SPM)”, MUAP-07017

- ✓ Plant Requirements
- ✓ System Requirements
- ✓ Design
- ✓ Implementation
- ✓ Test
- ✓ Installation
- ✓ Operation and Maintenance

➤ All independent V&V activities are performed by MHI in accordance with the SPM

➤ Process includes integration of complete system including hardware, basic software, and application software

➤ ITAAC demonstrates compliance with SPM



5. Safety Criteria Conformance



Quality (3/3)

➤ Augmented quality for non safety systems

Items	Specific requirements for non-safety system
Safety Functions Controlled by O-VDUs	DI&C-ISG-04
Safety Parameter Display System (SPDS)	10 CFR 50.34 (f)(2)(iv), "Additional TMI-Related Requirements" regarding the SPDS
	NUREG 0737 Supplement 1, "Clarification of TMI Action Plan Requirements - Requirements for Emergency Response Capability", with respect to SPDS
Alarms for Credited Manual Operator Actions	SECY-93-087, Item II. T, "Control Room Annunciator (Alarm) Reliability"
Signal Selection Algorithm (SSA)	RG 1.153, "Criteria for Safety Systems"
	IEEE 603-1991, Clause 6.3 "Interaction between the Sense and Command features and other Systems"
Risk-significant non-safety I&C system	Risk-significant non-safety I&C system identified in DCD Table 17.4-1 (primarily systems that can cause AOO)
Diverse Actuation System	BTP 7-19, "Guidance for Evaluation of Diversity and Defense-in-Depth in Digital Computer-Based Instrumentation and Control Systems"
	Generic Letter 85-06, "Quality Assurance Guidance for ATWS Equipment That Is Not Safety-Related"

5. Safety Criteria Conformance



Equipment Qualification (1/2)


- PSMS and other safety-related components are qualified by type tests to generic environmental and seismic conditions that are expected to envelope all potential sites
- Testing is performed in accordance with applicable industry standards (IEEE Std. 323, 344) and regulatory requirements (RG 1.89)
- ITAAC verifies the qualification test results envelope actual site specific conditions
- Instrument sensing lines comply with RG 1.151 which endorses ANSI/ISA S67.02, including freeze protection
- Lines that are connected to ASME Class 1 or 2 process piping or vessels are designed as ASME Class 2 Seismic Category I

5. Safety Criteria Conformance



Equipment Qualification (2/2)

- **Environmental Test**
 - ✓ Mild Environment
 - ✓ Temperature / Humidity
- **Seismic Test**
 - ✓ OBE/SSE requirements are satisfied
 - ✓ Conformance to IEEE Std 344
- **Electromagnetic Compatibility Test**
 - ✓ Conformance to RG 1.180



5. Safety Criteria Conformance



Secure Development and Operational Environment (SDOE) (1/3)

- **Security of all PSMS software complies with SDOE requirements of RG 1.152**
 - ✓ During development by the independent V&V and configuration control processes defined in the “Software Program Manual”, MUAP-07017, which also encompasses MELTAC Basic Software
 - ✓ During operation by system design features (e.g., locked doors, alarms, module removal restrictions) and Memory Integrity Checks

- **Compliance to the SDOE requirements of RG 1.152 assures:**
 - ✓ Unintended functions have not been introduced at any point in PSMS software development
 - ✓ System contains design features that prevent and detect unintended alterations during its operation

5. Safety Criteria Conformance




SDOE (2/3)

- **All safety functions of PSMS are installed in non-volatile memory that cannot be altered in any manner while operating**
- **PSMS software changes require:**
 - ✓ Equipment room access (locked and alarmed)
 - ✓ Cabinet access (locked and alarmed)
 - ✓ Module removal (alarmed and controlled by Tech Specs)
 - ✓ Module reprogramming in external chassis
 - ✓ Module reinstallation (alarmed)
- **Redundant PSMS divisions are geographically separated in four I&C equipment rooms**
- **Unintended software changes are detectable by the periodic Memory Integrity Check**

5. Safety Criteria Conformance



SDOE (3/3)



➤ Corporate Electronic Archive System (CEAS)

- ✓ Stores basic software and application software
- ✓ Access control by password
- ✓ Physically secured
- ✓ System does not allow file delete or change (write only)
- ✓ Periodic backup

➤ Development Environment

- ✓ Access control to development machine by password
- ✓ Entry/exit control of the development area
- ✓ Isolated from the corporate network

6. Open Items



Status of SER Open Items (1/3)

RAI No.	RAI Topic/ NRC Concern	Status
RAI 568-4588	Selection criteria of PAM should be refined	RAI response under NRC review
RAI 753-5742	Basis for the inputs and assumptions used in D3 Coping Analysis	RAI response under NRC review
RAI 992-6999	1.Sufficient evidence to demonstrate that the use of O-VDUs enhance the performance of the safety system 2.ITAAC that adequately verifies testing for normal and abnormal data transmission conditions for all non-safety to safety interfaces	1.MHI will provide RAI response demonstrating safety merit of O-VDU, including quantitative analysis for reduced task burden 2.MHI will add new ITAAC for communication faults

6. Open Items



SER Open Items (2/3)

RAI No.	RAI Topic/ NRC Concern	RAI Response/ DCD Impact
RAI 995-7024	Process to flow down the requirements for MELTAC platform hardware/ software components	RAI response under NRC review
RAI 993-7027	Process to ensure vendor's safety software development process	RAI response under NRC review
RAI 988-7021	Basis for the inputs and assumptions used in D3 Coping Analysis	RAI response under NRC review

6. Open Items



SER Open Items (3/3)

RAI No.	RAI Topic/ NRC Concern	RAI Response/ DCD Impact
RAI 996-7040	How the plant would be adequately protected from each PCMS failure, including single failures and design defects (i.e., potential software CCFs)	MHI will provide RAI response demonstrating that transients causing PCMS single failures are bounded by AOOs in DCD Ch. 15, and transients caused by potential basic software CCFs are bounded by PAs in DCD Ch. 15

7. Summary



- **Digital I&C Systems provide significant advancements;**
 - ✓ Higher availability
 - ✓ Higher accuracy
 - ✓ Lower potential for human error
 - ✓ Better performance
 - ✓ Improved operator command & control capability
 - ✓ Reduction of maintenance workload & resources
- **The US-APWR employs proven digital designs with many years of demonstrated reliability in Japan**
- **Conventional DAS ensures plant safety is maintained if all digital systems fail**
- **MHI is working closely with NRC to complete US licensing**

List of Acronyms (1/2)

A/I	Analog Input	D/O	Digital Output
ALR	Automatic Load Regulator	DTM	Design Team Manager
AOO	Anticipated Operational Occurrence	ECCS	Emergency Core Cooling System
APWR	Advance Pressurized Water Reactor	EFW	Emergency Feed Water
ATWS	Anticipated Transient without Scram	EHG	Electric Hydraulic Governor
AVR	Automatic Voltage Regulator	EMC	Electromagnetic Compatibility
BISI	Bypass and Inoperable Status Indication	EMI	Electromagnetic Interference
BTP	Branch Technical Position	E/O	Electrical to Optical or Optical to Electrical
BOP	Balance of Plant	EOF	Emergency Operating Facility
CCF	Common Cause Failure	EOP	Emergency Operating Procedure
CCW	Component Cooling Water	ERDS	Emergency Response Data System
CDF	Core Damage Frequency	ESD	Electrostatic Discharge
CEAS	Corporate Electronic Archive System	ESF	Engineered Safety Features
CH	Channel	ESFAS	Engineered Safety Features Actuation System
CHP	Charging Pump	FPAG	Field Programmable Gate Array
COL	Combined License	F-ROM	Flash Electrically Erasable Programmable Read Only Memory
COM	Communication Subsystem	GTG	Gus Turbine Generator
CPU	Central Processing Unit	HFE	Human Factors Engineering
CRC	Cyclic Redundancy Check	HSI	Human System Interface
CRDM	Control Rod Drive Mechanism	HSIS	Human System Interface System
CS	Containment Spray	HVAC	Heating, Ventilation and Air Conditioning
C/V	Containment Vessel	H/W	Hardware
CVCS	Chemical Volume Control System	HX	Heat Exchanger
D-RAP	Design Reliability Assurance Program	I&C	Instrumentation and Control
D3	Defense in Depth and Diversity	I/F	Interface
D/A	Digital to Analog Convertor	I/O	Input/Output
DAS	Diverse Actuation System	IR	Intermediate Range
DAAC	Diverse Automatic Actuation Cabinet	ISG	Interim Staff Guidance
DCD	Design Control Document	ISO	Isolation
DHP	Diverse HSI Panel	IT	Information Technology
D/I	Digital Input	ITAAC	Inspections, Tests, Analyses, and Acceptance Criteria
DI&C	Digital I&C		

List of Acronyms (2/2)

LCO	Limiting Conditions for Operation	RCP	Reactor Coolant Pump
LDP	Large Display Panel	RCS	Reactor Coolant System
LOOP	Loss of Offsite Power	RHR	Residual Heat Removal
MCC	Motor Control Center	ROM	Read Only Memory
MCCB	Molded Case Circuit Breaker	RPS	Reactor Protection System
MCP	Main Control Panel	RSR	Remote Shutdown Room
MCR	Main Control Room	RT	Reactor Trip
MELCO	Mitsubishi Electric Corporation	RTB	Reactor Trip Breaker
MELTAC	Mitsubishi Electric Total Advanced Controller	SDCV	Spatially Dedicated Continuously Visible
MFW	Main Feed Water	SDOE	Secure Development and Operational Environment
M/G	Motor Generator	SG	Steam Generator
MGL	Multi Greek Letter	SIS	Safety Injection System
MHI	Mitsubishi Heavy Industries, Ltd.	SLS	Safety Logic System
MIC	Memory Integrate Check	SPDS	Safety Parameter Display System
MNES	Mitsubishi Nuclear Energy System, Inc.	SPM	Software Program Manual
MRP	MELTAC Re-evaluation Program	SR	Source Range
MTBF	Mean Time Between Failure	SSA	Signal Selector Algorithm
NIS	Nuclear Instrumentation System	SSE	Safe Shutdown Earthquake
NFB	No Fuse Breaker	STS	Standard Technical Specifications
OBE	Operational Basis Earthquakes	S-VDU	Safety VDU
O/E	Optical/Electrical Converter	S/W	Software
OLM	On-Line Maintenance	TADOT	Trip Actuation Device Operability Test
O-VDU	Operational VDU	TR	Topical Report
PA	Postulated Accident	T-Spec.	Technical Specification
PAM	Post Accident Monitoring	TSC	Technical Support Center
PCMS	Plant Control and Monitoring System	UPS	Uninterruptible Power Supply
PIF	Power Interface	UV	Under Voltage
PR	Power Range	VCT	Volume Control Tank
PRA	Probability Risk Assessment	VDU	Visual Display Unit
PSMS	Protection and Safety Monitoring System	V&V	Verification and Validation
QA	Quality Assurance	WDT	Watchdog Timer
QAP	Quality Assurance Program		
RAM	Random Access Memory		



Presentation to the ACRS Subcommittee

US-APWR Design Certification Application Review

Safety Evaluation Report with Open Items

Chapter 7: Instrumentation and Controls

April 25-26, 2013

Objective and Expected Outcome

Objective

- Brief the Subcommittee on the staff's review of the US-APWR instrumentation and control (I&C) system

Expected Outcome

- Common understanding of the background, the staff's evaluation efforts, and the current status of the US-APWR I&C system review

Staff Review Team

Technical Staff from NRO/DE/ICE2

Dinesh Taneja

Joseph Ashcraft

Khoi Nguyen

Erick Martinez

Tung Truong

Project Managers

William Ward

Jeff Ciocco

Presentation Outline

- **Introduction**
- **Background**
- **Key Technical Topics of Interest**
 - Redundancy
 - Independence
 - Determinism
 - Defense-in-Depth and Diversity
 - Simplicity

Presentation Outline

(Continued)

- **Other Technical Topics**
 - Software program manual
 - Post accident monitoring (PAM) instruments
 - Non-safety PCMS failures' impact on safety
- **Non-Concurrence**
- **Discussion/Committee Questions**

Introduction

- MHI submitted the US-APWR design certification application on December 31, 2007
- Safety evaluation and related reports represent over five years of effort
- Oak Ridge National Lab was initially contracted for technical support

Introduction

(Continued)

- **In April 2010, the I&C review was on critical path due to significant technical issues and challenges:**
 - Applicant's original strategy of receiving generic review/approval of MELTAC digital I&C platform was a factor
 - MELCO, MHI's subcontractor and developer of MELTAC platform, did not have an Appendix B program, which impacted the staff review
 - There were a significant number of unresolved RAIs
 - Data communication independence was a significant challenge

Introduction

(Continued)

- **A closure plan was developed in August 2010 for resolving key issues including:**
 - Identification and resolution of outstanding RAIs
 - Topical Reports MUAP-07004 and MUAP-07005 converted to Technical Reports as part of the US-APWR design certification I&C design
 - SPM revised to address US-APWR software QA issues, including MELTAC Basic and Application software
 - Key digital I&C design principles emphasized
- **MELCO established Appendix B program for building safety-related MELTAC platform**

- **Two Significant Audits**
 - Kobe, Japan and Arlington, Virginia
 - Data communication independence
 - Deterministic performance of digital I&C systems including implementation of watchdog timers
 - US-APWR software development process
 - Integration of MELTAC basic software into the US-APWR application software for safety I&C systems
 - MELTAC test reports on products developed for the Japanese nuclear plants
 - Draft US-APWR emergency response guidelines used for determining the required PAM variables

Status Overview

SRP Section / DCD Section		No. of Open Items	Brief Description of Open Item
7.1	Introduction	2	1. QA of vendors' safety Software 2. MELTAC Platform - CGD
7.2	Reactor Trip System		
7.3	Engineered Safety Features Systems		
7.4	Systems Required for Safe Shutdown		
7.5	Information Systems Important to Safety	1	Bases for PAM Variables
7.6	Interlocks Important to Safety		
7.7	Control Systems Not Required for Safety	1	PCMS failures' impact on safety
7.8	Diverse I&C Systems	1	D3 Coping Analysis
7.9	Data Communication Systems	1	Manual controls of safety components from O-VDU
Total		6	

Background

Major Documents Reviewed

Doc. Number	Title	Revision
Docket 52-021	US-APWR DCD FSAR, Tier 1 Section 2.5; and Tier 2 Chapter 7	3
MUAP-07004P	Safety I&C System Description and Design Process Technical Report	7
MUAP-07005P	Safety System Digital Platform -MELTAC- Technical Report	8
MUAP-07006P	Defense-in-Depth and Diversity Topical Report	2-Acc
MUAP-07014P	Defense-In-Depth and Diversity Coping Analysis Technical Report	5
MUAP-07017P	US-APWR Software Program Manual	4
MUAP-09021P	US-APWR Response Time of Safety I&C Systems	2
MUAP-09022P	US-APWR Instrument Setpoint Methodology	2

Significant Technical Issues of the Original Design

- Complex architecture
- Bi-directional data communication between safety and non-safety systems
- Continuous connection between safety systems and maintenance network
- Capabilities to make on-line software changes
- Diverse actuation system (DAS) 2-out-of-2 logic
- Use of time-critical manual actions from DAS

Major Design Changes

- Data communication from non-safety to safety systems reduced
 - Now limited for manual control of safety components (Open Item)
- Automatic signals from non-safety to safety systems hardwired through Class 1E isolators
- Interface between PSMS and maintenance network changed to temporary connection

Major I&C Design Changes

(Continued)

- Software changes made off-line
- Enable/Disable switch added that provides capability to disconnect all non-safety signals going to safety-systems
- DAS upgraded to four cabinets and actuated using 1-out-of-2 taken twice logic

Major Design Changes

(Continued)

- Time-critical DAS manual actuations converted to automatic
- Priority logic employed throughout safety components
- Additional data communication design details added to DCD and technical reports

Redundancy

- **US-APWR I&C Safety Systems**
 - PSMS - sustains a single failure and completes its safety function
 - Meet GDC 21 & 24, and Section 5.1 of IEEE Std. 603-1991
 - Have single-failure ITAAC
- Staff's evaluation in Sections 7.1.4.1.1.2, 7.1.4.1.2, 7.1.4.2.2, and additional sections scattered throughout Sections 7.2 through 7.9 of the safety evaluation

- **Regulations and Guidance**
 - GDC 21 & 24
 - 10 CFR 50.55a(h)
 - IEEE Std. 603-1991, Section 5.1
 - RG 1.53 / IEEE Std. 379-2000

Redundancy

(Continued)

- **PSMS**
 - Redundancy between trains
 - Redundancy within divisions and systems
 - System level failure modes and effects analysis (FMEA)

- **PCMS**
 - Duplex redundant
 - Input and Output (I/O) redundancy

Independence

- Physical Independence
- Electrical Independence
- Functional Independence
- Communication Independence

Independence


(Continued)

- **Communication Independence**
 - Among safety trains
 - Between safety and non-safety systems

Independence

(Continued)

- Data Communication Interfaces**



DCS Interface Configuration

- **Regulations and Guidance**
 - 10 CFR 50.55a(h)
 - GDC 22 & 24
 - IEEE Std. 603-1991, Section 5.6
 - SRP 7.9
 - DI&C-ISG-04
 - RG 1.152 / IEEE Std. 7-4.3.2-2003

- **Independence among Safety Trains**

Design Features Supporting the Staff Findings

- Limited to voting logic, bypass status, and message authentication status
- One-way point-to-point data link protocol with no communication handshaking
- Failure or communication fault of a single train does not affect the other trains

Independence


(Continued)

- All safety functions are performed without interruption by any other signals. The priority logic provides prioritization of safety signals for safety functions over other signals
- All communications are performed utilizing 2-port memory
- The communication processor is separated from the functional processor

Independence

(Continued)

- Independence between Safety and Non-safety Systems**



Communication Between Safety and Non-safety Systems

- **Data Communications through COM-2**
 - Manual control commands of safety components from the O-VDU
 - Manual operating/maintenance bypass, lock, and reset commands from the O-VDU

Independence

(Continued)

- **Design Features Supporting the Staff Findings**

- DI&C-ISG-04 is the key guidance used

Note: Staff evaluation of conformance to ISG-04 can be found in Table 7.9.4-1 of the SE

- All safety functions, whether manual or automatic, are performed without being interrupted by non-safety signals, regardless of whether these non-safety signals are valid or erroneous. The priority logic provides prioritization of safety signals for safety functions over non-safety signals (ISG-04, Staff Position 1)

Independence

(Continued)

- The communication controller is separate from the functional processor that performs safety functions (ISG-04, Staff Position 4)
- Communications between the control network module and the CPU module are performed via a 2-port memory to ensure no disruption of the CPU's deterministic operation (ISG-04, Staff Position 4)
- Desired data are transmitted in fixed format, fixed length, and predefined message (ISG-04, Staff Position 15)

Independence

(Continued)

- Erroneous data are limited by using data checks (ISG-04, Staff Position 12)
- The execution of all basic software functions is monitored and verified continuously for deterministic cycle time performance by an external hardware watchdog timer, which detects anomalies and forces fail-safe processing termination (ISG-04, Staff Position 5)
- Watchdog timer ensures that a locked-up controller is shifted to the fail-safe mode

Independence

(Continued)

- **NRC Audits**

- Reviewed un-docketed documents
- Confirmed key design features described in the DCD
- Witnessed demonstrations on actual MELTAC controllers to address the staff's concerns

Independence

(Continued)

- **Open Item**

- The applicant is asked to justify the use of non-safety component to operate safety equipments
 - Sufficient evidence associated with the HFE full scope simulator testing or a quantitative analysis to demonstrate that the use of O-VDU to operate safety equipment enhances the performance of the safety function
 - Provide an ITAAC to test normal and abnormal data transmission conditions for all non-safety to safety interfaces

Determinism

- **Regulations and Guidance**
 - 10 CFR 50.55a(h)
 - IEEE Std. 603-1991, Section 4.10
 - SRP BTP 7-21

- **Staff's Review**
 - Software failures or system malfunctions are accommodated by the MELTAC internal diagnostic functions and the built-in watchdog timers
 - All functions execute with cyclical single task processing
 - Cycle times are pre-determined and fixed for all MELTAC processors with the same sequence of processing steps in each cycle
 - Message sizes and communication rates are constant, resulting in constant communication loads under all circumstances

Determinism

(Continued)

- Communication independence features ensure deterministic processing, that cannot be disrupted by other PSMS trains or the Unit Bus
- No external interrupts exist. There are two internal interrupts; CPU module & peripheral
- Processing is monitored for deterministic cycle time performance by a hardware based external watchdog timer, which detects anomalies and forces fail safe processing termination

Note: In safety evaluation Section 7.1.4.2.3, real-time performance is evaluated using SRP BTP 7-21 guidance

- **Response Time Analysis**
 - MUAP-09021, “US-APWR Response Time of Safety I&C System,” is evaluated using SRP BTP 7-21 guidance in Section 7.1.4.7 of the safety evaluation
 - Safety system response times in Chapter 15 are the analytical limits and are specified as allocated response times for each safety function
 - Total MELTAC response time accounts for all network components and data communication interfaces

Determinism

(Continued)

- Maximum and minimum controller response times are calculated to demonstrate compliance with allocated times
- In test phase, system response time is confirmed by measurement
- Final response time is verified through ITAAC

Defense-in-Depth and Diversity

- **Diverse Actuation System (DAS) Design Features**
 - Non-safety analog hardwired system that is independent from the PSMS and PCMS to cope with potential software common cause failures
 - Four diverse automatic actuation cabinets designed as Seismic Category I are located in separate Class 1E electrical rooms; and powered by Class 1E UPS power source
 - Uses a 1-out-of-2 taken twice voting logic
 - Automatic/manual actuation functions and indications included on the diverse HSI panel located in the main control room

- **Policy and Guidance**
 - SRM on SECY-93-087
 - DI&C-ISG-02
 - DI&C-ISG-05
 - SRP 7.8
 - SRP BTP 7-19

- **Staff's review**

- MHI previously submitted Topical Report, MUAP-07006, "Defense-in-Depth and Diversity," which has been approved by the staff with the Application Specific Action Items (ASAs)
- For the US-APWR design, the applicant referenced MUAP-07006 and submitted MUAP-07014, "D3 Coping Analysis"
- Functions performed by DAS are based on a best-estimate D3 coping analysis
- Review of the D3 coping analysis is coordinated with the experts in human factors and reactor systems

- **DAS design changes**
 - Changed diverse ECCS actuation from manual to automatic
 - Upgraded seismic classification to Category I
 - Changed DAS cabinets from two to four
 - Actuation logic changed from 2-out-of-2 to 1-out-of-2 taken twice
 - Upgraded other design features to address internal and external hazards

Defense-in-Depth and Diversity

(Continued)

- **Open Item**
 - Outstanding RAIs are related to the review of the D3 coping analysis
 - Reactor Systems is evaluating or awaiting responses to the RAIs

Simplicity

- **Staff Review Approach**

- Staff guidance discusses simple means to address hazards for specific design aspects like data communications
- More complex design alternatives require a more in-depth and detailed review by the staff

- **Design Changes**

- The applicant proposed multiple design changes to reduce design complexity

- **Design Attributes**
 - A single platform (MELTAC) is utilized for the entire plant
 - DAS is a hardwired analog system
 - All functions are executed with cyclical single task processing and no external (outside of the PSMS) interrupts
 - All the software modules are executed during a fixed cycle time in a predefined order
 - Application software is written in a graphically symbolized manner, so that functions can be easily understood, verified and validated
 - No dynamic allocation of memory exists

Software Program Manual

- **Background**
 - US-APWR SPM describes the software life cycle processes used to develop PSMS software; this description is provided through 12 software plans in the SPM
 - Majority of software plans in the SPM are also applicable to PCMS (augmented quality)

- **Regulations and Guidance**
 - 10 CFR 50.55a(a)(1)
 - GDC 1
 - 10 CFR 50 Appendix B
 - RG 1.152 (IEEE Std. 7-4.3.2-2003)
 - SRP BTP 7-14 (IEEE Std. 603-1991)

- **Staff Review**

- Reviewed 12 software plans in the SPM against SRP BTP 7-14
- Reviewed secure development and operational environment against RG 1.152, Revision 3

- **Open Item**

- The staff requested applicant explain or describe the process it plans to use to ensure that its vendor's safety software development process and the resulting software conform to NRC regulation and guidance. In addition, the staff requested that the applicant include an ITAAC to provide verification of such a process

Post Accident Monitoring

- **Background**

- MHI decided to identify performance based list of PAM variables in the DCD
- Function of PAM variables is to aid the operator in rapid detection of abnormal operating conditions
- PAM variables represent a minimum set of plant parameters needed to assess plant safety status
- Staff is working closely with experts in Human Factors, Reactor Systems, Technical Specification, and Containment Design for reviewing the list of PAM variables
- Audited draft US-APWR Emergency Response Guidelines used as one of the bases for the PAM list

Post Accident Monitoring

(Continued)

- **Regulations and Guidance**
 - 10 CFR 50.34(f), “Additional TMI-Related Requirements” applies to accident monitoring instrumentation
 - RG 1.97, Rev. 4 (guidance for selecting performance based list of PAM variables)
 - SRP BTP 7-10 (guidance on application of RG 1.97)

Post Accident Monitoring

(Continued)

- **Open Item**

- Revised draft RAI response received in April 2013 is being reviewed
- Staff is working with the applicant in resolving limited number of remaining issues
 - Use of alarms for credited manual operator actions
 - Adequacy of using containment pressure to determine containment integrity
- Staff is working with experts in Human Factors, Reactor Systems, and Containment Design for reviewing this open item

PCMS Failures' Impact on Safety

- **Background**
 - SRP Section 7.7 states, in part, that failure of any control system component should not cause plant conditions more severe than those described in the analysis of anticipated operational occurrences in Chapter 15 of the DCD

- **Open Item**
 - To assure that this concern is addressed, the staff asked the applicant to provide additional information on the effects of control system failures (including software common cause failures) on the safety function

Non-Concurrence

(NCP-2012-007)

- **Background**

Employee submitted non-concurrence on Chapter 7 safety evaluation raising issues with:

- Commercial grade dedication of MELTAC System
- MELTAC Basic software lifecycle development process
- US-APWR data communication system

Non-Concurrence

(Continued)

- **Actions taken**
 - Followed the non-concurrence implementation guidance outlined in NRC MD 10.158
 - Asked applicant to verify that all MELTAC technical and quality requirements are identified in the DCD; and provide ITAAC to verify and validate the as-built safety I&C system in conformance with the specified technical and quality requirements

Non-Concurrence

(Continued)

- Asked applicant to ensure that its vendors' safety software development process and resulting software conform to the NRC regulations and guidance; and provide ITAAC to verify such a process
- Asked applicant to demonstrate that multi divisional control of safety components from O-VDU result in enhancement of safety function performance; and provide ITAAC for testing normal and abnormal data transmission conditions for all non-safety to safety interfaces

Note: All actions taken to address non-concurrence are being tracked as Open Items

Discussion / Committee Questions

List of Acronyms

APWR	Advanced Pressurized Water Reactor
ASAI	Application Specific Action Item
BTP	Branch Technical Position
CCF	Common Cause Failure
CGD	Commercial Grade Dedication
COM	Communication System
CPU	Central Processing Unit
D3	Defense-in-Depth and Diversity
DAS	Diverse Actuation System
DCD	Design Control Document
DCS	Data Communication System
DI&C	Digital Instrumentation and Control
ECCS	Emergency Core Cooling System
ESFAS	Engineered Safety Features Actuation System
FMEA	Failure Modes and Effects Analysis
FPGA	Field Programmable Gate Array

List of Acronyms

(Continued)

F-ROM	Flash Electrically Erasable Programmable Read Only Memory
FSAR	Final Safety Analysis Report
GDC	General Design Criteria
HFE	Human Factors Engineering
HSIS	Human System Interface System
I&C	Instrumentation and Control
IEEE	Institute of Electrical and Electronics Engineers
I/O	Input/Output
ISG	Interim Staff Guidance
ITAAC	Inspections, Tests, Analyses, and Acceptance Criteria
MELCO	Mitsubishi Electric Corporation
MELTAC	Mitsubishi Electric Total Advanced Controller
MHI	Mitsubishi Heavy Industries, Ltd.
O-VDU	Operational Visual Display Unit
PAM	Post Accident Monitoring
PCMS	Plant Control and Monitoring System

List of Acronyms

(Continued)

PRA	Probability Risk Assessment
PSMS	Protection and Safety Monitoring System
QA	Quality Assurance
RAI	Request for Additional Information
RAM	Random Access Memory
RCS	Reactor Coolant System
RG	Regulatory Guide
ROM	Read Only Memory
RPS	Reactor Protection System
SE	Safety Evaluation
SLS	Safety Logic System
SPM	Software Program Manual
SRP	Standard Review Plan
S-VDU	Safety Visual Display Unit
UPS	Uninterruptible Power Supply

Reference Slides

Descriptions of Open Items

Open Item	Brief Description
RAI 993-7027, Question 07-56	Oversight of vendors' safety software development process
RAI 995-7024, Question 07.01-45	MELTAC platform and CGD issues
RAI 996-7040, Question 07.07-33	Impact of PCMS failures' on safety functions
RAI 992-6999, Question 07.09-26	Bases for manual control of safety components from O-VDU, and testing of normal and abnormal data transmission conditions for all non-safety to safety interfaces
RAI 568-4588, Question 07.05-18	Bases for PAM variables
RAI 753-5742, Question 07.08-17 to 22 RAI 988-7021, Question 07.08-26 to 30 RAI 7045 Question 24724-24727 RAI 7066 Questions 24764-24767 & 24771	D3 coping analysis



Luminant



LUMINANT GENERATION COMPANY

Comanche Peak Nuclear Power Plant, Units 3 and 4

ACRS, US-APWR Subcommittee



**FSAR Chapter 7 –
Instrumentation and
Controls**

April 25, 2013



Luminant



Agenda

- Introduction
- Site-Specific Aspects
- Summary



Introduction

- ❑ COLA uses “Incorporated by Reference” methodology**
- ❑ No departures from the US-APWR DCD for FSAR Chapter 7**
- ❑ CPNPP COLA Revision 2 submitted in June 2011 and Revision 3 in June 2012**
- ❑ No contentions pending before ASLB**



Luminant



Sections That Are 100% IBR

Sections 7.0 - 7.3 and 7.6 - 7.9 are IBR with no departures or supplements



7.4 Systems Required for Safe Shutdown

- ❑ **CPNPP COLA FSAR Summary**
 - **Addresses site-specific component control and indication to achieve safe shutdown as related to UHS**

- ❑ **NRC SER Summary**
 - **No outstanding issues**



7.5 Information Systems Important to Safety

- ❑ **CPNPP COLA FSAR Summary**
 - **Addresses site-specific type D PAM variables related to UHS**
 - **Addresses site-specific type E PAM variables for monitoring meteorological parameters**
 - **Describes CPNPP Units 3 and 4 EOF**

- ❑ **NRC SER Summary**
 - **No outstanding issues**



Acronyms

ASLB	Atomic Safety and Licensing Board
COLA	Combined License Application
CPNPP	Comanche Peak Nuclear Power Plant
DCD	Design Control Document
EOF	Emergency Operations Facility
FSAR	Final Safety Analysis Report
IBR	Incorporated by reference
PAM	Post-accident monitoring
R-COLA	Reference Combined License Application
SER	Safety Evaluation Report
UHS	Ultimate heat sink
US-APWR	United States Advanced Pressurized Water Reactor



Presentation to the ACRS Subcommittee

**Comanche Peak Nuclear Power Plant, Units 3 and 4
COL Application Review**

Safety Evaluation Report

CHAPTER 7: Instrumentation and Controls

April 25-26, 2013

Staff's Presentation Order

- **Stephen Monarque** - Comanche Peak COLA Lead
Project Manager
- **William Ward** - Project Manager
- **Eugene Eagle** – Instrumentation and Controls Branch

Chapter 7 Instrumentation and controls

- ◆ No Open items



Luminant



LUMINANT GENERATION COMPANY

Comanche Peak Nuclear Power Plant, Units 3 and 4

ACRS US-APWR Subcommittee

FSAR Sections

- 2.0 Site Characteristics**
- 2.1 Geography and Demography**
- 2.2 Nearby Industrial, Transportation, and Military Facilities**
- 2.3 Meteorology**

April 26, 2013





Luminant



Agenda

- Introduction**
- SER Open Item**
- Site-Specific Aspects**



Introduction

- FSAR uses IBR methodology**
- No departures from US-APWR DCD Sections 2.0-2.3**
- All COL Items addressed in FSAR**
- One SER Open Item**
- No SER Confirmatory Items**
- No contentions pending before ASLB**



Luminant



SER Open Item

Open Item 2.3.4

Changes to Sections 2.0-2.3

Luminant submitted changes to FSAR Sections 2.0-2.3 in February 2013 to provide atmospheric dispersion updates due to standard plant changes

Resolution – NRC Staff will review the change



Luminant



Site-Specific Aspects

2.0 Site Characteristics

All key site parameters are enveloped by DCD



2.1 Geography and Demography

- Proposed CPNPP Units 3&4 site is co-located with operating CPNPP Units 1&2**

- 7950-ac site located in north central Texas, 40 miles southwest of downtown Fort Worth**

- Nearest population center is Cleburne, Texas located 24 miles east**



2.2 Nearby Industrial, Transportation, and Military Facilities

- CPNPP Units 3&4 design is bounded by DCD Section 2.2**
- Evaluated Design Basis Events for hazardous materials and activities in the vicinity of the site**
- No additional mitigation required**



2.3 Meteorology

- ❑ **Hurricanes - One hurricane has been recorded within 50 miles of the CPNPP site since 1851: a Category 1 hurricane in 1900 with winds of ~65 mph as it passed within 50 miles of the site location.**
 - ❑ **Maximum hurricane site characteristics are bounded by the US-APWR DCD based on RG 1.221.**
- ❑ **Tornadoes are the more likely concern for the CPNPP site. In the 56-year period from 1950 to 2006, 3 tornadoes were reported in Somervell County (the location of the site).**
 - ❑ **Maximum tornado site characteristics are bounded by the US-APWR DCD based on RG 1.76.**



Acronyms

ASLB	Atomic Safety and Licensing Board
CPNPP	Comanche Peak Nuclear Power Plant
DCD	Design Control Document
FSAR	Final Safety Analysis Report
IBR	Incorporated by reference
SER	Safety Evaluation Report
US-APWR	United States Advanced Pressurized Water Reactor



Presentation to the ACRS Subcommittee

Comanche Peak Units 3 & 4 Combined License Application Review

SER/OI Chapter 2

Section 2.1 –Geography and Demography

Section 2.2 –Nearby Industrial , Transportation, and Military Facilities

Section 2.3 – Meteorology

April 26, 2013

Staff Review Team

- Technical Staff
 - ◆ Tech Reviewer Name
RPAC Branch: Seshagiri Rao Tammara
 - ◆ RHMB Branch: Kevin Quinlan
- Project Managers
 - ◆ Lead PM: Stephen Monarque
 - ◆ Chapter PM: Tarun Roy

2.1 Geography, Demography

- DCD Incorporated By Reference
 - Site specific information
 - Site Location
 - Exclusion Area Boundary (EAB)
 - Population Distribution, Projections,
Population Center and Population Density
 - Conclusions

2.2 Nearby Facilities

2.2.1-2.2.2 Location and Description

- DCD Incorporated By Reference
- Site specific information
 - Nearby Industrial, Transportation, and Military Facilities
 - Pipelines
 - Gas wells
 - CPNPP Un its 1 and 2
 - Onsite chemical storage facilities
- Conclusions

2.2 Nearby Facilities (Con'd)

2.2.3 Evaluation of Potential Accidents

- The evaluation of potential hazards to new units 1 and 2 due to potential accidents from nearby facilities, pipelines, and transportation routes.
- The evaluation of potential toxic chemical releases from nearby facilities, transportation routes and onsite storage for the control room habitability of new units 3 and 4.
- DCD Incorporated By Reference
 - Onsite storage of Chemicals
- Site Specific Evaluations
 - Explosions
 - Gas Pipelines
 - Aircraft hazards
 - Toxic Chemicals (Control Room Habitability)
 - Fires
 - Collision with intake structures
 - Liquid Spills
- Conclusions

Meteorology

- **2.3 – Meteorology**

- FSAR Chapter 2.3 incorporates by reference Revision 3 of the US-APWR DCD.

- COL items and Supplemental Information
 - CP COL 2.3(1) – Site Meteorology
 - Addressed in Subsections 2.0, 2.3.1, and 2.3.2
 - CP SUP 2.3(1) – Comparison of Site Parameters Versus Site Characteristics
 - CP COL 2.3(2) – Short Term Atmospheric Transport and Diffusion
 - Addressed in Subsections 2.0 and 2.3.4
 - CP COL 2.3(3) – Long Term Atmospheric Transport and Diffusion
 - Addressed in Subsections 2.0 and 2.3.5

- **Technical Topics of Interest**
 - ♦ **2.3.1 Regional Climatology**
 - All CPNPP site characteristic values presented in FSAR Section 2.3.1 have been found to be acceptable
 - 50-year/100-year Wind Speed (3-second gust)
 - Extreme Wind Speed (other than in tornado)
 - Maximum Tornado Wind Speed
 - Maximum Roof Load (Winter Precipitation)
 - Air Temperature and Humidity
 - ♦ **2.3.2 Local Meteorology**
 - Provided detailed information showing that the CPNPP onsite meteorological data are representative of the site area
 - Addressed cooling tower-induced effects on ambient temperature, moisture, and salt deposition

- **Technical Topics of Interest**
 - ◆ **2.3.3 Onsite Meteorological Measurements Program**
 - COL applicant described the existing onsite meteorological measurements program and provided a copy of the resulting meteorological data
 - Applicant met RG 1.23, Revision 1 criteria for siting of the tower in relation to Units 3 & 4

- **Technical Topics of Interest**
 - ♦ **2.3.4 Short-Term (Accident) Diffusion Estimates**
 - All CPNPP site characteristic values presented in FSAR Section 2.3.4 have been found to be acceptable
 - EAB & LPZ χ/Q values
 - Control Room χ/Q values
 - Minor changes expected to Control Room χ/Q values due to Integrated Seismic Closure Plan
 - ♦ **2.3.5 Long-Term (Routine) Diffusion Estimates**
 - All CPNPP site characteristic values presented in FSAR Section 2.3.5 have been found to be acceptable
 - CP COL 2.3(3) verified release points and receptor locations

- **Conclusion**

- ◆ All CPNPP site characteristics presented in FSAR Section 2.3 have been found to be acceptable and bounded by the corresponding US-APWR site parameters
- ◆ All regulatory requirements for Section 2.3 have been satisfied
- ◆ No open items related to Meteorology
- ◆ No exemptions or departures
- ◆ One confirmatory item (updated Control Room χ/Q values due to Integrated Seismic Closure Plan)