

Gallagher, Carol

**From:** Stanislav Hustak <hus@ujv.cz>  
**Sent:** Monday, May 27, 2013 5:28 AM  
**To:** INFOCOLLECTS Resource  
**Subject:** Response from "Comment on NRC Documents"

2013 JUN 11 AM 9:05

Below is the result of your feedback form. It was submitted by

RECEIVED

Stanislav Hustak ([hus@ujv.cz](mailto:hus@ujv.cz)) on Monday, May 27, 2013 at 05:28:28

Document\_Title: NUREG-1855, Rev. 1

Comments: Reference to Section 5.2.1.

The "natural" screening criterion "An event which does not fulfill a definition of IE in PRA (e.g. ASME definition) can be screened out" would be very useful to add as an example of criteria.

Rationale: Such criterion can be utilized especially for events potentially occurred during shutdown operation when it can be determined whether an event is type "IE" or type "unavailability". Unless the "unavailability" type event significantly contributes to unavailability due to repair (waiting for repair) such event can be screened out from the PRA. The example of "unavailability" type event during shutdown operation can be the fire affecting DG (and nothing else, and no induced LOOP occurs). The example of "IE" type event during shutdown can be the trip of the pump actually removing decay heat from the core.

organization: UJV Rez, a. s.

address1: Hlavni 130

address2:

city: Husinec - Rez

state: ---Selected---

zip: 25068

country: Czech Republic

phone:

4/15/2013

78 FR 20349

4

SUNSI Review Complete  
Template = ADM - 013  
E-RIDS= ADM-03  
Add= M. Drouin (mvd)