## PRELIMINARY NOTIFICATION

June 18, 2013

## PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE - PNO-III-13-005

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. Some of the information may not yet be fully verified or evaluated and is basically all that is known by the Region III staff on this date.

<u>Facility</u>	<u>Licensee Emergency Classification</u>
Perry Nuclear Power Plant	Notification of Unusual Event
FirstEnergy Nuclear Operating Company	Alert
Perry, OH	Site Area Emergency
Docket No.: 05000440	General Emergency
_icense No.: NPF-58	X Not Applicable

SUBJECT: UNPLANNED SHUTDOWN GREATER THAN 72 HOURS DUE TO A

PRESSURE BOUNDARY LEAK.

On June 16, 2013 at 0200 EDT, the Perry Nuclear Power Plant commenced a controlled plant shutdown due to a pressure boundary leak. Perry reduced power to around 8 percent on Friday, June 14, 2013, to make a drywell entry and investigate an increasing drywell leakage trend. The leak was identified on June 15, 2013 at 2250 EDT, when steam was observed coming from a three-quarter inch vent line off the top of the 'B' Reactor Recirculation Flow Control Valve. The licensee evaluated the leak rate as approximately 0.3 gpm and it appeared to be coming from a weld flaw on the inlet to the inboard vent valve. The leak was subsequently determined to meet Technical Specification 3.4.5, Action (C) which requires the plant to be in Mode 3 within 12 hours.

The leakage was contained in the plant. There was no impact on public health.

The State of Ohio has been notified.

This preliminary notification is issued for information only.

Region III received initial notification of this occurrence when the licensee called the Senior Resident Inspector at 2330 EDT on June 15, 2013. The NRC resident staff monitored Perry's actions to identify the leak and the subsequent repairs.

The information presented herein has been discussed with the licensee, and is current as of 0800 EDT on June 18, 2013.

ADAMS Accession Number: ML13169A367

Contact: M. Kunowski

(630) 829-9618

Michael.Kunowski@nrc.gov