

## MAGILL HALL FIRST FLOOR CORRIDORS

### (SURVEY UNITS 1 THROUGH 5)

The Magill Hall First Floor Corridors include Corridor 100B, Foyer 100C, Office 142, Corridor 100C, Corridor 100E, Office 130, Corridor 100G, and Room 134A (as a result of renovations, Room 134A has been incorporated into Corridor 100G). The floors and walls within these areas were classified as MARSSIM Class 2 and Class 3 areas, respectively (see Table A1.1). Figures (including sample locations) are included in Attachment A-1-1. Radiologically impacted areas were divided into SUs based on MARSSIM-recommended size constraints, resulting in a total of 5 SUs (SU-1 through SU-5) in the area identified herein as Magill Hall First Floor Corridors. Survey data from the floors and walls are located in Tables A1.2 through A1.6.

**Overview of Surveys Performed.** Ludlum Model 43-89 dual phosphor ZnS detectors coupled with Ludlum Model 2360 scalers were used for the collection of quantitative alpha/beta scan surveys and fixed-point (i.e., static) measurements. The alpha/beta static measurements were performed at systematic locations for MARSSIM Class 2 areas and at randomly generated locations for Class 3 areas. Given that scan surveys did not detect the presence of activity that was elevated with respect to the investigation level, biased fixed-point measurements were not necessary. Removable contamination measurements (i.e., swipes) were also collected at each static location to quantify residual removable activity. The swipes were counted using a Ludlum Model 43-10-1 alpha/beta sample counter. QA/QC information relative to the instruments used is contained in Section 5.0 of the main text and in Appendix C.

**Table A1.1. Magill Hall Corridor Summary Table<sup>a</sup>**

Room Number / Description	Floor Area (m <sup>2</sup> )	Walls		Floors	
		Included (Yes/No)	MARSSIM Classification	Included (Yes/No)	MARSSIM Classification
Corridor 100B	98	Yes	Class 2 <sup>b</sup>	Yes	Class 2
Foyer 100C	21			Yes	Class 2
Office 142	20			Yes	Class 2
Corridor 100C	67			Yes	Class 2
Corridor 100E	124			Yes	Class 2
Office 130	17			Yes	Class 2
Corridor 100G/Room 134A <sup>c</sup>	75			Yes	Class 2

<sup>a</sup> The ceiling tiles were removed and disposed of as radiological waste prior to the FSS.

<sup>b</sup> Areas were combined for the MARSSIM Class 2 Wall Survey.

<sup>c</sup> These rooms were combined after building renovations in 2005. Building figures have not been updated to reflect this.

**Fixed-Point Measurements.** Fixed-point measurements were obtained from MARSSIM Class 2 (systematic - random start triangular grid) or MARSSIM Class 3 (random) locations. Class 3 fixed point measurements were obtained from random locations with emphasis on areas with a greater likelihood of residual activity. Results of the static measurements are listed in Tables A1.2 through A1.6, and locations are shown on Figures A1.1 through A1.6. All alpha results were below the site-specific alpha DCGL of 1,160 dpm/100 cm<sup>2</sup> for Am-241. Residual beta activity was compliant with both the Cs-137 surface contamination level of 5,000 dpm/100 cm<sup>2</sup> specified in AEC Regulatory Guide 1.86 (AEC 1974) and the NRC screening level DCGL of 28,000 dpm/100 cm<sup>2</sup> cited in Table 5.19 of NUREG-5512 (NRC 1999) for Cs-137 on structures.

**Table A1.2. SU-1 Corridor 100B, Foyer 100C, and Office 142 Class 2 Floor Measurements**

Sample Number	Survey Surface	Location	Total Alpha Activity (dpm/100 cm <sup>2</sup> )	Total Beta Activity (dpm/100 cm <sup>2</sup> )	Removable Alpha Activity (dpm/100 cm <sup>2</sup> )	Removable Beta Activity (dpm/100 cm <sup>2</sup> )
1	Linoleum	100c foyer	-5	537	3	-13
2	Linoleum	100c foyer	8	186	3	6
3	Linoleum	100b	46	416	0	12
4	Linoleum	100b	8	712	0	-10
5	Linoleum	100b	20	307	3	-24
6	Linoleum	100b	20	460	0	-2
7	Linoleum	100b	8	208	0	-27
8	Linoleum	100b	8	526	3	-16
9	Linoleum	100b	8	351	3	-19
10	Linoleum	142	-5	340	0	9

The MDC is the minimum detectable concentration on a surface that an instrument is expected to detect (e.g., activity expected to be detected with 95 percent confidence).

The instrument MDCs for fixed samples 1-10 are 21 (alpha) and 257 dpm/100 cm<sup>2</sup> (beta); the MDCs for removable samples 1-10 are 18 (alpha) and 212 dpm/100 cm<sup>2</sup> (beta); and the MDCs for QC sample #5 are 53.8 (alpha) and 223.4 dpm/100cm<sup>2</sup> (beta).

Negative results indicate results that are below background for the respective building material.

N/A – Not Applicable

**Table A1.3. SU-2 Corridor 100C Class 2 Floor Measurements**

Sample Number	Survey Surface	Location	Total Alpha Activity (dpm/100 cm <sup>2</sup> )	Total Beta Activity (dpm/100 cm <sup>2</sup> )	Removable Alpha Activity (dpm/100 cm <sup>2</sup> )	Removable Beta Activity (dpm/100 cm <sup>2</sup> )
1	Linoleum	100c	-5	844	0	-5
2	Linoleum	100c	-5	548	3	-8
3	Linoleum	100c	-5	99	0	29
4	Linoleum	100c	-5	625	0	-2
5	Linoleum	100c	-5	449	0	-8
6	Linoleum	100c	-5	515	0	-8
7	Linoleum	100c	-5	373	0	-5
8	Linoleum	100c	8	537	0	-13
9	Linoleum	100c	-5	471	0	-27
10	Linoleum	100c	20	953	3	-38
11	Linoleum	100c	8	603	0	-33
12	Linoleum	100c	8	581	0	-19

The MDC is the minimum detectable concentration on a surface that an instrument is expected to detect with 95 percent confidence.

The instrument MDCs for fixed measurements 1-12 are 21 dpm/100 cm<sup>2</sup> (alpha) and 257 dpm/100 cm<sup>2</sup> (beta); the MDCs for removable samples 1-12 are 18 dpm/100 cm<sup>2</sup> (alpha) and 212 dpm/100 cm<sup>2</sup> (beta); and the MDCs for QC measurement #8 are 53.8 dpm/100 cm<sup>2</sup> (alpha) and 223.4 dpm/100cm<sup>2</sup> (beta).

Negative results indicate results that are below background for the respective building material.

N/A – Not Applicable

**Table A1.4. SU-3 Corridor 100E and Office 130 Class 2 Floor Measurements**

Sample Number	Survey Surface	Location	Total Alpha Activity (dpm/100 cm <sup>2</sup> )	Total Beta Activity (dpm/100 cm <sup>2</sup> )	Removable Alpha Activity (dpm/100 cm <sup>2</sup> )	Removable Beta Activity (dpm/100 cm <sup>2</sup> )
1	Linoleum	100e	-5	581	0	-2
2	Linoleum	100e	-5	493	0	9
3	Linoleum	100e	-5	975	0	-16
4	Linoleum	100e	-5	274	0	-49
5	Linoleum	100e	-5	658	0	-35
6	Linoleum	100e	-5	460	0	-13
7	Linoleum	100e	-5	581	3	-10
8	Linoleum	100e	8	395	3	-27

**Table A1.4. SU-3 Corridor 100E and Office 130 Class 2 Floor Measurements (Continued)**

Sample Number	Survey Surface	Location	Total Alpha Activity (dpm/100 cm <sup>2</sup> )	Total Beta Activity (dpm/100 cm <sup>2</sup> )	Removable Alpha Activity (dpm/100 cm <sup>2</sup> )	Removable Beta Activity (dpm/100 cm <sup>2</sup> )
9	Linoleum	100e	-5	723	0	-5
10	Linoleum	130	20	559	0	-5

The MDC is the minimum detectable concentration on a surface that an instrument is expected to detect with 95 percent confidence.

The instrument MDCs for fixed measurements 1-10 are 21 dpm/100 cm<sup>2</sup> (alpha) and 257 dpm/100 cm<sup>2</sup> (beta); the MDCs for removable samples 1-10 are 18 dpm/100 cm<sup>2</sup> (alpha) and 212 dpm/100 cm<sup>2</sup> (beta); and the MDCs for QC sample #6 are 53.8 dpm/100 cm<sup>2</sup> (alpha) and 223.4 dpm/100cm<sup>2</sup> (beta).

Negative results indicate results that are below background for the respective building material.

N/A – Not Applicable

**Table A1.5. SU-4 Corridor 100G Class 2 Floor Measurements**

Sample Number	Survey Surface	Location	Total Alpha Activity (dpm/100 cm <sup>2</sup> )	Total Beta Activity (dpm/100 cm <sup>2</sup> )	Removable Alpha Activity (dpm/100 cm <sup>2</sup> )	Removable Beta Activity (dpm/100 cm <sup>2</sup> )
1	Linoleum	100g	-5	405	3	-8
2	Linoleum	100g	-5	756	0	1
3	Linoleum	100g	8	482	0	-16
4	Linoleum	100g	-5	679	0	-13
5	Linoleum	100g	20	603	0	-5
6	Linoleum	100g	-5	219	0	-10
7	Linoleum	100g	8	526	0	4
8	Linoleum	100g	8	625	3	-19
9	Linoleum	100g	-5	438	0	-10
10	Linoleum	100g	8	975	3	-5
11	Linoleum	100g	-5	548	0	-10
12	Linoleum	100g	-5	559	6	-16

The MDC is the minimum detectable concentration on a surface that an instrument is expected to detect with 95 percent confidence.

The instrument MDCs for fixed measurements 1-12 are 21 dpm/100 cm<sup>2</sup> (alpha) and 257 dpm/100 cm<sup>2</sup> (beta); the MDCs for removable samples 1-12 are 18 dpm/100 cm<sup>2</sup> (alpha) and 212 dpm/100 cm<sup>2</sup> (beta); and the MDCs for QC sample #6 are 53.8 dpm/100 cm<sup>2</sup> (alpha) and 223.4 dpm/100cm<sup>2</sup> (beta).

Negative results indicate results that are below background for the respective building material.

N/A – Not Applicable

The wall area (from the floor to 3 m [10 ft] in height) for the first floor corridors is 970 m<sup>2</sup>. This area excludes windows and ventilation openings that were present within the walls of the corridors.

**Table A1.6. SU-5 First Floor Corridor Class 2 Wall Measurements**

Sample Number	Survey Surface	Location	Total Alpha Activity (dpm/100 cm <sup>2</sup> )	Total Beta Activity (dpm/100 cm <sup>2</sup> )	Removable Alpha Activity (dpm/100 cm <sup>2</sup> )	Removable Beta Activity (dpm/100 cm <sup>2</sup> )
1	Concrete	100c Foyer	90	334	3	43
2	Concrete	100c Foyer	80	577	3	12
3	Concrete	100b	38	451	0	-5
4	Concrete	100b	59	518	0	29
5	Concrete	100b	27	292	0	-16
6	Concrete	100b	38	276	0	15
7 <sup>a</sup>	Concrete	100h	48	1,746	3	-13
8 <sup>a</sup>	Concrete	100h	90	2,131	0	12
9 <sup>a</sup>	Concrete	100h	69	1,571	0	-2
10 <sup>a</sup>	Concrete	100h	69	1,688	3	-19
11	Concrete	100c	90	819	0	6
12	Concrete	100c	80	969	0	29
13	Concrete	100c	27	827	0	-16

**Table A1.6. SU-5 First Floor Corridor Class 2 Wall Measurements (Continued)**

Sample Number	Survey Surface	Location	Total Alpha Activity (dpm/100 cm <sup>2</sup> )	Total Beta Activity (dpm/100 cm <sup>2</sup> )	Removable Alpha Activity (dpm/100 cm <sup>2</sup> )	Removable Beta Activity (dpm/100 cm <sup>2</sup> )
14	Concrete	100c	48	936	0	-19
15	Concrete	100c	27	585	6	18
16	Concrete	100c	27	710	0	15
17	Concrete	100e	38	551	0	34
18	Concrete	100e	69	635	0	4
19	Concrete	100e	38	735	0	-10
20	Concrete	100e	27	209	3	23
21	Concrete	100e	17	384	0	6
22	Concrete	100e	6	-150	0	-35
23	Concrete	100e	59	627	0	4
26	Concrete	100e	69	618	0	-5
27	Concrete	100e	48	543	0	-8
28	Concrete	100e	27	409	0	-10
29	Concrete	100e	6	251	0	-30
30	Concrete	100g	38	535	0	6
31	Concrete	100g	48	802	3	-16
32	Concrete	100g	38	292	0	-16
33	Concrete	100g	27	568	3	-13
34	Concrete	100b	48	627	0	-16
35	Concrete	100b	27	301	3	-19
36	Concrete	100b	38	409	0	4
37	Concrete	100b	27	217	0	-5
38	Concrete	100g	38	618	0	12
39	Drywall	142	7	482	-1	12
40	Drywall	130	-7	92	-1	20

<sup>a</sup> The walls of Room 100H were collected and evaluated with this SU (i.e., SU-5 of the First Floor Corridor). The floors for Room 100H are included in SU-23 in Attachment 4.

The MDC is the minimum detectable concentration on a surface that an instrument is expected to detect with 95 percent confidence.

The instrument MDCs for fixed measurements 1-12 are 21 dpm/100 cm<sup>2</sup> (alpha) and 257 dpm/100 cm<sup>2</sup> (beta); the MDCs for removable samples 1-12 are 18 dpm/100 cm<sup>2</sup> (alpha) and 212 dpm/100 cm<sup>2</sup> (beta); and the MDCs for QC sample #6 are 53.8 dpm/100 cm<sup>2</sup> (alpha) and 223.4 dpm/100cm<sup>2</sup> (beta).

Negative results indicate results that are below background for the respective building material.

N/A – Not Applicable

**Summary.** Residual levels of radioactivity in the Magill Hall First Floor Corridors clearly demonstrate that residual concentrations of radionuclide COPCs achieve the site-specific Am-241 (alpha) DCGL of 1,160 dpm/100 cm<sup>2</sup> and the most restrictive beta DCGL of 5,000 dpm/100 cm<sup>2</sup> for Cs-137. In addition, the actual percentage of removable activity was determined to be approximately 3 percent.

Given these results, it is clearly demonstrated that the null hypothesis (i.e., that the Magill Hall First Floor Corridors exceeds DCGLs) is rejected. Review of survey data supports the conclusion that the Magill Hall First Floor Corridors contain an adequate number of samples; a sufficient percentage has been scanned; and they have been appropriately classified consistent with MARSSIM requirements using the process noted in Section 4.0 of the main text of this document. All scan and fixed measurement results collected from the Magill Hall First Floor Corridors at Southeast were below the DCGL. As such, formal assessment using the Sign Test is not required.

**Conclusion.** Levels of radioactivity in the Magill Hall First Floor Corridors achieve criteria for unrestricted release consistent with the provisions of 10 *CFR* 20, Subpart E.

**ATTACHMENT A-1-1**

**FIGURES**

**THIS PAGE INTENTIONALLY LEFT BLANK**

Delete this page and insert Figures A1.1 through A1.5

**THIS PAGE INTENTIONALLY LEFT BLANK**