June 24, 2013

Mr. Scott Head, Manager Regulatory Affairs STP Units 3 & 4 Nuclear Innovation North America, LLC 122 West Way, Suite 405 Lake Jackson, TX 77566

## SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 426 RELATED TO SRP SECTION 01.05 FOR THE NUCLEAR INNOVATION NORTH AMERICA, LLC COMBINED LICENSE APPLICATION

Dear Mr. Head:

By letter dated September 20, 2007, South Texas Project (STP) submitted for approval a combined license application pursuant to Title 10 of the *Code of Federal Regulations* (10 CFR) Part 52. The U.S. Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

To support the review schedule, you are requested to respond within **30** days of the date of this letter. If changes are needed to the safety analysis report, the staff requests that the RAI response include the proposed wording changes.

S. Head

If you have any questions or comments concerning this matter, I can be reached at 301-415-5787 or by e-mail at <u>rocky.foster@nrc.gov</u> or you may contact George Wunder at 301-415-1494 or <u>george.wunder@nrc.gov</u>.

Sincerely,

## /**RA**/

Rocky D. Foster, Project Manager Licensing Branch 3 Division of New Reactor Licensing Office of New Reactors

Docket Nos.: 52-012 52-013

eRAI Tracking No.: 7150

Enclosure: Request for Additional Information

cc: William Mookhoek Richard Scheide Loree Elton S. Head

If you have any questions or comments concerning this matter, I can be reached at 301-415-5787 or by e-mail at <u>rocky.foster@nrc.gov</u> or you may contact George Wunder at 301-415-1494 or <u>george.wunder@nrc.gov</u>.

Sincerely,

#### /**RA**/

Rocky D. Foster, Project Manager Licensing Branch 3 Division of New Reactor Licensing Office of New Reactors

Docket Nos.: 52-012 52-013

eRAI Tracking No.: 7150

Enclosure: Request for Additional Information

cc: William Mookhoek Richard Scheide Loree Elton

## DISTRIBUTION:

PUBLIC LB3 R/F RFoster, NRO SGreen, NRO RidsNroDsraSrsb RidsNroDnrILb3 GWunder, NRO GThomas, NRO JDonoghue, NRO

ADAMS ACCESSION NO.: ML13171A261				NRO-002	
OFFICE	TR:DSRA/SRSB	BC:DSRA/SRSB	LA:DNRL/LB3	LPM:DNRL/LB3	PM:DNRL/LB3
NAME	GThomas*	JDonoghue*	SGreen	GWunder (TTai for)	RFoster
DATE	06/10/2013	06/12/2013	06/20/2013	06/24/2013	06/20/2013

\*Approval captured electronically in the electronic RAI system.

OFFICIAL RECORD COPY

### **Request for Additional Information 426**

Issue Date: 6/20/2013 Application Title: South Texas Project Units 3 and 4 - Dockets 52-012 and 52-013 Operating Company: South Texas Project Nuclear Operating Co Docket No. 52-012 and 52-013 Review Section: 01.05 - Other Regulatory Considerations Application Section: 01.05

### QUESTIONS

#### 01.05-12

In regards to the response to RAI 01.05-5, the staff reviewed the applicant's response and determined that the response is insufficient to completely address the staff's concerns. The NRC staff needs sufficient information in order to reach a safety conclusion within the COLA review. The applicant should address the specific provisions in Interim Staff Guidance (ISG) JLD-ISG-2012-01, "Compliance with Order EA-12-049, Order Modifying Licenses with Regard to Requirements for Mitigation Strategies for Beyond-Design-Basis External Events," (ML12229A174) dated August 29, 2012 that endorses the Nuclear Energy Institute (NEI) 12-06, "Diverse and Flexible Coping Strategies (FLEX) Implementation Guide". The ISG provides an acceptable method for satisfying Order EA-12-049. As stated in the ISG, other methods may be used to satisfy Order EA-12-049, but these methods will be reviewed by the NRC staff on a case-by-case basis to determine their acceptability. If the applicant proposes to use methods that differ from those in the ISG and endorsed guidance, the applicant should explain why these alternative methods are acceptable.

# Core Cooling/RCIC

Over the initial 36 hour timeline (Figure 1 shown in the STP 3& 4 ABWR FLEX- Integrated Plan, U7-C-NINA-NRC-130031), RCIC receives inventory from CST and SP for 27.5 and 8.5 hours, respectively. Therefore, significant credit is taken for the CST in the integrated plan. Provide information with a discussion that supports the position that the CST is "robust" and the switchover instrumentation mounted near the tank will be operational following and during ELAP events.