

PMFermiCOLPEm Resource

From: Eudy, Michael
Sent: Tuesday, June 04, 2013 12:02 PM
To: Hinson, Charles; Govan, Tekia; White, Duncan; Jenkins, Ronaldo; Ryan C Pratt; brandonm@dteenergy.com
Cc: FermiCOL Resource
Subject: Fermi 5/30/13 Open Items Call Summary

June 4, 2013

Docket No.: 52-033

MEMORANDUM TO: Ronaldo V. Jenkins, Branch Chief
Licensing Branch 3
Division of New Reactor Licensing
Office of New Reactors

FROM: Michael Eudy, Project Manager
Licensing Branch 3
Division of New Reactor Licensing
Office of New Reactors

SUBJECT: SUMMARY OF WEEKLY CONFERENCE CALL MEETING TO DISCUSS OPEN ITEMS AND OUTSTANDING REQUESTS FOR ADDITIONAL INFORMATION RESPONSES RELATED TO DTE ELECTRIC COMPANY'S FERMI 3 COMBINED LICENSE APPLICATION

On Thursday, May 30, 2013, the U.S. Nuclear Regulatory Commission's (NRC) staff held a public conference call from 3:30 pm to 4:30 pm with members of DTE Electric Company. The purpose of the conference call was to discuss the status of the remaining open items (OI) related to the Fermi 3 Combined License Application. A list of the agenda items, actions items discussed during the call and a list of attendees are below.

Agenda Items:

- 1) Staff feedback on RAI response to RAI 01-7:
 - a) Part 30 Materials and decommissioning financial assurance,
 - b) Cf-252 Material classification

The NRC staff discussed that the amounts of byproduct materials listed in the applicant's revised FSAR Table 12.2-207 were higher than exemption limits and did not support the applicant's claim that financial decommissioning assurance, prior to plant operation, was not needed for Part 30 materials. The applicant believed that the amounts listed were conservative and would not be reached until well into plant operation. The NRC staff and the applicant agreed to further review the issue and discuss possible solutions during the upcoming scheduled June 5, 2013 call.

The NRC pointed out that Cf-252 listed by the applicant as a special nuclear material in revised FSAR Table 12.2-209 should be specified as a byproduct material in revised FSAR Table 12.2-208. The applicant agreed and planned to submit a revised RAI response to correct this error.

Meeting Action Items:

Continue discussion during June 5, 2013 Open Items call.

The List of Participants for the Meeting:

Tekia Govan	NRC/NRO/DNRL – Lead Project Manager
Michael Eudy	NRC/NRO/DNRL – Project Manager
Duncan White	FSME/DMSSA/ASPB – Branch Chief
Charles Hinson	NRC/NRO/DSEA/RPAC – Technical Reviewer
Mike Brandon	DTE
Ryan Pratt	DTE
Patricia Campbell	GEH
Walter ‘Skip’ Schumitsch	GEH
Dave B (Ben) Evans	Dominion

Michael A. Eudy - Project Manager
U.S. Nuclear Regulatory Commission
NRO/DNRL/LB3
301-415-3104

Hearing Identifier: Fermi_COL_Public
Email Number: 1220

Mail Envelope Properties (9E28710E0B702149AEC6639728636440012DF89A8703)

Subject: Fermi 5/30/13 Open Items Call Summary
Sent Date: 6/4/2013 12:01:33 PM
Received Date: 6/4/2013 12:01:35 PM
From: Eudy, Michael

Created By: Michael.Eudy@nrc.gov

Recipients:

"FermiCOL Resource" <FermiCOL.Resource@nrc.gov>
Tracking Status: None
"Hinson, Charles" <Charles.Hinson@nrc.gov>
Tracking Status: None
"Govan, Tekia" <Tekia.Govan@nrc.gov>
Tracking Status: None
"White, Duncan" <Duncan.White@nrc.gov>
Tracking Status: None
"Jenkins, Ronaldo" <Ronaldo.Jenkins@nrc.gov>
Tracking Status: None
"Ryan C Pratt" <prattrc@dteenergy.com>
Tracking Status: None
"brandonm@dteenergy.com" <brandonm@dteenergy.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	2916	6/4/2013 12:01:35 PM

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: