

ITAAC Closure Notifications Examples Review

June 27, 2013

Mahmoud Jardaneh, PE
NRO/DCIP/CITB

ICN Example Review Results

- ICN for AP1000 ITAAC 2.6.09.05c
- Example S2
- Physical Security ITAAC to verify that testing and/or analyses of the alarm systems will be performed
- The ICN has sufficient information to support ITAAC closure verification after incorporating the proposed edits.

Proposed Edit 1

Current

...such that all functions needed to detect, assess, and initiate response of both onsite and offsite security forces is available in each location.

Proposed

...such that all functions needed to detect and assess alarms, and initiate the response of both onsite and offsite security forces is available in each location.

Proposed Edit 2

Current

An inspection and analysis of the CAS/SAS were performed of the central and secondary alarm stations to confirm that they are designed and....

Proposed

An inspection and analysis of the CAS/SAS were performed to confirm that they are designed and....

Referenced ICN Examples ML Numbers

- S2 ML13176A363
- S2 ML12227A889 (initial submittal)