

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

June 24, 2013

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No. 13-362
SPS-LIC/CGL R0
Docket Nos. 50-280/281
License No. DPR-32/37

VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION)
SURRY POWER STATION UNITS 1 AND 2
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION
REQUEST FOR APPROVAL TO USE A SUBSEQUENT
ASME SECTION XI CODE AND ADDENDA FOR
EXAMINATION CATEGORIES B-L-1 AND C-B
IN THE FOURTH INSERVICE INSPECTION (ISI) INTERVAL

By a letter dated May 1, 2013 (Serial No. 13-264), Virginia Electric and Power Company (Dominion) submitted a request for approval to use a subsequent ASME Code edition and addenda for the ASME Section XI, Examination Categories B-L-1 and C-B, in the fourth ISI interval.

On June 5, 2013, the NRC requested additional information in order to complete its technical review of our request. The response to the NRC's request for additional information is provided in the attachment.

As indicated in our May 1, 2013 letter, Dominion requests approval of the use of the subsequent Code edition and addenda by September 30, 2013 to support use of the later Code edition and addenda during the Surry Units 1 and 2 refueling outages in Fall 2013 and Spring 2014, respectively.

If you have further questions or require additional information, please contact Mrs. Candee G. Lovett at (757) 365-2178.

Sincerely,



N. L. Lane
Site Vice President – Surry Power Station

Attachment: Response to Request for Additional Information Regarding Request for Approval to Use a Subsequent ASME Code Edition and Addenda for Examination Categories B-L-1 and C-B in the Fourth ISI Interval

Commitments made by this letter: None

A047
NLL

cc: U.S. Nuclear Regulatory Commission, Region II
Marquis One Tower
245 Peachtree Center Avenue NE, Suite 1200
Atlanta, Georgia 30303-1257

State Health Commissioner, Virginia Department of Health
James Madison Building - 7th floor
109 Governor Street, Suite 730
Richmond, Virginia 23219

NRC Senior Resident Inspector
Surry Power Station

Ms. K. R. Cotton, NRC Project Manager - Surry
U. S. Nuclear Regulatory Commission
One White Flint North, Mail Stop O8 G9A
11555 Rockville Pike
Rockville, Maryland 20852

Dr. V. Sreenivas, NRC Project Manager – North Anna
U. S. Nuclear Regulatory Commission
One White Flint North, Mail Stop O8 G9A
11555 Rockville Pike
Rockville, Maryland 20852

Mr. R. A. Smith
Authorized Nuclear Inspector
Surry Power Station

Attachment

**Response to Request for Additional Information Regarding
Request for Approval to Use a Subsequent ASME Code Edition and Addenda
for Examination Categories B-L-1 and C-B in the Fourth ISI Interval**

**Virginia Electric and Power Company
(Dominion)
Surry Power Station Units 1 and 2**

**Response to Request for Additional Information Regarding
Request for Approval to Use a Subsequent ASME Code Edition and Addenda
for Examination Categories B-L-1 and C-B in the Fourth ISI Interval**

Request for Additional Information Question 1:

Section 1 of the request specifies one of the affected ASME Code Section XI components as Residual Heat Removal (RHR) Heat Exchanger Reinforcement Plate Welds to Vessel (C-B). The NRC staff notes that many components are listed under examination category C-B in Table IWC-2500-1 of the 2007 edition of the ASME Code, Section XI. The component items range from C2.10 to C2.33. For example, the reinforcement plate welds to vessel is classified as Item C 2.31. Based on Section 1 of the request, it appears that the only component that will be affected under Examination Category C-B is Item C2.31, reinforcing plate welds to nozzle and vessel.

Section 3 of the request states: "Flaw Acceptance Standards for Class 2 austenitic Pressure Retaining Welds of Nozzles in Vessels (ASME Category C-B) exists in IWC-3511, of the 2007 Edition, 2008 Addenda, "Standards for Examination Category C-B, Pressure Retaining Welds of Nozzles," by referring to Table IWB-3514.2. Acceptance criteria do not exist for the RHR Heat Exchangers using the current ASME Code Edition and Addenda of record for Surry Units 1 and 2." As stated above, IWC-3511 is applicable to Examination Category C-B pressure retaining welds of nozzles to vessels. Therefore, it appears that all components under Examination Category C-B in Table IWC-2500-1 are affected by the request. This seems to be contradicting Section 1 of the request, which implies only Item C2.31 is the affected component.

Please identify the exact component(s) (specify the component Item number) under Examination Category C-B in Table IWC-2500-1 that will use the 2007 edition through the 2008 addenda of the Code and that will be affected by the request.

Response to Question 1:

The exact component(s) under Examination Category C-B in Table IWC-2500-1 that will use the 2007 edition through the 2008 addenda of the Code and that will be affected by the request is Item No. C2.31, Reinforcing Plate Welds to Nozzle and Vessel.

Request for Additional Information Question 2:

Please identify the material specification of the reactor coolant pump casing welds (e.g., stainless steel ER 308L).

Response to Question 2:

The 1969 Westinghouse material specification for the reactor coolant pump casing welds is SA-298 or SA-371.