FAQ 020: Tsunamis — Combining Water Levels

A. TOPIO	<u>C:</u> Tsuna	mis – Combining Water Leve	lls		
Source do	ocument:	JLD-ISG-2012-06		Section:	4
B. DESCRIPTION:					
Guidance document JLD-ISG-2012-06, Enclosure 2, Tsunami Hazard Assessment, Section 3.4.2 states that "Section 4 addresses post-modeling tsunami water level additions, such as wind waves and wave run-up." While section 4.2 addresses wave run-up, no guidance is given in Section 4 with regards to wind waves. This inquiry is intended to clarify the requirements as to the appropriate combinations of the effects of tsunami and other natural phenomena.					
C. Initiator:					
Name:	Scott Maze		Phone:	805-78	1-9791
Date:		E-Mail:sxm		003 70	<u> </u>
D. RESOLUTION: (Include additional pages if necessary. Total pages: 1)					
Inquiry number: 20 Priority: High					
run-up and antecedent 10 percent exceedence high tide. However the guidance in section H.5 of the NUREG is misleading in that the PMT run-up estimation already includes the 10 percent exceedence high tide, therefore adding the high tide parameter to PMT run-up is not necessary (and would result in double counting of this effect). This resolution is consistent with new reactor tsunami hazard assessments for combined licenses and early site permits. For example, this combination for shore locations was specifically reviewed and accepted as part of the COLAs for the Levy Nuclear Plant Units 1 and 2 (ref. FSAR section 2.4.6.6.3.9), Turkey Point Units 6 & 7 (ref. FSAR section 2.4.6.4.1.2), and Calvert Cliffs Nuclear Power Plant (CCNPP FSAR Section 2.4.6.5).					
(Territorial State Section 2. 1101.1121/) and saire to sair state (Section 1. 1. 3. at Section 2. 1101.07).					
Revision:	_2 Date:_	06-06-2013			
E. NRC F	Review:				
Not Nece	ssary		Necessary	Χ	
Explanati	on:				
F. Indus	stry Approval:				
Documen	ntation Method:	June 6, 2013 meeting sum	mary	_ Date	: <u>06-07-13</u>
	Acceptance:	-	· · ·		
Interpret	ation <u>X</u>	_	Agency Positio	n	<u> </u>
Documen	ntation Method:			Date:	