

Whited, Jeffrey

From: Whited, Jeffrey
Sent: Tuesday, July 09, 2013 1:18 PM
To: 'Tripoli, John L' (jltropoli@pplweb.com)
Cc: Filchner, Duane L (dfilchner@pplweb.com); Jennings, Jason (JJennings@pplweb.com)
Subject: SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2 – ACCEPTANCE OF REQUESTED LICENSING ACTION RE: CHANGE TO TS SR 3.5.1.12 (TAC NOS. MF1955 AND MF1956)

SUBJECT: SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2 – ACCEPTANCE OF REQUESTED LICENSING ACTION RE: CHANGE TO TECHNICAL SPECIFICATION SURVEILLANCE REQUIREMENT 3.5.1.12 (TAC NOS. MF1955 AND MF1956)

Dear Mr. John Tripoli:

By letter dated June 06, 2013, (Agencywide Document Access and Management System Accession No. ML13158A096) PPL Susquehanna, LLC, Inc. submitted a license amendment request for Susquehanna Steam Electric Station, Units 1 and 2 (SSES 1 and 2, respectively). The proposed amendments would change Surveillance Requirements 3.5.1.12 in Technical Specification (TS) 3.5.1 “ECCS - Operating.” Specifically, the proposed amendments would eliminate the TS requirement for the Automatic Depressurization System (ADS) valves to open during manual actuation of the ADS circuitry. The purpose of this e-mail is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff’s acceptance review of this license amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), an amendment to the license (including the TS) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the NRC staff to complete its detailed technical review and make an independent assessment regarding the acceptability of the proposed license amendment request in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff’s ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. You will be advised of any further information needed to support the NRC staff’s detailed technical review by separate correspondence.

If you have any questions, please contact me at 301-415-4090.

Jeffrey Whited

Project Manager-Susquehanna Units 1 and 2
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
(301)415-4090