

Definition for section 4.2

Sustained Operation: The ability to operate 7 days or a shorter time if an alternative method of containment heat removal is put in place by using installed or portable equipment (e.g., a means of shutdown cooling aligned directly to the RPV, drywell or a means of suppression pool cooling). Such method should allow restoration of the Containment Source term control function.